

USNRC  
DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

JUL 12 4 31  
July 2, 1982

WILLIAM O. PARKER, JR.  
VICE PRESIDENT  
STEAM PRODUCTION

TELEPHONE: AREA 704  
373-4083

Mr. James P. O'Reilly, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Re: McGuire Nuclear Station Unit 1  
Docket No. 50-369

Dear Mr. O'Reilly:

Please find attached Reportable Occurrence Report RO-369/82-47. This report concerns T.S.3.1.2.6, "As a minimum, the following borated water source(s) shall be operable as required by specification 3.1.2.2: a. A boric acid storage system..."; 4.1.2.6, "Each borated water source shall be demonstrated operable: a. At least once per 7 days by: 1. Verifying the boron concentration in the water,..."; and 3.1.2.2, "At least two of the following three boron injection flow paths shall be operable: a. The flow path from the boric acid tanks...". This incident was considered to be of no significance with respect to the health and safety of the public.

Very truly yours,

*William O. Parker, Jr.*

William O. Parker, Jr. *by PNB*

PBN/jfw  
Attachment

cc: Document Control Dest  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Records Center  
Institute of Nuclear Power Operations  
1820 Water Place  
Atlanta, Georgia 30339

Mr. P. R. Bemis  
Senior Resident Inspector-NRC  
McGuire Nuclear Station

8207150425 820702  
PDR ADDCK 05000369  
S PDR

OFFICIAL COPY

TE22