

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

July 12, 1982

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303


Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET  
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE  
REPORT SQRO-50-327/82078

The enclosed report provides details concerning indications of high oxygen concentrations in one waste gas decay tank. This event required entry into action statement b of limiting condition for operation 3.11.2.5 and is reportable under Sequoyah unit 1 Technical Specification 6.9.1.13.b.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

  
J. A. Green  
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Records Center  
Institute of Nuclear Power Operations  
1820 Water Place  
Atlanta, Georgia 30339

NRC Inspector, Sequoyah

OFFICIAL COPY

8207150489 820712  
PDR ADOCK 05000327  
S PDR

An Equal Opportunity Employer

TE 22