

SUMMARY OF OPERATING EXPERIENCE FOR OCTOBER 1993

Initial criticality for Cycle 11 was attained on November 3, 1993 at 1109. The plant went off-line at 0731 to repair an EHC leak on November 5, 1993. Return to power took place at 0944 on November 6, 1993. On November 6 the turbine was taken off-line at 2105 to perform overspeed trip testing. The test failed, repairs were made, and the turbine was returned to service November 8 at 0534. At 1419, the turbine was taken off-line, the overspeed test was reperformed satisfactorily and the turbine was back on-line at 1705. The outage officially ended at this time. Full power was reached by approximately 2030 on November 13, 1993 and continued for the remainder of the month.

9312100174 931203  
PDR ADOCK 05000255  
R PDR