



**Commonwealth Edison**

Dresden Nuclear Power Station  
R.R. #1  
Morris, Illinois 60450  
Telephone 815/942-2920

July 20, 1982

DJS LTR: #82/805

James G. Keppler, Regional Administrator  
Directorate of Regulatory Operations Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Reportable Occurrence Report #82-26/03L-0, Docket #050-237 is being submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.B.2.(b), conditions leading to operation in a degraded mode permitted by a limiting condition for operation or plant shutdown required by a limiting condition for operation.

*D. J. Scott*  
D. J. Scott *ja*

Station Superintendent  
Dresden Nuclear Power Station

DJS:mb

Enclosure

cc: Director of Inspection & Enforcement  
Director of Management Information & Program Control  
U. S. NRC, Document Management Branch  
File/NRC



Commonwealth Edison

## DEVIATION REPORT

DVR NO. 12 2 82 43  
STA UNIT YEAR NO.

PART 1 TITLE OF DEVIATION

OCCURRED 7/1/82 0030  
DATE TIME

LPCI M02-1501-5C Suction Valve Breaker Failure

SYSTEM AFFECTED 1500  
LPCI

PLANT STATUS AT TIME OF EVENT

MODE RUN

PWR(MWT) 2335

LOAD(MWE) 760

TESTING  
☒ YES ☐ NO

DESCRIPTION OF EVENT

Breaker tripped while attempting to close LPCI M0-1501-5C valve during LPCI valve operability test, DOS 1500-1. On second attempt to close valve, arcing was observed from the outside of the motor control center cubicle.

10 CFR50.72 NRC RED PHONE  
NOTIFICATION MADE☐ YES ☒ NO

EQUIPMENT FAILURE

D-21372

☒ YES☐ NO

WORK REQUEST NO.

RESPONSIBLE SUPERVISOR M. Evans

DATE 7/1/82

PART 2 OPERATING ENGINEER'S COMMENTS

Main contractor in MCC cubicle was replaced and breaker and valve operated satisfactorily.

☐ EVENT OF PUBLIC INTEREST☐ TECH. SPEC. VIOLATION☐ NON REPORTABLE OCCURRENCE☐ 14 DAY REPORTABLE/T.S.☒ 30 DAY REPORTABLE/T.S. 6.6.B.2.b☐ ANNUAL/SPECL REPORT REQ'D

A.I.R. #

L.E.R. # 82-26/03L-0

☐ 24-HOUR NRC NOTIFICATION REQ'D

TELEPH N/A

REGION III

DATE TIME

TELEGM/TELECOPY N/A

REGION III

DATE TIME

☐ CECO CORPORATE NOTIFICATION MADE  
IF ABOVE NOTIFICATION IS PER 10CFR21☐ 5-DAY WRITTEN REPORT REQ'D PER 10CFR21

TELEPH F. A. Palmer

CECO CORPORATE OFFICER

7/8/82

DATE TIME 1046

PRELIMINARY REPORT  
COMPLETED AND REVIEWED

John M. Almer

OPERATING ENGINEER

7/7/82

DATE

INVESTIGATED REPORT & RESOLUTION  
ACCEPTED BY STATION REVIEWRESOLUTION APPROVED AND  
AUTHORIZED FOR DISTRIBUTION

STATION SUPERINTENDENT

DATE