



Log # TXX-90285
File # 10110
909.4
Ref. # 10CFR50.55(e)

William J. Cahill, Jr.
Executive Vice President

August 8, 1990

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NO. 50-446
SAFEGUARDS BUILDING OVERTEMPERATURE CONDITION
SDAR-CP-90-07 (INTERIM REPORT)

Gentlemen:

On July 9, 1990, TU Electric orally notified Mr. A. T. Howell of the Region IV staff of a deficiency involving the adequacy of ventilation systems in the vicinity of the Main Steam Isolation Valves. This condition was identified as a result of exceeding the Unit 1 main steam penetration Technical Specification temperature limit. For Unit 1, this issue was addressed by Special Report No. SR-1-90-006-00, "Elevated Temperatures in Safeguards Building Normal Areas," submitted by TXX-90205, dated June 8, 1990. This is an interim report (Unit 2) of a potentially reportable item under the provisions of 10CFR50.55(e).

TU Electric is currently evaluating this deficiency in relation to the design of Unit 2. The next report will be submitted no later than October 1, 1990.

Sincerely,

William J. Cahill, Jr.

William J. Cahill, Jr.

By: *Roger D. Walker*

Roger D. Walker
Manager, Nuclear Licensing

CBC/cbc

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

9008130177 900808
PDR ADDCK 05000A446
S FIC

IF27
110