



UNITED STATES
NUCLEAR REGULATORY COMMISSION

REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137-5927

OCT 21 1993

Docket No. 50-341

The Detroit Edison Company
ATTN: D. R. Gipson
Senior Vice President
Nuclear Generation
6400 North Dixie Highway
Newport, MI 48166

Subject: Station Blackout Inspection Report No. 50-341/93021(DRS)

Dear Mr. Gipson:

This refers to the special safety inspection conducted by Mr. Rolf A. Westberg and others of this office on October 4-8, 1993. The inspection reviewed the implementation of the Station Blackout (SBO) Rule, 10 CFR 50.63, at the Fermi 2 Nuclear Power Station. At the conclusion of the inspection, the findings were discussed with you and those members of your staff identified in the enclosed report.

The team considered the SBO Rule to be adequately implemented. The materiel condition of the plant was good. In addition, the team noted that the plant's self assessment of SBO identified many of the same concerns as our team. The team identified some minor weaknesses in the SBO calculations but these weaknesses did not change the overall results of the calculations.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

No violations of NRC requirements were identified during the course of this inspection.

270075

9310280023 931021
PDR ADOCK 05000341
Q PDR

1/0
Public-IEO1

OCT 11 1993

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC Public Document Room. We will gladly discuss any questions you have concerning this inspection.

Sincerely,

Ronald N. Gardner

Ronald N. Gardner, Chief
Plant Systems Section

Enclosures:

1. Inspection Report
No. 50-341/93021(DRS)
2. Appendix A - Persons Contacted

Distribution

cc w/enclosure:

John A. Tibai, Supervisor
of Compliance

P. A. Marquardt, Corporate
Legal Department

OC/LFDCB

Resident Inspector, RIII

James R. Padgett, Michigan Public
Service Commission

Michigan Department of
Public Health

Monroe County Office of
Civil Preparedness

Fermi, LPM, NRR

R. Hasse, TSS