Southern California Edison Company IFIVINE, CALIFORNIA 92716 October 28, 1993 WALTER C MARSH (714) £ 14 4403 U. S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, D. C. 20555 Gentlemen: Subject: Docket No. 50-361 Special Report on Inoperable Stack Noble Gas Monitor San Onofre Nuclear Generating Station, Unit 2 The purpose of this letter is to provide a Special Report to the NRC regarding Plant Vent Stack Wide Range Noble Gas Monitor 3RT-7865. Specifically, Unit 3 Plant Vent Stack Wide Range Monitor, 3RT-7865, was removed from service on October 14, 1993, at U810, to implement Minor Maintenance Package (MMP) 2/3-6835. During this period, Unit 2 was in Mode 1 operations and Unit 3 was shutdown in Mode 5. Because monitor 3RT-7865 remained out of service for greater than 72 hours, this special report is required. The preplanned alternate method of monitoring the plant vent stack was implemented in accordance with the requirements of Technical Specification 3.3.3.1 Action 19. It is estimated that 3RT-7865 will be returned to service by December 3, 1993. If you have any questions, please contact me. Sincerely, Hallis C March cc: B. H. Faulkenberry, Regional Administrator, NRC Region V M. B. Fields, NRC Project Manager, San Onofre Units 2 and 3 NRC Resident Inspector Office, San Onofre Units 1, 2, and 3