

November 15, 1993

Docket No. 50-293

Mr. E. Thomas Boulette, Ph.D
Senior Vice President - Nuclear
Boston Edison Company
Pilgrim Nuclear Power Station
Rocky Hill Road
Plymouth, Massachusetts 02360

Dear Mr. Boulette:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - PILGRIM NUCLEAR POWER STATION,
INCREASE ALLOWED FUEL ASSEMBLY STORAGE (TAC NO. M85898)

On February 11, 1993, Boston Edison Company submitted an application to amend the Technical Specifications (TSs) for Pilgrim Nuclear Power Station. The proposed change would revise the TSs to increase allowed fuel assembly storage. In order to complete our review, we require further information or clarification for selected issues. Enclosed is a list of the information we require. If you need clarification on this request, please call me at (301) 504-3041.

The requirements of this letter affect fewer than 10 respondents, and, therefore, are not subject to the Office of Management and Budget review under P.L. 96-511.

Sincerely,

Original signed by
Ronald B. Eaton, Senior Project Manager
Project Directorate I-3
Division of Reactor Projects - 1/11
Office of Nuclear Reactor Regulation

Enclosure:

As stated

cc w/enclosure:

See next page

DISTRIBUTION:

Docket File
NRC & local PDRs
PDI-3 R/F
SVarga
JCalvo

WButler
Slittle
REaton
OGC
ACRS (10)
JLinville, RI

OFFICE	PDI-3:LA	PDI-3:PM	PDI-3:D / B		
NAME	Slittle	REaton:dt	WButler		
DATE	11/15/93	11/15/93	11/15/93		

OFFICIAL RECORD COPY
DOCUMENT NAME: A:\RAI

170066

NRC FILE CENTER COPY

9311180055 931115
PDR ADOCK 05000293
P PDR

DF01



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

November 15, 1993

Docket No. 50-293

Mr. E. Thomas Boulette, Ph.D
Senior Vice President - Nuclear
Boston Edison Company
Pilgrim Nuclear Power Station
Rocky Hill Road
Plymouth, Massachusetts 02360

Dear Mr. Boulette:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - PILGRIM NUCLEAR POWER STATION,
INCREASE ALLOWED FUEL ASSEMBLY STORAGE (TAC NO. M85898)

On February 11, 1993, Boston Edison Company submitted an application to amend the Technical Specifications (TSs) for Pilgrim Nuclear Power Station. The proposed change would revise the TSs to increase allowed fuel assembly storage. In order to complete our review, we require further information or clarification for selected issues. Enclosed is a list of the information we require. If you need clarification on this request, please call me at (301) 504-3041.

The requirements of this letter affect fewer than 10 respondents, and, therefore, are not subject to the Office of Management and Budget review under P.L. 96-511.

Sincerely,

A handwritten signature in dark ink, appearing to read "Ronald B. Eaton", is written over the typed name.

Ronald B. Eaton, Senior Project Manager
Project Directorate 1-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. E. Thomas Boulette

Pilgrim Nuclear Power Station

cc:

Mr. Edward S. Kraft,
Vice President of Nuclear
Operations & Station Director
Pilgrim Nuclear Power Station
RFD #1 Rocky Hill Road
Plymouth, Massachusetts 02360

Resident Inspector
U. S. Nuclear Regulatory Commission
Pilgrim Nuclear Power Station
Post Office Box 867
Plymouth, Massachusetts 02360

Chairman, Board of Selectmen
11 Lincoln Street
Plymouth, Massachusetts 02360

Office of the Commissioner
Massachusetts Department of
Environmental Protection
One Winter Street
Boston, Massachusetts 02108

Office of the Attorney General
One Ashburton Place
20th Floor
Boston, Massachusetts 02108

Mr. Robert M. Hallisey, Director
Radiation Control Program
Massachusetts Department of
Public Health
305 South Street
Boston, Massachusetts 02130

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Mr. Paul J. Hamilton
Licensing Division Manager
Boston Edison Company
25 Braintree Hill Park
Braintree, Massachusetts 02184

Mr. H. Vernon Oheim
Manager, Reg. Affairs Dept.
Pilgrim Nuclear Power Station
RFD #1 Rocky Hill Road
Plymouth, Massachusetts 02360

Mr. David F. Tarantino
Nuclear Information Manager
Pilgrim Nuclear Power Station
RFD #1, Rocky Hill Road
Plymouth, Massachusetts 02360

Mr. Thomas Rapone
Secretary of Public Safety
Executive Office of Public Safety
One Ashburton Place
Boston, Massachusetts 02108

Mr. David Rodham, Director
Massachusetts Emergency Management
Agency
400 Worcester Road
P.O. Box 1496
Framingham, Massachusetts 01701-0317
Attn: James Muckerheide

Chairmen, Citizens Urging
Responsible Energy
P. O. Box 2621
Duxbury, Massachusetts 02331

Citizens at Risk
P. O. Box 3803
Plymouth, Massachusetts 02361

W. S. Stowe, Esquire
Boston Edison Company
800 Boylston St., 36th Floor
Boston, Massachusetts 02199

REQUEST FOR ADDITIONAL INFORMATION

A. Heavy Loads Handling Concerns

1. Provide a figure showing the proposed rack lift rig.
2. What is the maximum load the lift rig is able to lift before reaching the yield stress on any component?
3. What is the maximum load the rig is able to lift before reaching the ultimate stress on any component?
4. Explain how the 150% test load you intend to employ for the lift rig (as noted on page 2-2 of the Holtec Report) complies with the test specified in Section 6.3 of ANSI N14.6-1978.
5. Show how you intend to test the lift rig to verify continuing compliance for use in installing racks after the initial reracked configuration.
6. The reactor building bridge crane (RBBC) is being specified for use in the reracking process. What is the ultimate load this crane can lift before any crane component fails?
7. Section (i) and (ii) on page 2-3 of the Holtec International Report (HI-92925) mention that "cranes" will be used in the reracking process. For those cranes other than the RBBC, provide the following information:
 - a. What will each crane be used for?
 - b. What specification has each crane been designed to, e.g. EOCI-61, CMAA-70?
 - c. What ultimate load can each crane lift before failing?
 - d. What is the maximum load each crane is expected to lift?
8. In section (i) on page 2-3 of the Holtec Report you state that cranes used in the project will receive a preventative maintenance checkup and inspection for the reracking operation. Will this be done for both the initial and other reracking configurations? How soon will this be accomplished before each reracking phase?
9. You state the following on page 2-3 of the Holtec Report:
 - (1) No heavy load (rack or rig) with a potential to drop on a rack has less than 3 feet lateral free zone clearance from actual fuel.

This assures the reader that there is at least 3 feet separation between a rack fully loaded with spent fuel and an empty rack or rig being moved.

It is not clear that a similar clearance will be maintained between a partially filled rack and a rack or rig being moved. Explain and justify any deviation for maintaining any lesser separation (less than 3 feet).

10. Show at what loads the rigging for the overhead platforms (discussed on page 2-5 of the Holtec Report) will fail. You intend to prevent damage to racks and spent fuel by carrying platforms over racks at a height of 36 inches or less. Discuss how you intend to monitor the 36 inch height.
 11. What is the purpose of the rack overhead platforms? Will all the racks have platforms or only the new racks? How will you monitor placement of material on the platforms so as to prevent damage to spent fuel?
- B. Thermal/Hydraulic Concerns
1. Show that the spent fuel pool cooling and cleaning system (FPCC) components are protected in the event of a spent fuel pool (SFP) cooling pump failure during a normal refueling. Provide the maximum temperature expected for the SFP bulk coolant, in that case.
 2. What systems are available to provide coolant for the SFP in the event of complete failure of the FPCC system? What coolant flow rate can be provided as makeup from each system in the event of such failure? Which, if any, is designed to function after a seismic event? Which systems can operate without off-site power?
 3. The Holtec Report, on page 5-13, shows the capability of residual heat removal (RHR) cooling mode 2 (maximum bulk pool temperature 129 °F) for a "normal" off load. What would be the SFP bulk coolant temperature in the event RHR cooling mode 1 was utilized? Are the decay heat loads in both cases 8.69 MBTU/Hr? Are there any refueling scenarios wherein an RHR pump would not be available in the event of a single failure?
 4. Explain your use of collocation in determining the velocity fields in the lower plenum and in-cell as noted in Section 5.7.2, "Model Description" of the Holtec Report.