

50-409 P
Ltr. 9/26/78

SEISMIC AND STRESS ANALYSIS OF LACBWR
FEEDWATER PIPING SYSTEM

Prepared Under NES Project 5101 for
DAIRYLAND POWER COOPERATIVE

NUCLEAR ENERGY SERVICES, INC.
Danbury, Connecticut 06810

Prepared by: A. Obligado

Approved by:

W. J. Mancini
Project Manager

L. E. G. G. G.
V.P. Engineering

DATE:

6/18/75

LPDR

1010004

PDR ADCK 050-409 P 780926

TABLE OF CONTENTS

VOLUME I	
1. SUMMARY	1
2. INTRODUCTION	2
3. PIPING SYSTEM DESCRIPTION	3
4. LOADING CRITERIA	5
4.1 Dead Weight and Other Sustained Mechanical Loads	5
4.2 Internal Pressure	5
4.3 Thermal Loading	5
4.4 Seismic Loading	5
5. STRESS ACCEPTANCE CRITERIA.....	7
5.1 Normal Operating Conditions	7
5.2 Upset Conditions	7
5.3 Emergency Conditions	7
6. ANALYTICAL METHODS	8
6.1 Mathematical Model	8
6.2 Static Load Analysis	8
6.3 Eigenvalue Analysis	9
6.4 Dynamic (Seismic) Analysis	10
6.5 Stress Analysis	12
7. DISCUSSION OF RESULTS	14
8. CONCLUSIONS AND RECOMMENDATIONS	25
9. REFERENCES	26
10. APPENDICES	
A. Analytical Input Data	
B. Tabulated Results of Analysis	

VOLUME II

COMPUTER OUTPUT - PIPESD Static and Dynamic Analysis of LACBWR Feedwater and Condensate Return Piping System.

1. SUMMARY

This report, prepared for Dairyland Power Cooperative, presents the results of seismic and stress analyses of the feedwater piping system for the LACBWR Nuclear Power Station. The seismic and stress analyses are performed in accordance with the design requirements for Class 2 piping components of the ASME Boiler and Pressure Vessel Code, Section III, Division 1, "Nuclear Power Plant Components", 1974. By providing adequate seismic restraints (snubbers) at critical locations of the feedwater system, the stresses in the piping due to a seismic event have been reduced to acceptable values. It is concluded that the stresses due to seismic, deadweight, pressure and thermal expansion loadings, combined according to the ASME Code rules for Class 2 components, satisfy the design requirements given in the Code.

2. INTRODUCTION

In response to AEC/DL's request to review the effects of an earthquake event on the LaCrosse Boiling Water Reactor, Dairyland Power Cooperative requested Gulf United Nuclear Fuels Corporation to evaluate the adequacy of the major structures and equipment to withstand seismic loadings. The seismic study performed by Gulf United (GU) Nuclear Fuels Corporation (Ref. 1) included an analysis of the main steam line which indicated that high stresses would be generated in the main steam line during a seismic event. It was also evident from these analyses that the LACBWR piping systems, in general, were not designed to accommodate horizontal accelerations, the primary earthquake induced loading condition. Anticipating the possibility of a seismically induced loss of coolant accident, it was, therefore, concluded that analyses of the major Class 1 piping systems should be performed to evaluate their structural integrity.

In order to verify that the seismic stresses are acceptable, it is necessary to show that the combined stresses in the piping system are within ASME Boiler and Pressure Vessel Code allowable values. This requires that the seismic stresses be combined with the stresses due to deadweight, pressure and thermal loadings in accordance with the ASME Code Section III rules(Ref. 2).

The rules for a Class 1 (Section III) analysis require that thermal stress and fatigue due to thermal cycling be considered. A review of the available feedwater piping system flexibility and stress analyses indicated that only thermal expansion was considered together with the pressure and deadweight loads in the original design. Consequently, it is not possible to perform a Class 1 analysis with the existing analytical data.

The existing analytical data, however, is sufficient to perform a Class 2 (Section III) analysis. Therefore, in the subject analysis, the adequacy of the feedwater piping system to withstand an earthquake event is evaluated by combining the stresses due to deadweight, pressure, thermal and seismic loadings in accordance with ASME Code requirements for the design of Class 2 components. It should be noted that the requirements of the ASME Code, Section III, for the design of Class 2 components are much more rigorous than the design requirements given in the Power Piping Code, USAS B31.1.0 (The applicable code for the LACBWR Project).

Section 3.0 of this report describes the scope of the feedwater piping system considered in the analysis. The loading criteria, design criteria and analytical methods used in the analyses are given in Sections 4.0, 5.0 and 6.0 respectively. The results of the analysis are discussed in Section 7.0. The conclusions and recommendations are summarized in Section 8.0.

3. DESCRIPTION OF PIPING SYSTEM


The feedwater piping system returns condensate from the turbine building and feeds it directly to the forced circulation suction header where the condensate is mixed with the recirculating coolant. Feedwater enters the containment building through an 8" line, passes through an 8" check valve and an 8" gate valve and flows into a manifold section. Two 6" lines connected to this manifold enter the biological shield and feed the water directly to the 16" forced-circulation suction header through four 4" nozzles. The condensate return line from the shutdown condenser is included in the analysis in order to account for its effects on the feedwater line. Condensate water from the shutdown condenser flows by gravity from a 6" to a 4" line and then through a parallel system of 4" control, check, and gate valves before entering the 8" feedwater line through a branch connection.

The governing design specification used in the analysis of the feedwater piping system is given in Reference 3. The piping arrangement and piping suspension (hangers, etc.) characteristics have been taken from the drawings listed in Reference 4. Piping properties have been taken from the information given in Reference 5 and from the piping specification (Reference 3). This information is summarized in Table A-1 of Appendix A.

An isometric drawing showing the feedwater piping system as analyzed, including the suspension system and recommended seismic snubbers, is given in Figure 3.1.

FIGURE 3.1

Mathematical Model -
LACBWR Feedwater and Condensate
Return Piping System



4. LOADING CRITERIA

The load cases which must be considered in performing a Class 2 stress analysis include: dead loads and sustained mechanical loads, internal pressure, thermal expansion loading, seismic inertia loads and seismic anchor movement loading. The static and dynamic load cases are summarized in Tables A-III and A-IV of Appendix A.

4.1 Dead Weight and Other Sustained Mechanical Loads (Static Load Case 1)

The deadweight of the piping system is calculated assuming the system to be insulated and filled with water. The weight of valves, valve operators, and branch piping are included in the analysis. Valve weights and dimensions are taken from vendor drawings and specifications supplied by DPC and are given in Table A-II of Appendix A. Sustained loads imposed on the piping system by constant load hangers are also considered in the dead weight analysis. These loads are taken from Ref. 4 drawings.

4.2 Internal Pressure (Static Load Cases 2 and 3)

System normal operating pressure, Load Case 2, and peak pressure, Load Case 3, used in the analysis are taken from Refs. 3 and 6. A value of 1300 psia for operating pressure and 1415 psia for peak pressure are used for the condensate return and main feedwater system. An operating pressure of 1350 psia and a peak pressure of 1615 psia are used for the feedwater piping between the containment vessel and the 8" gate valve.

4.3 Thermal Loading (Static Load Case 4)

The thermal expansion stresses are based on the thermal loading for the normal operating condition. A normal operating temperature of 547°F is used for the condensate return and main feedwater piping, while a temperature of 295°F is used for the feedwater piping between the containment vessel and the 8" gate valve (Reference 9).

Thermal anchor movements at the nozzle connections to the recirculation suction line manifold are taken from the NES recirculation line thermal analysis (Ref. 8). Thermal anchor movement at the shutdown condenser connection is taken from Ref. 9.

4.4 Seismic Loading

A dynamic analysis of the piping system is performed using the response spectrum method of analysis (Section 6.4). Two seismic loading events are considered: the safe shutdown earthquake (SSE), and the operating basis earthquake (OBE). The established design criteria (Ref. 7, Reg. Guide 1.48, May 1973) for Class 2 analysis considers the OBE (or 1/2 SSE) to be the normal and upset condition while the SSE is considered the faulted condition.

Seismic inertia loading is imposed on the piping system in the form of seismic acceleration spectra which were derived for the LACBWR plant (Ref.1). The horizontal acceleration spectrum used for the feedwater line is that corresponding to the reactor vessel at an elevation of 664.5 ft. The vertical response spectrum for the SSE loading is taken as 2/3 of the horizontal SSE ground response spectrum assuming no amplification of vertical response in the structure. For the operating basis earthquake the vertical piping response spectrum is taken as 1/2 of the SSE vertical response spectrum. Damping values used are 1% for the OBE and 2% for the SSE.

The horizontal spectra in either the global X- direction (Dynamic Load Cases 8 and 10) or the global Z- direction (Dynamic Load Cases 9 and 11) are applied simultaneously with the vertical spectra in the global Y- direction. Load cases 8 and 9 represent the operating bases earthquake while 10 and 11 represent the SSE earthquake. The applicable response spectra used in the analysis for dynamic load cases are shown in Table A-V of Appendix A.

Seismically induced anchor movements (Static Load Cases 6,7,12, and 13) for points 10,11, 38, 45 and 104 were estimated by calculating low frequency displacements from the containment vessel response spectra at the different anchor point elevations.

5. STRESS ACCEPTANCE CRITERIA

The requirements for acceptability of a Class 2 piping system are given in AEC regulatory position 8 of Reference 7 and Section NC-3611 of Reference 2. Calculated stresses resulting from specified load combinations must meet the stress limits of equations 8 through 11 (Section 6.5).

5.1 Normal Operating Conditions

Under normal operating conditions, the combined stresses due to design pressure, weight, and other sustained loads (load Cases 1 and 2) must not exceed the basic material allowable stress at maximum temperature, S_H , and the requirements of Equation 8, Section 6.5. Additionally, either the stress range due to thermal expansion and seismic anchor movements (Load Cases 4 and 6) as calculated by Equation 10, Section 6.5, must not exceed the allowable expansion stress range S_A (Reference 2), or the combined stresses due to design pressure, weight, other sustained loads and the stress range due to thermal expansion (Load Cases 1, 2, 4 and 6 or 7) must not exceed the sum of S_A and S_H as required by Equation 11, Section 6.5.

5.2 Upset Conditions

The requirements for operation under upset conditions include compliance with the requirements of Equations 8, 10 and 11 as described above as well as Equation 9, Section 6.5. Equation 9 requires that the combined stresses produced by peak pressure (Load Case 3), live and dead loads (Load Case 1), and those produced by occasional loads -- in this analysis defined as the OBE earthquake -- (Load Cases 8 and 9), must not be greater than 1.2 times the allowable stress value S_H .

5.3 Faulted Conditions

During faulted conditions, the requirements of Equation 9 must be met using a stress limit of 1.8 S_H . For the purpose of satisfying this criteria, the faulted conditions are specified as peak pressure loads (Load Case 3), live and dead loads (Load Case 1), the SSE seismic inertia loadings (Load Cases 1 and 11) and the seismic anchor movement loads associated with the SSE (Load Cases 12 and 13).

6. ANALYTICAL METHODS

6.1 Mathematical Model

In order to perform static, dynamic and stress analyses, the continuous piping system is mathematically modeled as an assembly of elastic structural elements interconnected at discrete nodal points (Figure 3.1). Nodal points are located at all points of interest in the piping system such as elbows, valves, anchorages, hangers, tee intersections, load points, all structural and material discontinuities, etc. This three dimensional multidegree-of-freedom model of the piping system is attached to the "ground" (structure) by means of rigid hangers, support springs, hydraulic snubbers and anchors. Stiffness characteristics of structural elements are related to the moment of inertia and the axial and effective shear area of the pipe cross section. The stiffness characteristics of the elbows and tee connections are modified to account for local deformation by using the flexibility factors given in the ASME Code (Ref. 2).

For the seismic analysis the distributed mass of the piping system is lumped at the system nodal points. Masses are lumped so that the lumped mass, multi-degree-of-freedom model represents the dynamic characteristics of the piping system. In order to reduce the number of dynamic degrees-of-freedom, only translational degrees-of-freedom are considered at each mass point (the masses associated with the rotational degrees-of-freedom are set to zero). This assumption has been shown to be completely satisfactory for accurate analysis of seismic response. Special items such as valves and actuators are modeled by lumping their masses at an appropriate offset from the center-line of the piping system.

6.2 Static Load Analysis

The static load analysis involves the application of the following loading conditions and their combinations:

- . Design Pressure
- . Gravity Loading (dead weight) and Sustained Mechanical Loads
- . Support Displacement
- . Thermal Expansion

For the pressure loadings, the hoop and longitudinal stresses in the affected piping are calculated using the formulae given in the Code (see Section 6.5).

For the deadweight, support displacement, or thermal expansion loading conditions the following equations of equilibrium written in matrix form are solved:

$$KU = P \quad (1)$$

where:

K = System stiffness matrix

U = Nodal point displacement vector

P = External forces, dead weight or equivalent thermal load vector.

The system stiffness matrix is obtained from element stiffness matrices using direct stiffness methods. The unknown nodal displacements U are obtained as follows:

$$U = K^{-1}P \quad (2)$$

The inversion of the stiffness matrix is performed using the Gauss-Siedel technique.

From the nodal displacements U , the member internal forces are determined using the member stiffness matrix. Finally the member internal forces are used in calculating the stresses.

6.3 Eigenvalue Analysis

The eigenvalues (natural frequencies) and the eigenvectors (mode shapes) for each of the natural modes of vibration are calculated by solving the following frequency equation:

$$\left[K - \omega_n^2 M \right] \left\{ \Phi_n \right\} = \left\{ 0 \right\} \quad (3)$$

where:

ω_n = Natural angular frequency for the n^{th} mode

M = System mass matrix

Φ_n = Mode shape vector for the n^{th} mode

0 = Null vector

The eigenvalue/eigenvector extraction is performed using the Householder-QR technique.

6.4 Dynamic (Seismic) Load Analysis

Considering only translational degrees of freedom and assuming viscous (velocity proportional) form of damping, the equation of motion in matrix form can be expressed as follows:

$$M(\ddot{U}_t + \ddot{U}_{gt}) + C\dot{U}_t + KU_t = 0 \quad (4)$$

where:

\ddot{U}_t = Relative acceleration time history vector

\ddot{U}_{gt} = Ground acceleration time history vector

C = Damping matrix

\dot{U}_t = Velocity time history vector

U_t = Relative displacement time history vector

Rearranging equation (4)

$$M\ddot{U}_t + C\dot{U}_t + KU_t = -M\ddot{U}_{gt} = P_{eff} \quad (5)$$

To uncouple equation (5), assume

$$U = \Phi Y_t$$

where:

Φ = Characteristic free vibration mode shapes matrix.

Y_t = Generalized coordinate displacement time history vector.

Pre-and post-multiplying equation (5) by the transpose of Φ and by Φ respectively and using orthogonality conditions, the following uncoupled equations of motion are obtained:

$$\ddot{Y}_{nt} + 2\omega_n \lambda_n \dot{Y}_{nt} + \omega_n^2 Y_{nt} = M_n^{*-1} R_n \ddot{U}_{gt} \quad (6)$$

where:

Y_{nt} = Generalized displacement coordinate time history for nth mode

λ_n = Damping ratio for the nth mode expressed as percent of critical damping

M_n^* = Generalized mass for the nth mode

$$= \Phi_n^T M \Phi_n = M_i \phi_{in}^2$$

The mode shape ϕ_n is normalized such that $M_n^* = 1$

R_n = Participation factor for the n^{th} mode

$$= \phi_n^T M I = \sum M_i \phi_{in}$$

I = Column vector whose elements are generally unity

The solution for the differential equation (6) is given by the Duhamel Integral

$$Y_{nt} = \frac{R_n}{M_n^* \omega_n} \int_0^t \ddot{u}_{gt} e^{-\lambda_n \omega_n (t-\tau)} \sin \omega_n (t-\tau) d\tau$$

Using the response spectrum method of analysis, the maximum values of the generalized response for each mode is given by:

$$\ddot{Y}_{n \max} = \frac{R_n S_{an}}{M_n^*} \quad (7)$$

where:

$\ddot{Y}_{n \max}$ = Maximum generalized coordinate acceleration response for the n^{th} mode.

S_{an} = Spectral acceleration value for the n^{th} mode (from the applicable response spectrum curve)

From the maximum generalized coordinate response, the maximum acceleration ($\ddot{U}_{n \max}$) and maximum inertia forces ($F_{n \max}$) at each mass point are given by:

$$\ddot{U}_{n \max} = \ddot{Y}_{n \max} \phi_{in}$$

$$F_{n \max} = M_n \ddot{U}_{n \max}$$

The inertia forces ($F_{n \max}$) for each of the system natural modes are applied as external static forces, and the piping system response (displacements, member internal forces and stresses) are calculated using the procedure described in Section 4.2. Total system response is then obtained by combining the individual modal response values by the square-root of the sum of the squares method; lower modes having large contribution to the response (all modes having natural frequency under 30 cycles per second) are considered and higher modes with negligible participation are neglected.

6.5 Stress Analysis

The design requirements of the ASME Code for Class 2 piping systems are satisfied when the calculated stresses in the piping system due to thermal expansion, weight, and other sustained and occasional loads are combined in accordance with and meet the limitations of, equations 8,9,10,and 11 of Subsection NC-3652 of Reference 8. These requirements are described below:

A. Sustained Loads

The effects of pressure weight and other sustained mechanical loads must meet the requirements of equation (8).

$$S_{SL} = \frac{PD_o}{4t_n} + \frac{0.75iM_A}{Z} \leq 1.0S_h \quad (8)$$

where:

P = Internal design pressure, psi

D_o = Outside diameter of pipe, in.

t_n = Nominal wall thickness, in.

M_A = Resultant moment loading on cross section due to weight and other sustained loads, in. (See NC-3652.4, Ref.8)

Z = Section modulus of pipe, in.³ (See NC-3652.4, Ref.8)

i = Stress intensification factor (NC-3673.2 (b), Ref.8)
The product of 0.75i shall never be taken as less than 1.0

S_h = Basic material allowable stress at design temperature

B. Occasional Loads

The effects of pressure, weight, other sustained loads and occasional loads including earthquake must meet the requirements of Equation (9).

$$S_{OL} = \frac{P_{max} D_o}{4t_n} + \frac{0.75i (M_A + M_B)}{Z} \leq 1.2S_h \quad (9)$$

where:

P_{max} = Peak pressure, psi

M_B = Resultant moment loading on cross section due to occasional loads such as earthquake loads

C. Thermal Expansion

The requirements of either Equation (10) or Equation (11) must be met.

1. The effects of thermal expansion must meet the requirements of Equation (10)

$$S_{TE} = \frac{iM_C}{Z} \leq S_A \quad (10)$$

where:

M_C = Range of resultant moments due to thermal expansion. Also include moment effects of anchor displacements due to earthquake if anchor displacement effects were omitted from Equation (9)

S_A = Allowable stress range for expansion stresses (NC-3611.2, Ref.8)

2. The effects of pressure, weight, other sustained loads and thermal expansion shall meet the requirements of Equation (11)

$$S_{TE} = \frac{PD_o}{4t_n} + 0.75i \frac{M_A}{Z} + \frac{iM_C}{Z} \leq (S_h + S_A) \quad (11)$$

The above mentioned static, dynamic and stress analyses are carried out using the PIPESD computer code. PIPESD was developed by URS/John A. Blume and Associates, Engineers, San Francisco, California and has been extensively used in the seismic and stress analysis of piping system for a number of nuclear power plants. PIPESD is available to Nuclear Energy Services through the Control Data Corporation CYBERNET Service.

7. DISCUSSION OF RESULTS

A preliminary seismic analysis of the feedwater piping system with its existing support configuration indicated that the stresses due to the operating basis earthquake would be substantially greater than the allowable stress values at critical locations (particularly in the vicinity of nodes 1,23, 29, 45,53 and 65). In addition, this preliminary analysis indicated that, in the relatively long condensate return line, the lateral deflections due to the seismic inertia loads would be of the order of 5 to 6 inches. In order to reduce the seismic stresses and deflections to acceptable values eleven seismic snubbers were located at critical locations in the piping system as shown in Figure 3.1. The results presented in this report represent the response of this modified system configuration.

The natural frequencies for the first 42 modes of vibration of the piping system are summarized in Table 7-1, from which it may be seen that the piping system is a fairly flexible (low frequency) system.

The deflections at each node point due to the various load cases are summarized in Table B-1, pages B-1 through B-10 of Appendix B. The maximum deflection due to the SSE seismic inertia loading (Load Case 10) is 0.46 inches at node point 88. For a flexible piping system this deflection should be acceptable. The maximum deflection due to thermal expansion (Load Case 4) is 3.3 inches at node 89. Table B-11, pages B-11 through B-14 of Appendix B, summarizes the elastic support reaction forces. The seismic restraints and anchors should be designed (sized) using these restraint forces. The maximum reaction force in the seismic restraints is 1041 pounds (Load Case 11).

The results of the detailed stress analysis in accordance with the requirements of Subarticle NC 3652 of the ASME Code for the Class 2 piping system are given in Table B-11, pages B-15 through B-41 of Appendix B. Figures No. 7.1 through 7.9 indicate node points with maximum stresses or stresses exceeding 10.0 ksi for specified Class 2 load conditions. From these stress results summaries, it may be seen that code allowable stress values are not exceeded.

TABLE 7-1
NATURAL FREQUENCIES OF VIBRATION

<u>Mode No.</u>	<u>Frequency (CPS)</u>	<u>Mode No.</u>	<u>Frequency (CPS)</u>
1	2.85	22	15.12
2	3.52	23	15.18
3	3.83	24	15.64
4	4.14	25	16.16
5	4.45	26	16.50
6	5.08	27	17.10
7	5.39	28	18.11
8	5.90	29	18.77
9	6.66	30	20.03
10	7.30	31	20.24
11	7.67	32	20.61
12	8.23	33	22.10
13	9.04	34	23.09
14	10.86	35	25.45
15	11.56	36	25.54
16	11.80	37	25.85
17	12.66	38	26.77
18	12.95	39	28.14
19	13.73	40	29.74
20	13.81	41	29.98
21	14.52	42	32.42

FIGURE 7.1

COMPLIANCE WITH ASME CODE EQUATION 8

Normal Operating Conditions

Applied Loads	
Design Pressure	
Dead Weight and Other Sustained Mechanical Loads	
Allowable Stress,	$1.0 S_h = 15.9 \text{ KSI}$
Maximum Stress at Node	53 = 7.5 KSI

(Stresses Greater Than 6.0 KSI Indicated)




FIGURE 7.2

COMPLIANCE WITH ASME CODE EQUATION 9

Upset Conditions

Applied Loads
Peak Pressure Dead Weight and Other Sustained Mechanical Loads $X + Y$ Earthquake (1/2 SSE)
Allowable Stress, $1.2 S_h = 19.1$ KSI
Maximum Stress at Node 53 = 14.7 KSI

(Stresses Greater Than 10.0 KSI Indicated)




FIGURE 7.3

COMPLIANCE WITH ASME CODE EQUATION 9

Upset Conditions	
Applied Loads	
Peak Pressure Dead Weight and Other Sustained Mechanical Loads Z + Y Earthquake (1/2 SSE)	
Allowable Stress, $1.2 S_h = 19.1$ KSI	
Maximum Stress at Node 53 = 14.1 KSI	

(Stresses Greater Than 10.0 KSI Indicated)




FIGURE 7.4

COMPLIANCE WITH ASME CODE EQUATION 10

Normal Operating and Upset Conditions

Applied Loads	
Design Temperature	
Thermal Anchor Movements	
Seismic Anchor Movements (X-direction)	
Allowable Stress, S_A	= 23.4 KSI
Maximum Stress at Node 29	= 12.5 KSI

(Stresses Greater Than 10.0 KSI Indicated)




FIGURE 7.5

COMPLIANCE WITH ASME CODE EQUATION 10

Normal Operating and Upset Conditions

Applied Loads	
Design Temperature	
Thermal Anchor Movements	
Seismic Anchor Movements (Z-direction)	
Allowable Stress, S_A	= 23.4 KSI
Maximum Stress at Node 29	= 17.0 KSI

(Stresses Greater Than 10.0 KSI Indicated)




FIGURE 7.6

COMPLIANCE WITH ASME CODE EQUATION 11

Normal Operating and Upset Conditions

Applied Loads	
Design Pressure and Temperature Dead Weight and Other Sustained Mechanical Loads Thermal Anchor Movements Seismic Anchor Movements (X-direction)	
Allowable Stress, $S_h + S_A =$	39.3 KSI
Maximum Stress at Node 29 =	17.1 KSI

(Stresses Greater Than 10.0 KSI Indicated)




FIGURE 7.7

COMPLIANCE WITH ASME CODE EQUATION 11

Normal Operating and Upset Conditions

Applied Loads
Design Pressure and Temperature
Dead Weight and Other Sustained Mechanical Loads
Thermal Anchor Movements
Seismic Anchor Movements (Z-direction)
Allowable Stress, $S_h + S_A = 39.3$ KSI
Maximum Stress at Node 29 = 21.6 KSI

(Stresses Greater Than 10.0 KSI Indicated)




FIGURE 7.3

COMPLIANCE WITH ASME CODE EQUATION 9

FAULTED Conditions

Applied Loads
Peak Pressure
Dead Weight and Other Sustained Mechanical Loads
X + Y Earthquake (SSE)
Seismic Anchor Movements (X-direction, SSE)
Allowable Stress, $1.8 S_h = 28.6$ KSI
Maximum Stress at Node 53 = 17.6 KSI

(Stresses Greater Than 10.0 KSI Indicated)





FIGURE 7.9

COMPLIANCE WITH ASME CODE EQUATION 9

Faulted Conditions

Applied Loads
Peak Pressure Dead Weight and Other Sustained Mechanical Loads Z + Y Earthquake (SSE) Seismic Anchor Movements (Z-direction, SSE)
Allowable Stress, $1.8 S_h = 28.6$ KSI
Maximum Stress at Node 53 = 18.3 KSI

(Stresses Greater Than 10.0 KSI Indicated)



8. CONCLUSION AND RECOMMENDATIONS

1. The existing support system of the LACBWR feedwater and condensate return piping system is not adequate to withstand the specified seismic events.
2. The results of the subject analysis, which includes effects of 11 additional seismic restraints, indicate that the deflections of the feedwater and condensate return piping system, due to dead weight, thermal expansion and seismic loading are nominal. In addition, the stresses resulting from these loadings, as calculated and combined in accordance with the rules given in Subarticle NC-3652 of Section III of the ASME Code (Ref.2), satisfy the design requirements for Class 2 piping systems.
3. It is therefore recommended that the feedwater and condensate return piping system be provided with eleven seismic restraints at the locations indicated in Figure 3.1. The seismic restraints and their attachments should be oriented as shown in Figure 3.1 and designed using the support reaction forces and node displacements given in Appendix B of this report.

9. REFERENCES

1. Gulf United Services Report No. SS-1162 "Seismic Evaluation of the LaCrosse Boiling Water Reactor", dated January 11, 1974.
2. ASME Boiler and Pressure Vessel Code, Section III, Division I, 1974 Edition, Nuclear Power Plant Components.
3. Sargent and Lundy Engineers "Specification for Piping System- LaCrosse Boiling Water Reactor" LACBWR #256.
4. Sargent and Lundy Engineers "LACBWR" Project Drawing Nos. 41-503374, 503375, 503376.
5. United Nuclear Corporation "Review of LACBWR Feedwater Nozzle and Recirculation Piping Stress Analyses" Report, dated October 1970.
6. Allis-Chalmers, "LaCrosse Boiling Water Reactor Safeguards Report Volume 1 and 11; LACBWR #283, dated August, 1967.
7. U.S. Atomic Energy Commission - Regulatory Guide 1.48, May 1973.
8. Nuclear Energy Services Report No. 81A0086 "Seismic and Stress Analysis of LACBWR Recirculation Piping System", dated June 20, 1975.
9. Sargent and Lundy Engineers, "Piping Flexibility Analysis for LACBWR Project", dated October 1965.

APPENDIX A
LACBWR FEEDWATER PIPING ANALYSIS
ANALYTICAL INPUT DATA

TABLE		PAGE
A-I	Pipe Properties	A-1
A-II	Valve Weights	A-2
A-III	Static Load Cases	A-3 through A-6
A-IV	Dynamic Load Cases	A-7
A-V	Seismic Response Spectra	A-8

TABLE A-1 - Pipe Data

Run No.	From Point	To Point	O.D. (in.)	Wall Thick.(in.)	Matl. ASTM	Fluid	Wt.of Pipe and Fluid (lb./in.)	Wt.of Insul. (lb./in.)	Design Temp. (°F)	Design Press. (psia)	Elastic Modulus (psi) ₋₆ x10 ⁻⁶
1	1	11	4.500	.337	A376 TYPE 304	WATER	1.66	0.45	547	1300	25.8
1	3	10	4.500	.337			1.66	0.45	547	1300	25.8
1	3	19	6.625	.562			3.89	0.71	547	1300	25.8
2	23	30	6.625	.562			3.89	0.71	547	1300	25.8
2	30	38	4.500	.337			1.66	0.45	547	1300	25.8
2	29	45	4.500	.337			1.66	0.45	547	1300	25.8
3	24	57	8.625	.593			5.81	0.85	547	1300	25.8
4	57	65	8.625	.500			5.27	0.85	295	1380	27.1
5	53	94	4.500	.337			1.66	0.45	547	1300	25.8
5	94	104	6.625	.562			3.89	0.71	547	1300	25.8

TABLE A-II - Valve Weights

<u>Valve</u>	<u>Node Location</u>	<u>Total Weight, Lbs.</u>	<u>Eccentric Weight, Lbs.</u>	<u>Eccentricity, In.</u>
8" Gate	57-570	810	405	18
8" Check	60	474	0	0
4" Check	69	156	0	0
4" Check	79	156	0	0
4" Gate	69-690	165	83	10
4" Gate	79-790	165	83	10
4" Control	71-710	630	315	40
4" Control	81-810	630	315	40

TABLE A-III
STATIC LOAD CASES

A) STATIC LOAD CASE : 1
LOAD CASE TITLE : DEAD LOAD PLUS SUSTAINED MECHANICAL LOADS

SINGLE JOINT FORCE AND MOMENT LOADING

JOINT ID	LOAD TYPE	LOAD DIRECTION	LOAD MAGNITUDE
17	FORCE	Y	730.0000
26	FORCE	Y	600.0000
54	FORCE	Y	1640.0000
77	FORCE	Y	660.0000
86	FORCE	Y	2300.0000
90	FORCE	Y	1050.0000
94	FORCE	Y	600.0000
100	FORCE	Y	1150.0000

B) STATIC LOAD CASE : 2
LOAD CASE TITLE : NORMAL OPERATING PRESSURE

THERMAL AND PRESSURE LOADINGS FOR ALL PIPE RUNS

RUN ID	DESIGN PRESSURE (PSI)	TEMPERATURE CHANGE (DEG)	LINEAR TEMPERATURE GRADIENT (DEG)	NONLINEAR TEMPERATURE GRADIENT (DEG)	LONG. PRESSURE STRESS
1	1255.00	0.00	0.000	0.000	NO
2	1235.00	0.00	0.000	0.000	NO
3	1285.00	0.00	0.000	0.000	NO
4	1365.00	0.00	0.000	0.000	NO
5	1285.00	0.00	0.000	0.000	NO

C) STATIC LOAD CASE : 3
LOAD CASE TITLE : MAXIMUM PRESSURE

THERMAL AND PRESSURE LOADINGS FOR ALL PIPE RUNS

RUN ID	DESIGN PRESSURE (PSI)	TEMPERATURE CHANGE (DEG)	LINEAR TEMPERATURE GRADIENT (DEG)	NONLINEAR TEMPERATURE GRADIENT (DEG)	LONG. PRESSURE STRESS
1	1400.00	0.00	0.000	0.000	NO
2	1400.00	0.00	0.000	0.000	NO
3	1400.00	0.00	0.000	0.000	NO
4	1500.00	0.00	0.000	0.000	NO
5	1400.00	0.00	0.000	0.000	NO

TABLE A-III

STATIC LOAD CASES (CONT'D)

D) STATIC LOAD CASE : 4

LOAD CASE TITLE : NORMAL OPERATING TEMPERATURE

INCL. THERMAL ANCHOR MOVEMENTS

SUPPORT DISPLACEMENTS

JOINT ID	LOAD TYPE	DISPLACEMENT DIRECTION	DISPLACEMENT MAGNITUDE
10	TRANS.	X	-.310
10	TRANS.	Y	.228
10	TRANS.	Z	.208
11	TRANS.	X	.160
11	TRANS.	Y	.229
11	TRANS.	Z	.353
4	TRANS.	Y	.228
35	TRANS.	Y	.228
38	TRANS.	X	-.054
38	TRANS.	Y	.227
38	TRANS.	Z	-.359
45	TRANS.	X	.360
45	TRANS.	Y	.228
45	TRANS.	Z	-.143
104	TRANS.	X	-.065
104	TRANS.	Z	-.113

THERMAL AND PRESSURE LOADINGS FOR ALL PIPE RUNS

RUN ID	DESIGN PRESSURE (PSI)	TEMPERATURE CHANGE (DEG)	LINEAR TEMPERATURE GRADIENT (DEG)	NONLINEAR TEMPERATURE GRADIENT (DEG)	LONG. PRESSURE STRESS
1	0.00	477.00	-0.000	-0.000	NO
2	0.00	477.00	-0.000	-0.000	NO
3	0.00	477.00	-0.000	-0.000	NO
4	0.00	225.00	-0.000	-0.000	NO
5	0.00	477.00	-0.000	-0.000	NO

TABLE A-111
 STATIC LOAD CASES (CONT'D)

E) STATIC LOAD CASE : 6
 LOAD CASE TITLE : SEISMIC ANCHOR MOVEMENTS X-DIRECTION (1/2 SSE)

SUPPORT DISPLACEMENTS

JOINT ID	LOAD TYPE	DISPLACEMENT DIRECTION	DISPLACEMENT MAGNITUDE
10	TRANS.	X	.560
11	TRANS.	X	.560
38	TRANS.	X	.560
45	TRANS.	X	.560
104	TRANS.	X	1.230

F) STATIC LOAD CASE : 7
 LOAD CASE TITLE : SEISMIC ANCHOR MOVEMENTS Z-DIRECTION (1/2 SSE)

SUPPORT DISPLACEMENTS

JOINT ID	LOAD TYPE	DISPLACEMENT DIRECTION	DISPLACEMENT MAGNITUDE
10	TRANS.	Z	.560
11	TRANS.	Z	.560
38	TRANS.	Z	.560
45	TRANS.	Z	.560
104	TRANS.	Z	1.230

TABLE A-III
 STATIC LOAD CASES (CONT'D)

G) STATIC LOAD CASE : 12
 LOAD CASE TITLE : SEISMIC ANCHOR MOVEMENTS X - DIRECTION (SSF)

SUPPORT DISPLACEMENTS

JOINT ID	LOAD TYPE	DISPLACEMENT DIRECTION	DISPLACEMENT MAGNITUDE
10	TRANS.	X	.740
11	TRANS.	X	.740
38	TRANS.	X	.740
45	TRANS.	X	.740
104	TRANS.	X	2.380

H) STATIC LOAD CASE : 13
 LOAD CASE TITLE : SEISMIC ANCHOR MOVEMENTS Z - DIRECTION (SSE)

SUPPORT DISPLACEMENTS

JOINT ID	LOAD TYPE	DISPLACEMENT DIRECTION	DISPLACEMENT MAGNITUDE
10	TRANS.	Z	.740
11	TRANS.	Z	.740
38	TRANS.	Z	.740
45	TRANS.	Z	.740
104	TRANS.	Z	2.380

TABLE A-IV - DYNAMIC LOAD CASES

<u>Load Case No.</u>	<u>Load Description</u>	<u>Spectrum IDS</u>			<u>Spectrum Multipliers</u>		
		X	Y	Z	X	Y	Z
8	x + y Earthquake ($\frac{1}{2}$ SSE)	1	3	0	386.4	128.8	0
9	z + y Earthquake ($\frac{1}{2}$ SSE)	0	3	1	0	128.8	386.4
10	x + y Earthquake (SSE)	2	3	0	386.4	257.6	0
11	z + y Earthquake (SSE)	0	3	2	0	257.6	386.4

TABLE A-V
SEISMIC RESPONSE SPECTRA

SPECTRUM ID	FREQUENCY CPS	PERIOD SEC.	ACCELERATION G.'s
1	40.000	.025	.16000
	15.000	.067	.16000
	10.000	.100	.16000
	7.000	.143	.27000
	6.000	.167	.29000
	5.000	.200	.24000
	4.000	.250	.57000
	3.500	.286	.45000
	3.000	.333	.24000
	2.400	.417	.35000
	2.000	.500	.70000
	1.800	.556	1.70000
	1.600	.625	1.70000
	1.400	.714	.63000
	1.200	.833	.55000
	1.000	1.000	.30000
	.900	1.111	.18000
.700	1.429	.11000	
.500	2.000	.09000	
2	40.000	.025	.25000
	20.000	.050	.25000
	13.000	.077	.25000
	10.000	.100	.34000
	9.000	.111	.50000
	8.000	.125	.50000
	6.000	.167	.70000
	5.000	.200	.60000
	3.500	.286	.43000
	3.000	.333	.25000
	2.000	.500	.60000
	1.700	.588	1.75000
	1.400	.714	.70000
	1.000	1.000	.40000
	.900	1.111	.33000
	.700	1.429	.21000
	.500	2.000	.15000
3	40.000	.025	.12000
	33.000	.030	.12000
	20.000	.050	.23000
	15.000	.067	.32000
	10.000	.100	.52000
	9.000	.111	.60000
	5.000	.200	.65000
	3.000	.333	.70000
	2.500	.400	.72000
	2.200	.455	.63000
	2.000	.500	.59000
	1.500	.667	.44000
	1.000	1.000	.31000
	.800	1.250	.24300
	.600	1.667	.18000
	.400	2.500	.13000
	.200	5.000	.08400
.100	10.000	.01400	

APPENDIX B

LACBWR FEEDWATER PIPING ANALYSIS

TABULATED RESULTS

TABLE		PAGE
B-I	JOINT DISPLACEMENTS	B-1 through B-10
B-II	ELASTIC SUPPORT REACTIONS	B-11 through B-14
B-III	CLASS 2 PIPING STRESS SUMMARY	B-15 through B-42

TABLE B-1 (a)

JOINT DISPLACEMENTS (LOAD CASE 1)

DEAD LOAD PLUS SUSTAINED MECHANICAL LOADS

JOINT (GIO)	DISPLACEMENTS (IN.)				DISPLACEMENTS (IN.)		
	X	Y	Z		X	Y	Z
1	.0001994	-.0000467	-.0008842	57	.0010724	-.0121963	-.0053340
2	.0003553	.0005264	-.0007451	59	.0010737	-.0059936	-.0031955
3	.0004499	.0002336	-.0005447	60	.0010745	-.0047649	-.0021174
4	.00034851	-.0000000	.0003149	61	.0010761	-.0019351	-.0005813
6	.0004946	-.0046555	.0005570	62	.0004585	-.0011077	-.0005048
7	.0003632	-.0069102	.0007451	63	-.0000279	-.0010947	-.0004146
8	.0000277	-.0008193	.0008754	64	-.0000741	-.0005435	.0000002
9	.0000022	-.0000100	.0002478	65	-.0000000	-.0000000	.0000000
10	.0000000	-.0000000	.0000000	66	-.0003259	.0131902	-.0110569
11	.0000000	-.0000000	-.0000000	67	-.0003263	.0213101	-.0108354
12	-.0013386	-.0041279	-.0013143	68	-.0060153	.0263623	-.0117302
13	-.0002417	-.0041153	-.0022397	69	-.0022974	.0555326	-.0165205
14	.0031925	-.0041076	-.0023073	71	.0046446	.0979442	-.0240995
15	.0009143	-.0020610	-.0040241	72	.0630726	.0963116	.0224804
16	.0111155	.0011590	-.0064954	73	-.0077026	.0174248	-.0110504
17	.0145246	.0046051	-.0103916	74	-.0062545	.0139412	-.0103332
18	.0145320	.0045646	-.0122334	75	.0161021	.0677293	.0120813
19	.0145342	-.0133238	-.0251031	76	.0274935	.0757048	.0122357
20	.0114458	-.0056874	-.0250996	77	.0374081	.0757169	.0036057
21	.0063299	-.0024231	-.0250939	78	.0427271	.0716228	.0049223
22	.0023273	-.0014403	-.0250382	79	.0369459	.0597031	.0049521
23	-.0009445	-.0014935	-.0250977	81	.0330877	.0610774	.0049311
24	-.0022577	-.0015075	-.0250477	82	.0503450	.0611460	.0145705
25	-.0009452	-.0018027	-.0109623	83	.0593076	.0701836	.0224547
26	-.0003652	-.0016473	-.0091015	84	.1665910	.0997511	.1018079
27	-.0008672	-.0016603	-.0081205	85	.2397089	.1013735	.1105760
28	-.0006659	-.0016651	-.0077741	86	.2799423	.1033253	.0690792
29	-.0005879	-.0016996	-.0050874	87	.2775550	.1034886	.0166533
30	-.0002944	-.0017223	-.0037205	88	.2395820	.1037979	-.0112250
31	.0001499	-.0017330	-.0030231	89	.1746093	.1042068	.0074755
32	.0000942	-.0016978	-.0029351	90	.0900290	.1046836	.0829565
33	.0001155	-.0024617	-.0029751	91	.0612707	.0368353	.1065411
34	.0000921	-.0012166	-.0023446	92	-.0284861	-.0227429	.1500827
35	.0000350	-.0000000	-.0024552	93	-.0951687	-.0774241	.1619142
36	.0000966	-.0001463	-.0001525	94	-.1053068	-.0304730	.1630543
37	.0000067	-.0000055	-.0000131	95	-.1077599	-.0309016	.1658132
38	-.0000000	-.0000000	-.0000000	96	-.1033352	-.0313033	.1566140
39	.0000668	-.0023052	-.0052073	97	-.1051476	-.0605809	.1111637
40	.0009875	-.0029770	-.0046285	98	-.0916148	-.0116893	.0678071
41	.0004716	-.0023336	-.0314923	99	-.0793634	.0104030	.0543454
42	.0007437	-.0024436	-.0006348	100	-.0631732	.0205240	.0448224
43	.0006917	-.0046312	.0000529	101	-.0224160	-.0051738	.0116649
44	.0000122	-.0000018	.0000621	102	-.0048641	-.0037625	-.0003117
45	.0000000	-.0000000	-.0000000	103	-.0000065	-.0000025	-.0000038
46	.0212262	-.0227624	-.0251017	104	.0000000	-.0000000	.0000000
47	.0279011	-.0221651	-.0203393	105	.0305370	.0462037	.1223176
48	.0277476	-.0033255	-.0157591	106	.0221691	.1033539	.0561136
49	.0238034	-.0041056	-.0150504	107	.0718547	.0344151	.0310116
50	.0000473	-.0041717	-.0157511	108	-.0011926	-.0033026	-.0003340
51	-.0107356	-.0043047	-.0149873	109	-.0052247	.0063700	-.0138476
52	-.0218521	-.0021255	-.0124145	710	-.0614945	.0473302	-.0714627
53	-.0032256	.0125011	-.0124182	720	.0389459	.0727746	.0073061
54	-.0078136	.0118411	-.0124183	810	-.0208290	.0610675	-.0160247
55	-.0033733	.0026516	-.0124187				
56	.0010711	-.0145072	-.0033490				

TABLE B-1 (b)

JOINT DISPLACEMENTS (LOAD CASE 4)

NORMAL OPERATING TEMPERATURE INCL. THERMAL ANCHOR MOVEMENTS

JOINT (GID)	DISPLACEMENTS (IN.)				X	Y	Z
	X	Y	Z				
1	.157347	.303143	.354668	56	.531343	-.154890	.612237
2	.142602	.298522	.379734	57	.354302	-.071164	.441417
3	.116496	.291662	.399822	59	.198409	-.003896	.274463
4	-.086579	.228000	.475214	60	.151702	.029633	.169135
6	-.203119	.203733	.507714	61	.061352	.077627	-.016331
7	-.288463	.229773	.447135	62	.028501	.060896	-.057914
8	-.307426	.297633	.240502	63	.021571	.028991	-.060966
9	-.311134	.274351	.208662	64	.003920	.001044	-.039260
10	-.310000	.228000	.200000	65	-.000000	.000000	.000000
11	.150000	.228000	.353000	66	.851783	-.407203	.373947
12	.256396	.345437	.173329	67	.832627	-.403169	.365072
13	.306874	.319452	.125218	68	.815406	-.404062	.393799
14	.364162	.209033	.092784	69	.773014	-.430775	.272897
15	.465174	.130530	.039116	71	.725289	-.457970	.180967
16	.543017	.095670	-.016035	72	.811565	-.230943	.061292
17	.661704	.034139	-.098238	73	.845699	-.395979	.393661
18	.693712	.026617	-.120631	74	.821237	-.382569	.410736
19	1.063270	.014622	-.340233	75	.640446	-.254915	.504896
20	1.026226	.007135	-.424010	76	.623966	-.207673	.500060
21	.973541	.000073	-.542408	77	.637100	-.173594	.478126
22	.917739	-.003456	-.661365	78	.678178	-.153644	.432170
23	.875227	-.004028	-.745137	79	.699317	-.221418	.342776
24	.857485	-.013743	-.772657	81	.729659	-.207304	.225450
25	.506926	-.060336	-.448132	82	.760647	-.233535	.126440
26	.463119	-.034433	-.458036	83	.755339	-.229072	.140069
27	.467793	.008604	-.431267	84	1.143238	.111636	-.185973
28	.456207	.015975	-.421074	85	1.638397	.919209	-.400629
29	.483889	.158957	-.376074	96	2.243139	.966051	-.584861
30	.513195	.242650	-.290672	97	2.770429	1.334333	-.591736
31	.545737	.326403	-.259713	88	3.155521	1.803714	-.494318
32	.537398	.356103	-.278541	89	3.200546	2.180662	-.267528
33	.415495	.263346	-.459792	90	3.126618	2.522880	.071183
34	.350633	.235365	-.447914	91	3.116261	2.539874	.200798
35	.274877	.228000	-.447340	92	2.769362	2.280632	.651945
36	-.024627	.217313	-.369452	93	2.314403	2.030521	1.004633
37	-.054545	.273106	-.360441	94	2.124426	2.050993	1.119325
38	-.054000	.227100	-.359000	95	1.947268	2.129443	1.146916
39	.502516	.141862	-.311245	96	1.519564	2.005325	1.156656
40	.520010	.151065	-.267236	97	1.169264	1.478590	1.095387
41	.493290	.290702	-.175985	98	.755159	.870341	1.007812
42	.459449	.313798	-.154927	99	.620272	.670404	.822563
43	.386843	.304293	-.141144	100	.534297	.517611	.794509
44	.359586	.274379	-.161864	101	.236227	.054279	.330908
45	.360000	.228000	-.143000	102	.010655	-.114835	-.001697
46	1.176152	.031433	-.140689	103	-.064652	-.006747	-.112375
47	1.045911	.052644	.048485	104	-.065000	.000000	-.113000
48	.986413	.053211	.102804	105	3.010008	2.446206	-.345430
49	.858156	-.000639	.104944	106	2.342016	1.077740	-.576165
50	.898485	-.230431	.303771	107	.828732	-.293026	.042916
51	.962665	-.507215	-.079358	570	.439284	-.094593	.441417
52	.902765	-.657537	-.079820	690	.762694	-.309742	.262036
53	.904852	-.414279	.390037	710	.655730	-.457970	.310934
54	.877346	-.406117	.414535	700	.629317	-.189923	.326639
55	.836638	-.327865	.666933	810	.634073	-.207804	.347523

TABLE B-1 (c)

JOINT DISPLACEMENTS (LOAD CASE 6)
SEISMIC ANCHOR MOVEMENTS X-DIRECTION (1/2 SSE)

JOINT (GIO)	DISPLACEMENTS (IN.)				X	Y	Z
	X	Y	Z				
1	.559351	.000036	.002043	59	.004176	-.000065	.009611
2	.559592	-.000933	.002258	60	.004163	-.000442	.004163
3	.559725	-.001417	.002529	61	.004137	-.001034	-.002440
4	.559695	-.000000	.001933	62	.003364	-.000652	-.002496
6	.559640	-.000005	.000704	63	.001939	-.000656	-.000896
7	.559979	.000133	.000042	64	.000363	-.000086	-.000009
8	.560025	.000020	.000018	65	.000000	.000000	-.000030
9	.560012	.000021	.000022	66	.000022	.004764	.066730
10	.560000	.000020	.000000	67	.005022	.007005	.060320
11	.560000	.000010	.000000	68	.007746	.009543	.053737
12	.559306	.004934	.001152	69	.029161	.013592	.033322
13	.559065	.003700	.001121	71	.015130	.029824	.010304
14	.560621	.003720	.001637	72	.014247	.029819	.011418
15	.527855	-.001322	.008921	73	.008421	.004465	.066730
16	.521346	-.007359	.020487	74	.001809	.005200	.063930
17	.514913	-.014229	.040116	75	.044018	.023145	.016196
18	.514503	-.014358	.047195	76	.041746	.025964	.009830
19	.514392	-.005658	.146887	77	.047294	.025965	.010178
20	.576899	-.002773	.146884	78	.061475	.026297	.010432
21	.567053	-.000147	.146879	79	.091959	.027465	.010492
22	.596263	.001439	.146874	81	.131812	.028948	.010491
23	.616703	.002334	.146871	82	.143347	.028949	.011145
24	.624930	.002613	.146871	83	.158233	.029283	.011418
25	.616651	.000231	.054395	84	.285288	.029812	.012132
26	.614631	-.002247	.043416	85	.423457	.029905	.010121
27	.611251	-.003543	.038056	86	.599926	.029797	.007190
28	.602566	-.003848	.036363	87	.773291	.029739	.006132
29	.590424	-.003932	.025094	88	.940341	.029741	.009067
30	.577179	-.003823	.018949	89	1.073686	.029774	.017072
31	.563818	-.003914	.014020	90	1.171879	.029768	.030152
32	.561273	-.005900	.013295	91	1.197460	.031672	.032875
33	.560699	-.003022	.013804	92	1.206254	.037621	.036726
34	.560626	-.000865	.013691	93	1.212965	.033162	.039310
35	.560606	-.000000	.012190	94	1.213616	.038153	.039592
36	.560531	-.000165	.001118	95	1.214260	.038153	.039801
37	.560268	.000002	.000156	96	1.214742	.033080	.036469
38	.560000	.000000	.000000	97	1.214769	.039556	.026659
39	.559568	-.000837	.026020	98	1.214344	.029822	.019295
40	.576339	.002412	.024175	99	1.215530	.026432	.015834
41	.561176	.002434	.011016	100	1.218152	.022330	.013359
42	.559854	.001060	.006215	101	1.226253	.008001	.005076
43	.560062	.000017	.000777	102	1.229792	.000933	.001001
44	.560100	-.000607	-.002144	103	1.230001	.000000	.000001
45	.560000	-.000000	.000000	104	1.230000	.000000	.000000
46	.402445	-.012504	.146803	105	1.194784	.034946	.033033
47	.408496	-.013657	.105503	106	.645362	.029795	.006639
48	.376625	-.005617	.062032	107	.190133	.029819	.011596
49	.366254	.000336	.047517	570	.012947	.000312	.022837
50	.339241	.000325	.064672	600	.117274	.023033	.022435
51	.249477	.000314	.042083	710	.120118	.029824	.009342
52	.225781	.002045	.044520	730	.011009	.035903	-.005769
53	.105022	-.001040	.044558	810	.005967	.023949	.003322
54	.036730	-.001840	.044560				
55	.049767	-.005369	.044674				
56	.004217	-.002132	.046036				
57	.004107	-.000351	.022807				

TABLE B-1 (d)

JOINT DISPLACEMENTS

(LOAD CASE 7)

SEISMIC ANCHOR MOVEMENTS Z-DIRECTION (1/2 SSE)

JOINT (GID)	DISPLACEMENTS (IN.)				X	Y	Z
	X	Y	Z				
1	.000570	-.000024	.559858	59	.005936	-.000910	.116432
2	.001014	-.000152	.560253	60	.005946	.001269	.082512
3	.001266	-.000242	.560776	61	.005967	.002537	.022744
4	.001267	-.000000	.560996	62	.006035	.002464	.006516
6	.001219	.000027	.559353	63	.005843	.002458	.002503
7	.001298	.000000	.559615	64	.001271	.000631	.000016
8	.000228	-.000038	.560024	65	-.000000	.000000	.000000
9	.000048	.000000	.560041	66	.071709	-.024743	.267595
10	.000000	.000000	.560000	67	.071709	-.024661	.265478
11	.000000	-.000000	.560000	68	.072620	-.024144	.263278
12	-.005092	.005328	.554567	69	.079546	-.020019	.256349
13	-.004585	.008939	.548859	71	.087374	-.014733	.248518
14	.005536	.008924	.535698	72	.086175	-.014725	.263245
15	.014297	.012494	.515627	73	.069556	-.025444	.267536
16	.019527	.016602	.495691	74	.067489	-.026377	.265751
17	.022075	.020104	.465662	75	.053848	-.036357	.253115
18	.022160	.020617	.457742	76	.051569	-.037917	.253032
19	.022245	.001726	.363267	77	.051119	-.037918	.255212
20	.009899	.001249	.383273	78	.057624	-.036252	.256927
21	-.007696	.000409	.383283	79	.063034	-.031141	.256929
22	-.026194	-.000046	.383233	81	.075626	-.023939	.256930
23	-.040104	.000204	.363300	82	.075008	-.023940	.261087
24	-.045868	.000448	.383300	83	.077714	-.021699	.263242
25	-.040065	.006652	.461459	84	.076574	-.014721	.320120
26	-.038464	.008662	.474034	85	.059071	-.014716	.414697
27	-.035865	.009658	.482200	86	.035103	-.014711	.546509
28	-.034524	.009830	.485259	87	.011592	-.014707	.645713
29	-.030265	.009876	.510279	88	-.007926	-.014702	.825617
30	-.010226	.009864	.524072	89	-.020039	-.014698	.943386
31	-.000284	.009852	.534950	90	-.023897	-.014694	1.035732
32	.000405	.011935	.536103	91	-.022742	-.023050	1.054096
33	-.000135	.006844	.539210	92	-.012718	-.066732	1.091974
34	-.000481	.002326	.540363	93	.002575	-.097641	1.172371
35	-.000461	.000000	.543168	94	.007612	-.101499	1.132436
36	-.000385	.000012	.558753	95	.011244	-.101499	1.141557
37	-.000250	-.000003	.559862	96	.017411	-.095106	1.162570
38	-.000000	-.000000	.560000	97	.018824	-.081351	1.179503
39	-.015114	.004394	.509392	98	.020471	-.065458	1.193578
40	-.007313	-.001621	.514435	99	.018808	-.056737	1.204819
41	.000147	-.001634	.544155	100	.016176	-.045434	1.209407
42	.000549	-.000795	.552292	101	.004458	-.014126	1.222607
43	.000067	-.000070	.559532	102	.000154	-.001552	1.228465
44	-.000029	.000004	.560346	103	-.000001	-.000000	1.223933
45	.000000	.000000	.560000	104	.000000	-.000000	1.230000
46	.046195	.005935	.283236	105	-.020104	-.033051	1.267335
47	.051123	.000977	.392463	106	.028839	-.014710	.682333
48	.052772	.002080	.397044	107	.035794	-.014725	.265967
49	.063728	-.000127	.388470	570	.033542	-.004883	.170464
50	.079582	-.001174	.384266	690	.075839	-.021846	.252642
51	.099495	-.000052	.252054	710	.072299	-.014733	.234470
52	.101167	-.002025	.273664	790	.063034	-.031650	.251977
53	.071709	-.024974	.273542				
54	.058020	-.025232	.273537	F10	.077570	-.023938	.244433
55	.056644	-.025664	.273511				
56	.005304	-.017319	.206321				
57	.005920	-.007609	.170464				

TABLE B-1 (e)

JOINT DISPLACEMENTS

(LOAD CASE 8)

X + Y EARTHQUAKE (1/2 SSE)

TOTAL RESPONSE EQUALS MODE 1 THROUGH 40 BY SQSS SUMMATION

JOINT GID	DISPLACEMENTS (IN.)				DISPLACEMENTS (IN.)		
	X	Y	Z		X	Y	Z
1	.0005391	.0000291	.0024528	56	.0112546	.0412445	.0934417
2	.0009672	.0014249	.0034098	57	.0112303	.0163523	.0709334
3	.0016218	.0022292	.0047316	59	.0111961	.0020348	.0496629
4	.0016138	.0000000	.0046764	60	.0111744	.0024236	.0360639
6	.0014669	.0006718	.0011416	61	.0111232	.0035001	.0129470
7	.0020757	.0008158	.0004903	62	.0096574	.0023156	.0164166
8	.0004421	.0001200	.0001342	63	.0050182	.0023027	.0023923
9	.0001069	.0000013	.0001164	64	.0008925	.0036432	.0000140
10	.0000000	.0000000	.0000000	65	.0000000	.0000000	.0000000
11	.0000000	.0000000	.0000000	66	.0821919	.0445651	.1110109
12	.0118545	.0120354	.0087546	67	.0821949	.0411613	.1099710
13	.0172091	.0139459	.0142696	68	.0850193	.0353200	.1075388
14	.0280070	.0139579	.0243145	69	.1103212	.0000000	.1095670
15	.0376068	.0117135	.0336786	71	.1430184	.0531270	.1234881
16	.0426225	.0090690	.0384111	72	.0202176	.0532057	.0158227
17	.0478929	.0089199	.0424246	73	.0764703	.0482504	.1110093
18	.0482987	.0089175	.0414909	74	.0706527	.0518178	.1099437
19	.0483566	.0028568	.0000064	75	.0477460	.1310043	.1067295
20	.0355017	.0000000	.0000083	76	.0565783	.1467375	.0965062
21	.0174774	.0015072	.0000114	77	.0693173	.1467469	.0906134
22	.0000000	.0015869	.0000147	78	.0715242	.1344753	.0676715
23	.0116280	.0020354	.0000170	79	.0421702	.0949531	.0676701
24	.0161667	.0023467	.0000170	81	.0514179	.0460239	.0676573
25	.0116197	.0054131	.0394631	82	.0219270	.0460273	.0321413
26	.0113568	.0054717	.0406441	83	.0209242	.0398018	.0158451
27	.0109047	.0054333	.0383472	84	.2186492	.0533338	.1543172
28	.0106470	.0054229	.0377743	85	.2775763	.0534534	.1630678
29	.0074788	.0054209	.0250579	86	.0781779	.0535860	.0482450
30	.0050495	.0054199	.0183805	87	.2310245	.0536962	.1369160
31	.0030601	.0054190	.0137146	88	.4116498	.0538076	.2331449
32	.0025359	.0055107	.0130481	89	.3211327	.0538950	.1592108
33	.0007160	.0035107	.0124735	90	.0979157	.0539753	.0000000
34	.0002033	.0019734	.0112690	91	.0432606	.0601486	.0394695
35	.0002017	.0000000	.0093253	92	.0597042	.1463160	.1245513
36	.0001955	.0001675	.0005108	93	.0839264	.2016055	.1578054
37	.0000660	.0000015	.0000508	94	.0849299	.2015252	.1513952
38	.0000000	.0000000	.0000000	95	.0877896	.2015339	.1437274
39	.0059644	.0043362	.0247829	96	.0993466	.2077915	.0978670
40	.0040676	.0047205	.0214132	97	.1056726	.2353943	.0000000
41	.0000100	.0047009	.0042372	98	.1136332	.2717845	.0610258
42	.0010371	.0038222	.0015265	99	.1176147	.2680525	.0706076
43	.0009486	.0039033	.0006166	100	.1166146	.2432169	.0717375
44	.0002852	.0030674	.0002022	101	.0657189	.1112432	.0422425
45	.0000000	.0030000	.0000000	102	.0176629	.0162540	.0115012
46	.0764141	.0130351	.0000000	103	.0000283	.0000009	.0000358
47	.1021947	.0169175	.0191955	104	.0000000	.0000000	.0000000
48	.1043397	.0053584	.0356831	105	.3000000	.0339986	.3691093
49	.1009516	.0034471	.0422756	106	.0000000	.0536153	.0000000
50	.1276116	.0034610	.0703330	107	.0000000	.0572147	.0000000
51	.1631203	.0034745	.1096656	108	.0208393	.0154043	.0709334
52	.1648131	.0092704	.1178705	109	.0999878	.0231686	.1145463
53	.0821206	.0940912	.1178837	710	.2621385	.0531270	.2403602
54	.0766322	.0553743	.1178842	700	.0421702	.1212870	.0812124
55	.0437438	.0549998	.1178875	810	.2046346	.0460233	.1777890

TABLE B-1 (f)

JOINT DISPLACEMENTS

(LOAD CASE 9)

Z + Y EARTHQUAKE (1/2 SSE)

TOTAL RESPONSE EQUALS MODE 1 THROUGH 40 BY SQSS SUMMATION

JOINT GID	/-----DISPLACEMENTS (IN.)-----/				X	Y	Z
	X	Y	Z				
1	.0004923	.0000253	.0020338				
2	.0004687	.0012031	.0025095	57	.0115683	.0227790	.1023934
3	.0007761	.0019305	.0031879	59	.0115455	.0027053	.0691935
4	.0007735	.0000000	.0028813	60	.0115311	.0032798	.0485475
6	.0007040	.0005205	.0007756	61	.0115011	.0038538	.0133662
7	.0010319	.0006803	.0002486	62	.0091103	.0021361	.0057054
8	.0002290	.0000741	.0000634	63	.0058724	.0021267	.0021173
9	.0000566	.0000010	.0000598	64	.0010639	.0006603	.0000140
10	.0000000	.0000000	.0000000	65	.0000000	.0000000	.0000000
11	.0000000	.0000000	.0000000	66	.0914724	.0627236	.1659351
12	.0065947	.0104820	.0044268	67	.00914736	.0587391	.1624244
13	.0093726	.0121652	.0078819	68	.0932448	.0506911	.1592117
14	.0153720	.0121759	.0152498	69	.1074384	.0000000	.1522015
15	.0207955	.0103554	.0217631	71	.1253582	.0767245	.1492374
16	.0236333	.0081595	.0248462	72	.0167152	.0768170	.0195036
17	.0267634	.0060530	.0277379	73	.0871586	.0686804	.1659326
18	.0268648	.0055946	.0271142	74	.0828516	.0744779	.1642104
19	.0270079	.0028829	.0000079	75	.0666448	.1426016	.1380872
20	.0193641	.0000000	.0000105	76	.0631832	.1544056	.1193764
21	.0093224	.0015101	.0000143	77	.0708245	.1544166	.0990190
22	.0000000	.0015277	.0000193	78	.0687905	.1385260	.0925230
23	.0061759	.0016171	.0000211	79	.0555664	.0852256	.0825121
24	.0085282	.0017069	.0000211	81	.0594929	.0340280	.0324865
25	.0061739	.0052232	.0223581	82	.0294361	.0340313	.0395709
26	.0060392	.0052869	.0233763	83	.0192510	.0365606	.0195352
27	.0057869	.0052745	.0226940	84	.1676737	.0769506	.1857557
28	.0056617	.0052698	.0222198	85	.2049680	.0770717	.2105898
29	.0042358	.0052667	.0167707	86	.0575843	.0772057	.0509733
30	.0031678	.0052659	.0150931	87	.1703835	.0773126	.1300393
31	.0019643	.0052651	.0155959	88	.3116806	.0774298	.2144770
32	.0017384	.0052553	.0162233	89	.2611583	.0775012	.1469270
33	.0005990	.0028651	.0155391	90	.0981119	.0775751	.0000000
34	.0001471	.0014495	.0141630	91	.0469649	.0841442	.0338546
35	.0001461	.0000000	.0118135	92	.0635578	.2077373	.1102280
36	.0001423	.0001260	.0007437	93	.1033948	.2754554	.1443971
37	.0000469	.0000012	.0000689	94	.1052099	.2736004	.1342004
38	.0000000	.0000000	.0000000	95	.1003528	.2736178	.1205036
39	.0034027	.0042046	.0166124	96	.0948034	.2710239	.0640638
40	.0025327	.0033599	.0147302	97	.0130230	.2736813	.0000000
41	.0007632	.0033477	.0042069	98	.0938826	.2767004	.0238673
42	.0006492	.0026492	.0021594	99	.0936680	.2648745	.0269866
43	.0006244	.0006013	.0004610	100	.0996482	.2794396	.0274373
44	.0001790	.0000045	.0001066	101	.0497756	.1079606	.0173721
45	.0000000	.0000000	.0000000	102	.0121354	.0161107	.0085210
46	.0456486	.0135320	.0000000	103	.0000306	.0000006	.0000371
47	.0664218	.0176220	.0165433	104	.0000000	.0000000	.0000000
48	.0704924	.0056839	.0325620	105	.0000000	.1195325	.0578414
49	.0794620	.0004460	.0473798	106	.0000000	.0772341	.0000000
50	.1177000	.0004546	.1050166	107	.0000000	.0768284	.0000000
51	.1677331	.0004534	.1642731	570	.0296594	.0216634	.1023934
52	.1676518	.0114579	.1760108	600	.0997263	.0142179	.1479401
53	.0914867	.0730761	.1750317	710	.2377350	.0767245	.2842832
54	.0861779	.0756210	.1760324	780	.0555684	.0302305	.0830890
55	.0524766	.0370510	.1760305	810	.1712176	.0340280	.2160737
56	.0118682	.0591593	.1384515				

TABLE B-1 (g)

JOINT DISPLACEMENTS

(LOAD CASE 10)

R+ Y DPE EARTHQUAKE (SSE)

TOTAL RESPONSE EQUALS MODE 1 THROUGH 40 BY SQSS SUMMATION

JOINT GID	DISPLACEMENTS (IN.)				DISPLACEMENTS (IN.)		
	X	Y	Z		X	Y	Z
1	.0005671	.0000479	.0041606				
2	.0020744	.0023633	.0060900	57	.0167684	.0255515	.1057158
3	.0034443	.0036604	.0088408	59	.0167177	.0030367	.0743002
4	.0034347	.0000000	.0091043	60	.0166355	.0041401	.0546743
6	.0031344	.0012411	.0021418	61	.0166079	.0051264	.0197657
7	.0043413	.0014625	.0010135	62	.0129102	.0034553	.0025821
8	.0009177	.0002468	.0002833	63	.0074532	.0034454	.0035562
9	.0002203	.0000022	.0002419	64	.0017252	.0009680	.0000217
10	.0000000	.0000000	.0000000	65	.0000000	.0000000	.0000000
11	.0000000	.0000000	.0000000	66	.1010566	.0661065	.1598303
12	.0240549	.0198654	.0184679	67	.1010590	.0694400	.1564711
13	.0342485	.0226377	.0290736	68	.1036125	.0513176	.1533790
14	.0557984	.0228568	.0471426	69	.1277831	.0000000	.1494136
15	.0743283	.0181814	.0643919	71	.1629748	.0751150	.1583767
16	.0839732	.0157601	.0733641	72	.0225544	.0752135	.0205568
17	.0939503	.0175061	.0804734	73	.0956148	.0713475	.1598776
18	.0946939	.0170556	.0786954	74	.0905568	.0757375	.1560675
19	.0947938	.0042714	.0000115	75	.0970588	.1648551	.1413813
20	.0677133	.0000000	.0000151	76	.1079564	.1830429	.1258940
21	.0344026	.0021439	.0000207	77	.1210146	.1830558	.1348914
22	.0000000	.0019071	.0000265	78	.1215759	.1670437	.0878654
23	.0203025	.0028829	.0000307	79	.0825295	.1161208	.0878619
24	.0319700	.0036359	.0000307	81	.0673515	.0571561	.0378426
25	.0229641	.0089249	.0795047	82	.0425648	.0571601	.0418611
26	.0225557	.0091990	.0820171	83	.0350914	.0520537	.0205873
27	.0216393	.0091861	.0784810	84	.2556384	.0753581	.2126776
28	.0211375	.0091785	.0763510	85	.3299727	.0754856	.2689144
29	.0147895	.0091776	.0509918	86	.0882216	.0756270	.0717328
30	.0102669	.0091764	.0376049	87	.2544775	.0757358	.2040471
31	.0056347	.0091752	.0279805	88	.4632792	.0758462	.3416577
32	.0045272	.0093099	.0265085	89	.3722383	.0759241	.2242533
33	.0014227	.0064337	.0253136	90	.1245982	.0759958	.0000000
34	.0003904	.0035242	.0227828	91	.0598603	.0522692	.0473024
35	.0003872	.0000000	.0147839	92	.0912802	.2063905	.1516939
36	.0003748	.0093133	.0009964	93	.1475974	.2793377	.1388662
37	.0001273	.0000027	.0000932	94	.1472911	.2780185	.1910204
38	.0000000	.0000000	.0000000	95	.1451467	.2730375	.1809416
39	.0116326	.0077950	.0594240	96	.1474478	.2795455	.1123058
40	.0077185	.0097722	.0436445	97	.1517379	.2997951	.0000000
41	.0017013	.0097291	.0088327	98	.1580733	.3303502	.0903300
42	.0022060	.0079664	.0070432	99	.1643511	.3234097	.1066506
43	.0020002	.0013989	.0012121	100	.1659725	.2930097	.1094296
44	.0006082	.0000159	.0004098	101	.0963554	.1337729	.0696522
45	.0000700	.0000000	.0000000	102	.0199799	.0145916	.0167891
46	.1495656	.0283153	.0000000	103	.0000392	.0000012	.0000438
47	.2011438	.0275502	.0384708	104	.0000000	.0000000	.0000000
48	.2100531	.0093062	.0727753	105	.0000000	.1169641	.0814937
49	.2058452	.0004790	.0799648	106	.0000000	.0756559	.0000000
50	.1813737	.0008903	.1018747	107	.0000000	.0752278	.0000000
51	.1966745	.0000021	.1871915	570	.0246567	.0231117	.1057168
52	.1567783	.0126432	.1633288	670	.1137055	.0256437	.1515665
53	.1010437	.0317102	.1593502	710	.1060707	.0751100	.3093795
54	.0947439	.0945393	.1593510	750	.0825295	.1406890	.1014733
55	.0560994	.0987367	.1593562	810	.2392242	.0571561	.2320176
56	.0160029	.0526855	.1372367				

TABLE B-1 (h)

JOINT DISPLACEMENTS

(LOAD CASE 11)

Z+ Y DBE EARTHQUAKE (SSE)

TOTAL RESPONSE EQUALS MODE 1 THROUGH 40 BY SQSS SUMMATION

JOINT GID	DISPLACEMENTS (IN.)				X	Y	Z
	X	Y	Z				
1	.0007000	.0000356	.0028060				
2	.0008530	.0016970	.0033609	57	.0157725	.0288514	.1335863
3	.0013010	.0027569	.0042364	59	.0157279	.0033774	.0933145
4	.0013113	.0000000	.0038873	60	.0156997	.0046991	.0675627
6	.0012225	.0009197	.0010334	61	.0156408	.0061674	.0233114
7	.0016042	.0011713	.0003724	62	.0121839	.0038377	.0110831
8	.0003446	.0001301	.0001283	63	.0074334	.0038295	.0040842
9	.0000938	.0000014	.0000908	64	.0013319	.0010219	.0000249
10	.0000000	.0000000	.0000000	65	.0000000	.0000000	.0000000
11	.0000000	.0000000	.0000000	66	.1155801	.0774512	.2062669
12	.0093945	.0151114	.0071369	67	.1155823	.0724872	.2016258
13	.0132942	.0176741	.0112692	68	.1173034	.0625173	.1972725
14	.0211963	.0176870	.0206337	69	.1324027	.0000000	.1374037
15	.0283451	.0156688	.0292934	71	.1538619	.0942992	.1934931
16	.0320774	.0132701	.0333809	72	.0204671	.0944144	.0240369
17	.0369739	.0109343	.0370193	73	.1111884	.0848702	.0862634
18	.0364041	.0101337	.0361406	74	.1074594	.0921739	.2038662
19	.0364570	.0039256	.0000133	75	.1215837	.1928769	.1719232
20	.0202252	.0000000	.0000175	76	.1318069	.1987194	.1438897
21	.0126688	.0020492	.0000238	77	.1376074	.1987341	.1243050
22	.0000000	.0020071	.0000304	78	.1318549	.1787359	.1035581
23	.0084904	.0021029	.0000350	79	.1025058	.1148510	.1035485
24	.0118244	.0022442	.0000350	81	.0815092	.0435735	.1035194
25	.0034872	.0082588	.0332418	82	.0506924	.0435773	.0430231
26	.0083400	.0086085	.0350355	83	.0351646	.0457948	.0240786
27	.0080534	.0086807	.0342069	84	.2086464	.0945809	.2403473
28	.0079059	.0086932	.0335992	85	.2580834	.0947313	.2818259
29	.0062304	.0086882	.0264816	86	.0715386	.0948978	.0665529
30	.0049286	.0086877	.0249549	87	.2104814	.0950300	.1705834
31	.0033830	.0086872	.0269232	88	.3859992	.0951637	.2875924
32	.0030579	.0086594	.0222264	89	.3234375	.0952624	.1947010
33	.0009982	.0046900	.0271412	90	.1224081	.0953531	.0000000
34	.0032496	.0023871	.0248057	91	.0594339	.1035127	.0425826
35	.0002479	.0000000	.0207406	92	.0829149	.2568975	.1372132
36	.0002407	.0002099	.0013277	93	.1363482	.3405700	.1906218
37	.0000608	.0000019	.0001228	94	.1375001	.3386188	.1585576
38	.0000000	.0000000	.0000000	95	.1307920	.3386401	.1522936
39	.0060576	.0073172	.0262153	96	.1239009	.3340412	.0830003
40	.0037787	.0063595	.0234463	97	.1275715	.3361544	.0000000
41	.0005979	.0063399	.0072159	98	.1245847	.3421344	.0420730
42	.0012547	.0050312	.0039444	99	.1255403	.3285229	.0491791
43	.0011903	.0011483	.0007754	100	.1217166	.2960487	.0504832
44	.0003415	.0000047	.0001594	101	.0677436	.1343761	.0314099
45	.0000000	.0000000	.0000000	102	.0160484	.0200503	.0114730
46	.0613472	.0182374	.0000000	103	.0000387	.0000010	.0000460
47	.0895081	.0236402	.0227337	104	.0000000	.0000000	.0000000
48	.0952311	.0078592	.0454519	105	.0000000	.1462927	.0722352
49	.1027938	.0037581	.0635400	106	.0000000	.0949329	.0000000
50	.1462584	.0007603	.1322443	107	.0000000	.0944262	.0000000
51	.2049582	.0007749	.2045912	570	.0355400	.0267353	.1339863
52	.2109736	.0141023	.2188732	690	.1240843	.0178947	.1842935
53	.1157653	.0084567	.2182979	710	.2974473	.0942992	.3497208
54	.1098193	.0336794	.2198979	790	.1125058	.1177706	.1086591
55	.0667336	.1085334	.2189855	810	.2241222	.0435735	.2750068
56	.0158116	.0607019	.1757079				

TABLE B-1 (j)

JOINT DISPLACEMENTS (LOAD CASE 12)

SEISMIC ANCHOR MOVEMENTS X - DIRECTION (SSE)

JOINT (GID)	DISPLACEMENTS (IN.)				DISPLACEMENTS (IN.)		
	X	Y	Z		X	Y	Z
1	.739144	.000048	.002690				
2	.739453	-.001229	.002965	59	.005464	-.000124	.012336
3	.739622	-.001808	.003311	60	.005447	-.000514	.005337
4	.739582	-.000000	.002520	61	.005413	-.001375	-.003133
6	.739511	-.000201	.000923	62	.004406	-.000810	-.003203
7	.739953	.000181	.000060	63	.002536	-.000815	-.001145
8	.740029	.000027	.000022	64	.000477	-.000096	-.000011
9	.740014	.000001	.000028	65	.000000	.000000	-.000000
10	.740000	.000007	.000033	66	.139253	.005534	.087133
11	.740000	.000000	.000000	67	.139253	.008942	.078662
12	.737856	.006503	.001593	68	.141852	.012862	.069970
13	.733651	.004878	.001539	69	.168875	.027082	.047946
14	.714647	.004906	.002307	71	.199420	.045571	.012404
15	.697874	-.001811	.011959	72	.258099	.049531	.012977
16	.699322	-.010307	.027247	73	.129534	.005168	.087133
17	.698868	-.018699	.053160	74	.120734	.006416	.023505
18	.699328	-.019638	.062497	75	.057210	.036279	.019925
19	.699183	-.007548	.193738	76	.099634	.041188	.011239
20	.797784	-.003683	.193733	77	.064983	-.041189	.011616
21	.740448	-.000197	.193777	78	.035689	.041482	.011946
22	.777679	.001912	.193771	79	.126698	.042933	.011944
23	.814779	.003074	.193766	81	.180317	.044774	.011943
24	.825606	.003469	.193766	82	.200731	.044775	.012689
25	.814711	.000333	.071960	83	.223179	.045039	.012978
26	.812044	-.002933	.057430	84	.449035	.045547	.011254
27	.807585	-.004643	.050438	85	.715866	.049532	.004576
28	.805362	-.005045	.048167	86	1.070009	.045516	-.003625
29	.788119	-.005024	.033229	87	1.420001	.045520	-.007461
30	.762652	-.005013	.025035	88	1.760037	.045435	-.002997
31	.745032	-.005001	.019341	89	2.033233	.045471	.011846
32	.741676	-.007626	.017583	90	2.235620	.045459	.037030
33	.740920	-.003989	.018254	91	2.270219	.049640	.043226
34	.740825	-.001144	.018099	92	2.322095	.063731	.099643
35	.740800	-.000000	.016112	93	2.349912	.060657	.064057
36	.740700	-.000217	.001476	94	2.349036	.066890	.064920
37	.740380	.000002	.000205	95	2.351216	.066889	.065238
38	.740000	.000000	.000000	96	2.353555	.067973	.060513
39	.773061	-.001091	.034450	97	2.353301	.065418	.069326
40	.761951	.003233	.032000	98	2.353174	.056531	.036166
41	.741549	.003267	.014556	99	2.355089	.050558	.023474
42	.739532	.001444	.008204	100	2.359414	.042931	.024144
43	.740097	.000933	.001023	101	2.373319	.019494	.009417
44	.740140	-.000010	-.000191	102	2.379825	-.001806	.001919
45	.740000	-.000000	.000000	103	2.380001	.000000	.000002
46	.611893	-.016775	.193919	104	2.380000	.000000	.000000
47	.941025	-.013361	.139439	105	2.289953	.056125	.047013
48	.926704	-.007513	.082423	106	1.192651	.045512	-.000207
49	.910294	.000430	.063199	107	.286786	.045510	.013087
50	.445330	.000413	.085296	570	.016925	-.000036	.029617
51	.341513	.000400	.107562	690	.184450	.044778	.023522
52	.340172	.002975	.105533	710	.145706	.045571	.012348
53	.139252	-.003004	.110648	790	.126633	.057536	-.009400
54	.127413	-.003716	.110651	810	.117052	.044774	.009371
55	.084976	-.009199	.110670				
56	.089719	-.004980	.070995				
57	.066492	-.000918	.029617				

TABLE B-1 (k)

JOINT DISPLACEMENTS (LOAD CASE 13)
SEISMIC ANCHOR MOVEMENTS Z - DIRECTION (SSE)

JOINT (GIO)	DISPLACEMENTS (IN.)				DISPLACEMENTS (IN.)		
	X	Y	Z		X	Y	Z
1	.000752	-.000031	.739908	59	.007846	-.001337	.154435
2	.001334	-.000212	.740327	60	.007660	.001722	.109540
3	.001665	-.000315	.741013	61	.007686	.003420	.030316
4	.001667	-.000000	.741302	62	.007987	.003313	.009744
6	.001603	.000037	.739935	63	.007741	.003305	.003359
7	.001707	.000012	.739493	64	.001695	.000851	.000022
8	.000300	-.000090	.740031	65	-.000000	.000000	.000000
9	.000063	.000000	.740053	66	.004683	-.033032	.354783
10	.000000	.000000	.740000	67	.004683	-.032866	.352032
11	.000000	-.000000	.740000	68	.005881	-.031837	.349140
12	-.006697	.007010	.732857	69	.105052	-.023572	.339973
13	-.006004	.011769	.725343	71	.115465	-.012801	.320553
14	.007369	.011750	.708012	72	.114199	-.012765	.359053
15	.018945	.016349	.681567	73	.091909	-.034449	.364734
16	.024935	.021877	.655278	74	.089305	-.036171	.353729
17	.020227	.026528	.615705	75	.073036	-.055814	.337460
18	.029340	.026507	.605258	76	.070030	-.058892	.338776
19	.025453	.002267	.506944	77	.069100	-.058854	.343078
20	.013135	.001944	.506953	78	.072128	-.055603	.346459
21	-.010114	.000539	.506966	79	.034157	-.045939	.346465
22	-.034590	-.000090	.506979	81	.100485	-.031243	.346472
23	-.052920	.000268	.506988	82	.099561	-.031237	.354740
24	-.050531	.000588	.506988	83	.103070	-.026810	.359048
25	-.052868	.003770	.610137	84	.099539	-.012777	.475121
26	-.050756	.011421	.626722	85	.071860	-.012769	.669475
27	-.047328	.012735	.637485	86	.033833	-.012760	.943646
28	-.045637	.013041	.641516	87	-.002454	-.012751	1.231299
29	-.026744	.013022	.674433	88	-.032847	-.012743	1.523629
30	-.013499	.013007	.692656	89	-.049894	-.012735	1.770182
31	-.000379	.012931	.706986	90	-.052860	-.012728	1.964659
32	.001190	.015816	.711140	91	-.048923	-.030245	2.003884
33	-.000179	.003020	.712599	92	-.023002	-.122864	2.086291
34	-.000635	.023723	.714117	93	.011186	-.199101	2.152625
35	-.000609	.030000	.717814	94	.021367	-.197365	2.173454
36	-.000508	.000015	.738356	95	.028209	-.197364	2.192436
37	-.000330	-.000004	.739818	96	.030675	-.185300	2.237084
38	-.000000	-.000000	.740000	97	.042070	-.159101	2.273568
39	-.019949	.005735	.673313	98	.044663	-.129302	2.314239
40	-.010316	-.002123	.679956	99	.041214	-.111602	2.377727
41	.000191	-.002145	.719113	100	.033060	-.089760	2.337133
42	.000854	-.001040	.729837	101	.008759	-.027769	2.364776
43	.000086	-.000091	.739448	102	.000449	-.003043	2.376806
44	-.000040	.000026	.740456	103	-.000002	-.000000	2.379976
45	.000000	.000010	.740000	104	.000000	-.000000	2.380000
46	.060047	.001214	.506903	105	-.001491	-.063453	2.032773
47	.020936	.001264	.519167	106	.023740	-.012757	1.018452
48	.082612	.007755	.625319	107	.113658	-.012774	.364645
49	.014334	-.000134	.514050	570	.044417	-.008929	.226083
50	.129608	-.000103	.442495	690	.108126	-.027003	.335040
51	.131106	-.000072	.373764	710	.114385	-.012801	.301600
52	.132273	-.003229	.362636	700	.034177	-.046332	.340037
53	.034683	-.033465	.362941	810	.103446	-.031203	.321768
54	.070907	-.033346	.362535				
55	.061460	-.035140	.362500				
56	.007803	-.023634	.300086				
57	.007824	-.010499	.226088				

TABLE B-11 ELASTIC SUPPORT REACTIONS

A) (LOAD CASE 1)

DEAD LOAD PLUS SUSTAINED MECHANICAL LOADS

SUPPORT JOINT	FORCE (LB.)			MOMENT (IN-LB.)		
	X	Y	Z	X	Y	Z
4	0.00	201.04	0.00	0.00	0.00	0.00
10	-3.52	124.19	-2.29	-1245.79	-113.01	14.81
11	-6.76	349.79	7.00	1748.90	-414.19	414.67
20	0.00	1154.75	0.00	0.00	0.00	0.00
22	0.00	294.01	0.00	0.00	0.00	0.00
35	0.00	190.42	0.00	0.00	0.00	0.00
38	20.43	85.51	4.93	70.54	-198.58	12.25
45	-22.97	111.14	5.36	-304.28	-336.73	1084.91
49	0.00	1149.86	0.00	0.00	0.00	0.00
59	0.00	1768.11	0.00	0.00	0.00	0.00
65	12.96	529.33	-4.45	10451.94	-1326.13	1244.23
104	-1.12	474.29	-11.23	-4918.95	3736.56	7825.63

B) (LOAD CASE 4)

NORMAL OPERATING TEMPERATURE INCL. THERMAL ANCHOR MOVEMENTS

SUPPORT JOINT	FORCE (LB.)			MOMENT (IN-LB.)		
	X	Y	Z	X	Y	Z
4	0.00	-675.46	0.00	0.00	0.00	0.00
10	560.38	203.75	254.97	-4012.44	9228.07	-6255.07
11	-1671.20	1097.22	157.11	-2634.61	-10517.07	1352.26
20	0.00	-1460.50	0.00	0.00	0.00	0.00
22	0.00	701.63	0.00	0.00	0.00	0.00
35	0.00	-857.45	0.00	0.00	0.00	0.00
38	877.50	375.12	254.22	7476.41	-9009.52	-3639.22
45	-350.08	-111.01	329.44	-5334.57	-10092.46	304.09
49	0.00	105.73	0.00	0.00	0.00	0.00
59	0.00	1149.37	0.00	0.00	0.00	0.00
65	559.55	-409.96	-1015.73	-18953.21	63617.50	-6022.39
104	33.94	-209.33	-10.00	29055.74	7026.95	-51897.47

C) (LOAD CASE 6)

SEISMIC ANCHOR MOVEMENTS X-DIRECTION (1/2 SSE)

SUPPORT JOINT	FORCE (LB.)			MOMENT (IN-LB.)		
	X	Y	Z	X	Y	Z
4	0.000	25.850	0.000	0.000	0.000	0.000
10	-12.370	-8.824	-12.937	-121.576	-61.175	70.762
11	337.391	-258.017	-79.741	-4294.223	-662.181	-2813.046
20	0.000	582.971	0.000	0.000	0.000	0.000
22	0.000	-231.847	0.000	0.000	0.000	0.000
35	0.000	73.904	0.000	0.000	0.000	0.000
38	-133.484	-17.491	-26.437	-806.606	348.309	1580.589
45	-47.869	84.952	-45.066	671.739	2309.582	574.516
49	0.000	-33.933	0.000	0.000	0.000	0.000
59	0.000	19.030	0.000	0.000	0.000	0.000
65	-209.442	-66.277	163.864	1421.700	6578.487	3858.059
104	4.774	-9.703	-7.782	1401.647	1105.730	-849.011

TABLE B-11 ELASTIC SUPPORT REACTIONS.

D) (LOAD CASE 7)

SEISMIC ANCHOR MOVEMENTS Z-DIRECTION (1/2 SSE)

SUPPORT JOINT	FORCE (LB.)			MOMENT (IN-LB.)		
	X	Y	Z	X	Y	Z
4	0.00	6.50	0.00	0.00	0.00	0.00
10	-20.58	-2.35	-18.50	-222.84	-222.82	261.79
11	-276.74	169.35	131.25	913.15	-1203.64	2189.23
20	0.00	-253.53	0.00	0.00	0.00	0.00
22	0.00	9.32	0.00	0.00	0.00	0.00
35	0.00	-110.53	0.00	0.00	0.00	0.00
38	135.68	35.45	31.60	722.41	-1230.43	-1393.21
45	-0.75	-50.47	114.94	-1619.36	-3633.07	-146.57
49	0.00	35.50	0.00	0.00	0.00	0.00
59	0.00	289.15	0.00	0.00	0.00	0.00
65	163.39	-134.63	-313.38	-11320.85	22271.01	-6334.05
104	-1.27	5.85	4.09	-2508.78	-1358.05	1316.13

E) (LOAD CASE 12)

SEISMIC ANCHOR MOVEMENTS X - DIRECTION (SSE)

SUPPORT JOINT	FORCE (LB.)			MOMENT (IN-LB.)		
	X	Y	Z	X	Y	Z
4	0.000	34.153	0.000	0.000	0.000	0.000
10	-15.923	-11.509	-16.653	-156.392	-77.147	88.625
11	522.274	-340.810	-104.779	-564.491	-347.644	-3703.637
20	0.000	748.713	0.000	0.000	0.000	0.000
22	0.000	-358.100	0.000	0.000	0.000	0.000
35	0.000	97.555	0.000	0.000	0.000	0.000
38	-176.100	-23.106	-34.922	-106.057	1253.515	2035.245
45	-52.216	111.128	-59.861	891.549	3171.608	767.649
49	0.000	-120.441	0.000	0.000	0.000	0.000
59	0.000	36.539	0.000	0.000	0.000	0.000
65	-277.446	-124.567	217.790	1541.311	8762.270	5108.541
104	10.009	-19.339	-1.524	2851.191	2014.627	-1530.613

F) (LOAD CASE 13)

SEISMIC ANCHOR MOVEMENTS Z - DIRECTION (SSE)

SUPPORT JOINT	FORCE (LB.)			MOMENT (IN-LB.)		
	X	Y	Z	X	Y	Z
4	0.00	8.13	0.00	0.00	0.00	0.00
10	-27.00	-3.07	-24.27	-292.28	-292.71	343.80
11	-365.76	223.60	238.74	1303.79	-1579.29	2890.30
20	0.00	-133.67	0.00	0.00	0.00	0.00
22	0.00	12.22	0.00	0.00	0.00	0.00
35	0.00	-145.71	0.00	0.00	0.00	0.00
38	173.04	46.72	41.66	951.10	-1700.24	-1837.64
45	-0.77	-66.10	151.40	-2120.23	-4716.79	-197.62
49	0.00	37.63	0.00	0.00	0.00	0.00
59	0.00	324.17	0.00	0.00	0.00	0.00
65	216.17	-134.85	-415.94	-15270.05	23520.23	-7413.14
104	-2.17	10.63	6.45	-5010.92	-2144.25	2458.70

TABLE B-II ELASTIC SUPPORT REACTIONS

G) X + Y EARTHQUAKE (1/2 SSE) (LOAD CASE 8)

TOTAL RESPONSE EQUALS MODE 1 THROUGH 40 BY SQSS SUMMATION

SUPPORT JOINT	FORCE (LB.)			MOMENT (IN-LB.)		
	X	Y	Z	X	Y	Z
4	0.0	50.0	0.0	0.	0.	0.
10	53.1	14.8	52.0	635.	446.	589.
11	320.9	207.5	105.9	4536.	3318.	2141.
20	0.0	538.2	0.0	0.	0.	0.
22	153.9	322.1	0.0	0.	0.	0.
35	0.0	36.9	0.0	0.	0.	0.
38	13.3	16.7	17.4	264.	731.	342.
45	38.1	84.9	86.6	930.	1170.	1458.
46	0.0	0.0	196.6	0.	0.	0.
49	0.0	125.5	0.0	0.	0.	0.
59	0.0	600.3	0.0	0.	0.	0.
65	505.3	338.9	268.2	11669.	16206.	10804.
69	0.0	545.9	0.0	0.	0.	0.
90	0.0	0.0	269.1	0.	0.	0.
97	0.0	0.0	702.2	0.	0.	0.
104	411.4	166.9	378.6	30760.	16299.	21012.
105	200.3	0.0	0.0	0.	0.	0.
106	172.9	0.0	129.9	0.	0.	0.

INCLINED AXIS SUPPORT REACTIONS

SUPPORT JOINT	REACTION TYPE	REACTION MAGNITUDE	DIRECTION COSINES (INCLINED AXIS)		
			X	Y	Z
107	FORCE	371.5	-.9061	0.0000	-.4230
107	FORCE	208.0	.4230	0.0000	-.9061

H) Z + Y EARTHQUAKE (1/2 SSE) (LOAD CASE 9)

TOTAL RESPONSE EQUALS MODE 1 THROUGH 40 BY SQSS SUMMATION

SUPPORT JOINT	FORCE (LB.)			MOMENT (IN-LB.)		
	X	Y	Z	X	Y	Z
4	0.0	46.0	0.0	0.	0.	0.
10	29.5	11.7	29.2	323.	234.	313.
11	200.7	130.2	60.6	3870.	1812.	1679.
20	0.0	469.6	0.0	0.	0.	0.
22	95.0	310.1	0.0	0.	0.	0.
35	0.0	31.3	0.0	0.	0.	0.
38	9.6	13.1	21.1	364.	896.	242.
45	12.6	51.4	73.6	491.	1120.	902.
46	0.0	0.0	266.2	0.	0.	0.
49	0.0	124.9	0.0	0.	0.	0.
59	0.0	798.1	0.0	0.	0.	0.
65	343.3	431.5	268.2	12091.	19031.	7625.
69	0.0	735.4	0.0	0.	0.	0.
90	0.0	0.0	337.8	0.	0.	0.
97	0.0	0.0	838.6	0.	0.	0.
104	421.2	120.6	458.9	29828.	9443.	23102.
105	303.1	0.0	0.0	0.	0.	0.
106	101.8	0.0	127.7	0.	0.	0.

INCLINED AXIS SUPPORT REACTIONS

SUPPORT JOINT	REACTION TYPE	REACTION MAGNITUDE	DIRECTION COSINES (INCLINED AXIS)		
			X	Y	Z
107	FORCE	374.7	-.9061	0.0000	-.4230
107	FORCE	291.4	.4230	0.0000	-.9061

TABLE B-11 ELASTIC SUPPORT REACTIONS

J) X+ Y DBE EARTHQUAKE (SSE) (LOAD CASE 10)

TOTAL RESPONSE EQUALS MODE 1 THROUGH 40 BY SQSS SUMMATION

SUPPORT JOINT	FORCE (LB.)			MOMENT (IN-LB.)		
	X	Y	Z	X	Y	Z
4	0.0	79.9	0.0	0.	0.	0.
10	107.1	25.6	104.8	1317.	914.	1213.
11	612.4	341.0	231.1	1411.	6768.	3755.
20	0.0	651.3	0.0	0.	0.	0.
22	292.0	387.1	0.0	0.	0.	0.
35	0.0	69.2	0.0	0.	0.	0.
38	25.4	31.2	33.7	514.	1466.	661.
45	81.8	181.2	178.7	1879.	2411.	3105.
46	0.0	0.0	295.8	0.	0.	0.
49	0.0	246.1	0.0	0.	0.	0.
59	0.0	910.6	0.0	0.	0.	0.
65	772.2	529.3	417.5	17580.	24075.	16461.
69	0.0	113.1	0.0	0.	0.	0.
90	0.0	0.0	311.7	0.	0.	0.
97	0.0	0.0	938.6	0.	0.	0.
104	609.8	227.2	505.7	37303.	25025.	27908.
105	336.9	0.0	0.0	0.	0.	0.
106	267.0	0.0	213.8	0.	0.	0.

INCLINED AXIS SUPPORT REACTIONS

SUPPORT JOINT	REACTION TYPE	REACTION MAGNITUDE	DIRECTION COSINES (INCLINED AXIS)		
			X	Y	Z
107	FORCE	616.0	-.9061	0.0000	-.4230
107	FORCE	343.3	.4230	0.0000	-.9061

K) Z+ Y DBE EARTHQUAKE (SSF) (LOAD CASE 11)

TOTAL RESPONSE EQUALS MODE 1 THROUGH 40 BY SQSS SUMMATION

SUPPORT JOINT	FORCE (LB.)			MOMENT (IN-LB.)		
	X	Y	Z	X	Y	Z
4	0.	67.	0.	0.	0.	0.
10	42.	16.	41.	494.	341.	461.
11	265.	254.	108.	5372.	2611.	2235.
20	0.	650.	0.	0.	0.	0.
22	146.	407.	0.	0.	0.	0.
35	0.	54.	0.	0.	0.	0.
38	18.	22.	38.	651.	1579.	419.
45	23.	90.	124.	738.	1917.	1723.
46	0.	0.	384.	0.	0.	0.
49	0.	212.	0.	0.	0.	0.
59	0.	906.	0.	0.	0.	0.
65	652.	535.	479.	18489.	23916.	14767.
69	0.	966.	0.	0.	0.	0.
90	0.	0.	422.	0.	0.	0.
97	0.	0.	1041.	0.	0.	0.
104	545.	180.	571.	37209.	14711.	28910.
105	380.	0.	0.	0.	0.	0.
106	155.	0.	243.	0.	0.	0.

INCLINED AXIS SUPPORT REACTIONS

SUPPORT JOINT	REACTION TYPE	REACTION MAGNITUDE	DIRECTION COSINES (INCLINED AXIS)		
			X	Y	Z
107	FORCE	482.7	-.9061	0.0000	-.4230
107	FORCE	451.3	.4230	0.0000	-.9061

TABLE B - III

Pages B - 16 through B - 42

LACBWR FEED WATER + CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

0.1 CLASS 2 STRESSES FOR ANALYSIS SET NUMBER 1

ASSIGNED LOAD COMBINATION IDENTIFIERS
NA = 1 MD = 7 MC = 3 P = 1 PHAX = 2

0.1.1 SATISFACTION OF EQUATION 1 (ANALYSIS SET 1)

STRAIGHT MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHAX)	SUSTAINED LOAD STRESS (LMA)	OCCASIONAL LOAD STRESS (LMB)	THERMAL EXPANSION STRESS (TMC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO (T/(S*SH))	MODIFIED STRESS RATIO
15	1	3716.977	0.000	131.607	0.000	0.000	3716.977	25493.401	.24445	
15	2	3716.977	0.000	131.191	0.000	0.000	3716.977	25493.401	.24426	
25	1	4219.645	0.000	465.499	0.000	0.000	4755.175	25779.725	.23497	
25	11	4219.645	0.000	323.195	0.000	0.000	4613.564	25747.115	.23716	
35	1	3716.977	0.000	341.292	0.000	0.000	4128.269	25455.273	.25964	
35	12	3716.977	0.000	199.175	0.000	0.000	3716.977	25455.273	.25079	
45	3	4219.645	0.000	45.741	0.000	0.000	4275.443	25401.770	.25718	
45	4	4219.645	0.000	363.254	0.000	0.000	4632.747	25413.749	.25764	
55	4	4219.645	0.000	76.971	0.000	0.000	4365.640	25774.248	.27461	
55	6	4219.645	0.000	266.551	0.000	0.000	4496.243	25774.248	.25974	
65	7	4219.645	0.000	129.552	0.000	0.000	4419.240	25774.248	.27704	
65	8	4219.645	0.000	219.707	0.000	0.000	4619.345	25774.248	.24136	
75	10	4219.645	0.000	219.684	0.000	0.000	4539.352	25774.248	.25151	
85	13	3716.977	0.000	170.713	0.000	0.000	3913.690	25455.136	.25168	
85	14	3716.977	0.000	153.743	0.000	0.000	3779.770	25455.136	.25168	
95	15	3716.977	0.000	116.255	0.000	0.000	3703.247	25774.248	.24329	
95	16	3716.977	0.000	176.763	0.000	0.000	3941.740	25401.770	.24329	
105	16	3716.977	0.000	176.763	0.000	0.000	3941.740	25401.770	.24329	
105	17	3716.977	0.000	546.978	0.000	0.000	4313.055	25811.736	.27252	
115	18	3716.977	0.000	451.376	0.000	0.000	4236.373	25811.736	.25456	
115	19	3716.977	0.000	53.669	0.000	0.000	3860.646	25927.863	.24407	

CURVED MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHAX)	SUSTAINED LOAD STRESS (LMA)	OCCASIONAL LOAD STRESS (LMB)	THERMAL EXPANSION STRESS (TMC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO (T/(S*SH))	MODIFIED STRESS RATIO
10	2	3716.977	0.000	44.479	0.000	0.000	3731.456	25915.315	.24097	
10	3	3716.977	0.000	32.771	0.000	0.000	3413.745	25923.474	.24524	
20	6	4219.645	0.000	76.951	0.000	0.000	4366.640	25774.248	.27463	
20	7	4219.645	0.000	266.551	0.000	0.000	4496.243	25774.248	.25978	
30	8	4219.645	0.000	193.791	0.000	0.000	4493.480	25774.248	.26198	
30	9	4219.645	0.000	322.861	0.000	0.000	4612.355	25779.175	.29039	

0.1 CLASS 2 STRESSES FOR ANALYSIS SET NUMBER 1

ASSIGNED LOAD COMBINATION IDENTIFIERS
NA = 1 MD = 7 MC = 3 P = 1 PHAX = 2

0.1.1 SATISFACTION OF EQUATION 1 (ANALYSIS SET 1)

STRAIGHT MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHAX)	SUSTAINED LOAD STRESS (LMA)	OCCASIONAL LOAD STRESS (LMB)	THERMAL EXPANSION STRESS (TMC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO (T/(S*SH))	MODIFIED STRESS RATIO
125	23	3716.977	0.000	267.661	0.000	0.000	4034.659	25479.335	.25521	
125	25	3716.977	0.000	52.254	0.000	0.000	3837.236	25915.562	.24144	
135	26	3716.977	0.000	74.764	0.000	0.000	3866.746	25915.562	.24313	
135	27	3716.977	0.000	51.501	0.000	0.000	3834.482	25915.562	.24141	
145	28	3716.977	0.000	62.331	0.000	0.000	3879.317	25915.562	.24147	
145	29	3716.977	0.000	116.741	0.000	0.000	3993.716	25923.474	.24552	
155	29	4219.645	0.000	324.281	0.000	0.000	4613.076	25774.248	.25713	
155	30	4219.645	0.000	112.871	0.000	0.000	4326.567	25774.248	.27149	
165	29	4219.645	0.000	223.994	0.000	0.000	4513.082	25774.248	.26355	
165	39	4219.645	0.000	76.971	0.000	0.000	4366.640	25774.248	.27463	
175	30	4219.645	0.000	112.871	0.000	0.000	4326.567	25774.248	.27149	
175	31	4219.645	0.000	131.981	0.000	0.000	4425.678	25774.248	.27736	
185	32	4219.645	0.000	73.711	0.000	0.000	4169.708	25804.933	.27498	
185	33	4219.645	0.000	101.351	0.000	0.000	4311.054	25774.248	.27617	
195	34	4219.645	0.000	51.394	0.000	0.000	4343.678	25915.562	.27319	
195	35	4219.645	0.000	265.261	0.000	0.000	4593.644	25774.248	.26476	
205	35	4219.645	0.000	265.261	0.000	0.000	4593.644	25774.248	.26476	
205	36	4219.645	0.000	29.731	0.000	0.000	4319.472	25915.562	.27185	
215	37	4219.645	0.000	51.621	0.000	0.000	4341.311	25915.562	.27374	
215	38	4219.645	0.000	37.061	0.000	0.000	4326.704	25915.562	.27317	
225	40	4219.645	0.000	25.901	0.000	0.000	4315.081	25915.562	.27161	
225	41	4219.645	0.000	117.331	0.000	0.000	4407.921	25774.248	.27717	
235	42	4219.645	0.000	117.341	0.000	0.000	4407.930	25774.248	.27720	
245	44	4219.645	0.000	51.911	0.000	0.000	4351.001	25804.933	.27655	
245	45	4219.645	0.000	173.691	0.000	0.000	4463.000	25774.248	.24072	
245	45	4219.645	0.000	266.491	0.000	0.000	4636.185	25777.051	.26278	

CURVED MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHAX)	SUSTAINED LOAD STRESS (LMA)	OCCASIONAL LOAD STRESS (LMB)	THERMAL EXPANSION STRESS (TMC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO (T/(S*SH))	MODIFIED STRESS RATIO
70	26	3716.977	0.000	76.871	0.000	0.000	3857.883	25917.496	.24774	
70	26	3716.977	0.000	105.951	0.000	0.000	3974.210	25923.474	.24441	
80	27	3716.977	0.000	69.801	0.000	0.000	3850.998	25915.562	.24707	
80	28	3716.977	0.000	70.111	0.000	0.000	3857.117	25915.562	.24703	
90	31	4219.645	0.000	261.421	0.000	0.000	4491.173	25774.248	.24070	
90	32	4219.645	0.000	119.731	0.000	0.000	4408.923	25774.248	.27720	

100	33	4279.658	0.000	101.364	0.000	0.000	4371.004	25771.471	.77817
	34	4287.658	0.000	53.991	0.000	0.000	4341.672	25771.471	.27319
110	36	4289.658	0.000	48.447	0.000	0.000	4374.165	25771.470	.27050
	37	4289.658	0.000	77.221	0.000	0.000	4265.939	25771.470	.27445
120	39	4289.658	0.000	112.741	0.000	0.000	4402.435	25771.471	.27688
	40	4289.658	0.000	43.231	0.000	0.000	4332.918	25771.475	.27251
130	41	4289.658	0.000	175.511	0.000	0.000	4465.201	25771.475	.28143
	42	4289.658	0.000	175.151	0.000	0.000	4426.578	25771.472	.28027
140	43	4289.658	0.000	136.091	0.000	0.000	4549.507	25769.730	.28613
	44	4289.658	0.000	259.811	0.000	0.000			

STRAIGHT MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (LMA)	OCCASIONAL LOAD STRESS (LMB)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SAW)	DESIGN STRESS RATIO (T/(1.0*SAW))	MODIFIED STRESS RATIO
255	19	4672.451	0.000	309.044	0.000	0.000	4681.530	25673.775	.31130	
	20	4672.451	0.000	561.712	0.000	0.000	5234.194	25673.774	.32017	
265	19	4672.451	0.000	354.941	0.000	0.000	5031.426	25673.772	.31644	
	46	4672.451	0.000	173.001	0.000	0.000	4645.481	25771.195	.30475	
275	20	4672.451	0.000	561.711	0.000	0.000	5234.194	25673.774	.32019	
	21	4672.451	0.000	321.241	0.000	0.000	4397.731	25673.772	.31407	
285	21	4672.451	0.000	321.241	0.000	0.000	4397.731	25673.772	.31407	
	22	4672.451	0.000	203.251	0.000	0.000	4475.736	25673.436	.32685	
295	22	4672.451	0.000	203.251	0.000	0.000	4475.736	25673.436	.32685	
	23	4672.451	0.000	151.791	0.000	0.000	4624.278	25707.141	.32741	
305	23	4672.451	0.000	5.161	0.000	0.000	4677.645	25731.510	.32410	
	24	4672.451	0.000	.001	0.000	0.000	4672.451	25731.510	.32417	
315	47	4672.451	0.000	282.411	0.000	0.000	4934.293	25631.435	.31037	
	48	4672.451	0.000	124.481	0.000	0.000	4620.562	25712.775	.30144	
325	49	4672.451	0.000	131.491	0.000	0.000	4833.302	25711.579	.30213	
	50	4672.451	0.000	131.591	0.000	0.000	4812.078	25703.733	.30245	
335	50	4672.451	0.000	131.591	0.000	0.000	4812.078	25703.733	.30245	
	51	4672.451	0.000	152.951	0.000	0.000	4825.434	25737.195	.30349	
345	52	4672.451	0.000	133.051	0.000	0.000	4825.434	25737.195	.30349	
	53	4672.451	0.000	297.461	0.000	0.000	5005.532	25711.324	.32273	
355	53	4672.451	0.000	2791.097	0.000	0.000	7454.645	25141.144	.47074	
	54	4672.451	0.000	1022.261	0.000	0.000	5671.574	25144.710	.46591	
365	54	4672.451	0.000	1022.261	0.000	0.000	5671.574	25144.710	.46591	
	55	4672.451	0.000	412.401	0.000	0.000	5634.741	25622.159	.35816	
375	56	4672.451	0.000	330.701	0.000	0.000	5034.890	25651.751	.31950	
	57	4672.451	0.000	445.401	0.000	0.000	5033.101	25659.324	.31467	
385	57	5541.562	0.000	427.361	0.000	0.000	5113.248	25644.154	.32190	
	59	5541.562	0.000	525.141	0.000	0.000	5935.927	25761.623	.35957	
							6086.706	25740.625	.36546	

CURVED MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (LMA)	OCCASIONAL LOAD STRESS (LMB)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SAW)	DESIGN STRESS RATIO (T/(1.0*SAW))	MODIFIED STRESS RATIO
150	46	4672.451	0.000	173.000	0.000	0.000	4845.481	25732.134	.30475	
	47	4672.451	0.000	262.412	0.000	0.000	4934.293	25651.110	.31037	
160	48	4672.451	0.000	159.511	0.000	0.000	4820.562	25673.700	.30542	
	49	4672.451	0.000	204.052	0.000	0.000	4874.533	25804.237	.31470	
170	51	4672.451	0.000	237.521	0.000	0.000	4911.001	25639.125	.30881	
	52	4672.451	0.000	206.011	0.000	0.000	4871.006	25645.432	.30816	
180	55	4672.451	0.000	412.401	0.000	0.000	5084.090	25651.751	.31350	
	56	4672.451	0.000	300.791	0.000	0.000	5003.181	25669.124	.31467	

STRAIGHT MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (LMA)	OCCASIONAL LOAD STRESS (LMB)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SAW)	DESIGN STRESS RATIO (T/(1.0*SAW))	MODIFIED STRESS RATIO
395	54	5886.562	0.000	525.141	0.000	0.000	6411.706	25667.753	.34874	
	60	5886.562	0.000	87.351	0.000	0.000	5973.914	25761.043	.33087	
405	60	5886.562	0.000	87.351	0.000	0.000	5973.914	25761.043	.33087	
	61	5886.562	0.000	72.521	0.000	0.000	5999.056	25761.634	.33694	
415	62	5886.562	0.000	88.261	0.000	0.000	5974.628	25761.132	.33942	
	63	5886.562	0.000	66.551	0.000	0.000	5973.113	25761.714	.33923	
425	64	5886.562	0.000	72.441	0.000	0.000	5965.406	25762.151	.33916	
	65	5886.562	0.000	324.581	0.000	0.000	6211.145	25714.132	.37417	

CURVED MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (LMA)	OCCASIONAL LOAD STRESS (LMB)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SAW)	DESIGN STRESS RATIO (T/(1.0*SAW))	MODIFIED STRESS RATIO
190	61	5886.562	0.000	128.131	0.000	0.000	6014.700	25751.474	.33733	
	62	5886.562	0.000	152.081	0.000	0.000	6047.311	25740.341	.33745	
200	63	5886.562	0.000	152.081	0.000	0.000	6031.413	25740.341	.33742	
	64	5886.562	0.000	120.701	0.000	0.000	6025.867	25740.733	.33600	

LACMWR FEED WATER + CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

STRAIGHT MEMBERS FOR RUN 5

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (SMD)	THERMAL EXPANSION STRESS (TMC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SMH)	DESIGN STRESS RATIO (S/T)	MODIFIED STRESS RATIO
435	53	4299.688	0.000	3080.489	0.000	0.000	7399.377	25173.545	0.42279	
445	66	4299.688	0.000	1757.462	0.000	0.000	6047.170	25477.481	0.39332	
455	67	4299.688	0.000	1627.755	0.000	0.000	6007.314	25438.944	0.38795	
465	68	4299.688	0.000	1377.766	0.000	0.000	5917.443	25475.128	0.37214	
465	73	4299.688	0.000	1274.264	0.000	0.000	5672.454	25504.166	0.35444	
465	69	4299.688	0.000	1538.361	0.000	0.000	5574.953	25547.873	0.35083	
475	69	4299.688	0.000	1202.037	0.000	0.000	5528.052	25446.810	0.36854	
485	71	4299.688	0.000	464.293	0.000	0.000	5491.728	25565.808	0.35539	
485	72	4299.688	0.000	1021.751	0.000	0.000	5446.167	25567.114	0.36492	
495	72	4299.688	0.000	691.447	0.000	0.000	4757.066	25721.428	0.29924	
495	77	4299.688	0.000	418.283	0.000	0.000	4757.066	25721.428	0.29924	
505	74	4299.688	0.000	1299.821	0.000	0.000	4951.133	25613.144	0.31939	
515	75	4299.688	0.000	279.871	0.000	0.000	4907.971	25683.574	0.30883	
515	76	4299.688	0.000	764.771	0.000	0.000	4773.514	25563.453	0.36584	
525	77	4299.688	0.000	484.251	0.000	0.000	4619.564	25772.193	0.25475	
525	78	4299.688	0.000	357.281	0.000	0.000	4619.564	25772.193	0.25475	
535	79	4299.688	0.000	1449.321	0.000	0.000	4446.975	25743.118	0.27796	
535	70	4299.688	0.000	1487.694	0.000	0.000	4759.016	25593.793	0.35770	
545	81	4299.688	0.000	1756.811	0.000	0.000	4759.016	25593.793	0.36210	
545	82	4299.688	0.000	1756.811	0.000	0.000	5996.499	25444.746	0.37714	
555	83	4299.688	0.000	1319.361	0.000	0.000	5946.499	25451.244	0.37714	
555	84	4299.688	0.000	505.721	0.000	0.000	5699.059	25543.577	0.30777	
565	72	4299.688	0.000	1633.831	0.000	0.000	4795.417	25713.474	0.31050	
565	84	4299.688	0.000	474.081	0.000	0.000	5923.526	25473.751	0.37255	
575	85	4299.688	0.000	325.151	0.000	0.000	4743.768	25729.119	0.29181	
585	86	4299.688	0.000	325.151	0.000	0.000	4614.835	25771.447	0.29024	
585	86	4299.688	0.000	219.863	0.000	0.000	4614.835	25771.447	0.29024	
585	86	4299.688	0.000	219.863	0.000	0.000	4619.564	25772.193	0.28705	
595	87	4299.688	0.000	201.131	0.000	0.000	4619.564	25772.193	0.28705	
595	87	4299.688	0.000	201.131	0.000	0.000	4519.373	25772.193	0.28705	
605	88	4299.688	0.000	353.013	0.000	0.000	4642.700	25745.776	0.29190	
615	89	4299.688	0.000	493.621	0.000	0.000	4642.700	25745.776	0.29190	
615	89	4299.688	0.000	493.621	0.000	0.000	4733.318	25714.745	0.30784	
625	90	4299.688	0.000	829.571	0.000	0.000	4733.318	25714.745	0.30784	
625	91	4299.688	0.000	342.211	0.000	0.000	4914.262	25647.167	0.29319	
635	105	4299.688	0.000	201.801	0.000	0.000	4631.907	25741.270	0.28131	
635	92	4299.688	0.000	799.171	0.000	0.000	4631.907	25741.270	0.28131	
635	93	4299.688	0.000	693.791	0.000	0.000	5079.862	25651.029	0.31549	
645	94	3786.977	0.000	123.551	0.000	0.000	4893.491	25662.675	0.30777	
645	95	3786.977	0.000	117.291	0.000	0.000	3710.533	25011.512	0.24595	

655	96	3786.977	0.000	464.221	0.000	0.000	4251.159	25821.120	0.26777	
655	97	3786.977	0.000	621.991	0.000	0.000	4468.585	25752.144	0.28107	
655	98	3786.977	0.000	611.391	0.000	0.000	4468.585	25752.144	0.28107	
675	99	3786.977	0.000	121.041	0.000	0.000	3095.019	25303.946	0.24579	
685	100	3786.977	0.000	517.121	0.000	0.000	4304.102	25517.876	0.27074	
685	103	3786.977	0.000	1240.371	0.000	0.000	5027.348	25564.149	0.31619	
695	101	3786.977	0.000	446.611	0.000	0.000	5027.348	25564.149	0.31619	
695	101	3786.977	0.000	446.611	0.000	0.000	4233.583	25133.953	0.26576	
705	102	3786.977	0.000	446.611	0.000	0.000	4233.583	25133.953	0.26576	
705	103	3786.977	0.000	245.461	0.000	0.000	4035.444	25374.768	0.25702	
715	104	3786.977	0.000	499.681	0.000	0.000	4236.662	25421.434	0.26560	
715	105	4299.688	0.000	499.681	0.000	0.000	4236.662	25421.434	0.26560	
725	106	4299.688	0.000	799.171	0.000	0.000	4431.197	25771.121	0.29247	
725	106	4299.688	0.000	799.171	0.000	0.000	4431.197	25771.121	0.29247	
735	107	4299.688	0.000	229.661	0.000	0.000	5079.862	25651.029	0.28244	
735	107	4299.688	0.000	229.661	0.000	0.000	4519.353	25772.117	0.24324	
735	107	4299.688	0.000	618.291	0.000	0.000	4907.971	25651.956	0.30883	
735	107	4299.688	0.000	618.291	0.000	0.000	4763.766	25729.199	0.29901	

CURVED MEMBERS FOR RUN 5

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (SMD)	THERMAL EXPANSION STRESS (TMC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SMH)	DESIGN STRESS RATIO (S/T)	MODIFIED STRESS RATIO
210	67	4299.688	0.000	2434.292	0.000	0.000	6723.570	25133.694	0.42230	
220	68	4299.688	0.000	2301.173	0.000	0.000	6593.461	25133.792	0.41453	
220	73	4299.688	0.000	1822.571	0.000	0.000	6282.011	25412.874	0.30071	
230	74	4299.688	0.000	1859.723	0.000	0.000	6282.011	25412.874	0.30071	
230	75	4299.688	0.000	371.661	0.000	0.000	6034.415	25479.174	0.34141	
230	76	4299.688	0.000	551.631	0.000	0.000	4631.907	25741.270	0.29131	
240	77	4299.688	0.000	750.441	0.000	0.000	4940.124	25672.099	0.31119	
240	78	4299.688	0.000	514.447	0.000	0.000	4940.124	25672.099	0.31119	
250	82	4299.688	0.000	1973.971	0.000	0.000	4824.136	25672.171	0.30148	
260	90	4299.688	0.000	776.491	0.000	0.000	4262.265	25491.096	0.33302	
260	91	4299.688	0.000	679.571	0.000	0.000	5046.187	25683.148	0.31737	
270	92	4299.688	0.000	342.211	0.000	0.000	4733.318	25714.745	0.29190	
270	94	4299.688	0.000	403.791	0.000	0.000	4631.907	25741.270	0.28131	
280	95	4299.688	0.000	433.201	0.000	0.000	4631.907	25741.270	0.28131	
280	96	3786.977	0.000	117.291	0.000	0.000	3786.977	25011.512	0.24595	
280	98	3786.977	0.000	464.221	0.000	0.000	4251.159	25821.120	0.26777	
290	99	3786.977	0.000	121.041	0.000	0.000	3095.019	25303.946	0.24579	
290	100	3786.977	0.000	517.121	0.000	0.000	4304.102	25517.876	0.27074	
300	102	3786.977	0.000	1240.371	0.000	0.000	5027.348	25564.149	0.31619	
300	103	3786.977	0.000	1240.371	0.000	0.000	5027.348	25564.149	0.31619	

LACRWR FEED WATER + CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

D.1.2 SATISFACTION OF EQUATION 9 (ANALYSIS SET 1)

STRAIGHT MEMBERS FOR RUN 1

Table with 11 columns: MEMBER NO., MEMBER ENDS, INTERNAL PRESSURE STRESS (PI), PEAK PRESSURE STRESS (PMAX), SUSTAINED LOAD STRESS (MA), OCCASIONAL LOAD STRESS (MB), THERMAL EXPANSION STRESS (MC), TOTAL STRESS (T), MODIFIED ALLOWABLE STRESS (SA), UPSET STRESS RATIO (T/(1.2*SA)), EMERGENCY STRESS RATIO (T/(1.5*SA)). Rows include members 15, 25, 35, 45, 55, 65, 75, 85, 95, 105, 115.

CURVED MEMBERS FOR RUN 1

Table with 11 columns: MEMBER NO., MEMBER ENDS, INTERNAL PRESSURE STRESS (PI), PEAK PRESSURE STRESS (PMAX), SUSTAINED LOAD STRESS (MA), OCCASIONAL LOAD STRESS (MB), THERMAL EXPANSION STRESS (MC), TOTAL STRESS (T), MODIFIED ALLOWABLE STRESS (SA), UPSET STRESS RATIO (T/(1.2*SA)), EMERGENCY STRESS RATIO (T/(1.5*SA)). Rows include members 12, 20, 30, 40, 50, 60, 70, 80.

STRAIGHT MEMBERS FOR RUN 2

Table with 11 columns: MEMBER NO., MEMBER ENDS, INTERNAL PRESSURE STRESS (PI), PEAK PRESSURE STRESS (PMAX), SUSTAINED LOAD STRESS (MA), OCCASIONAL LOAD STRESS (MB), THERMAL EXPANSION STRESS (MC), TOTAL STRESS (T), MODIFIED ALLOWABLE STRESS (SA), UPSET STRESS RATIO (T/(1.2*SA)), EMERGENCY STRESS RATIO (T/(1.5*SA)). Rows include members 125, 135, 145, 155, 165, 175, 185, 195, 205, 215, 225, 235, 245.

CURVED MEMBERS FOR RUN 2

Table with 11 columns: MEMBER NO., MEMBER ENDS, INTERNAL PRESSURE STRESS (PI), PEAK PRESSURE STRESS (PMAX), SUSTAINED LOAD STRESS (MA), OCCASIONAL LOAD STRESS (MB), THERMAL EXPANSION STRESS (MC), TOTAL STRESS (T), MODIFIED ALLOWABLE STRESS (SA), UPSET STRESS RATIO (T/(1.2*SA)), EMERGENCY STRESS RATIO (T/(1.5*SA)). Rows include members 70, 80, 90, 100, 110, 120.

130	41	0.000	4673.591	175.811	607.683	0.000	5443.757	25741.445	.38667	.19112
	42	0.000	4673.591	176.157	643.000	0.000	5492.836	25741.438	.23789	.19132
140	43	0.000	4673.591	136.891	625.679	0.000	5436.195	25741.452	.26441	.19104
	44	0.000	4673.591	259.811	633.235	0.000	5563.646	25765.730	.29160	.19440

STRAIGHT MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (TS)	MODIFIED ALLOWABLE STRESS (SAM)	UPSET STRESS RATIO T9/(1.2*SM)	EMERGENCY STRESS RATIO T9/(1.3*SM)
255	19	0.000	5070.641	507.049	415.825	0.000	5614.514	25671.125	.30410	.20778
	20	0.000	5070.641	561.713	435.003	0.000	6082.378	25621.214	.31904	.21270
265	19	0.000	5070.641	354.945	503.724	0.000	5901.310	25663.132	.31232	.20731
	46	0.000	5070.641	173.000	413.769	0.000	5677.410	25701.135	.29756	.21377
275	20	0.000	5070.641	561.713	435.003	0.000	6082.378	25623.374	.31232	.21377
	21	0.000	5070.641	321.241	243.451	0.000	5681.351	25671.132	.29472	.20781
285	21	0.000	5070.641	321.241	249.501	0.000	5681.351	25671.132	.29472	.20781
	22	0.000	5070.641	203.251	215.327	0.000	5512.223	25616.414	.28399	.20781
295	22	0.000	5070.641	203.251	215.327	0.000	5512.223	25616.414	.28399	.20781
	23	0.000	5070.641	151.797	224.453	0.000	5466.851	25707.341	.28652	.21262
305	23	0.000	5070.641	5.164	.000	0.000	5095.855	25734.500	.25778	.19735
	24	0.000	5070.641	.000	.000	0.000	5193.161	25711.574	.26441	.19747
315	47	0.000	5070.641	262.411	533.059	0.000	5871.112	25611.435	.30476	.20746
	48	0.000	5070.641	123.483	605.903	0.000	5825.183	25712.715	.30435	.20767
325	49	0.000	5070.641	321.401	594.351	0.000	5815.303	25711.475	.30444	.20823
	50	0.000	5070.641	123.491	430.039	0.000	5660.276	25703.933	.28666	.19777
335	50	0.000	5070.641	123.491	430.039	0.000	5660.276	25703.933	.28666	.19777
	51	0.000	5070.641	142.952	474.362	0.000	5714.670	25707.099	.29972	.19711
345	52	0.000	5070.641	175.051	462.234	0.000	5715.630	25711.704	.29998	.19772
	53	0.000	5070.641	231.246	345.946	0.000	6340.055	25141.749	.43390	.32668
355	53	0.000	5070.641	2779.091	1372.144	0.000	9561.615	25144.710	.41847	.32668
	54	0.000	5070.641	1022.261	630.413	0.000	6743.313	25522.164	.35342	.21662
365	54	0.000	5070.641	1022.261	630.413	0.000	6743.313	25522.164	.35342	.21662
	55	0.000	5070.641	412.401	563.725	0.000	6056.774	25641.341	.31201	.21262
375	56	0.000	5070.641	333.700	645.859	0.000	6163.440	25661.124	.31510	.21277
	57	0.000	5070.641	445.881	674.425	0.000	6190.603	25644.164	.32447	.21271
385	57	0.000	6037.500	427.361	741.753	0.000	7214.318	25751.507	.36215	.26145
	59	0.000	6037.500	925.141	662.675	0.000	7425.522	25746.825	.37077	.26451

CURVED MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (TS)	MODIFIED ALLOWABLE STRESS (SAM)	UPSET STRESS RATIO T9/(1.2*SM)	EMERGENCY STRESS RATIO T9/(1.3*SM)
150	46	0.000	5070.641	173.000	413.769	0.000	5677.410	25702.135	.29756	.19477
	47	0.000	5070.641	262.411	533.059	0.000	5871.112	25611.435	.30476	.20746
160	48	0.000	5070.641	199.511	942.500	0.000	6232.739	25667.210	.32646	.21278
	49	0.000	5070.641	204.051	922.965	0.000	6217.661	25695.237	.32587	.21255
170	51	0.000	5070.641	237.521	737.600	0.000	6065.761	25649.125	.31791	.21174
	52	0.000	5070.641	206.611	764.397	0.000	6061.693	25695.632	.31770	.21180

180	55	0.000	5070.641	412.401	583.725	0.000	6056.774	25651.751	.31071	.21268
	56	0.000	5070.641	330.700	648.096	0.000	6069.440	25669.124	.31610	.21207

STRAIGHT MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (TS)	MODIFIED ALLOWABLE STRESS (SAM)	UPSET STRESS RATIO T9/(1.2*SM)	EMERGENCY STRESS RATIO T9/(1.3*SM)
395	64	0.000	6900.000	925.143	662.675	0.000	8284.722	25667.511	.41607	.27734
	65	0.000	6900.000	87.351	631.023	0.000	7424.374	25769.543	.38249	.26523
405	65	0.000	6900.000	87.351	631.023	0.000	7424.374	25769.543	.38249	.26523
	66	0.000	6900.000	72.521	489.067	0.000	7393.590	25761.594	.37051	.26701
415	67	0.000	6900.000	89.065	373.612	0.000	7366.677	25760.332	.36031	.26454
	68	0.000	6900.000	86.551	423.234	0.000	7404.789	25761.714	.37198	.26498
425	64	0.000	6900.0	78.844	547.742	0.000	7528.086	25761.351	.37792	.26194
	65	0.000	6900.0	324.582	694.669	0.000	7919.251	25713.132	.39755	.26504

CURVED MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (TS)	MODIFIED ALLOWABLE STRESS (SAM)	UPSET STRESS RATIO T9/(1.2*SM)	EMERGENCY STRESS RATIO T9/(1.3*SM)
190	61	0.000	6900.000	175.131	702.392	0.000	7749.133	25751.176	.38071	.26074
	62	0.000	6900.000	153.946	664.350	0.000	7724.548	25744.341	.38779	.26440
200	63	0.000	6900.000	197.921	747.753	0.000	7933.720	25746.610	.39160	.26137
	64	0.000	6900.000	139.325	879.421	0.000	8009.733	25749.533	.40210	.26596

LACROW FEED WATER + CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

STRAIGHT MEMBERS FOR RUN 5

Table with 11 columns: MEMBER NO., MEMBER ENDS, INTERNAL PRESSURE STRESS (PSI), PEAK PRESSURE STRESS (PSI-MAX), SUSTAINED LOAD STRESS (EMA), OCCASIONAL LOAD STRESS (EMA), THERMAL EXPANSION STRESS (EMA), TOTAL STRESS (TSI), MODIFIED ALLOWABLE STRESS (ISA), UPSET RATIO, and EFFICIENCY RATIO. Rows are grouped by member numbers (435-485, 495-575, 605-675, 685-775, 785-875, 885-975).

PIPES

Table with 11 columns: MEMBER NO., MEMBER ENDS, INTERNAL PRESSURE STRESS (PSI), PEAK PRESSURE STRESS (PSI-MAX), SUSTAINED LOAD STRESS (EMA), OCCASIONAL LOAD STRESS (EMA), THERMAL EXPANSION STRESS (EMA), TOTAL STRESS (TSI), MODIFIED ALLOWABLE STRESS (ISA), UPSET RATIO, and EFFICIENCY RATIO. Rows include member numbers 655-705, 715-735, and 745-765.

CURVED MEMBERS FOR RUN 5

Table with 11 columns: MEMBER NO., MEMBER ENDS, INTERNAL PRESSURE STRESS (PSI), PEAK PRESSURE STRESS (PSI-MAX), SUSTAINED LOAD STRESS (EMA), OCCASIONAL LOAD STRESS (EMA), THERMAL EXPANSION STRESS (EMA), TOTAL STRESS (TSI), MODIFIED ALLOWABLE STRESS (ISA), UPSET RATIO, and EFFICIENCY RATIO. Rows include member numbers 210, 220, 230, 240, 250, 260, 270, 280, 290, and 300.

LADDER FEED WATER + CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

D.1.3 SATISFACTION OF EQUATION 10 (ANALYSIS SET 1)

STRAIGHT MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T10/(1.0*SMA)	MODIFIED STRESS RATIO T10/(1.0*SMA)
15	1	0.000	0.000	0.000	0.000	3813.949	3813.949	24493.491	.15591	.15796
	2	0.000	0.000	0.000	0.000	1273.127	1273.127	25773.734	.04937	.04945
18	25	0.000	0.000	0.000	0.000	9743.246	9743.246	25773.734	.37797	.37803
	11	0.000	0.000	0.000	0.000	1316.922	1316.922	25773.734	.05110	.05115
35	1	0.000	0.000	0.000	0.000	1311.243	1311.243	25773.734	.05085	.05090
	12	0.000	0.000	0.000	0.000	1462.588	1462.588	25773.734	.05677	.05682
45	3	0.000	0.000	0.000	0.000	3172.116	3172.116	25773.734	.12299	.12304
	4	0.000	0.000	0.000	0.000	2629.123	2629.123	25773.734	.10198	.10203
55	4	0.000	0.000	0.000	0.000	2629.123	2629.123	25773.734	.10198	.10203
	6	0.000	0.000	0.000	0.000	3213.572	3213.572	25773.734	.12468	.12473
65	7	0.000	0.000	0.000	0.000	2564.715	2564.715	25773.734	.09948	.09953
	8	0.000	0.000	0.000	0.000	2389.025	2389.025	25773.734	.09271	.09276
75	9	0.000	0.000	0.000	0.000	2564.715	2564.715	25773.734	.09948	.09953
	10	0.000	0.000	0.000	0.000	2763.471	2763.471	25773.734	.10724	.10729
85	13	0.000	0.000	0.000	0.000	1532.494	1532.494	25773.734	.05948	.05953
	14	0.000	0.000	0.000	0.000	907.909	907.909	25773.734	.03524	.03529
95	15	0.000	0.000	0.000	0.000	1192.949	1192.949	25773.734	.04658	.04663
	16	0.000	0.000	0.000	0.000	1426.056	1426.056	25773.734	.05521	.05526
105	16	0.000	0.000	0.000	0.000	1426.056	1426.056	25773.734	.05521	.05526
	17	0.000	0.000	0.000	0.000	1936.032	1936.032	25773.734	.07514	.07519
115	18	0.000	0.000	0.000	0.000	2001.303	2001.303	25773.734	.07787	.07792
	19	0.000	0.000	0.000	0.000	2505.683	2505.683	25773.734	.09729	.09734

CURVED MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T10/(1.0*SMA)	MODIFIED STRESS RATIO T10/(1.0*SMA)
10	2	0.000	0.000	0.000	0.000	1620.336	1620.336	25773.734	.06278	.06283
	3	0.000	0.000	0.000	0.000	1220.022	1220.022	25773.734	.04734	.04739
20	6	0.000	0.000	0.000	0.000	3213.572	3213.572	25773.734	.12468	.12473
	7	0.000	0.000	0.000	0.000	2564.715	2564.715	25773.734	.09948	.09953
30	8	0.000	0.000	0.000	0.000	3572.146	3572.146	25773.734	.13856	.13861
	9	0.000	0.000	0.000	0.000	4014.546	4014.546	25773.734	.15578	.15583
40	12	0.000	0.000	0.000	0.000	2227.145	2227.145	25773.734	.08637	.08642
	13	0.000	0.000	0.000	0.000	2051.666	2051.666	25773.734	.07965	.07970
50	14	0.000	0.000	0.000	0.000	907.909	907.909	25773.734	.03524	.03529
	15	0.000	0.000	0.000	0.000	1192.949	1192.949	25773.734	.04658	.04663
60	17	0.000	0.000	0.000	0.000	2661.458	2661.458	25773.734	.10324	.10329
	18	0.000	0.000	0.000	0.000	2661.930	2661.930	25773.734	.10338	.10343

STRAIGHT MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T10/(1.0*SMA)	MODIFIED STRESS RATIO T10/(1.0*SMA)
125	23	0.000	0.000	0.000	0.000	3127.240	3127.240	25773.734	.12130	.12135
	25	0.000	0.000	0.000	0.000	1894.248	1894.248	25773.734	.07353	.07358
135	26	0.000	0.000	0.000	0.000	1492.454	1492.454	25773.734	.05803	.05808
	27	0.000	0.000	0.000	0.000	1723.372	1723.372	25773.734	.06693	.06698
145	24	0.000	0.000	0.000	0.000	1649.535	1649.535	25773.734	.06394	.06399
	29	0.000	0.000	0.000	0.000	2471.353	2471.353	25773.734	.09582	.09587
155	29	0.000	0.000	0.000	0.000	12503.747	12503.747	25773.734	.48541	.48546
	30	0.000	0.000	0.000	0.000	3021.135	3021.135	25773.734	.11707	.11712
165	29	0.000	0.000	0.000	0.000	4820.025	4820.025	25773.734	.18704	.18709
	31	0.000	0.000	0.000	0.000	2053.744	2053.744	25773.734	.07965	.07970
175	30	0.000	0.000	0.000	0.000	3293.135	3293.135	25773.734	.12769	.12774
	31	0.000	0.000	0.000	0.000	4277.481	4277.481	25773.734	.16601	.16606
185	32	0.000	0.000	0.000	0.000	4356.400	4356.400	25773.734	.16934	.16939
	33	0.000	0.000	0.000	0.000	2542.462	2542.462	25773.734	.09887	.09892
195	34	0.000	0.000	0.000	0.000	3480.070	3480.070	25773.734	.13506	.13511
	35	0.000	0.000	0.000	0.000	4132.483	4132.483	25773.734	.16147	.16152
205	35	0.000	0.000	0.000	0.000	4132.483	4132.483	25773.734	.16147	.16152
	36	0.000	0.000	0.000	0.000	4132.483	4132.483	25773.734	.16147	.16152
215	37	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
	38	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
225	43	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
	41	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
235	42	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
	43	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
245	44	0.000	0.000	0.000	0.000	2621.265	2621.265	25773.734	.10174	.10179
	45	0.000	0.000	0.000	0.000	2116.449	2116.449	25773.734	.08203	.08208

CURVED MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T10/(1.0*SMA)	MODIFIED STRESS RATIO T10/(1.0*SMA)
70	25	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
	26	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
80	27	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
	28	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
90	31	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
	32	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
100	33	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
	34	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
110	35	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
	36	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
120	37	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429
	38	0.000	0.000	0.000	0.000	2428.453	2428.453	25773.734	.09424	.09429

130	41	0.000	0.000	0.001	0.000	2797.632	2797.632	25751.645	.01979	.10450
	42	0.000	0.000	0.001	0.000	3758.361	3758.361	25751.634	.01982	.10448
140	43	0.000	0.000	0.001	0.000	4264.058	4264.058	25751.652	.01979	.10451
	44	0.000	0.000	0.001	0.000	3921.039	3921.039	25765.730	.01990	.10218

STRAIGHT MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (LMA)	OCCASIONAL LOAD STRESS (LMB)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T10/(1.0*SMA)	MODIFIED STRESS RATIO T10/(1.0*SMA)
255	19	0.000	0.000	0.000	0.000	821.929	821.929	25671.935	.01919	.03211
	20	0.000	0.000	0.000	0.000	877.500	877.500	25621.734	.01957	.03425
265	19	0.000	0.000	0.000	0.000	1615.044	1615.044	25691.122	.01916	.03433
	46	0.000	0.000	0.000	0.000	1956.767	1956.767	25732.515	.01979	.03413
275	20	0.000	0.000	0.000	0.000	877.500	877.500	25621.734	.01979	.03425
	21	0.000	0.000	0.000	0.000	1057.761	1057.761	25671.932	.01929	.03470
285	21	0.000	0.000	0.000	0.000	1057.761	1057.761	25671.932	.01929	.03470
	22	0.000	0.000	0.000	0.000	1277.706	1277.706	25654.406	.01914	.03511
295	22	0.000	0.000	0.000	0.000	1277.706	1277.706	25654.406	.01914	.03511
	23	0.000	0.000	0.000	0.000	1770.536	1770.536	25707.141	.01981	.03487
305	23	0.000	0.000	0.000	0.000	.000	.000	25735.500	.00000	.00000
	24	0.000	0.000	0.000	0.000	.000	.000	25735.500	.00000	.00000
315	47	0.000	0.000	0.000	0.000	1691.519	1691.519	25691.136	.01910	.03365
	48	0.000	0.000	0.000	0.000	1644.571	1644.571	25712.705	.01947	.03394
325	49	0.000	0.000	0.000	0.000	1324.496	1324.496	25711.675	.01911	.03351
	50	0.000	0.000	0.000	0.000	708.419	708.419	25703.911	.01933	.03255
335	50	0.000	0.000	0.000	0.000	708.419	708.419	25703.911	.01933	.03255
	51	0.000	0.000	0.000	0.000	2435.513	2435.513	25707.146	.01929	.03474
345	52	0.000	0.000	0.000	0.000	2679.708	2679.708	25711.174	.01942	.03422
	53	0.000	0.000	0.000	0.000	6617.793	6617.793	25111.043	.02619	.02600
355	53	0.000	0.000	0.000	0.000	6233.979	6233.979	25144.730	.02601	.02611
	54	0.000	0.000	0.000	0.000	2091.050	2091.050	25622.165	.01944	.03220
365	54	0.000	0.000	0.000	0.000	2016.050	2016.050	25622.168	.01944	.03220
	55	0.000	0.000	0.000	0.000	2167.513	2167.513	25651.051	.01934	.03204
375	56	0.000	0.000	0.000	0.000	1821.400	1821.400	25643.324	.01926	.03206
	57	0.000	0.000	0.000	0.000	1464.993	1464.993	25644.154	.01927	.03213
385	57	0.000	0.000	0.000	0.000	1551.022	1551.022	25761.633	.01914	.03226
	59	0.000	0.000	0.000	0.000	2519.104	2519.104	25749.925	.01914	.03283

CURVED MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (LMA)	OCCASIONAL LOAD STRESS (LMB)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T10/(1.0*SMA)	MODIFIED STRESS RATIO T10/(1.0*SMA)
150	46	0.000	0.000	0.000	0.000	1956.767	1956.767	25732.535	.01979	.03413
	47	0.000	0.000	0.000	0.000	1691.519	1691.519	25691.135	.01910	.03365
160	48	0.000	0.000	0.000	0.000	2553.746	2553.746	25637.230	.01935	.03318
	49	0.000	0.000	0.000	0.000	2056.748	2056.748	25619.037	.01907	.03304
170	51	0.000	0.000	0.000	0.000	3762.233	3762.233	25619.125	.01915	.03223
	52	0.000	0.000	0.000	0.000	4161.319	4161.319	25695.692	.01919	.03195

180	55	0.000	0.000	0.000	0.000	2367.513	2367.513	25651.951	.01938	.03229
	56	0.000	0.000	0.000	0.000	1821.400	1821.400	25641.324	.01919	.03296

STRAIGHT MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (LMA)	OCCASIONAL LOAD STRESS (LMB)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T10/(1.0*SMA)	MODIFIED STRESS RATIO T10/(1.0*SMA)
395	59	0.000	0.000	0.000	0.000	2518.104	2518.104	25667.913	.01914	.03410
	60	0.000	0.000	0.000	0.000	2572.285	2572.285	25703.647	.01945	.03355
405	60	0.000	0.000	0.000	0.000	2572.285	2572.285	25703.643	.01945	.03355
	61	0.000	0.000	0.000	0.000	3402.484	3402.484	25743.694	.01977	.03317
415	62	0.000	0.000	0.000	0.000	3610.610	3610.610	25783.192	.01913	.03416
	63	0.000	0.000	0.000	0.000	3516.873	3516.873	25760.714	.01917	.03444
425	64	0.000	0.000	0.000	0.000	3349.016	3349.016	25762.151	.01916	.03300
	65	0.000	0.000	0.000	0.000	3155.027	3155.027	25719.132	.01924	.03272

CURVED MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (LMA)	OCCASIONAL LOAD STRESS (LMB)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T10/(1.0*SMA)	MODIFIED STRESS RATIO T10/(1.0*SMA)
190	61	0.000	0.000	0.000	0.000	6011.076	6011.076	25751.176	.02079	.02145
	62	0.000	0.000	0.000	0.000	6379.546	6379.546	25749.341	.02144	.02179
200	63	0.000	0.000	0.000	0.000	6212.014	6212.014	25744.610	.02141	.02129
	64	0.000	0.000	0.000	0.000	5917.007	5917.007	25749.603	.02177	.02200

STRAIGHT MEMBERS FOR RUN 5

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MA)	THERMAL EXPANSION STRESS (MPC)	TOTAL STRESS (TIC)	MODIFIED ALLOWABLE STRESS (SAM)	DESIGN STRESS RATIO T10/(1.0*SAM)	MODIFIED STRESS RATIO T10/(1.0*SAM)
435	53	0.000	0.000	0.000	0.000	2670.815	2670.815	25170.545	.11433	.17653
	56	0.000	0.000	0.000	0.000	1775.447	1775.447	25447.471	.07433	.09376
445	66	0.000	0.000	0.000	0.000	1202.310	1202.310	25474.746	.05574	.06842
	67	0.000	0.000	0.000	0.000	1240.355	1240.355	25474.746	.05814	.07171
455	66	0.000	0.000	0.000	0.000	847.631	847.631	25524.124	.03300	.03300
	73	0.000	0.000	0.000	0.000	804.130	804.130	25524.124	.03143	.03143
465	68	0.000	0.000	0.000	0.000	1202.767	1202.767	25534.319	.05150	.06716
	69	0.000	0.000	0.000	0.000	1205.799	1205.799	25555.508	.05163	.07116
475	69	0.000	0.000	0.000	0.000	1205.743	1205.743	25567.114	.05163	.07116
	71	0.000	0.000	0.000	0.000	2010.772	2010.772	25721.423	.07810	.10717
485	71	0.000	0.000	0.000	0.000	2010.772	2010.772	25721.423	.07810	.10717
	72	0.000	0.000	0.000	0.000	1826.351	1826.351	25571.934	.07220	.09717
495	72	0.000	0.000	0.000	0.000	2208.743	2208.743	25530.334	.08641	.11400
505	74	0.000	0.000	0.000	0.000	2137.146	2137.146	25612.576	.08134	.10707
	75	0.000	0.000	0.000	0.000	790.614	790.614	25741.453	.03075	.03903
515	76	0.000	0.000	0.000	0.000	601.443	601.443	25772.832	.02358	.02358
	77	0.000	0.000	0.000	0.000	527.236	527.236	25742.576	.02036	.02036
525	78	0.000	0.000	0.000	0.000	534.877	534.877	25745.718	.02161	.02161
	79	0.000	0.000	0.000	0.000	512.149	512.149	25534.729	.02033	.02033
535	79	0.000	0.000	0.000	0.000	512.149	512.149	25534.729	.02033	.02033
545	81	0.000	0.000	0.000	0.000	546.813	546.813	25551.244	.02341	.02341
	82	0.000	0.000	0.000	0.000	546.813	546.813	25491.244	.02341	.02341
555	83	0.000	0.000	0.000	0.000	488.811	488.811	25547.577	.02033	.02033
	84	0.000	0.000	0.000	0.000	476.143	476.143	25713.474	.01882	.01882
565	84	0.000	0.000	0.000	0.000	524.592	524.592	25731.751	.02146	.02146
	85	0.000	0.000	0.000	0.000	1455.451	1455.451	25771.139	.06232	.08559
575	85	0.000	0.000	0.000	0.000	826.239	826.239	25751.447	.03333	.04375
	86	0.000	0.000	0.000	0.000	818.325	818.325	25775.132	.03304	.04375
585	86	0.000	0.000	0.000	0.000	818.325	818.325	25775.132	.03304	.04375
	87	0.000	0.000	0.000	0.000	959.473	959.473	25774.700	.04110	.05324
595	87	0.000	0.000	0.000	0.000	1462.660	1462.660	25777.137	.06233	.08675
605	88	0.000	0.000	0.000	0.000	2245.703	2245.703	25745.376	.09116	.12423
	89	0.000	0.000	0.000	0.000	2245.703	2245.703	25745.376	.09116	.12423
615	89	0.000	0.000	0.000	0.000	2910.407	2910.407	25715.045	.12762	.17400
	90	0.000	0.000	0.000	0.000	2910.407	2910.407	25715.045	.12762	.17400
625	91	0.000	0.000	0.000	0.000	3657.146	3657.146	25681.167	.15660	.21337
	92	0.000	0.000	0.000	0.000	3432.675	3432.675	25744.770	.14113	.19356
635	92	0.000	0.000	0.000	0.000	3027.713	3027.713	25774.121	.12046	.16705
	93	0.000	0.000	0.000	0.000	2746.277	2746.277	25651.729	.11772	.15760
645	94	0.000	0.000	0.000	0.000	4033.741	4033.741	25631.835	.16772	.22798
	95	0.000	0.000	0.000	0.000	1242.639	1242.639	25921.912	.05321	.07496
	95	0.000	0.000	0.000	0.000	1248.902	1248.902	25922.442	.05348	.07421

PIPES

655	96	0.000	0.000	0.000	0.000	1115.763	1115.763	25523.120	.04776	.06415
	97	0.000	0.000	0.000	0.000	1156.003	1156.003	25742.444	.04967	.06499
665	97	0.000	0.000	0.000	0.000	1156.003	1156.003	25742.444	.04967	.06499
	98	0.000	0.000	0.000	0.000	1736.059	1736.059	25712.746	.07434	.09732
675	99	0.000	0.000	0.000	0.000	1919.356	1919.356	25517.478	.08719	.11744
	100	0.000	0.000	0.000	0.000	2024.244	2024.244	25664.189	.09686	.13033
685	100	0.000	0.000	0.000	0.000	2024.244	2024.244	25664.189	.09686	.13033
	101	0.000	0.000	0.000	0.000	2016.145	2016.145	25722.563	.09687	.13149
695	101	0.000	0.000	0.000	0.000	2016.145	2016.145	25722.563	.09687	.13149
	102	0.000	0.000	0.000	0.000	3027.713	3027.713	25774.368	.12047	.16371
705	103	0.000	0.000	0.000	0.000	4108.147	4108.147	25821.944	.16259	.21810
	104	0.000	0.000	0.000	0.000	4105.470	4105.470	25821.072	.16259	.21810
715	105	0.000	0.000	0.000	0.000	3027.713	3027.713	25774.121	.12046	.16371
	106	0.000	0.000	0.000	0.000	2746.277	2746.277	25651.729	.11759	.15760
725	106	0.000	0.000	0.000	0.000	959.473	959.473	25774.700	.04110	.05324
	107	0.000	0.000	0.000	0.000	1462.660	1462.660	25777.137	.06233	.08675
735	107	0.000	0.000	0.000	0.000	2133.966	2133.966	25684.556	.08134	.10707
	108	0.000	0.000	0.000	0.000	1455.451	1455.451	25720.199	.06232	.08559

CURVED MEMBERS FOR RUN 5

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MA)	THERMAL EXPANSION STRESS (MPC)	TOTAL STRESS (TIC)	MODIFIED ALLOWABLE STRESS (SAM)	DESIGN STRESS RATIO T10/(1.0*SAM)	MODIFIED STRESS RATIO T10/(1.0*SAM)
21C	67	0.000	0.000	0.000	0.000	1855.293	1855.293	20701.464	.09040	.07336
	68	0.000	0.000	0.000	0.000	1799.163	1799.163	20331.747	.08704	.07102
22C	73	0.000	0.000	0.000	0.000	1202.484	1202.484	20412.334	.05891	.04733
	74	0.000	0.000	0.000	0.000	1182.647	1182.647	20435.374	.05844	.04644
23C	75	0.000	0.000	0.000	0.000	859.674	859.674	20771.871	.04152	.03454
	76	0.000	0.000	0.000	0.000	823.775	823.775	20771.710	.03997	.03305
24C	77	0.000	0.000	0.000	0.000	701.101	701.101	20677.859	.03449	.02843
	78	0.000	0.000	0.000	0.000	754.775	754.775	20707.171	.03723	.03136
25C	83	0.000	0.000	0.000	0.000	731.192	731.192	20441.956	.03531	.02979
	84	0.000	0.000	0.000	0.000	712.242	712.242	20441.130	.03450	.02979
26C	90	0.000	0.000	0.000	0.000	3657.146	3657.146	20647.167	.18100	.14787
	91	0.000	0.000	0.000	0.000	3422.675	3422.675	20741.270	.16713	.13726
27C	93	0.000	0.000	0.000	0.000	4033.741	4033.741	20631.835	.19772	.16171
	94	0.000	0.000	0.000	0.000	4377.138	4377.138	20774.480	.21404	.17324
28C	95	0.000	0.000	0.000	0.000	1248.902	1248.902	20901.442	.05944	.04821
	96	0.000	0.000	0.000	0.000	1115.763	1115.763	20873.120	.04776	.04700
29C	97	0.000	0.000	0.000	0.000	1736.059	1736.059	20511.246	.08474	.06700
	98	0.000	0.000	0.000	0.000	1919.356	1919.356	20511.246	.09687	.07494
30C	102	0.000	0.000	0.000	0.000	3027.713	3027.713	20574.743	.15000	.11901
	103	0.000	0.000	0.000	0.000	4108.147	4108.147	20821.944	.19591	.15010

0.1.4 SATISFACTION OF EQUATION 11 (ANALYSIS SET 1)

STRAIGHT MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (TI1)	MODIFIED ALLOWABLE STRESS (SIAM)	DESIGN STRESS RATIO TII/(SIAM+SA)	MODIFIED STRESS RATIO TII/(SIAM+SAM)
15	1	3786.977	0.000	131.607	0.000	3513.945	7732.509	2583.411	.13849	.14604
	2	3786.977	0.000	129.127	0.000	3513.945	5029.205	2583.411	.12412	.13026
18	25	4289.688	0.000	465.485	0.000	3244.056	14098.244	2572.118	.35916	.37172
	11	4289.688	0.000	323.875	0.000	3298.922	7710.445	2572.118	.10643	.11452
35	1	3786.977	0.000	241.292	0.000	1311.283	5439.572	2585.243	.12457	.13227
	12	3786.977	0.000	199.971	0.000	1662.088	5849.041	2585.243	.14761	.15419
45	3	4289.688	0.000	85.745	0.000	3157.176	7567.629	2582.720	.19279	.19147
	4	4289.688	0.000	363.250	0.000	2629.173	7212.070	2574.174	.15551	.17487
55	4	4289.688	0.000	363.250	0.000	2629.173	7212.070	2574.174	.15551	.17487
	6	4289.688	0.000	76.951	0.000	3213.572	7550.212	2584.619	.19111	.19176
65	7	4289.688	0.000	206.555	0.000	2566.715	7060.955	2577.048	.17988	.18492
	8	4289.688	0.000	129.552	0.000	2788.025	6807.266	2573.411	.17342	.18177
75	9	4289.688	0.000	215.707	0.000	2683.775	7159.170	2575.104	.18315	.19241
	10	4289.688	0.000	219.664	0.000	2763.971	7273.323	2574.243	.18529	.19443
85	13	3786.977	0.000	196.713	0.000	1536.994	5514.604	2555.936	.14049	.15157
	14	3786.977	0.000	183.743	0.000	907.909	4478.720	2566.722	.12429	.13475
95	15	3786.977	0.000	116.260	0.000	1192.949	5035.195	2583.160	.12923	.13811
	16	3786.977	0.000	176.763	0.000	1476.036	5388.636	2589.235	.13731	.14987
105	17	3786.977	0.000	176.763	0.000	1476.036	5388.636	2589.235	.13731	.14987
	18	3786.977	0.000	546.078	0.000	1966.032	6319.027	2581.726	.16094	.18149
115	18	3786.977	0.000	451.396	0.000	2901.308	6239.682	2573.146	.15399	.16452
	19	3786.977	0.000	93.665	0.000	2505.683	6296.329	25807.443	.16269	.15275

CURVED MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (TI1)	MODIFIED ALLOWABLE STRESS (SIAM)	DESIGN STRESS RATIO TII/(SIAM+SA)	MODIFIED STRESS RATIO TII/(SIAM+SAM)
110	2	3786.977	0.000	44.479	0.000	1620.336	5451.793	25914.115	.13849	.13117
	3	3786.977	0.000	32.771	0.000	1226.222	5039.770	25829.594	.12039	.11911
120	6	4289.688	0.000	76.951	0.000	3213.572	7549.212	2585.619	.19311	.19176
	7	4289.688	0.000	206.555	0.000	2566.715	7060.955	2577.048	.17988	.18492
130	8	4289.688	0.000	193.791	0.000	3572.146	8058.626	2575.175	.17022	.18127
	9	4289.688	0.000	322.667	0.000	4014.545	8426.901	2575.175	.18127	.19232
140	12	3786.977	0.000	267.984	0.000	2227.145	6732.337	25875.921	.16304	.17412
	13	3786.977	0.000	263.742	0.000	2071.866	6102.256	25871.703	.15546	.16654
150	14	3786.977	0.000	183.743	0.000	907.909	4478.720	2566.722	.12429	.13475
	15	3786.977	0.000	116.260	0.000	1192.949	5035.195	2583.160	.12923	.13811
160	17	3786.977	0.000	711.791	0.000	2681.454	7159.225	2572.761	.18292	.19391
	18	3786.977	0.000	604.911	0.000	2681.930	7073.615	25793.224	.18021	.18664

PIPED

STRAIGHT MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (TI1)	MODIFIED ALLOWABLE STRESS (SIAM)	DESIGN STRESS RATIO TII/(SIAM+SA)	MODIFIED STRESS RATIO TII/(SIAM+SAM)
125	23	3786.977	0.000	267.681	0.000	3127.200	7161.519	25479.455	.18245	.17146
	24	3786.977	0.000	52.259	0.000	1364.248	5733.468	25916.562	.14510	.14438
135	26	3786.977	0.000	78.769	0.000	1364.248	5733.468	25916.562	.14669	.14772
	27	3786.977	0.000	51.595	0.000	1724.372	5567.454	25816.432	.14194	.14315
145	29	3786.977	0.000	52.339	0.000	1642.595	5411.911	25715.549	.13665	.14119
	29	3786.977	0.000	116.741	0.000	2471.393	6375.111	25402.860	.16741	.16950
155	30	4289.688	0.000	324.281	0.000	12603.747	17117.723	25752.377	.43602	.41097
	30	4289.688	0.000	112.879	0.000	3201.135	7601.762	2575.334	.19371	.19256
165	29	4289.688	0.000	253.594	0.000	4420.829	9134.121	25773.427	.33799	.32395
	30	4289.688	0.000	75.173	0.000	2983.784	7328.245	25824.325	.18673	.18758
175	32	4289.688	0.000	112.879	0.000	3201.135	7603.762	2575.334	.19371	.19256
	31	4289.688	0.000	135.549	0.000	4277.143	8733.686	2575.334	.22792	.23033
185	32	4289.688	0.000	79.710	0.000	4376.400	8705.843	25824.127	.22029	.22733
	33	4289.688	0.000	101.365	0.000	2542.462	5033.516	25741.431	.17663	.18677
195	34	4289.688	0.000	50.190	0.000	3460.000	7833.728	25824.488	.19840	.19710
	35	4289.688	0.000	269.460	0.000	4130.463	8946.031	25763.194	.22134	.22458
205	36	4289.688	0.000	269.460	0.000	4130.463	8946.031	25763.194	.22134	.22458
	37	4289.688	0.000	29.733	0.000	2495.877	6005.293	25814.023	.17937	.18174
215	38	4289.688	0.000	51.623	0.000	2495.877	6005.293	25814.023	.17937	.18174
	39	4289.688	0.000	37.066	0.000	2495.877	6005.293	25814.023	.17937	.18174
225	40	4289.688	0.000	28.999	0.000	2309.537	6826.105	25714.100	.16885	.17645
	41	4289.688	0.000	117.393	0.000	1870.263	6277.274	25756.108	.15992	.16795
235	42	4289.688	0.000	117.762	0.000	2479.446	6810.938	25791.317	.17345	.18157
	43	4289.688	0.000	91.567	0.000	2850.447	7331.798	25821.425	.18423	.19342
245	44	4289.688	0.000	173.692	0.000	2621.265	7054.645	25734.232	.18048	.18996
	45	4289.688	0.000	206.497	0.000	2116.449	6012.834	25777.791	.16846	.18666

CURVED MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (TI1)	MODIFIED ALLOWABLE STRESS (SIAM)	DESIGN STRESS RATIO TII/(SIAM+SA)	MODIFIED STRESS RATIO TII/(SIAM+SAM)
250	25	3786.977	0.000	70.032	0.000	2474.254	6709.267	25912.436	.16190	.16136
	26	3786.977	0.000	100.567	0.000	2570.110	6449.590	25912.436	.18177	.18177
260	27	3786.977	0.000	69.021	0.000	2317.110	6179.956	25813.170	.14924	.14924
	28	3786.977	0.000	79.187	0.000	2701.724	6874.722	25813.170	.17424	.17424
270	31	4289.688	0.000	203.479	0.000	6474.376	10781.495	25727.744	.27421	.27421
	32	4289.688	0.000	119.731	0.000	6016.440	10274.773	25727.744	.17421	.17421
100	34	4289.688	0.000	101.161	0.000	7440.442	6884.710	25793.471	.17603	.18039
	35	4289.688	0.000	53.911	0.000	3440.210	7009.728	25813.170	.14924	.14924
110	36	4289.688	0.000	66.477	0.000	3117.110	6520.644	25713.170	.16714	.16714
	37	4289.688	0.000	77.723	0.000	2721.449	6064.795	25713.170	.18006	.18006
120	38	4289.688	0.000	117.741	0.000	4433.460	8935.877	25794.471	.21118	.21118
	40	4289.688	0.000	63.281	0.000	2464.879	7247.747	25813.170	.14924	.14924

130	41	4779.648	0.000	175.511	0.000	2717.432	7267.873	25771.649	1.18502	1.17434
	42	4279.648	0.000	176.151	0.000	3718.761	8174.305	25771.649	1.22126	1.19112
140	43	4779.648	0.000	176.890	0.000	4294.088	8670.667	25771.649	1.22148	1.20449
	44	4279.648	0.000	259.611	0.000	3921.333	8470.546	25765.710	1.21579	1.20330

STRAIGHT MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T11)	MODIFIED ALLOWABLE STRESS (S14M)	DESIGN STRESS RATIO T11/(S14M)	MODIFIED STRESS RATIO T11/(S14M)
255	19	4672.441	0.000	307.849	0.000	821.379	5693.459	25673.175	1.16784	1.17459
	20	4672.441	0.000	501.713	0.000	877.508	8111.655	25679.734	1.16770	1.17427
265	19	4672.441	0.000	358.945	0.000	1615.045	6596.474	25679.732	1.15932	1.17031
	46	4672.441	0.000	173.080	0.000	1976.787	8302.247	25702.416	1.17199	1.17550
275	20	4672.441	0.000	561.713	0.000	877.508	6111.655	25679.734	1.15976	1.17229
	21	4672.441	0.000	321.249	0.000	1072.761	5051.442	25678.179	1.16416	1.16707
285	21	4672.441	0.000	321.249	0.000	1072.761	6051.442	25678.179	1.16416	1.16707
	22	4672.441	0.000	203.255	0.000	1227.206	6161.442	25679.426	1.15702	1.16117
295	22	4672.441	0.000	203.255	0.000	1227.206	6161.442	25679.426	1.15702	1.16117
	23	4672.441	0.000	151.797	0.000	1770.539	6504.714	25737.141	1.16100	1.16410
305	23	4672.441	0.000	151.797	0.000	1770.539	6504.714	25737.141	1.16100	1.16410
	24	4672.441	0.000	5.164	0.000	4003	4672.441	25739.514	1.11803	1.11721
315	47	4672.441	0.000	262.412	0.000	1971.569	6826.432	25671.115	1.17791	1.16416
	48	4672.441	0.000	175.441	0.000	1944.501	6445.453	25712.715	1.16420	1.17499
325	49	4672.441	0.000	131.401	0.000	1324.456	6121.378	25711.675	1.15612	1.17277
	50	4672.441	0.000	139.591	0.000	708.419	5521.497	25731.711	1.16764	1.17607
335	50	4672.441	0.000	139.591	0.000	708.419	5521.497	25731.711	1.16764	1.17607
	51	4672.441	0.000	152.957	0.000	2475.573	7261.227	25737.036	1.18491	1.17451
345	52	4672.441	0.000	133.851	0.000	2674.728	7455.241	25711.124	1.19491	1.17915
	53	4672.441	0.000	212.447	0.000	6637.793	11172.742	25141.348	1.36125	1.16737
355	53	4672.441	0.000	2799.057	0.000	6203.179	17765.556	25144.733	1.35668	1.16116
	54	4672.441	0.000	1072.261	0.000	2056.059	7742.791	25532.146	1.19552	1.18112
365	54	4672.441	0.000	1072.261	0.000	2056.059	7742.791	25532.146	1.19552	1.18112
	55	4672.441	0.000	412.407	0.000	2317.513	7452.403	25661.311	1.18945	1.17915
375	56	4672.441	0.000	319.705	0.000	1821.469	6824.581	25663.974	1.17346	1.16417
	57	4672.441	0.000	445.697	0.000	1464.933	6573.282	25644.564	1.16771	1.15746
385	57	5541.562	0.000	427.365	0.000	1671.282	7650.269	25761.613	1.19077	1.18059
	59	5541.562	0.000	529.143	0.000	2516.194	8584.603	25743.415	1.21407	1.20275

CURVED MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T11)	MODIFIED ALLOWABLE STRESS (S14M)	DESIGN STRESS RATIO T11/(S14M)	MODIFIED STRESS RATIO T11/(S14M)
150	46	4672.441	0.000	173.080	0.000	1976.787	6802.247	25732.416	1.17329	1.16250
	47	4672.441	0.000	262.412	0.000	1911.533	6826.432	25671.115	1.17191	1.16416
160	48	4672.441	0.000	159.519	0.000	2583.746	7425.745	25697.290	1.16117	1.17157
	49	4672.441	0.000	204.852	0.000	2356.748	6933.291	25696.237	1.17661	1.16768
170	51	4672.441	0.000	237.521	0.000	3712.231	8692.234	25559.125	1.22144	1.21000
	52	4672.441	0.000	206.611	0.000	4161.316	9043.416	25695.692	1.23231	1.21734

180	58	4672.441	0.000	412.407	0.000	2367.513	7452.403	25661.311	1.19115	1.17915
	59	4672.441	0.000	330.700	0.000	1821.400	6824.561	25661.324	1.17386	1.16417

STRAIGHT MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T11)	MODIFIED ALLOWABLE STRESS (S14M)	DESIGN STRESS RATIO T11/(S14M)	MODIFIED STRESS RATIO T11/(S14M)
395	59	5886.562	0.000	529.143	0.000	2516.194	8979.609	25667.513	1.22267	1.21127
	60	5886.562	0.000	87.391	0.000	2572.275	8546.199	25761.543	1.21311	1.20175
405	60	5886.562	0.000	87.391	0.000	2572.275	8546.199	25761.543	1.21311	1.20175
	61	5886.562	0.000	72.523	0.000	3422.434	9361.570	25781.634	1.23244	1.22148
415	62	5886.562	0.000	85.261	0.000	3611.690	9655.319	25760.392	1.23902	1.22628
	63	5886.562	0.000	86.550	0.000	3955.873	9464.968	25763.714	1.21662	1.21409
425	64	5886.562	0.000	78.844	0.000	3349.010	9114.423	25762.181	1.23227	1.21988
	65	5886.562	0.000	324.582	0.000	3155.027	9366.172	25719.132	1.23156	1.22137

CURVED MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T11)	MODIFIED ALLOWABLE STRESS (S14M)	DESIGN STRESS RATIO T11/(S14M)	MODIFIED STRESS RATIO T11/(S14M)
190	61	5886.562	0.000	128.138	0.000	6011.678	12026.377	25721.375	1.29389	1.21164
	62	5886.562	0.000	155.598	0.000	6379.546	12421.706	25741.841	1.30475	1.21714
200	63	5886.562	0.000	152.991	0.000	6212.013	12251.502	25746.417	1.30550	1.21431
	64	5886.562	0.000	139.305	0.000	5917.207	11943.675	25743.503	1.29761	1.21201

LACBWR FEED WATER + CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

STRAIGHT MEMBERS FOR RUN 5

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (ML)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T11)	MODIFIED ALLOWABLE STRESS (SAM)	DESIGN STRESS RATIO T11/(SH+SA)	MODIFIED STRESS RATIO T11/(SH+SAM)
435	53	4289.658	0.000	3309.899	0.000	2670.015	10070.352	25173.444	.25527	.24194
445	56	4289.658	0.000	1757.462	0.000	1775.647	7622.797	27447.451	.19929	.18970
455	67	4289.658	0.000	1627.354	0.000	1272.713	7390.733	25433.746	.18101	.17493
465	69	4289.658	0.000	1375.761	0.000	1244.395	7157.979	25475.123	.15785	.15373
475	71	4289.658	0.000	1245.264	0.000	847.691	6515.146	25531.166	.16568	.15770
485	72	4289.658	0.000	1534.361	0.000	804.130	6174.023	25447.423	.18751	.15191
495	74	4289.658	0.000	1202.035	0.000	1007.767	7639.819	25434.379	.17111	.16335
505	75	4289.658	0.000	1174.475	0.000	1205.739	6677.517	25557.618	.17062	.16152
515	77	4289.658	0.000	468.297	0.000	1205.739	6677.517	25557.618	.17043	.15113
525	78	4289.658	0.000	468.297	0.000	2010.772	6743.765	24721.428	.17244	.16263
535	79	4289.658	0.000	1019.754	0.000	2010.772	6743.765	24721.428	.17244	.16263
545	81	4289.658	0.000	841.441	0.000	1926.351	7157.749	25591.994	.18230	.17243
555	82	4289.658	0.000	618.282	0.000	2291.345	7243.461	25633.434	.18568	.17415
565	83	4289.658	0.000	1273.425	0.000	2133.966	7041.937	24639.656	.17340	.16372
575	84	4289.658	0.000	229.371	0.000	759.954	6231.129	25561.421	.16074	.15170
585	85	4289.658	0.000	308.775	0.000	621.443	5121.083	25772.733	.13746	.12789
595	86	4289.658	0.000	468.281	0.000	558.734	5207.168	25742.476	.13270	.12509
605	87	4289.658	0.000	357.486	0.000	522.236	5249.205	24721.432	.13451	.12686
615	88	4289.658	0.000	1448.721	0.000	504.577	5151.662	25745.318	.13124	.12370
625	89	4289.658	0.000	1448.721	0.000	512.143	6271.165	25584.799	.15074	.15145
635	90	4289.658	0.000	1705.811	0.000	512.143	6271.165	25584.799	.17972	.15243
645	91	4289.658	0.000	1705.811	0.000	546.113	6541.311	25459.744	.18169	.15121
655	92	4289.658	0.000	1317.161	0.000	438.811	6047.861	25453.577	.15624	.14715
665	93	4289.658	0.000	505.725	0.000	476.143	5271.560	25711.474	.13429	.12415
675	94	4289.658	0.000	1633.837	0.000	524.592	6443.119	25711.474	.16427	.15045
685	95	4289.658	0.000	474.051	0.000	1455.451	6219.219	25721.751	.15444	.14461
695	96	4289.658	0.000	325.151	0.000	426.339	5441.077	25751.247	.13341	.12743
705	97	4289.658	0.000	210.867	0.000	418.375	5318.331	25771.119	.13501	.12763
715	98	4289.658	0.000	210.867	0.000	418.375	5318.331	25771.119	.13501	.12763
725	99	4289.658	0.000	201.136	0.000	418.375	5318.331	25771.119	.13501	.12763
735	100	4289.658	0.000	229.665	0.000	418.375	5318.331	25771.119	.13501	.12763
745	101	4289.658	0.000	353.011	0.000	2247.703	6834.408	24745.376	.17548	.16543
755	102	4289.658	0.000	493.625	0.000	2247.703	6834.408	24745.376	.17548	.16543
765	103	4289.658	0.000	493.625	0.000	2247.703	6834.408	24745.376	.17548	.16543
775	104	4289.658	0.000	674.577	0.000	2247.703	6834.408	24745.376	.17548	.16543
785	105	4289.658	0.000	342.215	0.000	3577.146	8576.447	25677.157	.21254	.20021
795	106	4289.658	0.000	201.591	0.000	342.215	6114.601	24741.235	.20272	.19444
805	107	4289.658	0.000	790.174	0.000	3027.173	7518.910	24773.121	.19195	.18043
815	108	4289.658	0.000	603.793	0.000	2746.277	7426.139	25651.079	.19977	.18974
825	109	4289.658	0.000	173.554	0.000	499.873	5453.697	24771.270	.13516	.13078
835	110	4289.658	0.000	173.554	0.000	499.873	5453.697	24771.270	.13516	.13078
845	111	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
855	112	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
865	113	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
875	114	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
885	115	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
895	116	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
905	117	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
915	118	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
925	119	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
935	120	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
945	121	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
955	122	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
965	123	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
975	124	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
985	125	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
995	126	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1005	127	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1015	128	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1025	129	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1035	130	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1045	131	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1055	132	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1065	133	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1075	134	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1085	135	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1095	136	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1105	137	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1115	138	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1125	139	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1135	140	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1145	141	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1155	142	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1165	143	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1175	144	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1185	145	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1195	146	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1205	147	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1215	148	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1225	149	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1235	150	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1245	151	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1255	152	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1265	153	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1275	154	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1285	155	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1295	156	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1305	157	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1315	158	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1325	159	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1335	160	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1345	161	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1355	162	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1365	163	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1375	164	4289.658	0.000	117.293	0.000	1462.663	5982.014	24772.137	.15239	.14275
1385	165</									

LIGNITE FED WATER + CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

D.2 CLASS 2 STRESSES FOR ANALYSIS SET NUMBER 2.

ASSIGNED LOAD COMBINATION IDENTIFIERS
M1 = 1 M2 = 2 M3 = 4 P = 1 PMAX = 2

D.2.1 SATISFACTION OF EQUATION 9 (ANALYSIS SET 2)

STRAIGHT MEMBERS FOR RUN 1

Table with 11 columns: MEMBER NO., MEMBER ENDS, INTERNAL PRESSURE STRESS (PSI), PEAK PRESSURE STRESS (PSI MAX), SUSTAINED LOAD STRESS (PSI), OCCASIONAL LOAD STRESS (PSI), THERMAL EXPANSION STRESS (PSI), TOTAL STRESS (PSI), MODIFIED ALLOWABLE STRESS (PSI), UPSET STRESS RATIO, EMERGENCY STRESS RATIO. Rows include members 15, 25, 35, 45, 55, 65, 75, 85, 95, 105, 115.

CURVED MEMBERS FOR RUN 1

Table with 11 columns: MEMBER NO., MEMBER ENDS, INTERNAL PRESSURE STRESS (PSI), PEAK PRESSURE STRESS (PSI MAX), SUSTAINED LOAD STRESS (PSI), OCCASIONAL LOAD STRESS (PSI), THERMAL EXPANSION STRESS (PSI), TOTAL STRESS (PSI), MODIFIED ALLOWABLE STRESS (PSI), UPSET STRESS RATIO, EMERGENCY STRESS RATIO. Rows include members 10, 20, 30.

Table with 11 columns: MEMBER NO., MEMBER ENDS, INTERNAL PRESSURE STRESS (PSI), PEAK PRESSURE STRESS (PSI MAX), SUSTAINED LOAD STRESS (PSI), OCCASIONAL LOAD STRESS (PSI), THERMAL EXPANSION STRESS (PSI), TOTAL STRESS (PSI), MODIFIED ALLOWABLE STRESS (PSI), UPSET STRESS RATIO, EMERGENCY STRESS RATIO. Rows include members 10, 20, 30.

STRAIGHT MEMBERS FOR RUN 2

Table with 11 columns: MEMBER NO., MEMBER ENDS, INTERNAL PRESSURE STRESS (PSI), PEAK PRESSURE STRESS (PSI MAX), SUSTAINED LOAD STRESS (PSI), OCCASIONAL LOAD STRESS (PSI), THERMAL EXPANSION STRESS (PSI), TOTAL STRESS (PSI), MODIFIED ALLOWABLE STRESS (PSI), UPSET STRESS RATIO, EMERGENCY STRESS RATIO. Rows include members 125, 135, 145, 155, 165, 175, 185, 195, 205, 215, 225, 235, 245.

CURVED MEMBERS FOR RUN 2

Table with 11 columns: MEMBER NO., MEMBER ENDS, INTERNAL PRESSURE STRESS (PSI), PEAK PRESSURE STRESS (PSI MAX), SUSTAINED LOAD STRESS (PSI), OCCASIONAL LOAD STRESS (PSI), THERMAL EXPANSION STRESS (PSI), TOTAL STRESS (PSI), MODIFIED ALLOWABLE STRESS (PSI), UPSET STRESS RATIO, EMERGENCY STRESS RATIO. Rows include members 70, 80, 90.

10C	33	0.000	4673.591	181.366	123.458	0.000	4674.434	0.000	26704	1.0174
	34	0.000	4673.591	51.397	163.231	0.000	4673.511	0.000	26659	1.0156
11C	36	0.000	4673.591	44.471	205.252	0.000	4673.319	0.000	26604	1.0137
	37	0.000	4673.591	77.201	244.142	0.000	4674.553	0.000	26179	1.0153
12C	39	0.000	4673.591	112.741	477.371	0.000	5263.709	0.000	27968	1.0132
	40	0.000	4673.591	43.230	425.941	0.000	5122.762	0.000	26649	1.0133
13C	41	0.000	4673.591	176.517	344.791	0.000	5247.859	0.000	27765	1.0135
	42	0.000	4673.591	176.151	421.254	0.000	5278.600	0.000	27675	1.0141
14C	43	0.000	4673.591	136.896	444.339	0.000	5249.679	0.000	27567	1.0178
	44	0.000	4673.591	259.216	461.462	0.000	5394.811	0.000	28275	1.0259

STRAIGHT MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SA)	UPSET STRESS RATIO T9/(1.2*SA)	EMERGENCY STRESS RATIO T9/(1.6*SA)
255	19	0.000	5070.641	309.049	461.445	0.000	5891.134	0.000	1.0713	1.2079
	20	0.000	5070.641	561.713	453.429	0.000	6195.720	0.000	1.1701	1.2174
265	19	0.000	5070.641	378.049	553.567	0.000	6005.253	0.000	1.1474	1.2063
	46	0.000	5070.641	173.000	484.153	0.000	5747.799	0.000	1.1224	1.2043
275	20	0.000	5070.641	561.713	453.425	0.000	6125.780	0.000	1.1271	1.2132
285	21	0.000	5070.641	321.249	202.225	0.000	5664.115	0.000	1.0656	1.1791
	22	0.000	5070.641	321.249	252.225	0.000	5664.115	0.000	1.0656	1.1791
295	22	0.000	5070.641	203.255	167.458	0.000	5451.354	0.000	1.0423	1.1512
	23	0.000	5070.641	151.797	134.057	0.000	5426.495	0.000	1.0441	1.1541
305	23	0.000	5070.641	5.164	.000	0.000	5070.641	0.000	1.0000	1.1225
	24	0.000	5070.641	.000	.000	0.000	5070.641	0.000	1.0000	1.1225
315	47	0.000	5070.641	262.412	524.327	0.000	5377.300	0.000	1.0707	1.2038
	48	0.000	5070.641	128.481	613.757	0.000	5833.879	0.000	1.1667	1.2481
325	49	0.000	5070.641	151.401	603.718	0.000	5833.760	0.000	1.1660	1.2473
	50	0.000	5070.641	131.593	426.667	0.000	5676.904	0.000	1.1268	1.1974
335	50	0.000	5070.641	173.597	424.667	0.000	5656.904	0.000	1.1248	1.1966
	51	0.000	5070.641	152.957	446.171	0.000	5739.665	0.000	1.1377	1.2051
345	52	0.000	5070.641	133.951	523.679	0.000	5751.342	0.000	1.1374	1.2051
	53	0.000	5070.641	212.467	1473.416	0.000	9374.924	0.000	4.3145	3.7744
355	54	0.000	5070.641	2793.031	2577.762	0.000	10417.639	0.000	5.4400	3.6400
	55	0.000	5070.641	1022.261	785.225	0.000	6693.121	0.000	1.3159	1.2416
365	54	0.000	5070.641	412.401	511.011	0.000	6014.061	0.000	1.1520	1.2113
	55	0.000	5070.641	445.807	603.359	0.000	6235.409	0.000	1.1643	1.2187
375	56	0.000	5070.641	320.700	484.160	0.000	6014.061	0.000	1.1520	1.2113
	57	0.000	5070.641	445.807	603.359	0.000	6235.409	0.000	1.1643	1.2187
385	57	0.000	6037.500	427.366	602.402	0.000	7267.356	0.000	1.2643	1.2722
	59	0.000	6037.500	525.141	1111.400	0.000	7674.051	0.000	1.3524	1.2563

CURVED MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SA)	UPSET STRESS RATIO T9/(1.2*SA)	EMERGENCY STRESS RATIO T9/(1.6*SA)
150	46	0.000	5070.641	173.000	434.159	0.000	5747.799	0.000	1.1225	1.2033
	47	0.000	5070.641	262.412	524.327	0.000	5877.420	0.000	1.1707	1.2481
160	46	0.000	5070.641	199.511	462.420	0.000	6252.510	0.000	1.1370	1.2167
	49	0.000	5070.641	204.051	445.275	0.000	6237.871	0.000	1.1355	1.2153
170	51	0.000	5070.641	237.527	764.791	0.000	6076.659	0.000	1.1485	1.2131
	52	0.000	5070.641	206.611	624.493	0.000	6119.740	0.000	1.1520	1.2183
180	56	0.000	5070.641	412.401	511.011	0.000	6014.061	0.000	1.1520	1.2113
	58	0.000	5070.641	330.700	484.160	0.000	5905.401	0.000	1.1391	1.2034

STRAIGHT MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SA)	UPSET STRESS RATIO T9/(1.2*SA)	EMERGENCY STRESS RATIO T9/(1.6*SA)
395	59	0.000	6000.000	525.141	1111.400	0.000	6536.551	0.000	1.2674	1.2809
	60	0.000	6000.000	67.361	671.691	0.000	7321.242	0.000	1.3243	1.2616
405	60	0.000	6000.000	67.361	671.691	0.000	7321.242	0.000	1.3243	1.2616
	61	0.000	6000.000	72.527	447.117	0.000	7400.641	0.000	1.3494	1.2499
415	62	0.000	6000.000	86.361	492.759	0.000	7450.824	0.000	1.3704	1.2534
	63	0.000	6000.000	86.361	522.770	0.000	7504.321	0.000	1.3897	1.2592
425	64	0.000	6000.000	78.444	604.354	0.000	7543.138	0.000	1.4004	1.2709
	65	0.000	6000.000	324.561	730.703	0.000	7955.375	0.000	1.5037	1.2624

CURVED MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T)	MODIFIED ALLOWABLE STRESS (SA)	UPSET STRESS RATIO T9/(1.2*SA)	EMERGENCY STRESS RATIO T9/(1.6*SA)
190	61	0.000	6000.000	128.134	474.339	0.000	7066.444	0.000	1.3161	1.2651
	62	0.000	6000.000	155.088	673.011	0.000	7476.774	0.000	1.3704	1.2617
200	63	0.000	6000.000	152.921	671.697	0.000	7376.076	0.000	1.3543	1.2635
	64	0.000	6000.000	139.301	1007.800	0.000	8107.107	0.000	1.4684	1.2732

LAGNER FEED WATER * CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

STRAIGHT MEMBERS FOR RUN 5

MEMBER NO.	MEMBER END 1	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PSIA)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MS)	THERMAL EXPANSION STRESS (MPC)	TOTAL STRESS (TS)	MODIFIED ALLOWABLE STRESS (SMA)	UPSET STRESS RATIO T ₃ /((1.2)*SM)	EMERGENCY STRESS RATIO T ₅ /((1.5)*SM)
435	53	0.000	4677.591	3268.849	6377.511	0.000	14067.790	0.000	.27371	.14964
445	66	0.000	4677.591	1757.462	3717.252	0.000	10224.304	0.000	.45007	.24738
455	67	0.000	4677.591	1767.024	2107.347	0.000	8573.558	0.000	.44495	.24067
465	66	0.000	4677.591	1627.357	2203.921	0.000	8330.266	0.000	.44663	.24000
475	73	0.000	4677.591	1377.764	2215.017	0.000	8266.374	0.000	.43325	.23883
485	68	0.000	4677.591	1285.204	1957.655	0.000	7918.510	0.000	.41502	.22663
495	69	0.000	4677.591	1478.167	2041.711	0.000	8291.667	0.000	.43454	.23879
485	71	0.000	4677.591	1202.035	2001.451	0.000	8379.431	0.000	.43117	.23278
485	71	0.000	4677.591	1174.675	2500.262	0.000	8344.351	0.000	.43259	.23940
485	71	0.000	4677.591	464.257	1461.074	0.000	6472.982	0.000	.33855	.21770
485	72	0.000	4677.591	469.297	1065.903	0.000	6207.790	0.000	.32136	.21090
495	72	0.000	4677.591	1074.750	1341.637	0.000	7056.578	0.000	.36336	.24456
495	107	0.000	4677.591	661.445	1703.114	0.000	6435.150	0.000	.36775	.23144
505	74	0.000	4677.591	615.287	1673.221	0.000	6402.043	0.000	.36122	.24751
515	75	0.000	4677.591	1203.407	1774.972	0.000	7651.368	0.000	.40178	.24759
515	76	0.000	4677.591	229.877	643.198	0.000	5591.645	0.000	.29317	.19545
525	77	0.000	4677.591	303.777	758.317	0.000	5830.663	0.000	.31559	.20173
525	78	0.000	4677.591	463.204	813.911	0.000	5955.761	0.000	.31215	.20110
535	79	0.000	4677.591	377.284	856.750	0.000	5837.676	0.000	.30546	.20107
545	81	0.000	4677.591	1467.094	924.140	0.000	7129.473	0.000	.37388	.24012
545	81	0.000	4677.591	1706.811	1378.744	0.000	7127.447	0.000	.37106	.24411
545	81	0.000	4677.591	1705.811	748.676	0.000	7771.163	0.000	.36116	.24007
555	82	0.000	4677.591	1319.361	709.323	0.000	7127.077	0.000	.37304	.24302
555	83	0.000	4677.591	595.721	781.301	0.000	6701.275	0.000	.35122	.23415
565	84	0.000	4677.591	1531.932	902.527	0.000	5949.620	0.000	.31204	.23027
565	84	0.000	4677.591	474.040	1678.154	0.000	7771.935	0.000	.37785	.24192
575	85	0.000	4677.591	325.150	1521.932	0.000	7771.935	0.000	.35502	.23664
575	85	0.000	4677.591	325.150	1521.932	0.000	6650.872	0.000	.34518	.23163
585	86	0.000	4677.591	210.557	938.947	0.000	5823.447	0.000	.30121	.20747
585	86	0.000	4677.591	210.557	938.947	0.000	5823.440	0.000	.30117	.21147
595	87	0.000	4677.591	201.136	1127.277	0.000	5937.003	0.000	.31431	.20854
595	87	0.000	4677.591	223.561	945.372	0.000	5849.627	0.000	.30445	.20445
605	88	0.000	4677.591	353.013	1705.820	0.000	6732.421	0.000	.35244	.24023
615	89	0.000	4677.591	443.621	1280.135	0.000	6447.355	0.000	.33701	.23523
615	89	0.000	4677.591	443.621	1280.135	0.000	5447.355	0.000	.31711	.20727
625	90	0.000	4677.591	623.571	731.324	0.000	6074.358	0.000	.31627	.21457
625	91	0.000	4677.591	342.211	975.305	0.000	5972.117	0.000	.31100	.20517
635	92	0.000	4677.591	201.508	1388.735	0.000	6273.674	0.000	.32472	.21741
635	92	0.000	4677.591	790.174	1344.014	0.000	6849.783	0.000	.35000	.23914
645	93	0.000	4677.591	603.793	2126.021	0.000	7424.004	0.000	.38805	.26570
645	94	0.000	4125.890	123.554	444.911	0.000	4744.356	0.000	.24864	.16877
645	95	0.000	4125.890	117.293	367.067	0.000	4610.280	0.000	.24163	.16108

655	96	0.000	4125.890	464.222	572.634	0.000	5162.745	0.000	.27591	.14439
665	97	0.000	4125.890	681.391	1524.441	0.000	6712.720	0.000	.33046	.22057
665	97	0.000	4125.890	681.391	1524.441	0.000	6712.720	0.000	.33046	.22057
675	98	0.000	4125.890	121.741	687.723	0.000	4494.659	0.000	.29583	.17172
675	98	0.000	4125.890	517.127	733.313	0.000	5447.027	0.000	.28522	.19015
685	100	0.000	4125.890	1740.171	676.250	0.000	8002.510	0.000	.31460	.20973
685	101	0.000	4125.890	1240.171	625.750	0.000	8002.510	0.000	.31460	.20973
695	101	0.000	4125.890	445.610	711.242	0.000	4810.742	0.000	.29014	.18459
695	101	0.000	4125.890	445.610	711.242	0.000	4810.742	0.000	.29014	.18459
705	103	0.000	4125.890	245.461	895.024	0.000	5269.550	0.000	.27618	.18412
705	103	0.000	4125.890	499.587	1005.052	0.000	6535.627	0.000	.34228	.22418
715	105	0.000	4125.890	494.271	1844.101	0.000	6973.261	0.000	.34451	.22947
725	106	0.000	4677.591	201.508	1354.735	0.000	6232.334	0.000	.32672	.21711
725	106	0.000	4677.591	790.174	1346.014	0.000	6849.783	0.000	.35000	.23914
735	107	0.000	4677.591	201.136	1127.277	0.000	5937.003	0.000	.31431	.20854
735	107	0.000	4677.591	223.561	945.372	0.000	5849.627	0.000	.30445	.20445
745	84	0.000	4677.591	518.287	1670.211	0.000	6892.083	0.000	.36122	.24031
745	84	0.000	4677.591	474.061	1626.154	0.000	6773.625	0.000	.35502	.23664

CURVED MEMBERS FOR RUN 5

MEMBER NO.	MEMBER END 1	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PSIA)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MS)	THERMAL EXPANSION STRESS (MPC)	TOTAL STRESS (TS)	MODIFIED ALLOWABLE STRESS (SMA)	UPSET STRESS RATIO T ₃ /((1.2)*SM)	EMERGENCY STRESS RATIO T ₅ /((1.5)*SM)
210	67	0.000	4677.591	2474.292	1876.473	0.000	10144.355	0.000	.51187	.34600
220	65	0.000	4677.591	2301.173	2113.846	0.000	10043.710	0.000	.52076	.34751
230	74	0.000	4677.591	1922.073	2471.189	0.000	9587.029	0.000	.48035	.31790
230	75	0.000	4677.591	1803.720	2075.076	0.000	9156.703	0.000	.47459	.31055
240	76	0.000	4677.591	343.662	1370.479	0.000	6049.891	0.000	.31705	.21139
240	77	0.000	4677.591	551.437	1171.211	0.000	6434.437	0.000	.31564	.22187
250	78	0.000	4677.591	700.481	1277.495	0.000	6731.578	0.000	.31647	.22101
250	82	0.000	4677.591	534.449	1066.743	0.000	6444.227	0.000	.31471	.21414
260	83	0.000	4677.591	1873.671	1073.851	0.000	7706.718	0.000	.40392	.26704
260	89	0.000	4677.591	324.449	1341.717	0.000	6078.054	0.000	.30885	.21907
270	91	0.000	4677.591	403.070	771.205	0.000	6274.783	0.000	.31077	.22136
270	94	0.000	4677.591	342.211	975.104	0.000	5972.117	0.000	.31100	.20517
280	95	0.000	4677.591	342.211	975.104	0.000	5972.117	0.000	.31100	.20517
290	96	0.000	4125.890	464.222	572.634	0.000	4744.356	0.000	.24864	.16877
290	96	0.000	4125.890	121.741	687.723	0.000	4494.659	0.000	.29583	.17172
300	99	0.000	4125.890	517.127	733.313	0.000	5447.027	0.000	.28522	.19015
300	103	0.000	4125.890	1740.171	676.250	0.000	8002.510	0.000	.31460	.20973
300	103	0.000	4125.890	1240.171	625.750	0.000	8002.510	0.000	.31460	.20973

D.2.2 SATISFACTION OF EQUATION 10 (ANALYSIS SET 2)

STRAIGHT MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T10/(1.0*SA)	MODIFIED STRESS RATIO
15	1	0.000	0.000	0.000	0.000	3432.578	3432.578	0.000		.10411
25	2	0.000	0.000	0.000	0.000	1216.449	1216.449	0.000		.05209
35	11	0.000	0.000	0.000	0.000	11170.547	11170.547	0.000		.47502
45	1	0.000	0.000	0.000	0.000	2492.552	2492.552	0.000		.12346
55	12	0.000	0.000	0.000	0.000	2106.190	2106.190	0.000		.09019
65	3	0.000	0.000	0.000	0.000	3678.670	3678.670	0.000		.14541
75	4	0.000	0.000	0.000	0.000	2724.741	2724.741	0.000		.11743
85	6	0.000	0.000	0.000	0.000	2723.741	2723.741	0.000		.11651
95	7	0.000	0.000	0.000	0.000	3224.325	3224.325	0.000		.13306
105	14	0.000	0.000	0.000	0.000	2542.854	2542.854	0.000		.10083
115	9	0.000	0.000	0.000	0.000	2366.531	2366.531	0.000		.10133
125	13	0.000	0.000	0.000	0.000	2654.455	2654.455	0.000		.11281
135	10	0.000	0.000	0.000	0.000	2719.749	2719.749	0.000		.11646
145	15	0.000	0.000	0.000	0.000	3218.594	3218.594	0.000		.14126
155	16	0.000	0.000	0.000	0.000	2229.963	2229.963	0.000		.09549
165	17	0.000	0.000	0.000	0.000	2732.287	2732.287	0.000		.11000
175	18	0.000	0.000	0.000	0.000	2732.444	2732.444	0.000		.11700
185	19	0.000	0.000	0.000	0.000	3444.961	3444.961	0.000		.14940
195	19	0.000	0.000	0.000	0.000	3430.572	3430.572	0.000		.14699
205	19	0.000	0.000	0.000	0.000	3778.042	3778.042	0.000		.16177

CURVED MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T10/(1.0*SA)	MODIFIED STRESS RATIO
10	2	0.000	0.000	0.000	0.000	1670.202	1670.202	0.000		.05948
20	6	0.000	0.000	0.000	0.000	1223.117	1223.117	0.000		.05160
30	7	0.000	0.000	0.000	0.000	3224.325	3224.325	0.000		.13406
40	8	0.000	0.000	0.000	0.000	2542.854	2542.854	0.000		.10088
50	9	0.000	0.000	0.000	0.000	3539.993	3539.993	0.000		.15158
60	12	0.000	0.000	0.000	0.000	3976.670	3976.670	0.000		.17128
70	13	0.000	0.000	0.000	0.000	4594.720	4594.720	0.000		.18674
80	14	0.000	0.000	0.000	0.000	4420.943	4420.943	0.000		.18039
90	15	0.000	0.000	0.000	0.000	2229.963	2229.963	0.000		.09549
100	17	0.000	0.000	0.000	0.000	2522.257	2522.257	0.000		.10100
110	18	0.000	0.000	0.000	0.000	4675.543	4675.543	0.000		.20021
120	18	0.000	0.000	0.000	0.000	4597.269	4597.269	0.000		.19645

PIPES

STRAIGHT MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T10/(1.0*SA)	MODIFIED STRESS RATIO
125	23	0.000	0.000	0.000	0.000	4327.222	4327.222	0.000		.18529
135	25	0.000	0.000	0.000	0.000	3119.345	3119.345	0.000		.13257
145	27	0.000	0.000	0.000	0.000	3171.022	3171.022	0.000		.13547
155	28	0.000	0.000	0.000	0.000	2497.591	2497.591	0.000		.12407
165	29	0.000	0.000	0.000	0.000	2753.416	2753.416	0.000		.11777
175	30	0.000	0.000	0.000	0.000	3420.677	3420.677	0.000		.16395
185	31	0.000	0.000	0.000	0.000	17206.104	17206.104	0.000		.72120
195	32	0.000	0.000	0.000	0.000	4684.797	4684.797	0.000		.20067
205	33	0.000	0.000	0.000	0.000	5430.028	5430.028	0.000		.24464
215	34	0.000	0.000	0.000	0.000	3539.993	3539.993	0.000		.15158
225	35	0.000	0.000	0.000	0.000	4454.570	4454.570	0.000		.20363
235	36	0.000	0.000	0.000	0.000	6103.047	6103.047	0.000		.25919
245	37	0.000	0.000	0.000	0.000	6270.033	6270.033	0.000		.26229
255	38	0.000	0.000	0.000	0.000	7607.295	7607.295	0.000		.32543
265	39	0.000	0.000	0.000	0.000	4056.413	4056.413	0.000		.17370
275	40	0.000	0.000	0.000	0.000	4445.570	4445.570	0.000		.20344
285	41	0.000	0.000	0.000	0.000	4445.570	4445.570	0.000		.20344
295	42	0.000	0.000	0.000	0.000	2940.253	2940.253	0.000		.12741
305	43	0.000	0.000	0.000	0.000	2943.839	2943.839	0.000		.12751
315	44	0.000	0.000	0.000	0.000	3291.836	3291.836	0.000		.14001
325	45	0.000	0.000	0.000	0.000	2783.437	2783.437	0.000		.14106
335	46	0.000	0.000	0.000	0.000	2781.116	2781.116	0.000		.13919
345	47	0.000	0.000	0.000	0.000	3572.726	3572.726	0.000		.15527
355	48	0.000	0.000	0.000	0.000	4312.717	4312.717	0.000		.18094
365	49	0.000	0.000	0.000	0.000	4249.405	4249.405	0.000		.17467
375	49	0.000	0.000	0.000	0.000	3601.453	3601.453	0.000		.15421

CURVED MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T10/(1.0*SA)	MODIFIED STRESS RATIO
70	26	0.000	0.000	0.000	0.000	4140.194	4140.194	0.000		.17593
80	27	0.000	0.000	0.000	0.000	4200.876	4200.876	0.000		.18021
90	28	0.000	0.000	0.000	0.000	3447.395	3447.395	0.000		.15076
100	29	0.000	0.000	0.000	0.000	3447.395	3447.395	0.000		.15076
110	30	0.000	0.000	0.000	0.000	4200.876	4200.876	0.000		.18021
120	31	0.000	0.000	0.000	0.000	4200.876	4200.876	0.000		.18021
130	32	0.000	0.000	0.000	0.000	4200.876	4200.876	0.000		.18021
140	33	0.000	0.000	0.000	0.000	4200.876	4200.876	0.000		.18021
150	34	0.000	0.000	0.000	0.000	4200.876	4200.876	0.000		.18021
160	35	0.000	0.000	0.000	0.000	4200.876	4200.876	0.000		.18021
170	36	0.000	0.000	0.000	0.000	4200.876	4200.876	0.000		.18021
180	37	0.000	0.000	0.000	0.000	4200.876	4200.876	0.000		.18021
190	38	0.000	0.000	0.000	0.000	4200.876	4200.876	0.000		.18021
200	39	0.000	0.000	0.000	0.000	4200.876	4200.876	0.000		.18021
210	40	0.000	0.000	0.000	0.000	4200.876	4200.876	0.000		.18021

130	41	0.000	0.000	0.000	0.000	4130.216	4130.236	0.000	.17866
	42	0.010	0.000	0.000	0.000	5279.541	5231.581	0.100	.22136
140	43	0.000	0.000	0.001	0.000	6451.226	6451.226	0.100	.27624
	44	0.000	0.000	0.001	0.000	6356.599	6356.599	0.100	.27219

STRAIGHT MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (TI)	MODIFIED ALLOWABLE STRESS (SA)	DESIGN STRESS RATIO (TIO/(1.0*SA))	MODIFIED STRESS RATIO
255	19	0.000	0.000	0.000	0.000	1192.722	1192.722	0.300	.05107	
	20	0.000	0.000	0.000	0.000	1125.944	1125.944	0.300	.04621	
265	19	0.000	0.000	0.000	0.000	1551.355	1551.355	0.300	.06677	
	46	0.000	0.000	0.000	0.000	2467.615	2467.615	0.300	.10568	
275	20	0.000	0.000	0.000	0.000	1125.944	1125.944	0.300	.04721	
	21	0.000	0.000	0.000	0.000	1292.302	1292.302	0.300	.05534	
285	21	0.000	0.000	0.000	0.000	1292.302	1292.302	0.300	.05534	
	22	0.000	0.000	0.000	0.000	1666.144	1666.144	0.300	.07134	
295	22	0.000	0.000	0.000	0.000	1666.144	1666.144	0.300	.07134	
	23	0.000	0.000	0.000	0.000	2465.678	2465.678	0.300	.10568	
305	23	0.000	0.000	0.000	0.000	.000	.000	0.300	.00000	
	24	0.000	0.000	0.000	0.000	.000	.000	0.300	.00000	
315	47	0.000	0.000	0.000	0.000	2961.694	2961.694	0.300	.12602	
	48	0.000	0.000	0.000	0.000	3032.493	3032.493	0.300	.12985	
325	49	0.000	0.000	0.000	0.000	2633.270	2633.270	0.300	.11276	
	50	0.000	0.000	0.000	0.000	741.963	741.963	0.300	.03177	
335	50	0.000	0.000	0.000	0.000	741.963	741.963	0.300	.03177	
	51	0.000	0.000	0.000	0.000	3471.107	3471.107	0.300	.14492	
345	52	0.000	0.000	0.000	0.000	3436.347	3436.347	0.300	.14427	
	53	0.000	0.000	0.000	0.000	10704.040	10704.040	0.300	.45874	
355	53	0.000	0.000	0.000	0.000	10526.307	10526.307	0.300	.45077	
	54	0.000	0.000	0.000	0.000	3554.996	3554.996	0.300	.15222	
365	54	0.000	0.000	0.000	0.000	3554.996	3554.996	0.300	.15222	
	55	0.000	0.000	0.000	0.000	4192.134	4192.134	0.300	.17951	
375	56	0.000	0.000	0.000	0.000	3335.202	3335.202	0.300	.14261	
	57	0.000	0.000	0.000	0.000	2061.614	2061.614	0.300	.08525	
385	57	0.000	0.000	0.000	0.000	2365.967	2365.967	0.300	.10367	
	59	0.000	0.000	0.000	0.000	2843.552	2843.552	0.300	.12099	

CURVED MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (TI)	MODIFIED ALLOWABLE STRESS (SA)	DESIGN STRESS RATIO (TIO/(1.0*SA))	MODIFIED STRESS RATIO
150	46	0.000	0.000	0.000	0.000	2447.515	2447.515	0.300	.10567	
	47	0.000	0.000	0.000	0.000	2961.694	2961.694	0.300	.12602	
160	48	0.000	0.000	0.000	0.000	4709.159	4709.159	0.300	.20164	
	49	0.000	0.000	0.000	0.000	4019.236	4019.236	0.300	.17010	
170	51	0.000	0.000	0.000	0.000	5328.166	5328.166	0.300	.22115	
	52	0.000	0.000	0.000	0.000	5957.464	5957.464	0.300	.25510	

180	55	0.000	0.000	0.000	0.000	4192.134	4192.134	0.300	.17951
	56	0.000	0.000	0.000	0.000	3335.202	3335.202	0.300	.14261

STRAIGHT MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (TI)	MODIFIED ALLOWABLE STRESS (SA)	DESIGN STRESS RATIO (TIO/(1.0*SA))	MODIFIED STRESS RATIO
395	59	0.000	0.000	0.000	0.000	2843.552	2843.552	0.300	.12099	
	60	0.000	0.000	0.000	0.000	2919.016	2919.016	0.300	.12420	
405	60	0.000	0.000	0.000	0.000	2919.016	2919.016	0.300	.12420	
	61	0.000	0.000	0.000	0.000	4371.071	4371.071	0.300	.18429	
415	62	0.000	0.000	0.000	0.000	4617.946	4617.946	0.300	.19347	
	63	0.000	0.000	0.000	0.000	4595.678	4595.678	0.300	.19254	
425	64	0.000	0.000	0.000	0.000	4349.332	4349.332	0.300	.18526	
	65	0.000	0.000	0.000	0.000	3940.370	3940.370	0.300	.16766	

CURVED MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAK)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (TI)	MODIFIED ALLOWABLE STRESS (SA)	DESIGN STRESS RATIO (TIO/(1.0*SA))	MODIFIED STRESS RATIO
190	61	0.000	0.000	0.000	0.000	7652.738	7652.738	0.300	.30561	
	62	0.000	0.000	0.000	0.000	8282.994	8282.994	0.300	.33243	
200	63	0.000	0.000	0.000	0.000	8119.693	8119.693	0.300	.32548	
	64	0.000	0.000	0.000	0.000	7664.615	7664.615	0.300	.32697	

LACMWR FEED WATER + CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

STRAIGHT MEMBERS FOR RUN 5

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PSI MAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MA)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (T10)	DESIGN STRESS RATIO (T10/(1.0*SA))	MODIFIED STRESS RATIO
435	53	0.000	0.000	0.000	0.000	1749.337	1749.337	0.100	.07669	
	56	0.000	0.000	0.000	0.000	1109.617	1109.617	0.100	.04751	
445	57	0.000	0.000	0.000	0.000	968.677	968.677	0.100	.04149	
455	58	0.000	0.000	0.000	0.000	916.677	916.677	0.100	.03925	
	73	0.000	0.000	0.000	0.000	443.228	443.228	0.100	.01974	
465	64	0.000	0.000	0.000	0.000	444.922	444.922	0.100	.01905	
	69	0.000	0.000	0.000	0.000	673.677	673.677	0.100	.03741	
475	69	0.000	0.000	0.000	0.000	902.777	902.777	0.100	.03346	
	71	0.000	0.000	0.000	0.000	902.777	902.777	0.100	.03366	
485	71	0.000	0.000	0.000	0.000	1641.405	1641.405	0.100	.07024	
	72	0.000	0.000	0.000	0.000	1641.405	1641.405	0.100	.07323	
495	72	0.000	0.000	0.000	0.000	1486.124	1486.124	0.100	.05364	
	107	0.000	0.000	0.000	0.000	1002.093	1002.093	0.100	.05145	
505	74	0.000	0.000	0.000	0.000	1768.499	1768.499	0.100	.07573	
	75	0.000	0.000	0.000	0.000	444.704	444.704	0.100	.01901	
515	76	0.000	0.000	0.000	0.000	431.037	431.037	0.100	.02000	
	77	0.000	0.000	0.000	0.000	464.799	464.799	0.100	.01944	
525	78	0.000	0.000	0.000	0.000	438.634	438.634	0.100	.01978	
	79	0.000	0.000	0.000	0.000	417.612	417.612	0.100	.01788	
535	79	0.000	0.000	0.000	0.000	416.126	416.126	0.100	.01772	
	81	0.000	0.000	0.000	0.000	416.126	416.126	0.100	.01772	
545	81	0.000	0.000	0.000	0.100	424.636	424.636	0.100	.01815	
	82	0.000	0.000	0.000	0.000	424.636	424.636	0.100	.01818	
555	83	0.000	0.000	0.000	0.000	402.018	402.018	0.100	.01721	
	72	0.000	0.000	0.000	0.000	401.331	401.331	0.100	.01715	
565	84	0.000	0.000	0.000	0.100	442.337	442.337	0.100	.01944	
	85	0.000	0.000	0.000	0.000	1253.449	1253.449	0.100	.05447	
575	85	0.000	0.000	0.000	0.000	542.402	542.402	0.100	.02309	
	86	0.000	0.000	0.000	0.000	842.492	842.492	0.100	.03688	
585	86	0.000	0.000	0.000	0.000	911.444	911.444	0.100	.03703	
	106	0.000	0.000	0.000	0.000	911.444	911.444	0.100	.03703	
595	87	0.000	0.000	0.000	0.000	1017.345	1017.345	0.100	.04356	
	88	0.000	0.000	0.000	0.000	1398.428	1398.428	0.100	.05938	
605	88	0.000	0.000	0.000	0.000	2014.774	2014.774	0.100	.08627	
	89	0.000	0.000	0.000	0.000	2014.774	2014.774	0.100	.08627	
615	89	0.000	0.000	0.000	0.000	2605.681	2605.681	0.100	.11157	
	90	0.000	0.000	0.000	0.000	2605.681	2605.681	0.100	.11157	
625	91	0.000	0.000	0.000	0.000	3155.145	3155.145	0.100	.13110	
	105	0.000	0.000	0.000	0.000	2945.476	2945.476	0.100	.12744	
635	92	0.000	0.000	0.000	0.000	2587.044	2587.044	0.100	.11079	
	93	0.000	0.000	0.000	0.000	2472.073	2472.073	0.100	.10545	
645	94	0.000	0.000	0.000	0.000	3897.866	3897.866	0.100	.16691	
	95	0.000	0.000	0.000	0.000	1203.938	1203.938	0.100	.05155	
						1209.256	1209.256	0.100	.05178	

PIPESD

655	96	0.000	0.000	0.000	0.000	1115.014	1115.014	0.100	.04774	
	97	0.000	0.000	0.000	0.000	1204.095	1204.095	0.100	.05164	
665	97	0.000	0.000	0.000	0.000	1206.095	1206.095	0.100	.05184	
	98	0.000	0.000	0.000	0.000	1749.504	1749.504	0.100	.07474	
675	99	0.000	0.000	0.000	0.000	1509.659	1509.659	0.100	.06177	
	100	0.000	0.000	0.000	0.000	1997.606	1997.606	0.100	.08554	
685	100	0.000	0.000	0.000	0.000	1997.606	1997.606	0.100	.08554	
	101	0.000	0.000	0.000	0.000	2767.211	2767.211	0.100	.11444	
695	101	0.000	0.000	0.000	0.000	2767.211	2767.211	0.100	.11449	
	102	0.000	0.000	0.000	0.000	3556.321	3556.321	0.100	.15155	
705	103	0.000	0.000	0.000	0.000	2876.747	2876.747	0.100	.11429	
	104	0.000	0.000	0.000	0.000	3434.207	3434.207	0.100	.14418	
715	105	0.000	0.000	0.000	0.000	2597.384	2597.384	0.100	.11078	
	92	0.000	0.000	0.000	0.000	2472.073	2472.073	0.100	.10545	
725	106	0.000	0.000	0.000	0.000	1017.345	1017.345	0.100	.04356	
	87	0.000	0.000	0.000	0.000	1398.428	1398.428	0.100	.05938	
735	107	0.000	0.000	0.000	0.000	1768.499	1768.499	0.100	.07573	
	84	0.000	0.000	0.000	0.000	1253.449	1253.449	0.100	.05447	

CURVED MEMBERS FOR RUN 5

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PSI MAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MA)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T10)	MODIFIED ALLOWABLE STRESS (T10)	DESIGN STRESS RATIO (T10/(1.0*SA))	MODIFIED STRESS RATIO
210	67	0.000	0.000	0.000	0.000	1371.248	1371.248	0.100	.05870	
	68	0.000	0.000	0.000	0.000	1700.970	1700.970	0.100	.06986	
220	73	0.000	0.000	0.000	0.000	609.573	609.573	0.100	.02469	
	74	0.000	0.000	0.000	0.000	671.197	671.197	0.100	.02714	
230	75	0.000	0.000	0.000	0.000	719.673	719.673	0.100	.02942	
	76	0.000	0.000	0.000	0.000	674.525	674.525	0.100	.02774	
240	77	0.000	0.000	0.000	0.000	674.525	674.525	0.100	.02774	
	78	0.000	0.000	0.000	0.000	624.649	624.649	0.100	.02547	
250	82	0.000	0.000	0.000	0.100	651.250	651.250	0.100	.02675	
	83	0.000	0.000	0.000	0.000	602.373	602.373	0.100	.02471	
260	91	0.000	0.000	0.000	0.000	315.145	315.145	0.100	.01279	
	92	0.000	0.000	0.000	0.000	2945.476	2945.476	0.100	.12744	
270	93	0.000	0.000	0.000	0.000	1997.606	1997.606	0.100	.08554	
	94	0.000	0.000	0.000	0.000	4271.428	4271.428	0.100	.18011	
280	95	0.000	0.000	0.000	0.000	1003.276	1003.276	0.100	.04076	
	96	0.000	0.000	0.000	0.000	1115.014	1115.014	0.100	.04774	
290	94	0.000	0.000	0.000	0.000	1749.504	1749.504	0.100	.07474	
	99	0.000	0.000	0.000	0.000	1509.659	1509.659	0.100	.06177	
300	101	0.000	0.000	0.000	0.000	2587.044	2587.044	0.100	.11079	
	103	0.000	0.000	0.000	0.000	2876.747	2876.747	0.100	.11429	

LAGS/ FEED WATER + CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

D-2.3 SATISFACTION OF EQUATION 11 (ANALYSIS SET 2)

STRAIGHT MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T11)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T11/(SMA+SA)	MODIFIED STRESS RATIO
15	1	3786.977	0.000	131.607	0.000	3932.978	7761.162	0.000	1.00746	
	2	3786.977	0.000	33.191	0.000	1216.449	5736.657	0.000	1.2231	
18	25	4289.688	0.000	465.459	0.000	11130.767	15846.844	0.000	1.4070	
	11	4289.688	0.000	321.475	0.000	2792.502	7506.116	0.000	1.0122	
35	1	3786.977	0.000	194.974	0.000	2100.160	6234.449	0.000	1.0582	
	12	3786.977	0.000	15.748	0.000	3428.670	7415.622	0.000	1.0001	
45	4	4289.688	0.000	343.754	0.000	3214.264	7519.517	0.000	1.0305	
	4	4289.688	0.000	281.254	0.000	2721.741	7176.677	0.000	1.0702	
55	6	4289.688	0.000	76.491	0.000	2723.741	7376.687	0.000	1.0702	
	7	4289.688	0.000	226.555	0.000	3724.328	7519.968	0.000	1.0338	
65	8	4289.688	0.000	129.552	0.000	2562.531	6785.771	0.000	1.0792	
18	75	4289.688	0.000	215.791	0.000	2358.408	7143.070	0.000	1.0650	
	10	4289.688	0.000	219.464	0.000	2715.749	7224.101	0.000	1.0616	
85	13	3786.977	0.000	156.712	0.000	3026.704	7292.604	0.000	1.0551	
	14	3786.977	0.000	193.742	0.000	2270.963	6280.683	0.000	1.0706	
95	15	3786.977	0.000	116.264	0.000	2522.287	6425.534	0.000	1.0628	
	16	3786.977	0.000	176.762	0.000	2737.444	6836.178	0.000	1.0759	
105	16	3786.977	0.000	176.762	0.000	2737.444	6836.178	0.000	1.0759	
	17	3786.977	0.000	546.071	0.000	3485.981	7122.136	0.000	1.0927	
115	18	3786.977	0.000	451.394	0.000	3430.572	7684.945	0.000	1.0937	
	19	3786.977	0.000	93.664	0.000	3773.042	7656.668	0.000	1.0911	

CURVED MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T11)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T11/(SMA+SA)	MODIFIED STRESS RATIO
10	2	3786.977	0.000	44.479	0.000	1630.702	5461.659	0.000	1.0014	
18	20	3786.977	0.000	32.771	0.000	1278.747	5248.135	0.000	1.0260	
	6	4289.688	0.000	76.951	0.000	3224.328	7519.968	0.000	1.0338	
30	8	4289.688	0.000	226.551	0.000	2562.531	7030.697	0.000	1.0732	
	9	4289.688	0.000	197.791	0.000	3539.593	8023.473	0.000	1.0040	
40	12	3786.977	0.000	322.661	0.000	3076.670	8819.025	0.000	1.0881	
	13	3786.977	0.000	267.984	0.000	4574.720	8649.642	0.000	1.0235	
50	14	3786.977	0.000	203.612	0.000	4420.943	8471.533	0.000	1.0511	
	15	3786.977	0.000	133.742	0.000	2029.963	6200.623	0.000	1.0706	
60	17	3786.977	0.000	116.264	0.000	2522.287	6425.534	0.000	1.0628	
18	18	3786.977	0.000	731.792	0.000	4675.247	9194.313	0.000	1.0242	
	19	3786.977	0.000	604.911	0.000	4597.269	8989.156	0.000	1.0290	

STRAIGHT MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T11)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T11/(SMA+SA)	MODIFIED STRESS RATIO
125	23	3786.977	0.000	247.681	0.000	4227.222	8391.681	0.000	1.2135	
	25	3786.977	0.000	52.284	0.000	3119.345	6985.541	0.000	1.0727	
135	26	3786.977	0.000	74.765	0.000	3171.922	7037.669	0.000	1.0729	
	27	3786.977	0.000	51.505	0.000	2897.591	6735.983	0.000	1.0760	
145	28	3786.977	0.000	52.323	0.000	2750.416	6643.733	0.000	1.0758	
	29	3786.977	0.000	116.741	0.000	3428.837	7732.555	0.000	1.0699	
155	20	4289.688	0.000	326.746	0.000	1726.134	21428.000	0.000	1.0578	
	30	4289.688	0.000	112.879	0.000	4664.737	9087.304	0.000	1.0355	
165	29	4289.688	0.000	223.504	0.000	3930.026	10343.310	0.000	1.0530	
	39	4289.688	0.000	75.373	0.000	3939.958	7904.989	0.000	1.0518	
175	30	4289.688	0.000	112.879	0.000	4664.737	9087.304	0.000	1.0355	
	31	4289.688	0.000	135.349	0.000	6301.007	10724.725	0.000	1.0732	
185	32	4289.688	0.000	79.730	0.000	6259.703	10728.421	0.000	1.0731	
	33	4289.688	0.000	101.356	0.000	2059.295	8345.343	0.000	1.0720	
195	34	4289.688	0.000	51.992	0.000	4056.432	8339.111	0.000	1.0700	
	35	4289.688	0.000	289.486	0.000	4844.510	9435.078	0.000	1.0369	
18	785	4289.688	0.000	261.866	0.000	4146.070	9435.078	0.000	1.0369	
	36	4289.688	0.000	79.733	0.000	2940.283	7233.075	0.000	1.0700	
215	37	4289.688	0.000	51.623	0.000	2341.471	7303.150	0.000	1.0696	
	38	4289.688	0.000	37.264	0.000	3216.876	7425.502	0.000	1.0626	
225	40	4289.688	0.000	28.901	0.000	2793.437	7102.025	0.000	1.0602	
	41	4289.688	0.000	117.371	0.000	2761.116	7144.137	0.000	1.0621	
235	42	4289.688	0.000	117.371	0.000	3502.276	7819.177	0.000	1.0618	
	43	4289.688	0.000	61.511	0.000	4312.727	8613.978	0.000	1.0701	
245	44	4289.688	0.000	173.691	0.000	4249.468	8712.548	0.000	1.0706	
18	45	4289.688	0.000	268.491	0.000	3601.493	8997.638	0.000	1.0629	

CURVED MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (OMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T11)	MODIFIED ALLOWABLE STRESS (SMA)	DESIGN STRESS RATIO T11/(SMA+SA)	MODIFIED STRESS RATIO
70	25	3786.977	0.000	70.932	0.000	4100.115	8517.027	0.000	1.0074	
18	80	3786.977	0.000	105.003	0.000	4650.805	8143.171	0.000	1.0074	
	28	3786.977	0.000	40.021	0.000	3082.056	7734.864	0.000	1.0074	
90	31	3786.977	0.000	70.137	0.000	3615.298	7540.616	0.000	1.0074	
	32	4289.688	0.000	213.421	0.000	2615.622	13071.722	0.000	1.0066	
100	37	4289.688	0.000	110.244	0.000	3013.209	13071.722	0.000	1.0066	
	38	4289.688	0.000	101.747	0.000	3330.000	11503.209	0.000	1.0070	
110	39	4289.688	0.000	51.001	0.000	1030.611	2571.111	0.000	1.0060	
	37	4289.688	0.000	44.471	0.000	4650.805	2720.000	0.000	1.0060	
120	39	4289.688	0.000	77.021	0.000	4211.471	8803.189	0.000	1.0069	
18	40	4289.688	0.000	110.244	0.000	1030.611	9517.114	0.000	1.0070	
	40	4289.688	0.000	43.701	0.000	4163.160	8436.044	0.000	1.0069	

130	41	4293.488	0.000	175.511	0.000	4110.270	8595.438	0.000	.21497
	42	4293.650	0.000	176.151	0.000	5213.571	9705.424	0.000	.24725
140	43	4299.068	0.000	176.891	0.000	6411.020	10877.804	0.000	.27712
	44	4289.688	0.000	259.811	0.000	6516.999	10926.106	0.000	.27784

18 STRAIGHT MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE (PSI)	PEAK PRESSURE STRESS (PHMAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MB)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T11)	MODIFIED ALLOWABLE STRESS (S1M)	DESIGN STRESS RATIO T11/(S1M+S2)	MODIFIED STRESS RATIO
255	19	4672.441	0.000	309.049	0.000	1192.722	8174.259	0.000	+10774	
	20	4672.441	0.000	561.713	0.000	1125.944	8340.139	0.000	+10753	
265	19	4672.441	0.000	375.945	0.000	1501.655	8572.440	0.000	+10642	
	46	4672.441	0.000	173.000	0.000	2467.415	7313.296	0.000	+10611	
275	20	4672.441	0.000	561.713	0.000	1125.944	8340.139	0.000	+10203	
	71	4672.441	0.000	371.244	0.000	1272.302	8246.032	0.000	+10014	
285	21	4672.441	0.000	371.244	0.000	1202.302	8246.032	0.000	+10014	
	22	4672.441	0.000	203.251	0.000	1876.144	8541.873	0.000	+10006	
295	22	4672.441	0.000	203.251	0.000	1876.144	8541.873	0.000	+10006	
	23	4672.441	0.000	151.792	0.000	2445.874	7244.956	0.000	+10001	
305	23	4672.441	0.000	5.161	0.000	.000	4672.441	0.000	+10000	
	24	4672.441	0.000	.000	0.000	.000	4672.441	0.000	+10000	
315	47	4672.441	0.000	262.411	0.000	2901.624	7816.577	0.000	+10017	
	48	4672.441	0.000	126.441	0.000	3032.413	7433.456	0.000	+10006	
325	49	4672.441	0.000	131.401	0.000	2673.790	7437.171	0.000	+10006	
	50	4672.441	0.000	131.591	0.000	741.503	5594.841	0.000	+10000	
335	50	4672.441	0.000	131.591	0.000	741.503	5594.841	0.000	+10000	
	51	4672.441	0.000	152.951	0.000	3421.107	8256.541	0.000	+10000	
345	52	4672.441	0.000	152.951	0.000	3421.107	8256.541	0.000	+10000	
	53	4672.441	0.000	2912.442	0.000	1074.040	18154.919	0.000	+10000	
355	51	4672.441	0.000	2793.031	0.000	10526.307	17997.885	0.000	+10000	
	54	4672.441	0.000	1022.260	0.000	3544.196	9246.737	0.000	+10000	
365	54	4672.441	0.000	1022.260	0.000	3544.196	9246.737	0.000	+10000	
	55	4672.441	0.000	412.400	0.000	4192.134	9277.023	0.000	+10000	
375	56	4672.441	0.000	330.700	0.000	3335.202	8335.283	0.000	+10000	
	57	4672.441	0.000	445.897	0.000	2041.614	7179.902	0.000	+10001	
385	57	5541.562	0.000	427.361	0.000	2365.587	8374.014	0.000	+10000	
	58	5541.562	0.000	525.142	0.000	2843.552	8910.258	0.000	+10000	

18 CURVED MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE (PSI)	PEAK PRESSURE STRESS (PHMAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MB)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T11)	MODIFIED ALLOWABLE STRESS (S1M)	DESIGN STRESS RATIO T11/(S1M+S2)	MODIFIED STRESS RATIO
150	46	4672.441	0.000	173.000	0.000	2467.415	7313.296	0.000	+10001	
	47	4672.441	0.000	262.412	0.000	2941.624	7816.577	0.000	+10117	
160	48	4672.441	0.000	199.519	0.000	4709.159	9581.359	0.000	+10000	
	49	4672.441	0.000	204.052	0.000	4885.276	8965.786	0.000	+10001	
170	51	4672.441	0.000	237.920	0.000	5328.166	10233.167	0.000	+10000	
	52	4672.441	0.000	206.611	0.000	5957.464	10836.561	0.000	+10000	

130	55	4672.441	0.000	412.400	0.000	4192.134	9277.023	0.000	.23633
	56	4672.441	0.000	330.700	0.000	3335.202	8335.283	0.000	.21242

18 STRAIGHT MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE (PSI)	PEAK PRESSURE STRESS (PHMAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MB)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T11)	MODIFIED ALLOWABLE STRESS (S1M)	DESIGN STRESS RATIO T11/(S1M+S2)	MODIFIED STRESS RATIO
395	59	5886.562	0.000	525.142	0.000	2843.552	9255.258	0.000	+10079	
	60	5886.562	0.000	87.351	0.000	2919.816	8532.979	0.000	+10175	
405	60	5886.562	0.000	87.351	0.000	2919.816	8532.979	0.000	+10175	
	61	5886.562	0.000	72.521	0.000	4331.791	10210.377	0.000	+10068	
415	62	5886.562	0.000	86.551	0.000	4687.915	10667.574	0.000	+10068	
	63	5886.562	0.000	86.551	0.000	4505.578	10568.690	0.000	+10034	
425	64	5886.562	0.000	78.844	0.000	4349.332	10314.739	0.000	+10021	
	65	5886.562	0.000	324.581	0.000	3940.370	12151.515	0.000	+10034	

18 CURVED MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE (PSI)	PEAK PRESSURE STRESS (PHMAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MB)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T11)	MODIFIED ALLOWABLE STRESS (S1M)	DESIGN STRESS RATIO T11/(S1M+S2)	MODIFIED STRESS RATIO
190	61	5886.562	0.000	128.132	0.000	7682.738	13667.439	0.000	+10001	
	62	5886.562	0.000	195.598	0.000	8242.894	14325.005	0.000	+10001	
200	63	5886.562	0.000	192.721	0.000	8119.692	14159.177	0.000	+10000	
	64	5886.562	0.000	139.300	0.000	7604.615	13710.442	0.000	+10000	

LACRMR FEED WATER * CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

STRAIGHT MEMBERS FOR RUN 5

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (TALL)	MODIFIED ALLOWABLE STRESS (SAMI)	DESIGN STRESS RATIO TALL/(SAMI)	MODIFIED STRESS RATIO
435	53	4229.688	0.000	3562.669	0.000	1779.337	9139.714	9.100	1.03284	
	64	4229.688	0.000	1707.462	0.000	1199.617	7196.767	9.100	1.12312	
445	66	4229.688	0.000	1777.626	0.000	908.877	7066.191	9.000	1.17476	
455	67	4229.688	0.000	1527.355	0.000	916.697	6533.740	9.100	1.17469	
	73	4229.688	0.000	1377.766	0.000	443.724	6130.882	9.000	1.15618	
465	68	4229.688	0.000	1249.264	0.000	444.322	6019.874	9.000	1.15336	
	69	4229.688	0.000	1536.363	0.000	873.677	6721.729	9.000	1.17771	
475	69	4229.688	0.000	1702.039	0.000	902.777	6394.505	9.000	1.16790	
	71	4229.688	0.000	1174.679	0.000	972.777	6315.944	9.100	1.16271	
485	71	4229.688	0.000	469.297	0.000	1641.405	6273.391	9.000	1.16303	
	72	4229.688	0.000	469.297	0.000	1641.405	6273.391	9.000	1.16303	
495	72	4229.688	0.000	1039.759	0.000	1446.123	6815.565	9.000	1.17363	
	107	4229.688	0.000	661.445	0.000	1952.399	6453.232	9.100	1.17459	
505	74	4229.688	0.000	619.281	0.000	1708.479	6676.469	9.000	1.17004	
	75	4229.688	0.000	1209.821	0.000	446.704	5793.213	9.100	1.15173	
515	76	4229.688	0.000	324.677	0.000	461.037	5030.682	9.000	1.12739	
	77	4229.688	0.000	368.775	0.000	464.739	5122.762	9.000	1.13050	
525	78	4229.688	0.000	461.261	0.000	438.634	5179.602	9.000	1.13238	
	79	4229.688	0.000	357.261	0.000	417.612	5094.987	9.000	1.12707	
535	79	4229.688	0.000	1469.321	0.000	416.126	6175.147	9.100	1.15731	
	81	4229.688	0.000	1467.694	0.000	416.126	6175.147	9.000	1.15727	
545	81	4229.688	0.000	1776.811	0.000	424.636	6421.135	9.000	1.16358	
	82	4229.688	0.000	1766.911	0.000	424.636	6421.135	9.000	1.16354	
555	81	4229.688	0.000	1317.361	0.000	402.018	6011.068	9.000	1.15313	
	82	4229.688	0.000	905.721	0.000	401.331	5196.748	9.100	1.13739	
565	84	4229.688	0.000	474.981	0.000	447.337	6365.463	9.100	1.16217	
	85	4229.688	0.000	325.151	0.000	1203.469	6017.277	9.000	1.15123	
575	85	4229.688	0.000	325.151	0.000	842.492	5497.330	9.000	1.13703	
	86	4229.688	0.000	210.861	0.000	311.445	5412.004	9.000	1.13903	
585	86	4229.688	0.000	210.467	0.000	411.448	5412.004	9.000	1.13787	
	106	4229.688	0.000	201.136	0.000	1017.749	5004.169	9.000	1.11747	
595	87	4229.688	0.000	227.661	0.000	1398.478	5917.711	9.000	1.14032	
	88	4229.688	0.000	353.011	0.000	2014.774	6657.473	9.000	1.16766	
605	88	4229.688	0.000	473.621	0.000	2605.631	7328.939	9.000	1.19660	
	89	4229.688	0.000	493.421	0.000	2605.631	7328.939	9.000	1.19724	
615	89	4229.688	0.000	629.571	0.000	3159.145	6774.407	9.000	1.15470	
	91	4229.688	0.000	342.311	0.000	2915.476	7617.314	9.100	1.14405	
625	91	4229.688	0.000	201.591	0.000	2537.054	7074.269	9.000	1.14072	
	105	4229.688	0.000	770.174	0.000	2472.073	7551.936	9.000	1.13219	
635	92	4229.688	0.000	603.791	0.000	3397.866	8791.347	9.100	1.23356	
	93	4229.688	0.000	123.551	0.000	1203.938	5114.470	9.000	1.13029	
645	94	4229.688	0.000	117.291	0.000	1209.256	5113.527	9.000	1.13027	

PIPESO

655	96	3746.977	0.000	464.227	0.000	1115.014	5766.213	9.000	1.13671	
	97	3746.977	0.000	681.991	0.000	1226.095	5675.083	9.000	1.14457	
665	97	3746.977	0.000	681.991	0.000	1226.095	5675.083	9.000	1.14457	
	98	3746.977	0.000	121.042	0.000	1745.504	5633.521	9.000	1.14421	
675	99	3746.977	0.000	517.121	0.000	1975.599	6213.641	9.000	1.15776	
	100	3746.977	0.000	1240.371	0.000	1997.405	7024.893	9.000	1.17436	
685	100	3746.977	0.000	1240.371	0.000	1997.405	7024.893	9.000	1.17436	
	101	3746.977	0.000	445.611	0.000	2767.211	7003.749	9.000	1.17479	
695	101	3746.977	0.000	445.611	0.000	2767.211	7003.749	9.000	1.17479	
	102	3746.977	0.000	245.461	0.000	3516.021	7621.465	9.000	1.19416	
705	103	3746.977	0.000	499.661	0.000	3336.747	8121.409	9.000	1.20695	
	104	3746.977	0.000	499.271	0.000	3324.227	8120.465	9.000	1.20687	
715	104	3746.977	0.000	201.501	0.000	2597.044	7073.280	9.000	1.14132	
	92	4229.688	0.000	750.174	0.000	2472.073	7551.936	9.100	1.13219	
725	104	4229.688	0.000	201.136	0.000	1017.749	5004.169	9.000	1.11747	
	87	4229.688	0.000	227.661	0.000	1398.478	5917.711	9.000	1.14032	
735	107	4229.688	0.000	618.281	0.000	1768.499	6676.469	9.000	1.17004	
	84	4229.688	0.000	474.981	0.000	1253.489	6017.257	9.000	1.15329	

CURVED MEMBERS FOR RUN 5

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MO)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (TALL)	MODIFIED ALLOWABLE STRESS (SAMI)	DESIGN STRESS RATIO TALL/(SAMI)	MODIFIED STRESS RATIO
210	57	4229.688	0.000	2434.292	0.000	1771.248	8995.226	9.000	1.00691	
	65	4229.688	0.000	2371.172	0.000	1308.496	7977.753	9.100	1.01120	
220	73	4229.688	0.000	1922.971	0.000	665.634	6777.801	9.000	1.17021	
	74	4229.688	0.000	1809.291	0.000	671.197	6776.613	9.000	1.17244	
230	75	4229.688	0.000	143.862	0.000	719.408	5793.213	9.100	1.16337	
	76	4229.688	0.000	91.163	0.000	676.925	6039.849	9.100	1.14103	
240	77	4229.688	0.000	703.443	0.000	676.925	5941.303	9.000	1.14384	
	78	4229.688	0.000	514.444	0.000	624.443	5443.426	9.000	1.13481	
250	82	4229.688	0.000	1373.671	0.000	621.362	6604.627	9.000	1.17445	
	83	4229.688	0.000	754.499	0.000	400.733	6074.027	9.000	1.14745	
260	90	4229.688	0.000	421.672	0.000	3105.149	6074.027	9.000	1.14745	
	91	4229.688	0.000	342.211	0.000	2945.476	7617.314	9.100	1.20678	
270	93	4229.688	0.000	603.791	0.000	3397.866	8791.347	9.100	1.15685	
	94	4229.688	0.000	423.221	0.000	4271.423	8944.345	9.100	1.20746	
280	95	3746.977	0.000	117.291	0.000	1209.256	5113.527	9.000	1.13027	
	96	3746.977	0.000	464.227	0.000	1115.014	5766.213	9.000	1.13671	
290	97	3746.977	0.000	121.042	0.000	1745.504	5633.521	9.000	1.14421	
	98	3746.977	0.000	517.121	0.000	1975.599	6213.641	9.000	1.15776	
300	102	3746.977	0.000	245.461	0.000	3516.021	7621.465	9.000	1.19416	
	103	3746.977	0.000	499.661	0.000	3336.747	8121.409	9.000	1.20695	

LACBWR FEED WATER + CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

0.5 CLASS 2 STRESSES FOR ANALYSIS SET NUMBER 9

ASSIGNED LOAD COMBINATION IDENTIFIERS
MA = 1 MB = 9 MC = 0 PD = 3 PMAX = 2

0.5.1 SATISFACTION OF EQUATION 9 (ANALYSIS SET 9)

STRAIGHT MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SHA)	OCCASIONAL LOAD STRESS (SHO)	THERMAL EXPANSION STRESS (MCI)	TOTAL STRESS (TBI)	MODIFIED ALLOWABLE STRESS (SAH)	UPSET STRESS RATIO T9/(1.2*SH)	EFFICIENCY STRESS RATIO T9/(1.8*SH)
15	1	0.000	4125.590	131.607	976.199	0.000	5231.896	0.000	.77431	.13288
	2	0.000	4125.590	33.191	442.010	0.000	4801.091	0.000	.74115	.16776
25	1	0.000	4673.591	465.480	5312.665	0.000	10449.745	0.000	.54764	.36512
	11	0.000	4673.591	323.875	2555.583	0.000	7553.024	0.000	.41583	.27764
35	1	0.000	4125.590	341.292	1932.563	0.000	6437.745	0.000	.33547	.20761
	12	0.000	4125.590	159.207	1610.703	0.000	5516.617	0.000	.31115	.20761
45	3	0.000	4673.591	65.745	1347.593	0.000	6137.171	0.000	.30708	.21379
	4	0.000	4673.591	363.258	469.075	0.000	5526.474	0.000	.24865	.19715
55	4	0.000	4673.591	363.258	469.075	0.000	5526.474	0.000	.24865	.19715
	6	0.000	4673.591	76.951	427.351	0.000	5177.793	0.000	.27133	.18002
65	7	0.000	4673.591	205.551	474.965	0.000	5355.131	0.000	.22867	.18711
	8	0.000	4673.591	121.451	155.704	0.000	4951.647	0.000	.25940	.17327
75	9	0.000	4673.591	213.654	315.879	0.000	5077.573	0.000	.26612	.18741
	10	0.000	4673.591	213.654	315.879	0.000	5077.573	0.000	.26612	.18741
85	13	0.000	4125.590	190.711	1662.764	0.000	5483.567	0.000	.31360	.20027
	14	0.000	4125.590	183.741	1245.524	0.000	5355.057	0.000	.29115	.17417
95	15	0.000	4125.590	115.261	1525.509	0.000	5767.668	0.000	.30229	.20153
	16	0.000	4125.590	176.761	1659.647	0.000	5953.300	0.000	.31202	.20001
105	17	0.000	4125.590	546.071	1815.677	0.000	6587.674	0.000	.34155	.21933
	18	0.000	4125.590	451.391	1655.491	0.000	6465.779	0.000	.32888	.22592
115	19	0.000	4125.590	93.661	1392.277	0.000	5811.630	0.000	.29412	.19609

CURVED MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SHA)	OCCASIONAL LOAD STRESS (SHO)	THERMAL EXPANSION STRESS (MCI)	TOTAL STRESS (TBI)	MODIFIED ALLOWABLE STRESS (SAH)	UPSET STRESS RATIO T9/(1.2*SH)	EFFICIENCY STRESS RATIO T9/(1.8*SH)
10	2	0.000	4125.590	44.479	592.517	0.000	4762.885	0.000	.74963	.16642
	3	0.000	4125.590	32.771	515.137	0.000	4673.703	0.000	.74496	.14931
20	6	0.000	4673.591	76.951	427.351	0.000	5177.793	0.000	.27133	.18002
	7	0.000	4673.591	205.551	474.965	0.000	5355.131	0.000	.22867	.18711
30	8	0.000	4673.591	173.791	232.911	0.000	5100.293	0.000	.26731	.17501
	9	0.000	4673.591	372.661	281.911	0.000	5279.168	0.000	.27663	.18442

40	12	0.000	4125.590	267.981	2155.127	0.000	6592.708	0.000	.34343	.22996
	13	0.000	4125.590	203.611	2201.547	0.000	6639.805	0.000	.34592	.23061
50	14	0.000	4125.590	183.741	1245.524	0.000	5355.057	0.000	.29115	.17417
	15	0.000	4125.590	115.261	1525.509	0.000	5767.668	0.000	.30229	.20153
60	17	0.000	4125.590	731.791	2811.831	0.000	7388.716	0.000	.34725	.25417
	18	0.000	4125.590	604.911	2530.745	0.000	7261.547	0.000	.33058	.25372

STRAIGHT MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SHA)	OCCASIONAL LOAD STRESS (SHO)	THERMAL EXPANSION STRESS (MCI)	TOTAL STRESS (TBI)	MODIFIED ALLOWABLE STRESS (SAH)	UPSET STRESS RATIO T9/(1.2*SH)	EFFICIENCY STRESS RATIO T9/(1.8*SH)
125	23	0.000	4125.590	267.681	1032.672	0.000	5446.273	0.000	.28754	.17109
	24	0.000	4125.590	52.251	1362.444	0.000	5243.992	0.000	.27449	.14312
135	26	0.000	4125.590	78.761	1031.443	0.000	5240.101	0.000	.27448	.14313
	27	0.000	4125.590	51.505	933.817	0.000	5111.207	0.000	.26786	.14260
145	28	0.000	4125.590	52.335	941.058	0.000	5121.202	0.000	.26841	.14264
	29	0.000	4125.590	116.741	311.159	0.000	4489.792	0.000	.24204	.14074
155	29	0.000	4673.591	324.237	1557.556	0.000	6355.434	0.000	.34351	.20405
	30	0.000	4673.591	112.079	1222.203	0.000	5931.672	0.000	.31787	.20705
165	29	0.000	4673.591	223.594	1272.407	0.000	6164.605	0.000	.32336	.20697
	30	0.000	4673.591	75.373	894.788	0.000	5645.122	0.000	.28941	.18720
175	30	0.000	4673.591	112.875	1151.205	0.000	5982.555	0.000	.31258	.20703
	31	0.000	4673.591	135.951	1406.207	0.000	6213.792	0.000	.32867	.21711
185	32	0.000	4673.591	74.711	1482.737	0.000	6155.052	0.000	.32263	.21703
	33	0.000	4673.591	101.365	566.617	0.000	5763.468	0.000	.30110	.18740
195	34	0.000	4673.591	51.941	837.134	0.000	5355.517	0.000	.28121	.18747
	35	0.000	4673.591	244.861	879.041	0.000	5571.571	0.000	.29956	.18731
205	36	0.000	4673.591	209.801	671.071	0.000	5372.571	0.000	.29076	.18731
	37	0.000	4673.591	231.731	461.944	0.000	5155.318	0.000	.27072	.18744
215	37	0.000	4673.591	51.221	535.043	0.000	5741.206	0.000	.27775	.18743
	38	0.000	4673.591	77.247	732.890	0.000	5441.156	0.000	.28531	.18730
225	40	0.000	4673.591	264.907	914.811	0.000	5814.101	0.000	.29574	.18710
	41	0.000	4673.591	137.331	1494.54	0.000	6286.122	0.000	.32164	.21604
235	42	0.000	4673.591	117.761	1489.932	0.000	6271.205	0.000	.32109	.21606
	43	0.000	4673.591	51.511	1149.680	0.000	6154.793	0.000	.30208	.21608
245	44	0.000	4673.591	173.691	1391.640	0.000	6241.925	0.000	.32789	.21617
	45	0.000	4673.591	206.491	1248.534	0.000	6166.671	0.000	.32330	.21654

CURVED MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SHA)	OCCASIONAL LOAD STRESS (SHO)	THERMAL EXPANSION STRESS (MCI)	TOTAL STRESS (TBI)	MODIFIED ALLOWABLE STRESS (SAH)	UPSET STRESS RATIO T9/(1.2*SH)	EFFICIENCY STRESS RATIO T9/(1.8*SH)
70	25	0.000	4125.590	75.030	1074.704	0.000	5670.126	0.000	.29156	.18187
	26	0.000	4125.590	151.203	1374.793	0.000	6111.914	0.000	.31600	.18188
80	27	0.000	4125.590	80.071	1071.500	0.000	5640.102	0.000	.29146	.18188
	28	0.000	4125.590	70.137	1071.500	0.000	5617.403	0.000	.29147	.18187
90	31	0.000	4673.591	203.403	1210.673	0.000	6111.693	0.000	.31600	.18187
	32	0.000	4673.591	189.237	2017.767	0.000	6893.405	0.000	.35034	.24796

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (SMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T9)	MODIFIED ALLOWABLE STRESS (SMA)	UPSET STRESS RATIO T9/(1.2*SM)	EMERGENCY STRESS RATIO T9/(1.5*SM)
100	33	0.000	4673.591	101.361	588.519	0.000	5363.478	0.000	.28118	.18760
	34	0.000	4673.591	63.301	637.938	0.000	5375.817	0.000	.28121	.18767
110	36	0.000	4673.591	44.471	691.973	0.000	5409.145	0.000	.28190	.18780
	37	0.000	4673.591	77.021	601.793	0.000	5552.715	0.000	.29102	.19102
120	39	0.000	4673.591	112.741	330.479	0.000	5127.162	0.000	.30113	.20109
	40	0.000	4673.591	43.731	1364.983	0.000	6016.273	0.000	.31301	.21208
130	41	0.000	4673.591	175.911	220.150	0.000	7054.753	0.000	.36946	.24764
	42	0.000	4673.591	176.151	222.411	0.000	7073.165	0.000	.37078	.24767
140	43	0.000	4673.591	136.491	2074.779	0.000	6893.259	0.000	.36107	.24371
	44	0.000	4673.591	259.811	2073.593	0.000	7007.608	0.000	.36724	.24483

STRAIGHT MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (SMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T9)	MODIFIED ALLOWABLE STRESS (SMA)	UPSET STRESS RATIO T9/(1.2*SM)	EMERGENCY STRESS RATIO T9/(1.5*SM)
255	19	0.000	5090.641	309.349	1001.196	0.000	6400.825	0.000	.33543	.22160
	20	0.000	5090.641	561.712	1107.736	0.000	6762.690	0.000	.35430	.23220
265	19	0.000	5090.641	309.349	1365.561	0.000	6815.247	0.000	.35925	.23893
	46	0.000	5090.641	173.000	910.776	0.000	6174.417	0.000	.32361	.21074
275	20	0.000	5090.641	501.713	1107.736	0.000	6762.690	0.000	.35430	.23220
	21	0.000	5090.641	321.244	719.051	0.000	6110.941	0.000	.32133	.21072
285	21	0.000	5090.641	321.244	719.051	0.000	6110.941	0.000	.32133	.21072
	22	0.000	5090.641	203.254	521.101	0.000	4745.199	0.000	.30373	.20043
295	22	0.000	5090.641	203.254	521.101	0.000	4745.199	0.000	.30373	.20043
	23	0.000	5090.641	151.791	563.944	0.000	5595.366	0.000	.32432	.21784
305	23	0.000	5090.641	5.161	.000	0.000	5015.425	0.000	.26708	.17165
	24	0.000	5090.641	.000	.000	0.000	5010.641	0.000	.26661	.17167
315	47	0.000	5090.641	202.411	1231.670	0.000	6515.932	0.000	.34523	.23115
	48	0.000	5090.641	173.481	1575.773	0.000	6794.855	0.000	.35618	.23747
325	49	0.000	5090.641	171.401	1574.162	0.000	6716.204	0.000	.35224	.23516
	50	0.000	5090.641	170.591	934.733	0.000	6163.670	0.000	.32330	.21053
335	50	0.000	5090.641	170.591	934.733	0.000	6163.670	0.000	.32330	.21053
	51	0.000	5090.641	172.951	1103.620	0.000	6371.213	0.000	.33290	.21694
345	52	0.000	5090.641	173.051	1147.753	0.000	6371.213	0.000	.33303	.21702
	53	0.000	5090.641	261.467	164.191	0.000	9566.719	0.000	.60033	.37255
355	53	0.000	5090.641	277.091	243.942	0.000	10341.319	0.000	.64210	.39340
	54	0.000	5090.641	1022.261	1622.615	0.000	7633.516	0.000	.48018	.28673
365	54	0.000	5090.641	1022.261	1622.615	0.000	7633.516	0.000	.48018	.28679
	55	0.000	5090.641	412.401	1561.447	0.000	7064.491	0.000	.43726	.24784
375	55	0.000	5090.641	335.701	1702.021	0.000	7187.362	0.000	.43740	.24789
	57	0.000	5090.641	445.807	1582.540	0.000	7118.988	0.000	.43711	.24774
385	57	0.000	6037.500	477.361	1812.150	0.000	8277.015	0.000	.41591	.23701
	59	0.000	6037.500	529.141	1688.367	0.000	8031.610	0.000	.41320	.23547

CURVED MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (SMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T9)	MODIFIED ALLOWABLE STRESS (SMA)	UPSET STRESS RATIO T9/(1.2*SM)	EMERGENCY STRESS RATIO T9/(1.5*SM)
150	46	0.000	5090.641	173.000	910.776	0.000	6174.417	0.000	.32351	.21074
	47	0.000	5090.641	262.411	1231.670	0.000	6516.932	0.000	.34523	.23115
160	48	0.000	5090.641	193.911	2447.817	0.000	7737.177	0.000	.48551	.27134
	49	0.000	5090.641	204.051	2445.812	0.000	7740.505	0.000	.48569	.27146
170	51	0.000	5090.641	237.521	1703.129	0.000	7051.249	0.000	.43956	.24538
	52	0.000	5090.641	236.611	1702.346	0.000	7079.607	0.000	.43765	.24537
180	55	0.000	5090.641	412.401	1561.442	0.000	7064.491	0.000	.43726	.24784
	56	0.000	5090.641	330.701	1762.021	0.000	7188.362	0.000	.43740	.24789

STRAIGHT MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (SMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T9)	MODIFIED ALLOWABLE STRESS (SMA)	UPSET STRESS RATIO T9/(1.2*SM)	EMERGENCY STRESS RATIO T9/(1.5*SM)
395	50	0.000	6000.000	520.163	1664.367	0.000	9091.510	0.000	.45650	.23433
	50	0.000	6000.000	67.351	1195.904	0.000	8183.745	0.000	.41081	.22187
405	60	0.000	6000.000	67.351	1195.904	0.000	8183.745	0.000	.41081	.22187
	61	0.000	6000.000	72.021	791.189	0.000	7743.712	0.000	.35974	.20181
415	62	0.000	6000.000	65.061	612.804	0.000	7603.889	0.000	.34157	.20418
	63	0.000	6000.000	60.951	707.054	0.000	7633.004	0.000	.33923	.20193
425	64	0.000	6000.000	79.841	1043.770	0.000	8026.600	0.000	.44104	.24859
	65	0.000	6000.000	324.581	1330.793	0.000	8561.300	0.000	.48979	.28653

CURVED MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PI)	PEAK PRESSURE STRESS (PMAX)	SUSTAINED LOAD STRESS (SMA)	OCCASIONAL LOAD STRESS (SMA)	THERMAL EXPANSION STRESS (EMC)	TOTAL STRESS (T9)	MODIFIED ALLOWABLE STRESS (SMA)	UPSET STRESS RATIO T9/(1.2*SM)	EMERGENCY STRESS RATIO T9/(1.5*SM)
190	61	0.000	6000.000	178.138	1379.912	0.000	7426.776	0.000	.42783	.23294
	62	0.000	6000.000	101.091	1042.771	0.000	6131.391	0.000	.34165	.20187
200	63	0.000	6000.000	121.221	1243.259	0.000	6702.179	0.000	.41078	.22185
	64	0.000	6000.000	139.301	1554.761	0.000	6994.010	0.000	.44449	.23960

LACMWR FEED WATER * CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

STRAIGHT MEMBERS FOR RUN 5

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE (PSI)	PEAK PRESSURE (PSI MAX)	SUSTAINED LOAD STRESS (LBS)	OCCASIONAL LOAD STRESS (LBS)	THERMAL EXPANSION STRESS (LBS)	TOTAL STRESS (LBS)	MODIFIED ALLOWABLE STRESS (LBS)	UPSET STRESS RATIO T9/(1.2*SH)	EMERGENCY STRESS RATIO T9/(1.8*SH)
435	53	0.000	4677.591	3010.689	9900.959	0.000	17633.238	0.000	0.92449	4.61673
	66	0.000	4677.591	1797.462	5196.712	0.000	11677.264	0.100	0.69426	4.60425
445	66	0.000	4677.591	1797.462	2706.023	0.000	9451.239	0.100	0.49935	3.31103
	67	0.000	4677.591	1627.751	3173.256	0.000	9403.201	0.100	0.49687	3.31124
455	66	0.000	4677.591	1377.701	3247.701	0.000	9231.257	0.100	0.48737	3.32491
	73	0.000	4677.591	1245.261	2917.674	0.000	8876.479	0.100	0.46922	3.32115
465	68	0.000	4677.591	1525.361	3173.256	0.000	9300.347	0.100	0.49116	3.32110
	69	0.000	4677.591	1202.031	3077.573	0.000	9151.208	0.100	0.47973	3.31942
475	69	0.000	4677.591	1104.475	3173.256	0.000	9140.652	0.100	0.47974	3.31936
	71	0.000	4677.591	468.297	2351.545	0.000	8002.472	0.100	0.45131	2.79644
485	71	0.000	4677.591	468.297	2293.711	0.000	7435.699	0.100	0.43063	2.79479
	72	0.000	4677.591	1070.751	2913.158	0.000	8711.499	0.100	0.46858	3.30139
495	72	0.000	4677.591	661.444	3214.237	0.000	8551.272	0.100	0.46428	3.30149
	197	0.000	4677.591	618.281	3471.187	0.000	8713.040	0.100	0.45023	3.30149
505	74	0.000	4677.591	1209.021	2774.556	0.000	8571.012	0.100	0.45011	3.30207
	75	0.000	4677.591	229.871	1123.737	0.000	6026.504	0.100	0.31037	2.17195
515	75	0.000	4677.591	366.771	1172.449	0.000	6214.846	0.100	0.32737	2.20205
	77	0.000	4677.591	444.261	1213.171	0.000	6195.041	0.100	0.33073	2.21175
525	78	0.000	4677.591	357.251	1223.702	0.000	6203.579	0.100	0.32512	2.21175
	79	0.000	4677.591	1469.321	1459.549	0.000	7931.667	0.100	0.40394	2.74647
535	79	0.000	4677.591	1469.321	1452.412	0.000	7774.699	0.100	0.39711	2.74647
	81	0.000	4677.591	1704.811	1752.712	0.000	8113.113	0.100	0.42826	2.85114
545	81	0.000	4677.591	1704.811	1245.545	0.000	7635.049	0.100	0.39168	2.85114
	82	0.000	4677.591	1319.361	1327.760	0.000	7320.712	0.100	0.38369	2.79679
555	82	0.000	4677.591	595.721	1411.632	0.000	6571.951	0.100	0.36544	2.37099
	72	0.000	4677.591	1633.831	1930.091	0.000	7887.519	0.100	0.41339	2.87103
565	84	0.000	4677.591	474.081	2497.955	0.000	7645.665	0.100	0.40072	2.87104
	85	0.000	4677.591	325.151	2325.543	0.000	7937.239	0.100	0.41693	2.87103
575	85	0.000	4677.591	325.151	2336.549	0.000	7917.249	0.100	0.41600	2.87103
	86	0.000	4677.591	210.861	1301.046	0.000	6715.504	0.100	0.35563	2.37099
585	86	0.000	4677.591	212.867	1391.746	0.000	6744.564	0.100	0.35847	2.37099
	106	0.000	4677.591	201.130	1362.705	0.000	6737.633	0.100	0.35733	2.37099
595	87	0.000	4677.591	229.865	1573.035	0.000	6573.194	0.100	0.35556	2.37099
	88	0.000	4677.591	353.011	1073.975	0.000	5176.565	0.100	0.27467	2.21175
605	88	0.000	4677.591	353.011	1074.175	0.000	5176.565	0.100	0.27467	2.21175
	89	0.000	4677.591	493.621	2301.314	0.000	7471.134	0.100	0.39157	2.85114
615	89	0.000	4677.591	493.621	2301.414	0.000	7471.134	0.100	0.39157	2.85114
	90	0.000	4677.591	629.571	1866.110	0.000	7163.773	0.100	0.38575	2.80000
625	91	0.000	4677.591	342.211	2153.581	0.000	7175.393	0.100	0.37607	2.80000
	105	0.000	4677.591	221.501	2213.552	0.000	7173.651	0.100	0.37598	2.80000
635	92	0.000	4677.591	750.174	2265.864	0.000	7723.629	0.100	0.40512	2.91675
	93	0.000	4677.591	603.791	3155.541	0.000	8442.925	0.100	0.44250	3.17662
645	94	0.000	4125.190	121.551	862.583	0.000	5111.998	0.000	0.26792	1.75595
	95	0.000	4125.190	117.291	769.629	0.000	5032.612	0.000	0.26377	1.75595

655	96	0.000	4125.190	464.221	811.497	0.000	5471.894	0.000	0.28476	1.91117
	97	0.000	4125.190	651.931	1775.245	0.000	5643.186	0.100	0.29503	2.00000
665	97	0.000	4125.190	651.931	1775.245	0.000	5643.186	0.100	0.29503	2.00000
	98	0.000	4125.190	121.041	1364.479	0.000	5615.411	0.100	0.29431	2.00000
675	98	0.000	4125.190	517.121	1646.318	0.000	6281.333	0.100	0.32956	2.10777
	100	0.000	4125.190	1240.371	1344.643	0.000	6712.993	0.100	0.35172	2.34448
685	100	0.000	4125.190	1240.371	1344.643	0.000	6712.993	0.100	0.35172	2.34448
	101	0.000	4125.190	446.611	584.496	0.000	5641.374	0.100	0.27941	1.91117
695	101	0.000	4125.190	446.611	584.496	0.000	5641.374	0.100	0.27941	1.91117
	102	0.000	4125.190	240.461	1565.003	0.000	5945.730	0.100	0.27754	1.91117
705	102	0.000	4125.190	240.461	1565.003	0.000	5945.730	0.100	0.27754	1.91117
	134	0.000	4125.190	499.541	2792.944	0.000	7416.519	0.100	0.38441	2.85114
715	134	0.000	4125.190	499.541	2792.944	0.000	7416.519	0.100	0.38441	2.85114
	105	0.000	4677.591	201.551	2293.703	0.000	7131.892	0.100	0.39157	2.85114
725	92	0.000	4677.591	790.174	2265.864	0.000	7723.629	0.100	0.40512	2.91675
	186	0.000	4677.591	201.130	2362.965	0.000	7237.633	0.100	0.37607	2.80000
735	87	0.000	4677.591	229.865	1573.035	0.000	6573.194	0.100	0.35556	2.37099
	107	0.000	4677.591	618.281	3451.187	0.000	8741.040	0.100	0.40394	3.30149
	84	0.000	4677.591	474.081	2497.955	0.000	7645.665	0.100	0.40072	2.87104

CURVED MEMBERS FOR RUN 5

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE (PSI)	PEAK PRESSURE (PSI MAX)	SUSTAINED LOAD STRESS (LBS)	OCCASIONAL LOAD STRESS (LBS)	THERMAL EXPANSION STRESS (LBS)	TOTAL STRESS (LBS)	MODIFIED ALLOWABLE STRESS (LBS)	UPSET STRESS RATIO T9/(1.2*SH)	EMERGENCY STRESS RATIO T9/(1.8*SH)
210	67	0.000	4677.591	2434.291	4755.710	0.000	11263.597	0.000	0.92178	4.61673
	68	0.000	4677.591	2301.171	4754.474	0.000	11201.148	0.000	0.91874	4.60425
220	73	0.000	4677.591	1422.571	4384.373	0.000	10360.514	0.100	0.92445	4.60425
	74	0.000	4677.591	1809.721	4745.191	0.000	10573.809	0.100	0.92147	4.60425
230	76	0.000	4677.591	342.661	1571.353	0.000	6674.405	0.100	0.50134	3.30149
	76	0.000	4677.591	651.631	1791.484	0.000	6986.127	0.100	0.51110	3.30149
240	77	0.000	4677.591	750.481	1824.731	0.000	7153.302	0.100	0.52172	3.30149
	78	0.000	4677.591	534.441	1839.457	0.000	7047.499	0.100	0.51637	3.30149
250	82	0.000	4677.591	1173.621	1364.141	0.000	6633.308	0.100	0.45204	2.80000
	83	0.000	4677.591	776.491	2111.601	0.000	7541.689	0.100	0.49677	2.80000
260	90	0.000	4677.591	694.971	1175.977	0.000	7073.859	0.100	0.51011	2.80000
	91	0.000	4677.591	342.211	2143.267	0.000	7175.881	0.100	0.52059	2.80000
270	93	0.000	4677.591	653.791	3167.674	0.000	8447.004	0.100	0.44771	2.80000
	94	0.000	4677.591	473.221	2975.616	0.000	8047.435	0.100	0.42111	2.80000
280	95	0.000	4125.190	117.291	789.383	0.000	5032.645	0.000	0.26176	1.75595
	96	0.000	4125.190	454.221	861.694	0.000	5471.706	0.000	0.28476	1.75595
290	99	0.000	4125.190	121.041	1367.021	0.000	5616.614	0.000	0.28074	1.75595
	99	0.000	4125.190	517.121	1641.194	0.000	6211.603	0.000	0.32756	2.10777
300	102	0.000	4125.190	240.461	1565.003	0.000	5945.730	0.000	0.27754	1.91117
	102	0.000	4125.190	499.541	2791.455	0.000	7417.073	0.000	0.38441	2.85114

LACER FEED WATER * CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

0.6 CLASS 2 STRESSES FOR ANALYSIS SET NUMBER 5

ASSIGNED LOAD COMBINATION IDENTIFIERS
MA * 1 MD * 10 MC * 0 P * 0 PHAX * 2

0.6.1 SATISFACTION OF EQUATION 3 (ANALYSIS SET 6)

STRAIGHT MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MB)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T9)	MODIFIED ALLOWABLE STRESS (S4M)	UPSET STRESS (R1T10)	EMERGENCY STRESS (R1T10)
							T9/(1.2*SH)		T9/(1.2*SH)	
15	1	0.000	4125.890	131.607	379.597	0.000	4628.093	0.700	24256	16171
	2	0.000	4125.890	33.191	243.434	0.000	4499.519	0.700	23105	15524
25	1	0.000	4673.591	445.469	2881.573	0.000	7944.673	0.300	44648	27773
	11	0.000	4673.591	323.875	1741.112	0.000	6738.578	0.300	38117	23146
35	1	0.000	4125.890	341.292	787.466	0.000	4914.048	1.000	27546	18300
	12	0.000	4125.890	143.975	1156.722	0.000	5482.186	1.000	29733	19395
45	3	0.000	4673.591	89.744	753.274	0.000	5512.613	0.000	29492	19261
	4	0.000	4673.591	383.254	243.179	0.000	5245.024	0.000	27699	18455
55	4	0.000	4673.591	343.254	243.179	0.000	5245.024	0.000	27699	18456
	6	0.000	4673.591	76.901	224.821	0.000	4975.742	0.000	26776	17844
65	7	0.000	4673.591	206.551	250.918	0.000	5171.764	0.000	26792	17718
	8	0.000	4673.591	129.551	94.216	0.000	4977.349	0.000	26567	17612
75	9	0.000	4673.591	215.707	121.719	0.000	5010.709	0.000	25242	17095
	10	0.000	4673.591	217.664	226.856	0.000	5123.740	0.000	26339	17397
85	13	0.000	4125.890	166.710	1169.909	0.000	5501.602	0.300	26311	17447
	14	0.000	4125.890	143.744	846.131	0.000	5175.764	0.300	27127	18044
95	15	0.000	4125.890	116.767	921.410	0.000	5173.969	0.000	27117	18078
	16	0.000	4125.890	176.767	929.349	0.000	5232.041	0.000	27429	18281
105	16	0.000	4125.890	176.767	929.349	0.000	5232.041	0.000	27429	18281
	17	0.000	4125.890	546.074	1113.365	0.000	7765.333	0.000	30321	20714
115	18	0.000	4125.890	451.394	1065.547	0.000	5643.832	0.000	29440	19729
	19	0.000	4125.890	93.661	1519.830	0.000	5739.368	0.000	30081	20054

CURVED MEMBERS FOR RUN 1

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MB)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T9)	MODIFIED ALLOWABLE STRESS (S4M)	UPSET STRESS (R1T10)	EMERGENCY STRESS (R1T10)
							T9/(1.2*SH)		T9/(1.2*SH)	
1C	2	0.000	4125.890	44.479	334.263	0.000	4504.637	0.000	23608	15739
	3	0.000	4125.890	32.771	247.894	0.000	4446.555	0.000	23305	15537
2C	6	0.000	4673.591	76.951	224.821	0.000	4775.742	0.000	26776	17794
	7	0.000	4673.591	206.551	250.918	0.000	5121.084	0.000	26482	17683
3C	8	0.000	4673.591	193.793	140.934	0.000	5008.316	0.000	25249	17097
	9	0.000	4673.591	322.667	181.995	0.000	5178.253	0.000	27140	18093

STRAIGHT MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MB)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T9)	MODIFIED ALLOWABLE STRESS (S4M)	UPSET STRESS (R1T10)	EMERGENCY STRESS (R1T10)
							T9/(1.2*SH)		T9/(1.2*SH)	
125	23	0.000	4125.890	267.681	1379.463	0.000	5753.040	0.300	32182	21101
	25	0.000	4125.890	72.259	802.649	0.000	4990.794	0.000	26105	17409
135	26	0.000	4125.890	78.769	793.331	0.000	5002.592	0.000	26221	17481
	27	0.000	4125.890	51.405	754.532	0.000	4831.026	0.000	25639	17099
145	28	0.000	4125.890	52.334	673.834	0.000	4607.063	0.000	24994	16716
	29	0.000	4125.890	110.743	472.464	0.000	5165.295	0.000	27091	17647
155	29	0.000	4673.591	304.793	3303.709	0.000	8791.648	0.000	44909	29116
	30	0.000	4673.591	112.674	1004.754	0.000	5975.724	0.000	30793	20209
165	29	0.000	4673.591	203.594	1641.775	0.000	6540.558	0.000	34242	22254
	30	0.000	4673.591	75.377	993.322	0.000	4748.248	0.000	26096	17064
175	30	0.000	4673.591	112.879	1044.627	0.000	4871.617	0.000	26771	17614
	31	0.000	4673.591	130.487	1144.237	0.000	5127.810	0.000	28116	18611
185	30	0.000	4673.591	79.710	1371.641	0.000	6045.540	0.000	31616	20200
	33	0.000	4673.591	101.261	625.122	0.000	5093.276	0.000	26474	17606
195	34	0.000	4673.591	83.134	671.176	0.000	5274.957	0.000	26912	18034
	35	0.000	4673.591	263.884	731.763	0.000	5679.219	0.000	29744	19490
205	36	0.000	4673.591	267.860	731.763	0.000	5679.219	0.000	29744	19490
	37	0.000	4673.591	21.737	591.695	0.000	5205.619	0.000	27486	18177
215	37	0.000	4673.591	51.620	597.193	0.000	5723.112	0.000	27999	18609
	38	0.000	4673.591	37.367	753.745	0.000	5484.402	0.000	26617	18048
225	40	0.000	4673.591	73.907	751.801	0.000	5404.343	0.000	26507	18004
	41	0.000	4673.591	117.332	1134.473	0.000	5905.476	0.000	31076	20044
235	40	0.000	4673.591	117.747	1343.120	0.000	6111.072	0.000	32117	20474
	43	0.000	4673.591	91.517	1996.178	0.000	6971.276	0.000	36078	23102
245	44	0.000	4673.591	173.042	1531.310	0.000	6279.112	0.000	33434	22098
	45	0.000	4673.591	206.449	1323.710	0.000	6241.618	0.000	32516	21677

CURVED MEMBERS FOR RUN 2

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHAX)	SUSTAINED LOAD STRESS (MA)	OCCASIONAL LOAD STRESS (MB)	THERMAL EXPANSION STRESS (MC)	TOTAL STRESS (T9)	MODIFIED ALLOWABLE STRESS (S4M)	UPSET STRESS (R1T10)	EMERGENCY STRESS (R1T10)
							T9/(1.2*SH)		T9/(1.2*SH)	
7C	35	0.000	4125.890	70.032	1079.477	0.000	5771.640	0.000	29744	19490
	36	0.000	4125.890	179.453	1263.327	0.000	7711.024	0.000	40795	26716
8C	37	0.000	4125.890	144.823	872.157	0.000	7128.440	0.000	37004	24011
	38	0.000	4125.890	70.117	918.070	0.000	6144.314	0.000	31905	20940
9C	31	0.000	4673.591	203.423	1947.170	0.000	6942.117	0.000	36107	23102
	32	0.000	4673.591	119.127	1900.400	0.000	6743.208	0.000	35119	22791

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHYS)	SUSTAINED LOAD STRESS (SHS)	OCCASIONAL LOAD STRESS (SHS)	THERMAL EXPANSION STRESS (SHS)	TOTAL STRESS (TS)	MODIFIED ALLOWABLE STRESS (SHS)	UPSET STRESS RATIO (TS/11.2*SH)	EMERGENCY STRESS RATIO (TS/11.8*SH)
100	37	0.000	4671.591	101.961	505.370	0.000	5278.922	5.310	1.27874	1.14451
	38	0.000	4671.571	51.091	611.376	0.000	5374.997	5.310	1.26107	1.16794
110	36	0.000	4671.571	44.471	749.792	0.000	5434.449	5.310	1.26410	1.19712
	37	0.000	4671.571	77.221	804.521	0.000	5645.332	5.310	1.25538	1.19729
120	39	0.000	4671.591	102.791	1487.644	0.000	6272.205	5.310	1.37477	1.21116
	40	0.000	4671.571	43.281	1103.003	0.000	5819.830	5.310	1.30207	1.20415
130	41	0.000	4671.591	179.911	1700.749	0.000	6549.003	5.310	1.30179	1.27446
	42	0.000	4671.571	176.151	2004.928	0.000	6854.674	5.310	1.35216	1.24461
140	43	0.000	4671.591	136.891	2240.437	0.000	7043.448	5.310	1.37177	1.24765
	44	0.000	4671.591	259.811	2207.494	0.000	7220.907	5.310	1.37845	1.25210

STRAIGHT MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHYS)	SUSTAINED LOAD STRESS (SHS)	OCCASIONAL LOAD STRESS (SHS)	THERMAL EXPANSION STRESS (SHS)	TOTAL STRESS (TS)	MODIFIED ALLOWABLE STRESS (SHS)	UPSET STRESS RATIO (TS/11.2*SH)	EMERGENCY STRESS RATIO (TS/11.8*SH)
250	19	0.000	5070.641	300.040	315.970	0.000	5718.598	5.310	1.27972	1.19941
	20	0.000	5070.641	541.713	694.654	0.000	6349.001	5.310	1.33276	1.22884
260	19	0.000	5070.641	300.041	1044.237	0.000	6711.323	5.310	1.34100	1.27743
	46	0.000	5070.641	173.001	1235.782	0.000	6439.423	5.310	1.34001	1.22704
270	20	0.000	5070.641	561.713	676.054	0.000	6743.000	5.310	1.32784	1.22784
	21	0.000	5070.641	321.241	541.004	0.000	5954.894	5.310	1.31210	1.24807
280	21	0.000	5070.641	321.241	541.004	0.000	5954.894	5.310	1.31210	1.24807
	22	0.000	5070.641	203.251	504.680	0.000	5681.576	5.310	1.31463	1.21726
290	22	0.000	5070.641	203.251	504.680	0.000	5681.576	5.310	1.31463	1.21726
	23	0.000	5070.641	151.791	359.429	0.000	5001.867	5.310	1.29136	1.19713
300	23	0.000	5070.641	5.161	.000	0.000	5070.641	5.310	1.26208	1.21205
	24	0.000	5070.641	.000	.000	0.000	5070.641	5.310	1.26211	1.19713
310	47	0.000	5070.641	262.441	1441.740	0.000	6274.715	5.310	1.30319	1.23119
	48	0.000	5070.641	174.461	1611.577	0.000	6209.699	5.310	1.31000	1.23472
320	49	0.000	5070.641	131.401	1472.189	0.000	6701.021	5.310	1.31141	1.24472
	50	0.000	5070.641	139.591	674.979	0.000	5935.175	5.310	1.30900	1.24431
330	50	0.000	5070.641	123.591	674.979	0.000	5935.175	5.310	1.30900	1.24431
	51	0.000	5070.641	172.851	1107.673	0.000	6441.166	5.310	1.32749	1.24744
340	52	0.000	5070.641	133.051	1303.800	0.000	6578.312	5.310	1.34006	1.24137
	53	0.000	5070.641	242.451	3504.424	0.000	11453.533	5.310	1.62729	1.44714
350	53	0.000	5070.641	273.091	4877.875	0.000	10717.972	5.310	1.66054	1.44135
	54	0.000	5070.641	1022.261	1705.400	0.000	7931.300	5.310	1.41448	1.27012
360	54	0.000	5070.641	1022.261	1705.400	0.000	7931.300	5.310	1.41448	1.27012
	55	0.000	5070.641	472.401	1469.559	0.000	6753.705	5.310	1.36445	1.24767
370	56	0.000	5070.641	330.700	1441.561	0.000	6862.922	5.310	1.35984	1.23973
	57	0.000	5070.641	445.807	1302.357	0.000	6874.805	5.310	1.36012	1.24035
380	57	0.000	5070.641	427.365	1547.342	0.000	6007.255	5.310	1.40177	1.24798
	59	0.000	5070.641	525.143	1407.123	0.000	6469.766	5.310	1.42119	1.23146

CURVED MEMBERS FOR RUN 3

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHYS)	SUSTAINED LOAD STRESS (SHS)	OCCASIONAL LOAD STRESS (SHS)	THERMAL EXPANSION STRESS (SHS)	TOTAL STRESS (TS)	MODIFIED ALLOWABLE STRESS (SHS)	UPSET STRESS RATIO (TS/11.2*SH)	EMERGENCY STRESS RATIO (TS/11.8*SH)
130	46	0.000	5070.641	173.000	1275.782	0.000	6439.423	5.310	1.34000	1.22704
	47	0.000	5070.641	262.442	1441.742	0.000	6274.715	5.310	1.30319	1.23119
140	48	0.000	5070.641	193.519	2533.475	0.000	7823.836	5.310	1.41000	1.27177
	49	0.000	5070.641	204.052	2214.561	0.000	7503.257	5.310	1.37997	1.24031
170	51	0.000	5070.641	237.521	1658.710	0.000	7147.871	5.310	1.37682	1.25115
	52	0.000	5070.641	206.611	2105.683	0.000	7424.139	5.310	1.36511	1.24040
180	55	0.000	5070.641	412.402	1450.859	0.000	6553.705	5.310	1.36445	1.24767
	56	0.000	5070.641	330.701	1441.561	0.000	6862.922	5.310	1.35984	1.23973

STRAIGHT MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHYS)	SUSTAINED LOAD STRESS (SHS)	OCCASIONAL LOAD STRESS (SHS)	THERMAL EXPANSION STRESS (SHS)	TOTAL STRESS (TS)	MODIFIED ALLOWABLE STRESS (SHS)	UPSET STRESS RATIO (TS/11.2*SH)	EMERGENCY STRESS RATIO (TS/11.8*SH)
330	59	0.000	6100.000	529.148	1907.123	0.000	6718.266	5.310	1.46643	1.31732
	60	0.000	6100.000	67.351	1501.602	0.000	6553.072	5.310	1.42320	1.29510
400	60	0.000	6100.000	67.351	1501.602	0.000	6553.072	5.310	1.42320	1.29510
	61	0.000	6100.000	72.521	1604.174	0.000	6777.332	5.310	1.43000	1.24705
410	62	0.000	6100.000	69.061	1401.022	0.000	6749.557	5.310	1.44100	1.24113
	63	0.000	6100.000	60.551	1677.933	0.000	6764.028	5.310	1.44478	1.24666
420	64	0.000	6100.000	78.864	1677.100	0.000	6956.603	5.310	1.44300	1.24473
	65	0.000	6100.000	324.581	2003.879	0.000	9284.460	5.310	1.46609	1.31072

CURVED MEMBERS FOR RUN 4

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PHYS)	SUSTAINED LOAD STRESS (SHS)	OCCASIONAL LOAD STRESS (SHS)	THERMAL EXPANSION STRESS (SHS)	TOTAL STRESS (TS)	MODIFIED ALLOWABLE STRESS (SHS)	UPSET STRESS RATIO (TS/11.2*SH)	EMERGENCY STRESS RATIO (TS/11.8*SH)
190	61	0.000	6100.000	124.138	2810.454	0.000	9053.573	5.310	1.47016	1.33111
	62	0.000	6100.000	159.878	3151.288	0.000	10211.443	5.310	1.51700	1.34743
200	63	0.000	6100.000	102.701	3317.117	0.000	10370.238	5.310	1.52000	1.34700
	64	0.000	6100.000	120.200	3463.342	0.000	10532.648	5.310	1.52870	1.35090

LACWR FEED WATER + CONDENSATE RETURN PIPING CLASS 2 ANALYSIS

STRAIGHT MEMBERS FOR RUN 5

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PSI)	SUSTAINED LOAD STRESS (PSI)	OCCASIONAL LOAD STRESS (PSI)	THERMAL EXPANSION STRESS (PSI)	TOTAL STRESS (PSI)	MODIFIED ALLOWABLE STRESS (PSI)	UPSET STRESS RATIO (TR/CL.2.0SH)	ENERGENCY STRESS RATIO (TR/CL.1.0SH)
430	53	0.000	4673.591	3070.609	10541.522	0.000	14282.101	0.300	469422	1.1441
445	66	0.000	4673.591	1757.467	5914.301	0.000	12416.013	0.400	455073	1.1742
455	66	0.000	4673.591	1757.467	3034.129	0.000	9513.344	0.500	448845	1.3170
465	66	0.000	4673.591	1677.301	2973.211	0.000	5274.177	0.900	435507	1.1745
475	63	0.000	4673.591	1235.264	3854.628	0.000	10021.645	0.300	452568	1.3046
485	63	0.000	4673.591	1713.761	3021.704	0.000	4614.274	0.100	43248	1.3139
495	63	0.000	4673.591	1772.007	3403.423	0.000	3276.053	0.100	44417	1.3041
505	71	0.000	4673.591	1574.475	3171.171	0.000	4051.030	0.100	44544	1.3776
515	71	0.000	4673.591	458.297	2212.304	0.000	7412.082	0.100	43056	1.2991
525	72	0.000	4673.591	461.297	1723.326	0.000	6165.124	0.000	43541	1.2947
535	72	0.000	4673.591	1219.791	1405.071	0.000	7021.112	0.100	43877	1.2846
545	72	0.000	4673.591	501.443	2721.254	0.000	5947.219	0.000	42245	1.2841
555	74	0.000	4673.591	414.281	3520.734	0.000	8112.101	0.100	41106	1.2901
565	74	0.000	4673.591	703.627	3144.465	0.000	9072.101	0.100	42139	1.1073
575	75	0.000	4673.591	111.171	1077.113	0.000	5540.710	0.100	41176	1.2187
585	77	0.000	4673.591	303.777	1341.573	0.000	6173.699	0.100	41406	1.2271
595	74	0.000	4673.591	464.281	1425.037	0.000	6057.107	0.100	41419	1.2946
605	79	0.000	4673.591	307.281	1415.102	0.000	6446.679	0.100	41288	1.2945
615	79	0.000	4673.591	1444.321	1871.677	0.000	7741.700	0.100	40812	1.2785
625	81	0.000	4673.591	1447.699	1612.704	0.000	7753.901	0.100	40613	1.2783
635	81	0.000	4673.591	1704.811	2121.154	0.000	8501.185	0.100	40457	1.2785
645	82	0.000	4673.591	1704.811	1462.371	0.000	7870.708	0.100	41041	1.2731
655	82	0.000	4673.591	1359.161	1576.173	0.000	7549.131	0.100	40566	1.2677
665	72	0.000	4673.591	515.721	1724.741	0.000	6953.200	0.100	40712	1.2411
675	84	0.000	4673.591	1933.281	2274.485	0.000	8241.683	0.100	41720	1.2517
685	85	0.000	4673.591	474.281	2471.147	0.000	7823.816	0.100	40857	1.2418
695	85	0.000	4673.591	335.151	2549.630	0.000	7933.370	0.100	40915	1.2413
705	86	0.000	4673.591	325.151	2549.630	0.000	7933.370	0.100	40915	1.2413
715	86	0.000	4673.591	125.151	1513.951	0.000	6404.467	0.100	40846	1.2377
725	86	0.000	4673.591	217.151	1513.951	0.000	6404.467	0.000	41165	1.2377
735	87	0.000	4673.591	201.131	1377.742	0.000	6242.175	0.100	40563	1.2338
745	83	0.000	4673.591	229.501	1301.446	0.000	6207.702	0.100	40215	1.2153
755	88	0.000	4673.591	353.011	2405.467	0.000	7412.718	0.100	40352	1.2486
765	89	0.000	4673.591	407.821	2405.467	0.000	7412.718	0.100	40352	1.2486
775	89	0.000	4673.591	407.821	1476.274	0.000	7041.474	0.100	40316	1.2410
785	90	0.000	4673.591	603.872	1374.774	0.000	7343.474	0.100	40316	1.2410
795	91	0.000	4673.591	342.211	1559.179	0.000	6551.339	0.100	40501	1.2364
805	91	0.000	4673.591	603.872	1374.774	0.000	7343.474	0.100	40316	1.2410
815	92	0.000	4673.591	342.211	1559.179	0.000	6551.339	0.100	40501	1.2364
825	92	0.000	4673.591	201.151	2019.771	0.000	6341.185	0.100	40375	1.2363
835	92	0.000	4673.591	740.174	2019.771	0.000	6341.185	0.100	40375	1.2363
845	94	0.000	4673.591	503.791	2019.771	0.000	6341.185	0.100	40375	1.2363
855	94	0.000	4673.591	123.451	703.167	0.000	4477.654	0.100	40588	1.2332
865	95	0.000	4673.591	117.291	599.209	0.000	4402.343	0.100	40570	1.1730

655	96	0.000	4125.190	444.220	823.504	0.000	6411.710	0.100	42874	1.1001
665	97	0.000	4125.190	601.791	1043.137	0.000	6744.016	0.100	43567	1.0979
675	99	0.000	4125.190	601.791	1343.137	0.000	6744.017	0.100	43567	1.0979
685	99	0.000	4125.190	121.041	1026.214	0.000	5273.140	0.100	42427	1.1425
695	100	0.000	4125.190	517.121	1240.847	0.000	5973.050	0.100	43973	1.1026
705	100	0.000	4125.190	1240.371	1073.423	0.000	6424.881	0.100	43372	1.0941
715	101	0.000	4125.190	1240.371	1073.423	0.000	6424.881	0.100	43372	1.0941
725	101	0.000	4125.190	444.811	618.221	0.000	5130.731	0.100	42706	1.1177
735	102	0.000	4125.190	444.811	617.221	0.000	5129.732	0.100	42706	1.1177
745	103	0.000	4125.190	241.461	1451.561	0.000	5026.259	0.100	43036	1.0957
755	104	0.000	4125.190	499.581	2724.467	0.000	7353.022	0.100	43522	1.0981
765	105	0.000	4125.190	499.581	2775.106	0.000	7431.957	0.100	43794	1.0963
775	105	0.000	4673.591	201.151	2019.771	0.000	6341.185	0.100	40375	1.2364
785	106	0.000	4673.591	740.174	2019.771	0.000	6341.185	0.100	40375	1.2364
795	107	0.000	4673.591	279.661	1304.446	0.000	6207.702	0.100	40215	1.1991
805	107	0.000	4673.591	639.281	3023.234	0.000	8312.102	0.100	43565	1.0941
815	84	0.000	4673.591	474.281	2476.147	0.000	7623.816	0.100	40857	1.2673

CURVED MEMBERS FOR RUN 5

MEMBER NO.	MEMBER ENDS	INTERNAL PRESSURE STRESS (PSI)	PEAK PRESSURE STRESS (PSI)	SUSTAINED LOAD STRESS (PSI)	OCCASIONAL LOAD STRESS (PSI)	THERMAL EXPANSION STRESS (PSI)	TOTAL STRESS (PSI)	MODIFIED ALLOWABLE STRESS (PSI)	UPSET STRESS RATIO (TR/CL.2.0SH)	ENERGENCY STRESS RATIO (TR/CL.1.0SH)
210	67	0.000	4673.591	2434.291	4447.021	0.000	16090.343	0.100	45711	1.1377
220	69	0.000	4673.591	2371.121	4447.021	0.000	15407.245	0.100	45011	1.1047
230	74	0.000	4673.591	1020.070	2042.419	0.000	11731.144	0.100	46747	1.1785
240	75	0.000	4673.591	1319.709	4419.110	0.000	11133.144	0.100	46447	1.3011
250	76	0.000	4673.591	343.261	1611.019	0.000	4128.078	0.100	46447	1.2167
260	77	0.000	4673.591	571.131	1410.078	0.000	7011.019	0.100	43778	1.2007
270	78	0.000	4673.591	834.441	2117.134	0.000	7576.022	0.100	43140	1.2007
280	82	0.000	4673.591	1573.571	3727.485	0.000	7576.022	0.100	43140	1.2007
290	83	0.000	4673.591	776.441	2637.304	0.000	8017.135	0.100	42794	1.1714
300	90	0.000	4673.591	724.520	1544.417	0.000	4447.021	0.100	43778	1.2007
310	91	0.000	4673.591	242.281	1771.074	0.000	4741.021	0.100	43140	1.2007
320	93	0.000	4673.591	431.791	2055.074	0.000	4741.021	0.100	43140	1.2007
330	94	0.000	4673.591	111.201	2340.184	0.000	7623.817	0.100	43140	1.2007
340	95	0.000	4673.591	111.201	2340.184	0.000	7623.817	0.100	43140	1.2007
350	96	0.000	4673.591	111.201	2340.184	0.000	7623.817	0.100	43140	1.2007
360	97	0.000	4673.591	111.201	2340.184	0.000	7623.817	0.100	43140	1.2007
370	98	0.000	4673.591	111.201	2340.184	0.000	7623.817	0.100	43140	1.2007
380	99	0.000	4673.591	111.201	2340.184	0.000	7623.817	0.100	43140	1.2007
390	100	0.000	4673.591	111.201	2340.184	0.000	7623.817	0.100	43140	1.2007
400	101	0.000	4673.591	111.201	2340.184	0.000	7623.817	0.100	43140	1.2007
410	102	0.000	4673.591	111.201	2340.184	0.000	7623.817	0.100	43140	1.2007
420	103	0.000	4673.591	111.201	2340.184	0.000	7623.817	0.100	43140	1.2007