

RS-1-62

# Calculation Title Page

DKH P. J. [Signature]  
7/25/90 86 167

Project SONGS-1 Job Order No. 3587 Discipline MECH.

Subject AFW FLOW VENTURE SIZING

Calculation No. SUPPL B DC-2836 QA Class SR No. Pages 62 + 9a, 40, 41, 6A, B, C

Responsible Engineer R. Q. [Signature] Date 3/23/90


Independent Review Engineer [Signature] Date 5/9/90

### ORIGINAL ISSUE

	NAME	DATE	SIGNATURE
Group Leader	<u>I. KATTER</u>	_____	_____
Discipline Sup. Engineer	<u>M. WHARTON</u>	_____	_____
Professional Engineer (if required)	_____	_____	_____

### RECORD OF REVISIONS

NO.	REASON FOR REVISION	DATE	RESP. ENGR.	IRE	GL	DSE	PE



PROFESSIONAL ENGINEER'S SEAL

9010220005 900730  
PDR ADDCK 05000206  
PNU

ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

P 80-159

SUPPL B 87 167

SUBJECT: AFW FLOW VENTURE SIZINGDESIGN CALCULATION NO. DC-2836 REVISION 5

J.O. NO.

MADE BY

R. A. 4DATE 3/22/90

CHK. BY

DATE

### TABLE OF CONTENTS

1.0	PURPOSE	R5-3
2.0	RESULTS	R5-4
3.0	ASSUMPTIONS	R5-7
4.0	METHODOLOGY	R5-8
5.0	DESIGN INPUT	R5-9
6.0	REFERENCES	R5-11
7.0	NOMENCLATURE	R5-13
8.0	CALCULATIONS	R5-15

### FIGURES AND ATTACHMENTS

FIGURE 1	CAVITATING FLOW LIMITS	R5 - 42
FIGURE 2	CAVITATING VENTURE FLOW LIMITS	R5 - 43
FIGURE 3	PUMP & SYS. CURVES, CASES 3, 4 & 5	R5 - 44
FIGURE 4	COMP. OF CASE 1 AND 2 FLOWS WITH LIMITS	R5 - 45
A	AFW P&ID	R5-46
B	-VENTURE DWG	R5-47
C	SYSTEM DESCRIPTION	R5-48
D	WESTINGHOUSE LETTER (REF 5)	R5-50
E	E-MAIL WESTINGHOUSE CALL (REF 4)	R5-52
F	VENTURE TEST DATA	R5-54
G	DC-2836 CALCULATIONS	R5-57
H	G10 W PUMP CURVE	R5-60
I	DC-2836 SUPPL A CALCULATIONS	R5-61

DWG. NO. R5-61

ENGINEERING DEPARTMENT  
CALCULATION SHEETDK# 7/2/94. 812 150  
SUPPL. B 88 167  
DC-2386 REVISION 0SUBJECT: AFW FLOW VENTURE SIZING DESIGN CALCULATION NO. DC-2386 REVISION 0I.O. NO. \_\_\_\_\_ MADE BY R. O. Luffa DATE 3/22/98 CHK. BY [Signature] DATE 5/9/981.0 PURPOSE

THE PURPOSES OF THIS CALCULATION ARE TO SIZE THE VENTURIS THAT LIMIT AUXILIARY FEEDWATER (AFW) TO THE STEAM GENERATORS AND DETERMINE MARGINS FOR THE REVISED AFW FLOW LIMITS AND VENTURE DESIGNS DUE TO THE CHANGED VENTURE SIZE AND FLOW REQUIREMENTS, THIS SUPPLEMENT SUPERCEDES FLOW RATES AND MARGINS CALCULATED IN PREVIOUS REVISIONS OF THIS CALCULATION.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET R5-4P 62 SHEETS

DKH  
7-25-90 P. 82 of 159  
89 167

SUBJECT AFW FLOW VENTURE SIZING DESIGN CALCULATION NO. DC-2886 REVISION 0

I.D. NO. \_\_\_\_\_ MADE BY R. A. W. J. DATE 3/22/90 CHK BY D DATE 5/9/90

2.0 RESULTS

1. THE VENTURES WILL MEET ALL AFW FLOW REQUIREMENTS. TABLE 2-1 COMPARES EXPECTED VENTURE FLOW RATES WITH FLOW RATE LIMITS AND PROVIDES MARGINS FOR EACH DESIGN CONDITION
2. VENTURES WILL HAVE THROAT DIAMETERS OF APPROXIMATELY 0.377 INCH. (SUPPLIER WILL DETERMINE EXACT DIAMETER.)
3. THE REQUIRED VENTURE PRESSURE DROPS AND PRESSURE DEPENDENT FLOW LIMITS ARE PROVIDED IN TABLE 2-2
4. THE RECOMMENDED VENTURE SIZE IS 140 +0, -10 GPM AT 1160 PSIG INLET PRESSURE.
5. IT WILL NOT BE NECESSARY TO EQUALIZE FLOW AMONG THE STEAM GENERATORS NOR ISOLATE BLOWDOWN IF THE REVISED FLOW LIMITS FOR POSTULATED FEEDWATER LINE BREAK EVENTS ARE INCORPORATED.
6. DUE TO CHANGES IN VENTURE SIZE AND FLOW REQUIREMENTS, THE FLOW RATES AND MARGINS CALCULATED IN THIS REVISION SUPERCEDES THOSE OF PREVIOUS REVISIONS.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 4a OF 62 SHEETS

DICK P. 83 of 154  
7/25/90 90 167  
SUPPL. B DC-2036 REVISION 0

SUBJECT AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC-2036 REVISION 0

JO. NO.

MADE BY

R. W. W.

DATE 5/10/90

CHK. BY


DATE 10/16/92

7. THIS CALCULATION DOES NOT CHANGE TECHNICAL SPECIFICATIONS OR THE OPERATING LICENSE, BUT DOES CONSIDER PROPOSED REVISIONS TO AFW FLOW LIMITS THAT WILL BE IMPLEMENTED PRIOR TO INSTALLING NEW AFW FLOW VENTURIS, AS NOTED IN TABLE 2-1.  
SURVEILLANCE PROCEDURES, Rev 5/10/90
8. RESULTS FOR A 140 GPM FLOW VENTURI, BASED ON BEST ESTIMATES OF VENTURI PRESSURE LOSSES ARE PRESENTED ON FIGURE 2-1.
9. RESULTS FOR A 140 GPM FLOW VENTURI, BASED ON MAXIMUM ALLOWABLE VENTURI PRESSURE LOSSES ARE PRESENTED ON FIGURE 2-2.
10. CASE 5 CONDITIONS, BASED ON MAXIMUM ALLOWABLE PRESSURE LOSSES, ARE PRESENTED ON FIGURE 2-3.

DWG. NO.

Made By    Date 5.21.96  
Ckd By    Date   

Calc No. DC-4836 Rev. 9/6 167  
Sh 25-6A of 62




TOTAL AFW FLOW (GPM)  
**FIGURE 2-1**  
**SUMMARY PLOT BEST ESTIMATE**  
**LOSSES FOR FLOW VENTURIS**

Made By RSW Date 5-21-96

Ckd By \_\_\_\_\_ Date \_\_\_\_\_

SUPPL 3 7/17/96 854-159  
Calc No. 06-2036 Rev 0/167

Sh RS-6B of 62



TOTAL AFW FLOW (GPM)  
FIGURE 2-2  
SUMMARY PLOT - MAXIMUM VENTURI  
PRESSURE LOSSES

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET R5-5 OF 62 SHEETS  
7/25/90  
DKH P 86 of 119  
93 167  
SUPPL. B  
DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. \_\_\_\_\_

J.O. NO. \_\_\_\_\_ MADE BY R. A. [Signature] DATE 3/29/90 CHK. BY [Signature] DATE 5/9/90

TABLE 2-1

VENTURI FLOW RATES & MARGINS

DESIGN CONDITION	FLOW LIMIT (GPM)	EXPECTED FLOW (GPM)	MARGIN	BOUNDING CASE
1. ANY PUMP TO ANY DEP. RESSUBORIZED. S.G.	< 150/SG	130-140 PER SG	7% TO 13%	① (G10+G10S)
2. G10W OR G10S TO 2 DEPRESS. S.G WITH A FW LINE BREAK	> 87.5/SG (175 TOTAL)	206-212 TOTAL	18% TO 21%	② (G10S)
3. G10W OR (G10+G10S) TO 3 S.G. AT 1015 PSIG	> 61.7/SG (185 TOTAL)	260-265 TOTAL	41% TO 43%	③ (G10W)
4. G10 TO 3 S.G. AT 1015 PSIG	> 55/SG (165 TOTAL)	268-263 TOTAL	62% TO 59%	
5. G10W OR (G10+G10S) TO 2 SG AT 1015 PSIG WITH A FW LINE BREAK	> 50/SG (100 TOTAL)	146 TOTAL	46%	③ (G10W)
6. G10S	< 420 TOTAL	335-320 TOTAL	20% TO 24%	

① BOUNDING CASE IS (G10+G10S+PARTIAL G10W). ALL OTHER CASES PROVIDE LESS FLOW

② VALUES ARE FOR G10S. G10W PROVIDES MORE FLOW & MORE MARGIN

③ VALUES ARE FOR G10W. (G10+G10S) PROVIDES MORE FLOW & MORE MARGIN

④ MARGINS ARE BASED ON PROPOSED (REF. 4 AND 5) CHANGES TO FLOW REQUIREMENTS. CURRENTLY APPROVED FLOW LIMITS (REF. 3) AND THEIR ASSOCIATED MARGINS ARE:

CASE 2 : 250 GPM TOTAL (-18% TO -21%)

CASE 5 : 125 GPM TOTAL (17%)

DWG. NO. \_\_\_\_\_



ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 85.6 OF 62 SHEETS

7/15/90  
DESIGN P. STEPHENSON  
SUPPL. B 94 167  
DC-2836 REVISION 0

SUBJECT AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 0

I.D. NO. \_\_\_\_\_ MADE BY R. W. J. DATE 3/2/90 CHK. BY [Signature] DATE 5/9/90

TABLE 2-2  
VENTURI FLOW DEPENDENT PRESSURES  
OR PRESSURE DROP

DESIGN  
CONDITION

- |  |                                  |
|--|----------------------------------|
| 1. G10+G10S TO ANY DEPRESS. ST. GEN. (INCLUDES PARTIAL G10 W FLOW) | 140+0, -10 GPM AT 1160 PSIG      |
| 2. G10W OR G10S TO 2 DEPRESS. ST. GEN. WITH A FW BREAK             | GREATER THAN 100 GPM AT 775 PSIG |
| 3. G10W OR (G10+G10S) TO 3 ST. GEN @ 1015 PSIG                     | LESS THAN 40 PSID LOSS AT 62 GPM |
| 4. G10 TO 5 ST. GEN AT 1015 PSIG                                   | BOUNDED BY CASE 3                |
| 5. G10W OR (G10+G10S) TO 2 ST. GEN AT 1015 PSIG WITH AFW BREAK     | BOUNDED BY CASE 3                |
| 6. G10S  | BOUNDED BY CASE 1                |

Made By LAJ Date 5.31.96  
 Ckd By \_\_\_\_\_ Date \_\_\_\_\_

Sum. D  
 Calc No. DC-4856 Rev. 05/16/97  
 Sh 25-6A of 62 7/5/90  
 Div




FIGURE 2-1  
 TOTAL AFW FLOW (GPM)  
 SUMMARY PLOT BEST ESTIMATES  
 LOSSES FOR FLOW VELOCITIES

Made By Ray Date 5-21-96

Ckd By \_\_\_\_\_ Date \_\_\_\_\_

SUPR 3 P. 24 Feb 199  
Calc No. 05-2036 Rev 960 167  
Sh RS-6P of 62 7/25/90  
DL4-




FIGURE 2-2  
SUMMARY PLOT - MAXIMUM VENTURI  
PRESSURE LOSSES


ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

SHEETS 5-6 OF 62 SHEETS  
 7/25/90 P. 200 (19)  
 DKH 97 167

SUBJECT **AFW FLOW VENTURE SIDING**

DESIGN CALCULATION NO. **DC-2836** SUPPL. B REVISION **0**

J.O. NO. \_\_\_\_\_ MADE BY **R.C.H.** DATE **5-21-90** CHK. BY \_\_\_\_\_ DATE \_\_\_\_\_



**FIGURE 2-3**  
**CASE 5 CONDITIONS BASED**  
**ON MAXIMUM VENTURE  $\Delta P$**

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKH J.A. B. S. G.  
7/25/90 98 167  
SUPPL. B 26.2836 REVISION 0SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. 26.2836 REVISION 0

J.O. NO.

MADE BY

P.A. W. J.

DATE 3/22/90

CHK. BY

D

DATE 5/9/90

3.0 ASSUMPTIONS

1. AUXILIARY FEEDWATER TEMPERATURE IS 70°F
2. VENTURI RECOVERY FACTORS WILL BE THE SAME AS THOSE REPORTED DURING THE CALIBRATION TESTING OF THE EXISTING AFW VENTURIS
3. AFW FLOW REQUIREMENTS FOLLOWING POSTULATED FEEDWATER LINE BREAKS WILL BE REDUCED TO THE VALUES PROVIDED IN 5.1.2 AND 5.1.5.
4. THE EFFECTS OF FRICTION AND ELEVATION LOSSES ARE NEGLIGIBLE WHEN CALCULATING CAVITATING VENTURI FLOW. THESE EFFECTS WILL BE ACCOUNTED FOR WHEN CALCULATING NON-CAVITATING FLOW TO THE STEAM GENERATORS. (THE VALIDITY OF THIS ASSUMPTION WILL BE VERIFIED IN THE CALCULATION)
5. LOSSES AND FLOW COEFFICIENTS OF THE THREE VENTURIS AND THE THREE AFW LOOPS ARE EQUAL

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEETDWN P. 92/190  
7/25/90 99 167  
SUPPL. BSUBJECT AFW FLOW VENTURI SIBINADESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_

MADE BY R.O. HDATE 5/9/90CHK BY ØDATE 5/9/904.0 METHODOLOGY

4.1 DETERMINE THE CAVITATING FLOW COEFFICIENT FOR THE EXISTING VENTURI DESIGN, USING DATA FROM REFERENCE 6.

4.2 DETERMINE AN AVERAGE NON-CAVITATING PRESSURE LOSS COEFFICIENT FOR THE EXISTING VENTURIS, USE REFERENCE 1 TEST DATA.

4.3 RESIZE THE FLOW VENTURIS FOR MAXIMUM FLOW RATES OF 150, 145, 140, AND 135 GPM, BASED UPON THE PUMP CURVE FOR (G10+G105+G10V) TAKEN FROM REFERENCE 6. FOR EACH SIZE VENTURI, CALCULATE:

- CAVITATING FLOW COEFFICIENT (C),
- NON-CAVITATING PRESSURE LOSS COEFFICIENT (KV),
- AREA, AND DIAMETER OF BORE.

4.4 CALCULATE FLOW RATES FOR EACH OF THE DESIGN CONDITIONS OF 5.1 FOR EACH SIZE VENTURI.

4.4.1 FLOW RATES ARE BASED ON THE INTERSECTIONS OF THE BOUNDING PUMP CURVES FOR EACH CASE OF 5.1 AND EITHER THE CAVITATING FLOW CURVE OR THE SYSTEM

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 45-86 OF 62 SHEETS

DKIT  
7/25/90 93  
SUPPL. D 99 167

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. 26-2826 REVISION 0

J.O. NO.

MADE BY

R.A. H

DATE 5/7/90

CHK BY

0

DATE 5/9/90

CURVE FOR EACH SIZE VENTURI

4.4.2 SYSTEM CURVES ARE DEVELOPED BY ADJUSTING THE FLOW COEFFICIENT OF THE EXISTING SYSTEM (REFERENCE 2) TO ACCOUNT FOR THE CHANGE IN THE VENTURI FLOW COEFFICIENT.

4.4.3 THE SYSTEM CURVES FOR CASE 5, WHICH PROVIDES FLOW TO A BREAK AND TWO PRESSURIZED STEAM GENERATORS, ACCOUNTS FOR BOTH THE EFFECTS OF MODIFIED KV AND C FOR EACH SIZE VENTURI.

4.4.4 DETERMINE MARGINS IN PRESSURE LOSS FOR EACH OF THE CASES.

4.5 DETERMINE MARGINS FOR EACH CASE BY COMPARING CALCULATED AND REQUIRED FLOWS FOR A VENTURI OF 140 GPM (+0), -10 GPM DESIGN. (130 GPM) VALUES ARE EXTRAPOLATED.

4.6 DETERMINE REQUIRED AND RECOMMENDED PRESSURE-FLOW AND PRESSURE LOSS-FLOW RELATIONS FOR THE RECOMMENDED VENTURI SIZE.

NOTE - FOR CONSERVATISM, MAXIMUM FLOW LIMITS WILL BE EVALUATED USING THE LARGER OF DESIGN OR ACTUAL PUMP CURVES. MINIMUM FLOW LIMITS WILL BE EVALUATED USING THE SMALLER OF DESIGN BASIS OR ACTUAL

PUMP CURVES.

DWG. NO.

5.0 DESIGN INPUT SHEET

Design Requirements  
 Design Input Change

PAGE 01 OF 02  
 RSG 62

DRH 7/25/90 P. 94 of 106  
 SUPP. 15  
 DC 2836-2

SUBJECT <b>AFW FLOW VENTURI SIZING</b>		PROJECT <b>501</b>
QUALITY CLASS <b>SR</b>	SEISMIC CLASS <b>A</b>	SPECIFICATION REFERENCE

Design Input **5.1 THE VENTURIS MUST BE SIZED TO MEET THE FOLLOWING CRITERIA:**

**5.1.1 MAXIMUM FLOW PER UNPRESSURIZED STEAM GENERATOR WITH PUMPS G10 AND G10S OPERATING - 150 GPM (REF. 3, PG. 3)**

**5.1.2 MINIMUM FLOW TO TWO UNPRESSURIZED STEAM GENERATORS WITH AN FW LINE BREAK FROM EITHER PUMP G10 OR G10S - 175 GPM (REF. 4)**

**5.1.3 MINIMUM FLOW TO THREE STEAM GENERATORS AT 1015 PSIG FROM EITHER G10 W PUMP OR G10 AND G10S PUMPS - 185 GPM (REF. 3, PG. 2)**

**5.1.4 MINIMUM FLOW TO THREE STEAM GENERATORS AT 1015 PSIG FROM G10 PUMP ALONE - 165 GPM (REF. 3, PG. 2)**

**5.1.5 MINIMUM FLOW TO TWO STEAM GENERATORS WITH A FEEDLINE BREAK FROM PUMP G10 W OR PUMPS G10 AND G10S - 100 GPM (REF. 5, PG. 6)**

LOW STEAM  
 (AT 1015 PSIG)

**5.1.6 MAXIMUM FLOW PUMP G10S - 420 GPM (REF. 3, PG. 3)**

RESPONSIBLE ENGINEER <i>R. G. [Signature]</i>	DATE 3/22/90	INDEPENDENT REVIEW ENGINEER <i>[Signature]</i>	DATE 5/9/90	GROUP LEADER	DATE
--	-----------------	---	----------------	--------------	------



DESIGN INPUT SHEET

Design Requirements  
 Design Input Change

PAGE 02 OF 02  
 RS-10 02

DKH 7/25/90 P. 95 of 107  
 102  
 DESIGN CALCULATION  
 SUPPL 8  
 DC2836-9

SUBJECT <b>AFW FLOW VENTURES SIZING</b>		PROJECT <b>SC1</b>
QUALITY CLASS <b>SR</b>	SEISMIC CLASS <b>A</b>	SPECIFICATION REFERENCE

Design Input

- 5.2 CONDITION 5.1.1 SHALL ALSO CONSIDER FLOW FROM PUMP G10W AT ITS LOW FLOW TRIP POINT.
  - 5.3 G10W LOW FLOW SIGNAL TO START PUMPS G10 AND G10S IS 57 GPM (REF. 6, pg. 24.29)
  - 5.4 THE THROAT DIAMETER OF THE EXISTING VENTURES IS 0.440, +0, - .005 IN. (REF. 7)
  - 5.5 ALL PUMP CURVES ARE TAKEN FROM REFERENCE 6, WHICH MODIFIED PUMP CURVES IN REFERENCE 2, TO CONSIDER BOTH DESIGN AND ACTUAL PERFORMANCE AND THE EFFECTS OF TURBINE INLET PRESSURE CONTROL ON G10 PUMP PERFORMANCE.
- FLOW RATES
- 5.6 ALL MAXIMUMS SHOULD INCLUDE MARGIN (REF. 9)

RESPONSIBLE ENGINEER <b>R. A. Hoff</b>	DATE <b>3/24/90</b>	INDEPENDENT REVIEW ENGINEER <b>Chad H. [Signature]</b>	DATE <b>5/9/90</b>	GROUP LEADER	DATE
---	------------------------	---	-----------------------	--------------	------

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 25/11 OF 62 SHEETS  
DEPT 7125790P. 94 of 159  
SUPPL. B 103 167

SUBJECT: AFW FLOW VENTURE SIBING DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY P.O. WJ DATE 3/22/90 CHK. BY P DATE 5/9/90

6.0 REFERENCES

1. DATA SHEETS "FOR WATER FLOW TESTS ON CAVITATING VENTURES" S/N 5413, 5414, AND 5415, DATED 10/13/88, 9/23/88 AND 9/27/88 WYLE LABORATORIES, ATTACHED TO REFERENCE 2.
2. CALCULATION DC-2836, REV. 3, "HYDRAULIC CALCULATIONS FOR AFW LINES/NEW VENTURE ADDITIONS", FLUOR ENGINEERS, INC.
3. SYSTEM DESCRIPTION, SD-501-620, REV. 2, "AUXILIARY FEEDWATER SYSTEM".
4. LETTER SCE-090-556, R.G. PEREZ, WESTINGHOUSE, TO B. CARLISLE, SCE, "FEEDLINE BREAK REANALYSIS WITH REDUCED AUXILIARY FEED FLOW" MAY 8, 1990.
5. LETTER NS-OPLS-OPL1-I-89-432, R.G. PEREZ, WESTINGHOUSE, TO P.D. MEYERS, SCE, "FEEDLINE BREAK REANALYSIS WITH REDUCED AUXILIARY FEED FLOW", DATED AUG. 23, 1989.
6. SUPPL. A REVD TO CALCULATION DC-2836, "HYDRAULIC CALCULATIONS FOR AFW LINES (DCP 3364.00TS)".

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 15-12 OF 62 SHEETS

DK-4-  
7125790 P. 970-150  
104 0167

SUBJECT AFW FLOW VENTURE SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R. C. Hoff DATE 3/22/90 CHK. BY [Signature] DATE 5/9/90

7. DRAWING 1810-AA 319-M007 (PERMUTIT NO. 556-34196 REV 0), PERMUTIT, PARAMUS NJ
8. TECHNICAL PAPER No. 410, "FLOW OF FLUIDS THROUGH VALVES, FITTINGS, AND PIPE", CRANE CO., CHICAGO, IL.
9. DESIGN CRITERIA FOR AUXILIARY FEEDWATER SYSTEM MODIFICATIONS, M86315 REV. 7, SCE.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 13 OF 62 SHEETS

DEPT P. 105/167  
7/25/90  
SUPPL B  
DC 2036

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DC 2036 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R.A. [Signature] DATE 3/24/90 CHK. BY [Signature] DATE 5/9/90

7.0 NOMENCLATURE

- A - FLOW AREA
- AFW - AUXILIARY FEEDWATER
- C - FLOW COEFFICIENT FOR VENTURI WHEN CAVITATING ( $C \equiv Q^2 / \Delta P$ )
- D - DIAMETER
- °F - DEGREES FAHRENHEIT
- FW - FEEDWATER
- $g_c$  - NEWTON'S CONSTANT =  $32.2 (LBM/LOF)(FT/SEC^2)$
- GPM - GALLONS PER MINUTE
- IN - INCH
- K - PROPORTIONALITY CONSTANT FOR PRESSURE LOSS
- $K_{sys}$  - SYSTEM PRESSURE LOSS COEFFICIENT ( $K_{sys} \equiv \Delta P / Q^2$ )
- $K_v$  - PRESSURE LOSS COEFFICIENT FOR VENTURI WHEN NOT CAVITATING ( $K_v \equiv \Delta P / Q^2$ )
- P - STATIC PRESSURE
- $P_0$  - PUMP DISCHARGE PRESSURE
- $P_0$  - TOTAL PRESSURE
- PSI - POUNDS PER IN<sup>2</sup>
- PSID - POUNDS PER IN<sup>2</sup> PRESSURE DROP
- PSIG - POUNDS PER IN<sup>2</sup> GAUGE
- R - RECOVERY FACTOR
- SG - STEAM GENERATOR

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DKW  
7/25/90 P. 99 of 59  
1060167

SUBJECT AFW FLOW VENTURE SIZING

DESIGN CALCULATION NO. 26-2836 SUPPL. 13 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R.O. WJ DATE 3/20/90 CHK. BY Ø DATE 5/9/90

$P_v$  - VAPOR PRESSURE

$Q$  - VOLUMETRIC FLOW RATE

$V$  - VELOCITY

$\Delta P$  - PRESSURE DROP

$\rho$  - DENSITY

150, 145, 140, 135 - VENTURE SIZES BASED ON  
MAXIMUM DESIGN FLOW RATE OF VENTURE

SUBSCRIPTS

T - TOTAL (ALL THREE STEAM GENERATORS)

1, 2, 3 - ANY OF THREE INDIVIDUAL STEAM GENERATORS

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 25 OF 62 SHEETS

DKH  
7/25/90 P. 1008  
1070/67  
SUPPL. B  
DC 2836

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DC 2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R. A. Hoff DATE 3/22/90 CHK. BY Ø DATE 5/9/90

B.O CALCULATIONS

B.1 EXISTING VENTURIS

THE MAXIMUM FLOW RATE WILL OCCUR WITH PUMPS G10 AND G10S OPERATING AND PARTIAL FLOW COMING FROM PUMP G10W AT THE LOW FLOW PUMP G10 + G10S START SIGNAL LEVEL. FIGURE 1 (FIGURE 10 OF REFERENCE B), SHOWS THAT THE (G10 + G10S + G10W) PUMP CURVE INTERSECTS THE VENTURI CURVE AT 555 GPM AND 1090 PSIG. THUS, THE CURRENT VENTURIS LIMIT SQ FLOW TO 555 GPM OR 555/3 = 185 GPM / STEAM GENERATOR.

FOR A CAVITATING VENTURI, FLOW IS LIMITED BY FLUID FLASHING.

$$\therefore \Delta P = P_{INLET} - \text{VAPOR PRESSURE} \quad (1)$$

$$\Delta P = \frac{\rho V^2}{2g_c} = \frac{\rho \left( \frac{Q^2}{A^2} \right)}{2g_c} \quad (2)$$

@ 70 °F VAPOR PRESSURE = 0.4 PSIA (REF. B)

$$\Delta P = 1090 + 14.7 - 0.4 = 1104 \text{ psid.}$$

IF  $\frac{\rho}{A^2 2g_c} \equiv C$ , THEN

$$\Delta P = \frac{Q^2}{C} \quad (3)$$

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 25.16 OF 62 SHEETS

DEPT 7/25/90 P. TOTAL 108 V167

SUBJECT AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DE-283 SUPPL. 3 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R.A. [Signature] DATE 3-22-90 CHK. BY [Signature] DATE 5/9/90

REARRANGING,  $C = \frac{Q^2}{\Delta P} \quad (4)$

FOR THE CURRENT VENTURI

$$C = 185^2 / 1104 = 30.99$$

THE THROAT DIAMETER OF THE EXISTING VENTURI = 0.440" (REF. 7)

∴ THE AREA OF THE EXISTING VENTURI

$$= \frac{\pi}{4} (.440/12)^2 = 1.056E-3 \text{ ft}^2$$

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DKR  
7/25/90  
109 0/167  
SUPPL. B  
DC-2026 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. 0

I.O. NO. \_\_\_\_\_ MADE BY E.A. W DATE 3/24/90 CHK BY Ø DATE 5/9/90

8.2 NON-CAVITATING VENTURI PRESSURE LOSSES

WHEN FLOW ENTERS A VENTURI, ITS STATIC PRESSURE DROPS, AS VELOCITY INCREASES, REACHING A MINIMUM AT THE THROAT. IF CAVITATION DOES NOT OCCUR, MOST OF THE PRESSURE LOSS IS RECOVERED IN THE VENTURI EXIT.

$$\text{FROM BERNULLI, } P_0 - P' = \frac{\rho V^2}{2g_c} = \frac{\rho}{2g_c} \left(\frac{Q}{A}\right)^2 \quad (5)$$

THE IRREVERSIBLE LOSSES ARE:

$$(1-R) \frac{\rho}{2g_c} \left(\frac{Q}{A}\right)^2 \quad (2), \text{ WHERE } R = \text{RECOVERY FACTOR}$$

DEFINING  $K'_V \equiv (1-R) \equiv \text{NON-CAVITATING LOSS FACTOR}$

$$\text{THUS } \Delta P = K'_V \frac{\rho}{2g_c} \left(\frac{Q}{A}\right)^2 \quad (6)$$

OR COMBINING ALL CONSTANTS INTO  $K_V''$

$$\Delta P = K_V'' \left(\frac{Q}{A}\right)^2 \quad (7)$$

$$\text{IF } K_V' \equiv \Delta P / Q^2 \quad (8)$$

FOR ANY GIVEN VENTURI

$$\text{OR } \Delta P = K_V Q^2 \quad (9)$$



ENGINEERING DEPARTMENT  
 CALCULATION SHEET

 DKH  
 7/25/90 P. 103 of 110  
 167
SUBJECT AFW FLOW VENTURIZ SIZINGDESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO.

MADE BY R. Q. [Signature]DATE 3/22/90CHK. BY [Signature]DATE 5/5/90
 TEST DATA FROM REFERENCES 1A02 SHCW :  
 TABLE 8-1

Q (GPM)	$\Delta P$ (PSI)	$K_v$ (CALCULATED FROM EQ (4))	VENTURI S/N
39.49	5.49	3.52 E-3	5413
60.30	13.97	3.84 E-3	5413
42.67	5.64	3.09 E-3	5414
62.58	13.04	3.33 E-3	5414
40.0	6.79	4.24 E-3	5415
61.52	16.39	4.33 E-3	5415

AVG.  $K_v$  @ 50 TO 62 GPM (AREA OF INTEREST)  
 $\approx 3.8 \text{ E-3}$

USE THIS VALUE TO DETERMINE LOSSES DUE TO VENTURIZ, WHEN OPERATING ON THE SYSTEM CURVES.

THERE ARE THREE SCENARIOS IN WHICH THE NON-CAVITATING LOSSES THRU THE VENTURIZ MIGHT AFFECT VENTURIZ SIZING, NAMELY:

- 185 GPM TO 3 SCS = 61.7 GPM/SC (SEG 5.1.3)
- 165 GPM TO 3 SCS = 55.0 GPM/SC (SEG 5.1.4)
- 100 GPM TO 2 SCS = 50.0 GPM/SC (SEG 5.1.4)

FROM EQ (5)  $\Delta P_{\text{VENTURIZ}} =$   
 @ 50 GPM  $\Delta P = 3.8 \text{ E-3} \times 50^2 = 9.50 \text{ PSI}$

@ 55 GPM  $\Delta P = 3.8 \text{ E-3} \times 55^2 = 11.50 \text{ PSI}$

@ 61.7 GPM  $\Delta P = 3.8 \text{ E-3} \times 61.7^2 = 14.47 \text{ PSI}$

DWS. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DEPT 7/25/90 P. 1st of 19  
111 167

SUBJECT AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DC-2036 REVISION 0  
SUPPL. B

J.O. NO. \_\_\_\_\_ MADE BY CAH DATE 2/24/90 CHK. BY 0 DATE 5/9/90

8.3 RESIZE VENTURIS

RESIZE VENTURIS FOR THE FOLLOWING FLOW RATES: 150, 145, 140 AND 135 GPM, AS FOLLOWS:

1) OBTAIN PRESSURE CORRESPONDING TO EACH FLOW RATE FROM (G10 + G10S + G10W) PUMP CURVE. (FIGURE 1.)

2) CALCULATE A VENTURI FLOW COEFFICIENT (C) FOR EACH FLOW RATE SIZE OF VENTURI USING THE EQUATION:  $C = \frac{Q^2}{P - P_v}$  (10)

$$C = \frac{Q^2}{P + 14.7 - 0.4} = \frac{Q^2}{P + 14.3}$$

Q (GPM)	TABLE 8-2 P (PSIG)	C
150	1159	19.41
145	1167	18.02
140	1174	16.70
135	1184	15.36

FROM EQUATIONS (2) AND (10)

$$Q^2 \sim A^2 \Delta P \sim C \Delta P \quad (11)$$

$$\therefore A^2 \sim C \quad (12)$$

$$A \sim \sqrt{C} \quad (13)$$

$$\therefore D \sim C^{1/4} \quad (14)$$

DWG. NO.

ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

SUBJECT AFW FLOW VENTURE SIZING

J.O. NO. \_\_\_\_\_ MADE BY R.Q.M. DATE 2/26/90 CHK. BY 0 DATE 5/4/90

FROM SECTION 8.1,  $C_{EXISTING} = 30.99$   
 $A_{EXISTING} = 1.056E-3 \text{ ft}^2$   
 $D_{EXISTING} = 0.440 \text{ in}$

RATIONS BY EQUATIONS (12) AND (13) YIELDS THE

FOLLOWING:

VENTURE SIZE	TABLE 9-3 A (FT <sup>2</sup> ) * E3	D (IN)
185 (EXIST) GPM	1.056	0.440
150	0.835	0.391
145	0.804	0.384
140	0.774	0.377
135	0.743	0.369

FROM EQ. (8);  $KV \cdot \Delta P / Q^2 \cdot C = Q^2 / \Delta P$  (FROM (10))

$\therefore KV \sim 1/C$  (15)

CALCULATING K FROM KV OF 9.2, RATIONS BY 1/C (EQ. 15)

VENTURE SIZE	TABLE 8-4 KV
185	3.8E-3
150	6.07
145	6.55
140	7.07
135	7.67

NOTE - DURING THE REST OF THIS CALCULATION, VENTURES WILL BE IDENTIFIED BY MAXIMUM FLOW THEY WILL PASS. i.e.

150, 145, 140, OR 135

ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

SHEETS 21 OF 62 SHEETS  
 DKH  
 7/25/90 P. J. [Signature]  
 SUPPL. B 113 167

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R. A. [Signature] DATE 3/22/90 CHK. BY [Signature] DATE 5/9/90

CALCULATE EFFECT OF NEGLECTING PRESSURE  
 LOSSES BETWEEN PUMPS AND VENTURIS WHEN  
 CALCULATING VENTURI FLOW RATES.

FROM PAGES 80 TO 81 OF REFERENCE 2:

AT A FLOW OF 131 GPM/SQ

$$\begin{aligned} \text{PUMP DISCH PRESSURE} &= 1244.7 \text{ PSIG} \\ \text{VENTURI INLET PRESSURE} &= 1224.1 \text{ PSIG} \\ &\quad \underline{20.6 \text{ PSIG}} \end{aligned}$$

$$\% \text{ ERROR} = \frac{20.6}{1224.1} = 1.7\%$$

VENTURIS SIZING IS BASED ON INLET PRESSURE,  
 ∴ RESULTS WILL BE  $\leq 1.7\%$  CONSERVATIVE FOR  
 ALL CASES IN WHICH IT IS DESIRABLE TO LIMIT  
 FLOW. (CASES 1, 5, AND 6). THERE WILL BE  
 NO EFFECT ON CASES 3 AND 4, BECAUSE VENTURIS  
 DO NOT CAVITATE IN THESE CASES. CASE 2 WILL  
 BE CALCULATED CORRECTLY BECAUSE VENTURI  
 SPECIFICATION AND CALCULATION ARE BOTH  
 BASED ON VENTURI INLET PRESSURE.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKH  
7/25/90 P 1074 159  
114 167

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC 2838 REVISION 0

I.O. NO.

MADE BY

R. G. W.

DATE 3/26/90

CHK. BY

D

DATE 2/9/90

8.4 CALCULATE FLOW RATES AT EACH DESIGN CONDITION

FLOW RATES WILL BE PROVIDED FOR EACH VENTURI SIZE AT EACH OF THE FOLLOWING DESIGN CONDITIONS:

1. CASE 1 (SEE 5.1.1) MAX FLOW  $(G_{10} + G_{10S} + G_{10W})$   
TO 3 UNPRESSURIZED S.G.S (MAX = 150 GPM/SG)
2. CASE 2 (SEE 5.1.2) MIN. FLOW  $G_{10W}$  OR  $G_{10S}$   
TO 2 UNPRESS. S.G.S + 1 BREAK (MIN = 175 GPM/2SG)
3. CASE 3 (SEE 5.1.3) MIN. FLOW  $G_{10W}$  OR  $(G_{10} + G_{10S})$   
TO 3 S.G.S @ 1015 PSIG (MIN = 185 GPM/3 SG)
4. CASE 4 (SEE 5.1.4) MIN. FLOW  $G_{10}$  TO  
3 S.G.S @ 1015 PSIG (MIN = 165 GPM/3 S.G.)
5. CASE 5 (SEE 5.1.5) MIN. FLOW  $G_{10W}$  OR  $(G_{10} + G_{10S})$   
TO 2 S.G.S @ 1015 PSIG + 1 BREAK (MIN = 100 GPM)
6. CASE 6 (SEE 5.1.5) MAX FLOW  $G_{10S} = 420$  GPM

8.4.1 CASE 1 MAX.  $(G_{10} + G_{10S} + G_{10W})$  FLOW TO 3 S.G.S

BY DEFINITION (SEE 8.3) FLOWS ARE  
150, 145, 140 & 135 GPM.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 23 OF 62 SHEETS

DEY 7125/40 P. 108/115 167

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R.A. [Signature] DATE 3/26/90 CHK. BY [Signature] DATE 5/9/90

8.4.2 CASE 2 G10W or G10S FLOW TO 2 UNPRESS. SCS + 1 FW BREAK

By inspection of Figs 1 & 3, G10S is a smaller pump than G10W.  
∴ ANALYZE FOR G10S ONLY, AS IT BOUNDS G10W.

USING EQUATION (10) AND THE FLOW COEFFICIENTS FOR EACH FLOW, CALCULATE VENTURI (CAVITATING) CURVES FOR EACH SIZE VENTURI IN THE REGION OF INTERSECTION WITH THE G10S ACTUAL PUMP CURVE AND PLOT TO FIND INTERSECTION ON FIG. 2.

RESULTS ARE SHOWN IN TABLE 4-5, BELOW.

TABLE 4-5

VENTURI SIZE (GPM)	C	Q (CURVE) ①		P = Q <sup>2</sup> /C ②	Q CALC'D ③			P CALC'D
		15G	35G		15G	25G	35G	
150	19.41	115	345	681	113	227	340 @	665
		110	330	623				
145	18.02	110	330	671	111	223	335 @	680
		115	345	734				
140	16.70	110	330	725	109	217	325 @	705
		105	315	660				
135	15.39	105	315	716	106	212	318 @	730
		110	330	786				

① USED TO CALCULATE VENTURI CURVE FROM EQ. (10)

② CALC'D FROM ① AND EQ. (10) TO DEVELOP VENTURI CURVE

③ CALC'D FROM INTERSECTION OF VENTURI CURVES (POINTS ① AND ②) AND G10S ACTUAL PUMP CURVE (FIG. 2)

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DKW  
7/25/90 P. 1098  
SUPPL 0 116 167  
DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DC-2836 REVISION 0

JO NO. \_\_\_\_\_ MADE BY R.G.W. DATE 3/22/90 CHK BY Ø DATE 5/9/95

8.4.3 CASE 3 G10W or (G10+G10S) FLOW TO 3 SG AT 1015 PSIG

INSPECTION OF FIGURE 3 SHOWS THAT IN THE AREA OF INTEREST ( $\approx 185$  GPM), THE PUMP CURVES FOR G10W AND (G10+G10S) INTERSECT EACH OTHER. THEREFORE, EVALUATION WILL CONSIDER BOTH PUMP CURVES, AS APPROPRIATE.

FLOW TO THE STEAM GENERATORS IS CONTROLLED BY FRICTION AND ELEVATION LOSSES, (RATHER THAN VENTURE CAVITATION, 6/4/81/90) BECAUSE OF THE HIGH STEAM GENERATOR PRESSURE. THESE LOSSES HAVE BEEN DEFINED BY REF. 6, p. R4-26 IN A SYSTEM CURVE FOR THE EXISTING DESIGN. BECAUSE REDUCING THE SIZE OF THE VENTURIS WILL INCREASE SYSTEM LOSSES, THE SYSTEM CURVE MUST BE RECALCULATED FOR EACH SIZE VENTURI. LOSS COEFFICIENTS FOR EACH VENTURI SIZE WERE CALCULATED IN SECTION 8.3. A NEW SYSTEM LOSS COEFFICIENT WILL BE CALCULATED FOR EACH VENTURI, BY ADDING THE INCREASE IN LOSS COEFFICIENT FOR EACH VENTURI TO THE EXISTING SYSTEM LOSS COEFFICIENT.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DKF  
7/25/90 P.H. of 59  
SUPP. B 117 167  
DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURE SIZING

DESIGN CALCULATION NO. \_\_\_\_\_

J.O. NO. \_\_\_\_\_ MADE BY R. A. W. DATE 3/26/90 CHK. BY CD DATE 5/9/90

DATA TO PLOT FIGURE 3

PLOT  $G_{10W}$  AND  $(G_{10} + G_{10S})$  ON THE SAME PLOT. USE AN EXPANDED SCALE THAT ENCOMPASSES AREA OF INTEREST (100 GPM TO 300 GPM)

$G_{10W}$  (FROM  $G_{10W}$  ADJUSTED CURVE, SHEET 24-57 OF REF. 6):

Q	P
100	1290
150	1260
200	1200
250	1130
300	1045

$(G_{10} + G_{10S})$  (FROM  $G_{10} + G_{10S}$  ACTUAL CURVE, SHEET 24-59)\* OF REF. 6, (FIGURE 2 OF THIS CALCULATION):

Q	P	* $(G_{10} + G_{10S})$ ACTUAL AND $(G_{10} + G_{10S})$ ACTUAL MERGE AT 300 GPM.
132	1225	
150	1220	
200	1210	
250	1195	
300	1175	

AT THIS TIME, ALSO PLOT  $G_{10}$  ACTUAL CURVE FOR FUTURE USE.

DWG. NO.



ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 25-26 OF 62 SHEETS

OKH  
7/25/90 P.H.H. 118  
SUPPL. B 118  
DC-2896 REVISION 0

SUBJECT AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC-2896 REVISION 0

J.O. NO. \_\_\_\_\_

MADE BY PAH

DATE 3/22/90

CHK. BY 0

DATE 5/9/90

G-10 FROM G10 ACTUAL CURVE OF REF. 6  
(FIG. 2 THIS CALCULATION)

Q	P	
150	1210	} EXTRAPOLATED
200	1170	
250	1125	
275	1100	
300	1070	

DWG. NO. \_\_\_\_\_

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEETS-27 OF 62 SHEETS  
DKH  
7/25/90 P. 42 of 49  
SUM 3 119 167  
DC 2836 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DC 2836 REVISION 0

I.D. NO. \_\_\_\_\_ MADE BY R. E. Hoff DATE 3/12/90 CHK. BY P DATE 5/9/90

FROM REFERENCE 6, SHEET 24-26, THE PRESSURE LOSS DUE TO ELEVATION = 10.6 PSID

FROM REFERENCE 6, SHEET 24-27

$Q_{TOTAL} = 604 \text{ GPM} @ 300 \text{ PSID}$  on  $201.3 \text{ GPM/SG} @ 300 \text{ PSI}$

FRICTION LOSS =  $300 - 10.6 = 289 \text{ PSI}$

$$\text{SYSTEM } K \equiv \frac{\Delta P}{Q^2} = \frac{289}{201.3^2} = 7.13 \text{E-3}$$

FROM 8.3, CURRENT VENTURI  $K = 3.8 \text{E-3}$

$\therefore K$  OF SYSTEM WITHOUT VENTURI =

$$(7.13 - 3.8) \text{E-3} = 3.33 \text{E-3}$$

CALCULATE A SYSTEM  $K$  FOR EACH SIZE VENTURI. THEN, CALCULATE LIMITED SYSTEM CURVES FOR EACH SIZE VENTURI NEAR INTERSECTIONS WITH PUMP CURVES.

$$\Delta P = KQ^2 + \text{ELEV. LOSS} = KQ^2 + 11.$$

FOR AN. SG AT 1015 PSIG,  $P = 1015 + \Delta P$   
 $= 1026 + KQ^2$

TABLE 8-6, BELOW SHOWS: THE <sup>ESTIMATED</sup>  $\Delta P$  FOR EACH VENTURI AT THE MINIMUM FLOW OF  $185/3 = 61.7 \text{ GPM/VENTURI}$ , NEW SYSTEM  $K$ 'S FOR EACH VENTURI AND THE TOTAL FLOW TO THE THREE STEAM GENERATORS

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 5.28 OF 62 SHEETS

DKH  
7/25/90 P-43  
120 167

SUBJECT: AFW FLOW VENTURE SIZING

DESIGN CALCULATION NO. DC2836 REVISION C

JO. NO. \_\_\_\_\_ MADE BY PA W DATE 3/22/90 CHK. BY P DATE 5/9/90

TABLE 9-6

VENTURE SIZE	$K_v$ ①	$\Delta P_{VENT.}$ ② @ 185 GPM TOTAL	$K_{SYS}$ ③	$Q_{CURVE}$ ④	$P$ ⑤	$Q_{CALC.}$ ⑥
150	6.07 E-3	23.1	9.41 E-3	270	1102	268
				240	1086	
145	6.55	24.9	9.88	270	1106	266
				240	1089	
140	7.07	26.9	10.40	270	1110	265
				240	1093	
135	7.67	29.2	11.00	270	1115	263
				240	1096	

① FROM TABLE 9.4

②  $\Delta P = K + 61.7^2$  (61.7 = 185/3)

③  $K_{SYS} = 3.33E-3 + K_v$

④ INPUT VALUE FOR SYS. CURVE

⑤ CALC'D FROM  $P = 1026 + K_{SYS} Q^2$

⑥ FROM INTERSECTION OF SYS. CURVE WITH GLOW PUMP CURVE (FIG 3)

ALL VENTURIS. HAVE LARGE MARGIN

CALCULATE MAXIMUM  $K$  &  $\Delta P$  VENTURE AT 61.79 gpm / SC  
= 185 gpm TOTAL

AT 185 GPM  $P = 1214$  (G10 + G10S PUMP CURVE)

$\Delta P_{SYS} = 1214 - (1015 + 11) = 188$  PSID

$K = 188 / \left(\frac{185}{3}\right)^2 = 49.4 E-3$

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 5.29 OF 62 SHEETS

DATE 7/25/90  
SUNAB 121 167  
P. H. H. 159

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 0

JO. NO.

MADE BY

P. Q. W.

DATE

3/22/90

CHK. BY

P

DATE

5/9/90

$$K_{\text{ALLOWABLE VENTURI}} = 49.4 \text{ E-3} - 333 \text{ E-3}$$

$$= 46.3 \text{ E-3}$$

$$\Delta P_{\text{ALLOWABLE}} = 46.3 \text{ E-3} + \left(\frac{185}{3}\right)^2 = 175 \text{ PSI}$$

WHICH IS MUCH LARGER THAN ESTIMATED

$\Delta P$ 'S OF 23.4 TO 29.2 PSI.  $\therefore$  THIS CASE  
WILL NOT CONTROL THE DESIGN, BUT MAY  
BE THE LIMITING CASE WITH RESPECT  
TO PRESSURE DROP.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEETS 30 OF 62 SHEETS

DK 4  
7/25/90 P.H.S. 122 167  
SUPPL B

SUBJECT: AFW VENTURI SIZING

DESIGN CALCULATION NO. DC-2936 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY RA. JF DATE 3/22/90 CHK. BY Ø DATE 5/9/90

8.4.4 CASE 4 G10 TO 3SGS AT 1015 psig

ANALYSIS IS SIMILAR TO CASE 3, EXCEPT THAT FLOWS ARE DETERMINED BY INTERSECTION OF NEW SYSTEM CURVES, CALCULATED IN 8.4.3, WITH G10 PUMP CURVE.

IN THIS FLOW RANGE G10 CURVE IS VERY CLOSE TO G10W CURVE (SEE FIG. 3). ∴ USE SYSTEM CURVES CALCULATED IN 8.4.3 TO DETERMINE FLOWS. FROM FIG. 3 :

TABLE 8. - 7

VENTURI SIZE	G10 FLOW GPM
150	272
145	270
140	268
135	265

AT 165 GPM  $P_0$  of G10  $\approx$  1198 psim

$$\Delta P = 1198 - 1026 = 172 \text{ psi}$$

$$K = 172 / \left(\frac{165}{3}\right)^2 = 56.9 \text{ E-3}$$

LARGER THAN FOR CASE 3

∴ CASE 3 K BOUNDS CASE 4

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 31 OF 62 SHEETS  
DKIT  
7/25/90  
SUPPL. B  
123  
167  
P446  
0  
0

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC-2076 REVISION 0

JO NO \_\_\_\_\_ MADE BY R. Q. W. DATE 3/22/90 CHK BY Ø DATE 5/9/90

8.4.5 CASE 5 GLOW OR (G10+G105) TO 250  
AT 1015 PSIG AND 1 BREAK

FROM FIGURE 3, GLOW AND (G10+G105) PUMP CURVES INTERSECT NEAR AREA OF INTEREST. BOUNDING CASE WILL BE DETERMINED DURING ANALYSIS. BOUNDING CASE IS PUMP THAT PROVIDES THE LEAST FLOW TO THE BREAK.

THE SYSTEM CURVE WILL CHANGE WHEN THERE IS A BROKEN LINE, BECAUSE

$$Q_T = Q_1 + Q_2 + Q_3 \quad (16)$$

WHERE:

$Q_T$  = TOTAL FLOW

$Q_1 = Q_2$  = FLOW TO PRESSURIZED STEAM GENERATOR

$Q_3$  = FLOW THROUGH BREAK

$$Q_1 = Q_2 = K_{1,2} \sqrt{(P_0 - P_{SG} - P_{GL})} \quad (17)$$

$P_0$  = PUMP DISCH PRESS

$P_{SG}$  = ST. GEN PRESS

$P_{GL}$  = ELEV PRESS. LOSS

$$Q_3 = C_3 \sqrt{(P_0 - P_V)} \quad (18)$$

$C_3$  = VENTURE COEFFICIENT

$P_V$  = VAPOR PRESSURE

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 5.32 OF 62 SHEETS

DKH  
7/25/90 P-170-59  
124 167

SUBJECT AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R. E. W. J. DATE 7/22/90 CHK. BY [Signature] DATE 5/9/90

COMBINING (16), (17) AND (18) YIELDS

$$Q_T = 2/K_{1,2} \sqrt{P_0 \cdot P_{S2} \Delta P_{EL}} + C_3 \sqrt{P_0 + (14.7 \cdot P_V)} \quad (19)$$

FOR SC PRESSURE OF 1015 PSIA,  $\Delta P_{EL} = 11$  PSIA (SEE 8.4.3)

AND  $P_V = 0.4$  PSIA (SEE 8.17); YIELDING:

$$Q_T = 2/K_{1,2} \sqrt{P_0 \cdot 1025} + C_3 \sqrt{P_0 + 14.3}$$

$K_{SYS}$  VALUES WERE CALCULATED IN SECTION 8.2

FOR USE IN EQUATION (9),  $\Delta P = K_{SYS} Q^2$

OR  $K_{SYS} = \Delta P / Q^2$  (NOTE:  $K_{SYS}$  IS FOR 1 LOOP TO SA)

BUT IN EQ. (9)  $K_{1,2} = Q / \sqrt{\Delta P}$

$$\therefore K_{1,2} = 1 / \sqrt{K_{SYS}} \quad (20)$$

C VALUES WERE DEVELOPED IN SECTION 8.3 FOR USE IN

EQ. (10).  $\Delta P = Q^2 / C$  OR  $C = Q^2 / \Delta P$

BUT IN EQ. (19)  $C_3 = Q / \sqrt{\Delta P}$

$$\therefore C_3 = \sqrt{C} \quad (21)$$

CALCULATE  $K_{1,2}$  &  $C_3$  FOR EACH VENTURI SIZE.

RESULTS ARE SUMMARIZED IN TABLE 8-8

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DATE 7/25/90  
SUPPL. # 125  
DESIGN CALCULATION NO. 06-2876  
REVISION 0

SUBJECT AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. 06-2876 REVISION 0

I.O. NO. \_\_\_\_\_ MADE BY P.A. Wf DATE 3/22/90 CHK. BY P DATE 5/9/90

TABLE 8-8

VENTURI SIZE	$K_{sys} \times E_3$	$K_{1,2}$	C	$C_3$
150	9.40	10.31	19.47	4.41
145	9.88	10.06	18.02	4.24
140	10.40	9.81	16.70	4.09
135	11.00	9.53	15.39	3.92

o USING THE ABOVE VALUES, DEVELOP SYSTEM CURVES FOR EACH VENTURI SIZE IN AREA THAT WILL INTERSECT  $Q_{10W}$  OR  $(Q_{10} + Q_{10S})$  PUMP CURVES, USING EQUATION (19).

o CALCULATE  $Q_T$  AND  $P_D$  FROM INTERSECTION WITH PUMP CURVE (SEE FIGURE 2)

o CALCULATE  $Q_1, Q_2$  &  $Q_3$  FROM EQUATIONS (17) AND (18).

LIST ALL VALUES IN TABLE 8-9, BELOW



ENGINEERING DEPARTMENT  
CALCULATION SHEET

DKW  
7/27/90  
SUPPL. B 126  
DC22836  
REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. 0

JG NO. \_\_\_\_\_ MADE BY R. J. [Signature] DATE 2/22/90 CHK. BY [Signature] DATE 5/9/90

TABLE 8.9

VENTURI SIZE	$K_{1,2}$	$C_3$	$P_0$ CURVE	$Q_T$ CURVE	$Q_T$ CALC	$P_0$ CALC	$Q_{1+2}$	$Q_3$
150	10.31	4.41	1080	297	285	1072	140	145
145	10.06	4.24	1070	282	284	1076	142	140
140	9.81	4.09	1080	279	281	1081	146	135
135	9.53	3.92	1090	270	278	1086	148	130

- ① FROM TABLE
- ② INPUT FOR SYSTEM CURVE
- ③ CALCULATED FROM EQ. (9)
- ④ FROM INTERSECTION OF SYS. CURVE & PUMP CURVE FIG 3
- ⑤ FROM EQ. (17) AND  $P_0$  CALC
- ⑥ FROM EQ. (18) AND  $P_0$  CALC.

\*NOTE - ALL FLOWS GREATER THAN 100 GPM REQUIRE ACCT

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 15-35 OF 62 SHEETS

DELT  
7125190 P. 1200-150  
127 167

SUBJECT AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC 2836 REVISION 0

J.O. NO. \_\_\_\_\_

MADE BY R.L.H.

DATE 3/22/91

CHK. BY Ø

DATE 5/9/90

ALL VENTURI SIZES IN TABLE 8-9 PROVIDE SUFFICIENT MARGIN, AS  $(Q_1 + Q_2)$  RANGES FROM 139 GPM TO 148 GPM. THE REQUIRED VALUE IS 100 GPM BECAUSE REDUCING VENTURI SIZE HAS A GREATER EFFECT ON FLOW LOST THROUGH THE LEAK, THAN ON SYSTEM FLOWS, THE SMALLER VENTURIS PERMIT MORE FLOW TO THE STEAM GENERATORS.

CHECK MARGIN ON  $\Delta P$

AT 100 GPM  $P_n (G10 + G105) = 1250$

$\Delta P = 1250 - 1026 = 224$

$K = 224 / \left(\frac{100}{2}\right)^2 = 89.6 E-3$

$89.6 E-3 > 50.5 E-3$  CALCULATED IN 8.4.3

$\therefore$  THE LOSSES ARE BOUNDED BY CASE 3.

8.4.6 CASE 6 G105 FLOW LIMIT

SECTION 8.4.2 CALCULATED FLOW TO EACH STEAM GENERATOR USING THE ACTUAL G105 CURVE. EXTRAPOLATING THE VENTURI CURVES TO THE G105 DESIGN CURVE YIELDS:

THE RESULTS PRESENTED BELOW, IN TABLE 8-10

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 25.36 OF 62 SHEETS

DKH  
7/25/90 P. 125  
SUPPL B 128 167

SUBJECT: AFW FLOW VENTURI SIZE

DESIGN CALCULATION NO. DC-2836 REVISION 0

JO. NO.

MADE BY

R. Q. Hoff

DATE 3/22/96

CHK BY

0

DATE

5/9/90

TABLE 8.10

VENTURI SIZE	G105 FLOW GPM
150	350
145	342
140	335
135	325

THUS, ALL VENTURIS PROVIDE LARGE MARGINS  
WITH RESPECT TO 420 GPM LIMIT.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DRAWN BY P. + 200/159  
7/25/90  
SUPPL 8 129 167

SUBJECT: AFW FLOW VENTURI SIZING DESIGN CALCULATION NO. DL-2836 REVISION 0

J.O. NO. \_\_\_\_\_ MADE BY R.A. WJ DATE 3/22/90 CHK. BY Ø DATE 5/4/90

8.5 DESIGN MARGINS

8.5.1 CASE 1 150 GPM MAX. / SG

REVIEW OF PREVIOUS CALCULATIONS SHOW ALL SIZES (135 - 150) PROVIDE LARGE MARGIN FOR ALL CASES.

IF 140 GPM +0, -10 GPM IS SELECTED  
MARGIN FOR CASE 1 IS  $\frac{150 - 140}{150} = 6.7\%$

AT 130 GPM MARGIN =  $\frac{150 - 130}{150} = 13.3\%$

8.5.2 CASE 2 175 MIN. TO TWO 061 SG + BREAK  
FROM SECTION 8.4.

FOR 135 GPM VENTURI 212 GPM PROVIDED  
MARGIN =  $\frac{212 - 175}{175} = 21\%$

REVIEW OF ALL CASES INDICATES CASE 2 WILL CONTROL DESIGN FOR CASE 1. PLOT CASE 1 FLOW VS. CASE 2 FLOW (FIGURE 4).

EXTRAPOLATING FLOW TO 130 GPM SHOWS 206 GPM TO 2 SGs

MARGIN =  $\frac{(206 - 175)}{175} = 18\%$

ENGINEERING DEPARTMENT  
CALCULATION SHEET

DKH  
7/25/90 P. 1234  
SUPPL. B 130 167  
DC-2036 REVISION 0

SUBJECT: AFW FLOW VENTURE SIZING

DESIGN CALCULATION NO. 0

J.O. NO. \_\_\_\_\_ MADE BY R. A. W. J. DATE 3/22/90 CHK BY 0 DATE 5/9/90

8.5.3 CASE 3 185 GPM TO 3 PRESS. SG (G10W) OR (G10+G10)

140 GPM DESIGN PROVIDES 265 GPM TO 3 SGS  
(8.4.3) TABLE 8-6

$$\text{MARGIN} = \frac{265 - 185}{185} = 43\% \quad (80 \text{ GPM})$$

EXTRAPOLATING TO 130 GPM SHOWS:

260 GPM TO 3 SA

$$\text{MARGIN} = \frac{260 - 185}{185} = 41\% \quad (7.5 \text{ GPM})$$

8.5.4 CASE 4 165 GPM TO 3 PRESS. SG (G10)

FROM 8.4.4 TABLE 8-7

140 GPM DESIGN PROVIDES 265 GPM

$$\text{MARGIN} = \frac{265 - 165}{165} = 61\% \quad (103 \text{ GPM})$$

EXTRAPOLATING TO 130 GPM YIELDS 262 gpm

$$\text{MARGIN} = \frac{263 - 165}{165} = 59\% \quad (98 \text{ GPM})$$

8.5.5 CASE 5 100 GPM TO 2 PRESS. SG + BREAK (G10W) OR (G10+G10)

FROM 8.4.5

A 140 DESIGN YIELDS 146 GPM.

$$\text{MARGIN} = \frac{146 - 100}{100} = 46\% \quad (46 \text{ GPM})$$

NOTE: SINCE ORIFICE SIZE, INCREASES FLOW.

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 25.39 OF 60 SHEETS

DKH  
7/25/90 P. 127 of 167  
SUPPL B 131

SUBJECT AFW FLOW VENTURE SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO.

MADE BY

R. A. Uff

DATE

3/22/96

CHK. BY

0

DATE

5/4/90

8.5.6 CASE 6 MAXIMUM GIOS FLOW  
FROM 8.4.6

140 DESIGN YIELDS 335 GPM

$$\text{MARGIN} = \frac{420 - 335}{420} = 20\%$$

(85 GPM)

EXTRAPOLATING TO 130 GPM YIELDS 320

$$\text{MARGIN} = \frac{420 - 320}{420} = 24\%$$

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEETDKIT  
7125/190 P. 125  
SUPPL 13 132 167  
DC 2836 REVISION 0SUBJECT AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO.

I.O. NO.

MADE BY

C. A. Hill

DATE 3/22/90

CHK. BY

D

DATE 5/9/90

8.6 DESIGN PARAMETERS

THIS SECTION PROVIDES THE PARAMETERS FOR SPECIFYING ORIFICE PERFORMANCE.

BASED ON CALCULATED MARGINS, A DESIGN OF 140 GPM  $\pm 0$ , -10 GPM APPEARS REASONABLE FROM (G10 + G10S + G10W) CURVE & SECTION 8.3 140 GPM OCCURS AT 1160 PSIG.

$\therefore$  SPECIFY VENTURES FOR 140  $\pm 0$ , -10 GPM AT 1160 PSIG. TO SATISFY CASE 1.

TO SATISFY CASE 2, EACH VENTURI MUST PASS 87.5 GPM. SPECIFY 100 GPM TO PROVIDE A MARGN. 100 GPM INTERSECTS G10S ACTUAL CURVE (FIGURE 2) AT 775 PSIG.

$\therefore$  SPECIFY THAT EACH VENTURI SHALL PASS AT LEAST 100 GPM AT 775 PSIG.

CASE 3 IS THE LIMITING CASE FOR NON-CAVITATION PRESSURE LOSS.

THE MAXIMUM ALLOWABLE PRESSURE DROP IS 175 PSID AT 61.7 GPM / VENTURE HOWEVER, TABLE 8-6 SHOWS THAT THE 140 GPM VENTURE SHOULD HAVE A 27 PSI PRESSURE DROP

DWG. NO.

ENGINEERING DEPARTMENT  
CALCULATION SHEETDEK  
7/25/90 P. 125  
SUPPL B 133  
167SUBJECT AF W FLOW VENTURI SIZINGDESIGN CALCULATION NO. DC-2836 REVISION 0

I.D. NO.

MADE BY R.G. WfDATE 3-22-90 CHK. BY ØDATE 5/5/90

EXTRAPOLATING TO A 130 GPM VENTURI YIELDS A  
32 PSID PRESSURE DROP.

∴ SPECIFY PRESSURE DROP NOT TO  
EXCEED 40 PSID AT 62 GPM. THIS SHOULD  
BE EASILY ATTAINABLE, PROVIDING AN EFFICIENT  
VENTURE, AND STILL PROVIDING CONSIDERABLE  
MARGIN  $(\frac{175-40}{40}) = 338\%$ .

THE VENTURE DIAMETER SHOULD BE APPROXIMATELY  
0.377" FROM TABLE B.3 TO PASS 140 GPM  
AT 130 GPM AND THE SAME PRESSURE, THE  
DIAMETER IS  $\approx 0.377 (\frac{130}{140})^{1/4} = 0.370$ .

THIS APPEARS TO BE READILY ATTAINABLE  
BECAUSE, IT REQUIRES A TOLERANCE OF  
 $+0, -0.0075$  INCH. OLD VENTURE TOLERANCE  
IS  $+0, -0.005$  INCH (REF. 7)



ENGINEERING DEPARTMENT  
CALCULATION SHEET

DEW  
7/21/90 P 127 of 159  
SUPPL. B 134 167  
DESIGN CALCULATION NO. DC-2836 REVISION 5

SUBJECT: AFW FLOW VENTURI SIZING

J.O. NO. \_\_\_\_\_ MADE BY R. Q. W. \_\_\_\_\_ DATE 5-21-96 CHK. BY \_\_\_\_\_ DATE \_\_\_\_\_

B.7 SUMMARY FIGURES

THE FOLLOWING SUMMARY FIGURES WILL BE PREPARED FOR THE RESULTS SECTION:

FIGURE 2-1 " SUMMARY PLOT - BEST ESTIMATE LOSSES FOR FLOW VENTURIS "

FIGURE 2-2 " SUMMARY PLOT MAXIMUM VENTURE PRESSURE LOSSES.

FIGURE 2-3 " CASE 5 CONDITIONS BASED ON MAXIMUM VENTURE  $\Delta P$ .

PUMP CURVES OBTAINED FROM FIGURES 1, 2, 3 AND ATTACHMENT H WILL BE PLOTTED ON FIGURES 2-1 AND 2-2. SYSTEM AND VENTURI CURVES, BASED ON THE BEST ESTIMATE OF VENTURE  $\Delta P$  WILL BE CALCULATED IN 8.7.1 AND PLOTTED ON FIGURE 2-1. SIMILAR CURVES BASED ON THE MAXIMUM ALLOWABLE VENTURE  $\Delta P$ 'S WILL BE CALCULATED IN 8.7.2 AND PLOTTED ON FIGURE 2-2. FIGURE 2-2 AND SECTION 8.4 RESULTS WILL BE SHOWN ON FIGURE 2-3, WHICH DEPICTS THE SYSTEM UNDER CASE 5 POSTULATED CONDITIONS

DWG. NO.

ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

DKH  
 7/25/90 P-128  
 SUPPL. 13  
 DC-2836  
 135 167  
 REVISION 0

SUBJECT: AFW FLOW VENTURE SIZING

DESIGN CALCULATION NO. \_\_\_\_\_

J.O. NO. \_\_\_\_\_ MADE BY E.A. Hoff DATE 5-21-90 CHK. BY \_\_\_\_\_ DATE \_\_\_\_\_

9.2.1 CALCULATE SYSTEM CURVES AND CAVITATION CURVES AND SUPERIMPOSE ON PLOT OF PUMP CURVE

DO FOR 135 AND 140 GPM VENTURES SYSTEM CURVE:

$$\Delta P = KQ^2 + \Delta P_{\text{bell}} = KQ^2 + 11.$$

FROM TABLE 8-6  $K(140) = 10.4E-3$  +  $K(135) = 11.00E-3$

FOR 15% FOR 3 SG'S DIVIDE K'S BY  $3^2 =$

$1.16E-3 (140)$  AND  $1.22E-3 (135)$

CAVITATING FLOW CURVE:

$$\Delta P = Q^2 / c \text{ OR } P = Q^2 / c - 14.$$

$c(140) = 16.70$  +  $c(135) = 15.39$  FOR 15%

FOR 3 SG  $c(140) = 16.7 \times 9 = 150.3$   $c(135) = 15.39 \times 9 = 138.5$

Q	140 sys + 1015 ft	135 sys + 1015 ft	CA(140)	CA(135)
100	1038	1038		
150	1052			
200	1072	1075	1077	
300	1130	1136	1142	585
325				669
350	1168			801
380				946
400	1212	1221	1232	1050
410				1104
425	1236			1188
435				1242
450	1261	1273		1333
				1448

DWG. NO. \_\_\_\_\_

ENGINEERING DEPARTMENT  
CALCULATION SHEET

SHEET 2541 OF 62 SHEETS

DLW 7/25/90 P-1270-159  
SUPPL. 3 136 167  
DC-2036 REVISION 0

SUBJECT: AFN FLOW VENTURI SIZING

DESIGN CALCULATION NO.

I.O. NO.

MADE BY

R. G. [Signature]

DATE 5-21-98

CHK. BY

DATE

8.7.2 EFFECT OF HIGHER VENTURI PRESSURE LOSSES

THE PREVIOUS CALCULATIONS USED  $K_s$  FOR NON-CAVITATING VENTURI PRESSURE LOSSES BASED ON TEST DATA FOR THE EXISTING VENTURIS MODIFIED TO ACCOUNT FOR THE CHANGED SIZES, AS CALCULATED IN SECTIONS 8.2 AND 8.7. LARGER VENTURI  $K_s$  WERE SPECIFIED AT THE VENTURI VENDOR'S REQUEST. THIS SECTION CALCULATES SYSTEM CURVES BASED ON THE SPECIFIED VENTURI LOSSES.

IF  $\Delta P_{max} @ 55 \text{ gpm} = 35 \text{ psid}$ :

$$K_v = \Delta P / Q^2 \text{ (Eq. 8)} = \frac{35}{55^2} = 1.157E-2$$

$$K_{sys} = 3.33E-3 + 1.157E-2 = 1.49E-2$$

IF  $\Delta P_{max} @ 62.5 \text{ gpm} = 45 \text{ psid}$ :

$$K_v = 45 / 62.5^2 = 1.152E-2 < 1.157E-2$$

$\therefore 55 \text{ GPM GMSG GOVERNS}$

$$P_{sys} = P_{sa} + \Delta P_{CL} + \Delta P_{sys}$$

@ 1015 psia & 11 psf  $\Delta P_{CL}$

$$P_{sys} = 1026 + 1.49E-2 \left(\frac{Q}{1.3}\right)^2$$

$$= 1026 + 1.656E-3 Q^2$$

DWG. NO.

ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

DKH P-1308-54  
 7125190 137 167  
 SUPPL. B  
 DESIGN CALCULATION NO. DC-2076 REVISION 0

SUBJECT: AFW FLOW VENTURIZING

J.O. NO. \_\_\_\_\_ MADE BY B. A. Hoff DATE 5.21.94 CHK. BY \_\_\_\_\_ DATE \_\_\_\_\_

SYSTEM CURVE

TOTAL FLOW (GPM)	PUMP DISC. PRESS (PSIG)
100	1044
200	1094
300	1176
350	1230
400	1292
450	1363

FOR CASE 5 (FROM 8.4.5)

$$Q_T = 2K_{1,2} \sqrt{P_0 - P_{sa} - \Delta P_{SL}} + C_3 \sqrt{P_0 + (14.7 - P_{PV})} \quad \text{Eq. 17}$$

$$= 2K_{1,2} \sqrt{P_0 - 1026} + C_3 \sqrt{P_0 + 14}$$

$$K_{1,2} = 1/\sqrt{K_{SYS}} \text{ (Eq. 20)} = 1/\sqrt{1.49E-2} = 8.19$$

$$Q_T = 2 * 8.19 \sqrt{P_0 - 1026} + 4.09 \sqrt{P_0 + 14}$$

PUMP DISCH. PRESS (PD) (PSIG)	TOTAL FLOW (Q_T) (GPM)
1050	212
1100	277
1150	322
1200	359
1250	390
1300	419

DWG. NO. \_\_\_\_\_

ENGINEERING DEPARTMENT  
 CALCULATION SHEET

 DKW  
 7/25/90 P. 131 of 157  
 SUPPL 3 138 167  
 DC-2836 REVISION 0

SUBJECT: AFW FLOW VENTURI SIZING

DESIGN CALCULATION NO. DC-2836 REVISION 0

J.O. NO.

MADE BY

R.L.M.

DATE

5/21/90

CHK. BY

DATE

$$\text{FOR CASE 5; } Q_T = 2K_{1,2} \sqrt{P_0 - 1026} + C_3 \sqrt{P_0 + 14.3}$$

$$\text{FOR 140 GPM VENTURI } 2K_{1,2} = 19.62, C_3 = 4.09$$

$$\text{135 GPM VENTURI } 2K_{1,2} = 19.06, C_3 = 3.92$$

P	Q <sub>T</sub> 140	Q <sub>T</sub> 135'
1026	132.	126.
1050	230	
1100	305	295
1150	358	
1200	401	388
1250	439.	
1300	473	458

DUE TO THE CLOSENESS OF THE VALUES FOR THE 135 GPM AND 140 GPM SYSTEM CURVES, PLOT VALUES FOR 140 GPM VENTURI SYSTEM CURVES ONLY.

$$\Delta P \text{ VENTURI AT CALCULATED FLOW OF 68 GPM / SG}$$

$$= 1.157E-2 (68)^2 = 53.5 \text{ psia}$$

SN 25-420F62

SUPPL B  
DC-2836 REV 0

MADE BY R.M. DATE 3/22/90 CHECKED BY CD DATE 5/4/90

DE 4  
7125190 P. 137  
157




FIGURE 1  
CAVITATING FLOW LIMIT

FIGURE 10

SH25-430F62

SUPPL. B  
DC 2836 REV. 0

MADE BY *[initials]* DATE 3/21/90 CHECKED BY *[initials]* DATE 5/7/90

71257403 170  
133 of 161  
59





FIGURE 11

SUPPLEMENT A DC-2836 REV. 20  
KIP

Made By R.A.W.P. Date 5/1/90  
 Ckd By [Signature] Date 5/9/90

Suppl. B  
 Calc No. DC2836 Rev. 0  
 Sh RS-44 of 62

**FIGURE 3**






SUPPL. B. DC-2036. RG40

MADE BY R. G. ~~W~~ DATE 3/26/90 CHECKED BY ~~Q~~ DATE 5/9/90

FIGURE 4  
COMPARISON OF  
CASE 1 AND CASE 2  
FLOWS WITH LIMITS

AFW FLOW (GPM) TO 2 DEG SG + FBRE FROM GLOW OR GLOS



MAXIMUM AFW FLOW TO 1 STEAM  
GENERATOR (GPIA) CASE 1

SUPPL. G DC-2836 REV. 0  
 ATTACHMENT A  
 P I I D  
 FROM REF. 2


MADE BY R.M.H. 3/22/90  
 CHECKBOOK DATE 5/8/93

SMRS-4806 6A

NUCLEAR GENERATION SITE  
 UNIT 1

AUXILIARY FEEDWATER SYSTEM

SYSTEM DESCRIPTION SD-501-620  
 REVISION 2 PAGE 25 OF 37



P. 155  
 DEK 7/25/80

FIGURE 1 - Ref 2  
 SUPPL. A DC-2836 Rev 0

FIGURE 1  
 SD-501-620-01-3

02/28/2011

ATTACHMENT B SUPPL B DC-2836 R0V0  
 VENTURI DWC

SH 125-47 CF 62

**SCE** Southern California Edison Company  
 Songs ① 2&3

INTERIM DCH NO.

MADE BY E. I. Uff 3/23/90  
 CHECKED BY [Signature] DATE 5/9/90

INTERIM DESIGN CHANGE  
 NOTICE (IDCN)/DESIGN  
 CHANGE NOTICE (DCN)  
 SUPPLEMENTAL PAGE

IDCN NUMBER 5-1					
DRAWING NO.	SHEET NO.	REV. NO.	DCN CONV.		QUALITY CLASS
			DATE		
			DWG. REV.	DCN NO.	
1810-AA319-M0007	-	0			SR


MSMP# 1-3587.01SM REV A SHT \_\_\_\_\_  
 DESCRIPTION OF CHANGE

Date 3-8-90 Page 2 of 3

By A. REYES

**BEFORE**

ORDER NUMBER	PERMIT SERIAL NO	PIPE SIZE	BETA RATIO	DESIGN		OPERATING		DESIGN FLOW RATE (CAVITATING MODEL)	FLUID
				PRESSURE	TEMP	PRESSURE	TEMP		
1810-AA319-M0007	N-5413	3" - SCH 80	.1517	600 PSIG	850 °F	524 PSIG	40°F	131 GPM @ 40 °F	WATER
1810-AA319-M0007	N-5414	3" - SCH 80	.1517	600 PSIG	850 °F	524 PSIG	40°F	131 GPM @ 40 °F	WATER
1810-AA319-M0007	N-5415	3" - SCH 80	.1517	600 PSIG	850 °F	524 PSIG	40°F	131 GPM @ 40 °F	WATER



P. 155-47  
 9/15/90  
 915/190

ATTACHMENT C  
 SYSTEM DESCRIPTION (REF. 3)

 NUCLEAR GENERATION SITE  
 UNIT 1

 SYSTEM DESCRIPTION SD-S01-620  
 REVISION 2 PAGE 2 OF 37

AUXILIARY FEEDWATER SYSTEM

 1.0 FUNCTIONS/DESIGN BASES

- 1.1 The Auxiliary Feedwater System has the following main functions:
- 1.1.1 To provide feedwater to the steam generators during abnormal or emergency conditions which result in a loss of Main Feedwater.
  - 1.1.2 To provide feedwater to the steam generators during normal start-up, normal shutdown and hot stand-by conditions.
- 1.2 The Auxiliary Feedwater System has the following additional functions:
- 1.2.1 To provide a means of filling and venting the Main Feedwater System in Modes 4, 5, or 6.
  - 1.2.2 To provide a means of filling and/or feeding the steam generators via the Main Feedwater System in Modes 4, 5 or 6.
- 1.3 The Auxiliary Feedwater System has the following design bases:
- 1.3.1 The Auxiliary Feedwater System is designed to provide sufficient steam generator feedwater flow and volume to achieve and maintain the Reactor Coolant System in 'HOT STANDBY' (Mode 3) for at least 32 hours, with no offsite power available, following a reactor trip from full power. The Steam Dump System is used in conjunction with the Auxiliary Feedwater System to meet this design basis.
  - 1.3.2 The Auxiliary Feedwater System is designed such that the Reactor Coolant System can be cooled down to less than 350°F from normal operating conditions with no offsite power available.
- 1.4 The Auxiliary Feedwater System has the following additional design bases:
- 1.4.1 The total minimum delivered flow to the steam generators from either AFW pumps G-10 and G-10S (operating concurrently) or AFW pump G-10W (operating alone) for all of feedwater events shall be 185 gpm (plus margin) at a steam generator pressure of 1015 psig.
  - 1.4.2 The total minimum delivered flow to the steam generators from AFW pump G-10 for station blackout events shall be 185 gpm (plus margin [1]) at a steam generator pressure of 1015 psig.

[1] This requirement anticipates the future application of generic Station Blackout requirements.

ATTACHMENT C  
SYSTEM DESCRIPTION (REF. 3)DEH 7/25/90  
P. 138  
145 167NUCLEAR GENERATION SITE  
UNIT 1SYSTEM DESCRIPTION SD-501-620  
REVISION 2 PAGE 2 OF 37AUXILIARY FEEDWATER SYSTEM1.0 FUNCTIONS/DESIGN BASES

1.1 The Auxiliary Feedwater System has the following main functions:

- 1.1.1 To provide feedwater to the steam generators during abnormal or emergency conditions which result in a loss of Main Feedwater.
- 1.1.2 To provide feedwater to the steam generators during normal start-up, normal shutdown and hot stand-by conditions.

1.2 The Auxiliary Feedwater System has the following additional functions:

- 1.2.1 To provide a means of filling and venting the Main Feedwater System in Modes 4, 5, or 6.
- 1.2.2 To provide a means of filling and/or feeding the steam generators via the Main Feedwater System in Modes 4, 5 or 6.

1.3 The Auxiliary Feedwater System has the following design bases:

- 1.3.1 The Auxiliary Feedwater System is designed to provide sufficient steam generator feedwater flow and volume to achieve and maintain the Reactor Coolant System in 'HOT STANDBY' (Mode 3) for at least 32 hours, with no offsite power available, following a reactor trip from full power. The Steam Dump System is used in conjunction with the Auxiliary Feedwater System to meet this design basis.
- 1.3.2 The Auxiliary Feedwater System is designed such that the Reactor Coolant System can be cooled down to less than 350°F from normal operating conditions with no offsite power available.

1.4 The Auxiliary Feedwater System has the following additional design bases:

- 1.4.1 The total minimum delivered flow to the steam generators from either AFW pumps G-10 and G-10S (operating concurrently) or AFW pump G-10W (operating alone) for each of feedwater events shall be 185 gpm (plus margin) at a steam generator pressure of 1015 psig.
- 1.4.2 The total minimum delivered flow to the steam generators from AFW pump G-10 for station blackout events shall be 185 gpm (plus margin [1]) at a steam generator pressure of 1015 psig.

[1] This requirement anticipates the future application of generic Station Blackout requirements.

SUPPL. 3 OC-2886 REV 0  
ATTACHMENT C  
(CONT)

MADE BY RAH 3/23/91 SN 25-49-0162  
CHECKED BY [initials] DATE 5/9/90 DEK 7/25/90  
P. 139 146 167

NUCLEAR GENERATION SITE  
UNIT 1

SYSTEM DESCRIPTION SD-S01-620  
REVISION 2 PAGE 3 OF 37

AUXILIARY FEEDWATER SYSTEM

1.0 FUNCTIONS/DESIGN BASES (Continued)

- 1.4.3 The total minimum delivered flow to the unaffected steam generators from AFW pump G-10W for feedwater line break events (upstream of the in-containment check valves) shall be 125 gpm (plus margin) at a steam generator pressure of 1015 psig with operator action to equalize flow in each AFW line.
- 1.4.4 The total minimum delivered flow to the unaffected steam generators from AFW pump pumps G-10 and G-10S, operating concurrently, for feedwater line break events (upstream of the in-containment check valves) shall be 125 gpm (plus margin) at a steam generator pressure of 1015 psig without operator action to equalize flow in each AFW line.
- 1.4.5 The total minimum delivered flow to the unaffected steam generators from AFW pump G-10W or G-10S for feedwater line break events (downstream of the in-containment check valves) shall be 250 gpm (plus margin) at depressurized steam generator conditions.
- 1.4.6 The maximum flow from AFW pump G-10S shall be limited to 420 gpm (pump runout limit) at depressurized steam generator conditions, considering the most limiting single active failure and using only passive mechanical means.
- 1.4.7 The maximum automatically delivered flow from AFW pump G-10W or G-10S shall be limited to 150 gpm per steam generator (water hammer limit) at depressurized conditions considering the most limiting single active failure and using only passive mechanical means.

CASE 4 Main Feedwater Line Break Downstream of In-Containment Check Valves at 50% Power

- 4a. The plant is initially operating at 53% of rated power.
- 4b. Initial reactor coolant average temperature is 4°F above the nominal value (551.5°F) corresponding to 50% power level on the nominal average temperature program (575.15°F at full power).
- 4c. Initial pressurizer water level is 30.0% narrow range span (NRS).
- 4d. Main feedwater to all steam generators is assumed to stop at the time of the feedline break.
- 4e. Pressurizer power-operated relief valves are available, but no credit is taken for the pressurizer sprays.
- 4f. AFW is assumed to be manually actuated and the system manually aligned to deliver flow of 225 gpm to two steam generators 15 minutes after the initiation of the event (feedline break).
- 4g. The steam flow/feed flow mismatch reactor trip is assumed not available.
- 4h. The feedline break size is assumed to be 0.7854 ft<sup>2</sup>. All three steam generators depressurize since SONGS-1 does not have main steamline isolation valves.

RESULTS

CASE 1 Main Feedwater Line Break Upstream of In-Containment Check Valves at 100% Power

The results of the feedline break at full power located upstream of inside containment check valve transient are shown in Figures 1 through 4. The time sequence of events is presented in Table 2. Reactor trip is provided by the steam flow/feed flow mismatch signal. The results show that an AFW flow of 100 gpm initiated 30 minutes after the break is sufficient to remove core decay heat. Calculations of this case show that the core remained in a coolable geometry during this FLB scenario. The detailed calculations involved showing that the mass relieved through the pressurizer PORVs (between the time of initial relief through the PORVs and the time the PORVs reseal due to the heat removal capability of the AFW exceeding the core decay heat) was not sufficient to uncover the core. As such, the acceptance criterion for a FLB event that the core remains in a coolable geometry during the transient was shown to be met.

MADE BY R. H. H. 3/23/90 CHECKED BY [initials] DATE 5/9/95

CASE 2 Main Feedwater Line Break Upstream of In-Containment Check Valves at 50% Power

The results of the feedline break at 50% power located upstream of inside containment check valve transient are shown in Figures 5 through 8. The time sequence of events is presented in Table 3. Reactor trip is provided by the high pressurizer water level (50% NRS) signal. The results show that an AFW flow of 100 gpm initiated 15 minutes after the break is sufficient to remove core decay heat. The reactor coolant system (RCS) remains subcooled and the pressurizer does not fill. Thus, the core remains covered with water. As such, the acceptance criterion for a FLB event that the core remains in a coolable geometry during the transient was shown to be met.

CASE 3 Main Feedwater Line Break Downstream of In-Containment Check Valves at 100% Power

The results of the feedline break at full power located downstream of inside containment check valve transient are shown in Figures 9 through 12. The time sequence of events is presented in Table 4. Reactor trip is provided by the steam flow/feed flow mismatch signal. The results show that an AFW flow of 225 gpm initiated 20 minutes after the break is sufficient to remove core decay heat. Calculations of this case show that the core remained in a coolable geometry during this FLB scenario. The detailed calculations involved showing that the mass relieved through the pressurizer PORVs (between the time of initial relief through the PORVs and the time the PORVs reseal due to the heat removal capability of the AFW exceeding the core decay heat) was not sufficient to uncover the core. As such, the acceptance criterion for a FLB event that the core remains in a coolable geometry during the transient was shown to be met.

CASE 4 Main Feedwater Line Break Downstream of In-Containment Check Valves at 50% Power

The results of the feedline break at full power located downstream of inside containment check valve transient are shown in Figures 13 through 16. The time sequence of events is presented in Table 5. Reactor trip is provided by the high pressurizer pressure signal. The results show that an AFW flow of 225 gpm initiated 15 minutes after the break is sufficient to remove core decay heat. Calculations of this case show that the core remained in a coolable geometry during this FLB scenario. The detailed calculations involved showing that the mass relieved through the pressurizer PORVs (between the time of initial relief through the PORVs and the time the PORVs reseal due to the heat removal capability of the AFW exceeding the core decay heat) was not sufficient to uncover the core. As such, the acceptance criterion for a FLB event that the core remains in a coolable geometry during the transient was shown to be met.

CONCLUSIONS

The reanalysis of the Rupture of a Main Feedwater Pipe supports SONGS 1 operation with the reduced AFW flows presented in Table 1. The reanalysis is applicable for SONGS 1 operation on both the Nominal Tavg Program and Reduced Tavg Program. The radiological consequences following a feedline break were not addressed in this safety evaluation.

MADE BY R.A. [Signature] 3/23/90  
CHECKED BY [Signature] DATES 5/9/90



Made By R. J. H. Date 5/4/90

5VPP6.B  
Calc No. DC2876 Rev. 0

Ckd By [Signature] Date 5/9/90 ment Transmittal  
Preliminary

PA ; Sh 85-52 of 62

DEIT  
7/25/90 P. 142 of 158  
149 167

SAN ONOFRE UNIT 1

FEEDLINE BREAK REANALYSIS WITH REDUCED AUXILIARY FEED FLOW

BACKGROUND

Due to waterhammer concerns, Southern California Edison (SCE) is investigating possible modifications to the auxiliary feedwater (AFW) system. The potential modifications will reduce their (AFW) flow rates. SCE has requested Westinghouse to reanalyze the feedline break event to support the reduced AFW flows. The feedline break event is the only accident that was reanalyzed.

The previous analyses, documented in Reference 1, contains four cases. Breaks are assumed both upstream and downstream of the in-containment check valves initiated when operating at 100% and 50% of Rated Thermal Power. The analyses documented in this report model only breaks downstream of the in-containment check valves. The specific cases that are modeled for this analysis are as follows:

- Case 1 - Downstream FLB initiated at 100% power with 200 gpm AFW initiated 20 minutes after the break.
- Case 2 - Downstream FLB initiated at 50% power with 200 gpm AFW initiated 15 minutes after the break.
- Case 3 - Downstream FLB initiated at 100% power with 175 gpm AFW initiated 20 minutes after the break.
- Case 4 - Downstream FLB initiated at 50% power with 175 gpm AFW initiated 15 minutes after the break.
- Case 5 - Downstream FLB initiated at 50% power with 30 gpm AFW initiated 1 minute after the break and increased to 125 gpm 20 minutes after the break.

ATTACHMENT E  
(REF. 4)

Made By RAM Date 5/8/90

Ckd By [Signature] Date 5/9/90

Document Transmittal

SUPPL B  
Calc No. 062036 Rev. 0

Sh R5-52 of 62

DKH P. 443/449  
7/2/90 150/167

Westinghouse Proprietary Class 2  
Preliminary

CASE 3 Main Feedwater Line Break Downstream of the In-Containment Check  
Valves at 100% Power with 175 gpm AFW

The Case 3 FLB results are shown in Figures 9 through 12. The time sequence of events is presented in Table 4. Reactor trip is provided by the steam flow/feed flow mismatch signal. The results show that an AFW flow of 175 gpm initiated 20 minutes after the break is sufficient to remove core decay heat. Calculations show that the mass relieved through the pressurizer PORVs was not sufficient to uncover the core and thus, the core remained in a coolable geometry during this FLB scenario. As such, the acceptance criterion for a FLB event that the core remains in a coolable geometry during the transient was shown to be met.

CASE 4 Main Feedwater Line Break Downstream of the In-Containment Check  
Valves at 50% Power with 175 gpm AFW

The results of the Case 4 FLB are shown in Figures 13 through 16. The time sequence of events is presented in Table 5. Reactor trip is provided by the high pressurizer water level (50% WAS) signal. The results show that an AFW flow of 175 gpm initiated 15 minutes after the break is sufficient to remove core decay heat. Calculations show that the mass relieved through the pressurizer PORVs was not sufficient to uncover the core and thus, the core remained in a coolable geometry during this FLB scenario. As such, the acceptance criterion for a FLB event that the core remains in a coolable geometry during the transient was shown to be met.

ATTACHMENT E  
(REF. 4)

# ATTACHMENT A (KEY 1) DATA SHEET

DEK 715190  
151  
447  
167

FINAL

CUSTOMER PERMUTIT  
Test Title: WATER FLOW TEST AND CAVITATING VENTURI  
Specimen 3" CAV. VENTURI  
Part No. \_\_\_\_\_

Job No. 057347  
S/N 5-113  
Date 10/13/88

PT RUN NO.	Q (GPM)	T1 (DEG. F)	P1 (PSIA)	P2 (PSIA)	P3 (PSIA)	P1-P2 (PSID)	P1-P3 (PSID)	CALC # DC-2836 BY CK'D	DC-2836 CA DAT
1	18.83	70.80	537.98	527.16	537.99	8.82	0.49		
2	39.49	71.11	537.34	501.21	531.85	36.13	5.49	Q - FLOW RATE	
3	60.30	71.19	538.13	458.95	524.16	79.18	13.97	T1 - INLET TEMP	
4	82.90	71.25	538.91	376.11	506.58	162.79	32.32	P1 - INLET PRESSURE	
5	95.93	71.37	537.83	334.90	496.13	202.93	41.70	P2 - THROAT PRESSURE	
6	104.27	71.47	537.08	291.30	487.83	247.78	51.25	P3 - OUTLET PRESSURE	
7	110.75	72.65	539.18	254.07	478.14	285.11	61.03		
8	114.02	73.06	539.25	238.86	474.50	300.39	64.75		
9	119.60	73.31	539.18	212.64	465.93	326.54	73.24		
10	127.20	73.64	536.69	135.51	447.23	401.17	89.46		
11	128.92	73.77	538.01	0.61	436.98	537.40	101.03		
12	128.23	73.86	538.44	0.61	318.25	537.83	220.19		
13	128.25	73.92	538.08	0.61	250.45	537.47	287.62		
14	128.02	73.94	537.39	0.61	218.80	536.78	338.53		
15	128.37	73.99	537.25	0.61	144.21	536.64	393.04		
16	128.80	76.59	538.11	0.70	390.84	537.41	147.20		
17	128.60	76.61	539.13	0.70	355.39	538.93	183.74		
18	129.77	76.62	538.93	0.70	300.84	538.23	238.09		
19	128.90	76.48	537.86	0.70	280.70	537.16	257.16		

TESTED BY: Nick R. Williams  
Douglas G. Anderson



Form Approval

MADE BY R. O. Uffler 3/23/90 CHECKED BY D. DATES 9/93  
SUPPL B DC-2836 REV 0

ATTACHMENT F  
(REF. 1)

SH. 25-530 F 62  
P. ~~147~~ 1520/167 DKA 7/25/90  
Page No. 15  
Revision A FINAL



DATA SHEET

CUSTOMER PERMUTIT CO. INC.  
Test Title: WATER FLOW TEST ON CAVITATING VENTURIS  
Specimen 3" CAVITATING VENTURI Job No. 57347  
S/N 5419  
Part No. \_\_\_\_\_ Date 9/23/90

PT. RUN NO.	Q (GPM)	T1 (DEG. F)	P1 (PSIA)	P2 (PSIA)	P3 (PSIA)	P1-P2 (PSID)	P1-P3 (PSID)	CALC # DC 2836	DATE
								BY CK'D	DATE
1	20.31	65.47	541.04	538.81	541.72	2.22	-0.68		
2	42.69	66.49	537.35	500.43	531.71	36.92	5.64	Q - FLOWRATE	
3	62.58	66.61	536.37	448.31	523.34	88.06	13.04	T1 - INLET TEMP	
4	82.22	66.88	538.69	387.40	515.60	171.29	23.10	P1 - INLET PRESSURE	
5	111.09	67.37	539.72	295.89	496.06	284.33	43.65	P2 - THROAT PRESSURE	
6	115.85	67.67	539.45	223.99	490.18	315.46	49.27	P3 - OUTLET PRESSURE	
7	130.62	69.62	540.82	129.71	472.75	526.46	68.07		
8	134.97	70.39	537.42	.579	303.78	536.84	233.64		
9	133.49	70.38	539.50	.575	272.72	538.92	266.77		
10	133.49	70.43	540.38	.577	178.34	539.80	362.04		
11	134.60	70.47	537.20	.584	171.72	526.72	365.58		
12	133.17	70.43	536.20	.591	154.76	535.71	381.54		
13	134.48	73.02	539.03	.606	235.03	538.42	304.02		
14	132.59	72.93	538.67	.591	157.28	538.08	381.40		

TESTED BY: W. R. Miranda  
Douglas G. Anderson

20 9-23-90

MADE BY R.G. Wh 3/23/90 CHECKED BY ⊙ DATE 5/9/91  
SUPPL. B - DC 2836 REV 1



ATTACHMENT G  
(FROM REF. 2)

SUPPL. B TO  
DC 2836 REV. 0

SH R5-570 F62

MADE BY R.E. *[Signature]* 3/23/90 CHECKED BY *[Signature]* DATE *[Signature]*

CASE 1-P.3

28	.00	15.00	41	42	43
29	.00	15.00	42	43	44
30	.00	21.70	44	45	46
31	.00	21.70	45	46	47
32	.00	31.50	47	48	
33	.00	18.10	34	35	49
34	.00	17.00	35	49	50
35	.00	23.15	50	51	
36	.00	23.15	51	52	

*26-13-88*  
CALC NO. M-DC-2836  
P. 80 OF P. 125  
BY MLOCASIO DATE 1-6-88  
CHK BY FA DATE 1/11/88  
*DKW*  
*7/25/90 P. 147-159*  
*153*  
*154*  
*167*

OUTPUT SELECTION: ALL RESULTS ARE OUTPUT EACH PERIOD

THIS SYSTEM HAS 52 PIPES WITH 33 JUNCTIONS , 11 LOOPS AND 9 FGNS

THE RESULTS ARE OBTAINED AFTER 4 TRIALS WITH AN ACCURACY = .00027

Pipe Network Test System  
AFW-G-10S IN OPERATION

CONTRACT NO. 468000

*ΔP ORIFICE*

PIPE NO. LINE	NODE NOS. 1 IS CLOSED	FLOWRATE	HEAD LOSS	PUMP HEAD	MINOR LOSS	VELOCITY	HL/1000
2	2 11	.00	.00	.00	.00	.00	.00
3	11 0	.00	.00	.00	.00	.00	.00
4	2 3	.00	.00	.00	.00	.00	.00
5	3 4	.00	.00	.00	.00	.00	.00
THE CHECK VALVE IN LINE NUMBER 6 IS CLOSED							
THE CHECK VALVE IN LINE NUMBER 7 IS CLOSED							
THE CHECK VALVE IN LINE NUMBER 8 IS CLOSED							
9	5 6	131.13	3.70	.00	.00	5.68	39.38
10	6 7	65.56	13.75	.00	.00	2.84	10.72
11	6 7	65.56	13.75	.00	.00	2.84	10.72
12	7 8	131.13	3.07	.00	.00	5.68	39.38
13	8 9	131.13	.32	.00	1178.42	5.68	39.38
LINE 14 IS CLOSED							
15	9 10	131.13	4.02	.00	.00	5.68	39.38
16	10 0	131.13	.02	.00	.00	.56	.13
THE PUMP IN LINE 17 IS OPERATING OUT OF RANGE <i>Q MAX 7405 gpm (OK for 405.45)</i>							
17	0 13	405.45	2.18	1296.30	.00	17.57	345.81
18	13 22	12.00	1248.93	.00	.00	4.44	94.95
19	22 0	12.00	4.48	.00	.00	1.89	11.38
20	13 14	393.45	47.62	.00	.00	17.05	326.15
21	14 15	393.45	18.15	.00	.00	9.90	81.38
22	15 16	131.14	.87	.00	.00	5.68	39.39
23	15 5	131.13	.52	.00	.00	3.65	13.02
24	15 27	131.19	.55	.00	.00	3.65	13.03
25	16 17	131.14	2.32	.00	.00	5.68	39.39
26	17 19	65.56	13.77	.00	.00	2.84	10.72
27	17 18	65.58	13.77	.00	.00	2.84	10.73
28	18 19	131.14	3.27	.00	.00	5.68	39.39
29	19 20	131.14	.32	.00	1178.61	5.68	39.39
LINE 30 IS CLOSED							
31	20 21	131.14	4.65	.00	.00	5.68	39.39
32	21 0	131.14	.02	.00	.00	.56	.13

ATTACHMENT G  
(FROM REF 2)

SUPPL B TO  
DC2836 RENO

SH 25-58 F 62

MADE BY *RLH* 3/23/90 CHECKED *[Signature]* DATE *5/9/93*

CALC NO. *M-DC-2836*

P. 21 OF P. 125

CASE 1-P4

LINE	IS	CLOSED							
33	IS	CLOSED							
34	24	33	.00	.00	.00	.00	.00	.00	.00
35	IS	CLOSED							
36	24	25	.00	.00	.00	.00	.00	.00	.00
37	25	26	.00	.00	.00	.00	.00	.00	.00
THE CHECK VALVE IN LINE NUMBER			38	IS	CLOSED				
THE CHECK VALVE IN LINE NUMBER			39	IS	CLOSED				
THE CHECK VALVE IN LINE NUMBER			40	IS	CLOSED				
41	27	28	131.19	2.36	.00	.00	5.69	39.42	
42	28	29	65.59	13.76	.00	.00	2.84	10.73	
43	28	29	65.59	13.76	.00	.00	2.84	10.73	
44	29	30	131.19	3.19	.00	.00	5.69	39.42	
45	30	31	131.19	.32	.00	1179.43	5.69	39.42	
46	IS	CLOSED							
47	31	32	131.19	4.18	.00	.00	5.69	39.42	
48	32	0	131.19	.03	.00	.00	.56	.13	
49	33	34	.00	.00	.00	.00	.00	.00	
50	34	35	.00	.00	.00	.00	.00	.00	
51	35	36	.00	.00	.00	.00	.00	.00	
52	36	0	.00	.00	.00	.00	.00	.00	

BY *W. Lock* DATE *1-1-88*  
CHK BY PA DATE *11/1/88*

JUNCTION NUMBER	DEMAND	GRADE LINE	ELEVATION	PRESSURE
2	.00	57.92	17.00	17.73
3	.00	57.92	16.00	18.17
4	.00	57.92	16.70	17.86
5	.00	1244.66	18.30	531.42
6	.00	1240.96	15.75	530.93
7	.00	1227.22	15.75	524.97
8	.00	1224.14	23.20	520.41
9	.00	45.40	23.20	9.62
10	.00	41.39	31.50	4.28
11	.00	57.92	21.80	15.65
13	.00	1310.95	16.80	560.80
14	.00	1263.33	16.80	540.16
15	.00	1245.18	16.70	532.34
16	.00	1244.32	15.00	532.70
17	.00	1241.99	15.00	531.70
18	.00	1228.23	15.00	525.73
19	.00	1224.96	22.40	521.11
20	.00	45.04	22.40	10.24
21	.00	41.39	31.50	4.28
22	.00	62.40	20.50	18.16
24	.00	57.92	18.80	16.95
25	.00	57.92	21.70	15.70
26	.00	57.92	22.70	15.26
27	.00	1244.64	16.70	532.11
28	.00	1242.27	15.00	531.82
29	.00	1228.52	15.00	525.86
30	.00	1225.32	21.70	521.57
31	.00	45.58	21.70	10.35
32	.00	41.40	31.50	4.29
33	.00	57.92	18.10	17.26
34	.00	57.92	17.00	17.73
35	.00	57.92	23.15	15.07
36	.00	57.92	23.15	15.07

*P. 11/1/88*  
*154/167*  
*155*  
*DEW 7/25/90*

THE NET SYSTEM DEMAND = .00


SUMMARY OF INFLOWS(+) AND OUTFLOWS(-) FROM FIXED GRADE NODES

ATTACHMENT G  
(FROM REG. 2)

SUPPL-B DC-2836 Lev 0 SW R5-59 of 63

MADE BY BA. H. 3/25/90 CHECKED BY P. DATE 5/9/93

CAGE 1-P.6



021-13-88  
CALC NO. MP-DC-2836 Lev 0  
P. 83 OF P. 125  
BY M. W. DATE 1-6-88  
CHK BY FA DATE 1/2/88


P. 119 of 156  
DC4 712790  
156 167



ATTACHMENT H  
 G10W CURVES  
 (FROM REF. 6)

- SUPPL. B DC-2836 REV. 6 SH R5-60 °F 62  
 MADE BY L.O. VFF 3/23/90 CHECKED BY P DARR 5/19/90

DKH  
 7/25/90 P. 120  
 157



NOTE: BASED ON DESIGN PUMP CURVES

20 Squares to the Inch

FIGURE 9

SUPPLEMENT A DC-2836 REV. 0

Ca VFF 3/23/90

MM  
 C

ATTACHMENT I SUPPL. B DC 2836  
(REF 6 CALC.)

SHR5-61-SE 62  
DW 7125190 P. 157  
157-167

MADE BY R.O. [signature] 3/23/90

CHECKED BY [signature] DATE 5/9/90

SHEET [redacted] SHEETS

ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

3123/90  
SUBJECT: SONGS 1 Hydraulic Calculation For AFV Lines - Flow Requirements  
Supplement A  
CALC NO. 2836 REV. 3  
I.O. NO. [redacted] MADE BY [redacted]

$$Q_1 = \sqrt{\frac{Q_2^2 (\Delta P_1 - \Delta P_E)}{\Delta P_2 - \Delta P_E}}$$

From G10 + G10S test data:

$$Q_2 = \text{Total G10 + G10S flow to S/G's} + 3 \text{ S/G's}$$

$$Q_2 = 526 \text{ gpm} + 3$$

$$Q_2 = 175.3 \text{ gpm}$$

$$\Delta P_2 = P_{\text{DISCHARGE}} - P_{\text{S/G}}$$

$$\Delta P_2 = 1030 \text{ psig} - 800 \text{ psig}$$

$$\Delta P_2 = 230 \text{ psig}$$

$$Q_1 = \sqrt{\frac{(175.3)^2 (\Delta P_1 - \Delta P_E)}{230 - \Delta P_E}}$$

Loss due to elevation:

$$\text{From Ref. 14, 17, 18, 19: } Z_{\text{S/G}} = 41' - 4 \frac{7}{16}" = 41.37 \text{ ft}$$

$$Z_{\text{PUMP G10}} = 17' - 0" = 17.0 \text{ ft}$$

$$Z_{\text{PUMP G10S}} = 16' - 10" = 16.83 \text{ ft}$$

For the largest difference in height, use elevation of Pump G10S.

$$h_L = Z_{\text{S/G}} - Z_{\text{PUMP G10S}}$$

$$h_L = 41.37 \text{ ft} - 16.83 \text{ ft}$$

$$h_L = 24.54 \text{ ft}$$

$$\text{Eq. 7, 8-5: } \Delta P_E = \frac{h_L \cdot \rho \cdot g}{1.44}$$

$$\Delta P_E = 10.62 \text{ psid}$$

ATTACHMENT I  
(FROM REF. 6)

SUPPL. B DC 2836

SH. 25-62 OF 62

DKH

7/25/90 P.

159  
159  
159

MADE BY CC. WJ 3/23/90

CHECKED BY

DATE 6/9/92

ENGINEERING DEPARTMENT  
**CALCULATION SHEET**

Supplement A

SUBJECT: SONGS 1 Hydraulic Calculation For APV Lines - Flow Requirements

J.O. NO. \_\_\_\_\_

MAD \_\_\_\_\_

$$Q_1 = \sqrt{\frac{(175.3)^2 (\Delta P_1 - 10.62)}{230 - 10.62}}$$

Sample calculation:

$$Q_1 = \sqrt{\frac{(175.3)^2 (200 - 10.62)}{(230 - 10.62)}} = 162.87 \text{ GPM}$$

$$Q_T = 162.87 \times 3 = 488.6 \text{ TOTAL FLOW TO 3/G'S.}$$

Data to plot System Loss Curve - Refer to Figure 6:

P <sub>1</sub> (psig)	Q <sub>1</sub> (gpm)	Q <sub>T</sub> (gpm)
300	201.3	604.0
250	183.1	549.4
200	162.9	488.6
180	154.0	462.1
160	144.7	433.9
140	134.6	403.9
100	111.9	335.7
60	83.2	249.5
20	36.2	108.6
10.62	0	0

System curve can be validated with the G10 test data for FCV's fully open with S/G pressure at 800 psig. Refer to Figure 6 for test data points.