

STRUCTURAL ANALYSIS REPORT  
for the  
LACROSSE BOILING WATER REACTOR  
SPENT FUEL POOL STRUCTURE

Prepared Under Project 5101  
for  
DAIRYLAND POWER COOPERATIVE

by  
Nuclear Energy Services, Inc.  
Danbury, Connecticut 06810

Prepared by: I. Husain

J. Risley

Approved by: Richard Milos  
Project Manager

C. H. Yule  
Engineering V.P.

R.E. Langman Jr., CDO  
Q.A. Manager

Date: 15 Sept 78



7810160146 P

TABLE OF CONTENTS

	<u>Page</u>
1. SUMMARY . . . . .	1-1
2. INTRODUCTION . . . . .	2-1
3. DESCRIPTION OF THE SPENT FUEL STORAGE POOL . . . . .	3-1
4. APPLICABLE CODES, STANDARDS AND SPECIFICATIONS . . . . .	4-1
5. LOADING CONDITIONS. . . . .	5-1
5.1 Load Cases . . . . .	5-1
5.2 Load Combinations . . . . .	5-2
6. STRUCTURAL ACCEPTANCE CRITERIA. . . . .	6-1
7. METHOD OF ANALYSIS . . . . .	7-1
7.1 Mathematical Models. . . . .	7-1
7.2 Mathematical Formulation of the Static Analysis . . . . .	7-1
7.3 Stress Analysis . . . . .	7-2
8. RESULTS OF ANALYSIS . . . . .	8-1
8.1 Spent Fuel Storage Pool Structural Analysis. .	8-1
9. CONCLUSIONS . . . . .	9-1
10. REFERENCES. . . . .	10-1
11. APPENDIX. . . . .	11-1

## LIST OF TABLES

	<u>Page</u>
8.1      Results of the Storage Pool Structural Analysis Load Combination #1, 1.4 D + 1.7 L . . . . .	8-3
8.2      Results of the Storage Pool Structural Analysis Load Combination #2, 1.4 D + 1.76 + 1.9 E (OBE Seismic Event) . . . . .	8-4
8.3      Results of the Storage Pool Structural Analysis Load Combination #3, 0.75 (1.4 D + 1.76 + 1.7 T) . . . . .	8-5
8.4      Results of the Storage Pool Structural Analysis Load Combination #4, 0.75 (1.4 D + 1.76 + 1.9 E + 1.7 T) . . . . .	8-6
8.5      Results of the Storage Pool Structural Analysis Load Combination #5, D + L + 1.25 E + I.L. (Cask Drop Event) . . . . .	8-7

## LIST OF FIGURES

	<u>Page</u>
3.1      Fuel Storage Pool Elevation - North and South Walls . . . . .	3-2
3.2      Fuel Storage Pool Elevation - East and West Walls . . . . .	3-3
3.3      Spent Fuel Storage Rack Arrangement Plan . . . . .	3-4
7.1.a     Spent Fuel Storage Pool - Finite Element Model Dimensions and Node Numbers . . . . .	7-4
7.1.b     Spent Fuel Storage Pool - Finite Element Model Plate Element Numbers . . . . .	7-5
7.1.c     Spent Fuel Storage Pool - Finite Element Model Plate Element Numbers . . . . .	7-6
7.1.d     Spent Fuel Storage Pool - Finite Element Model Appropriate Boundary Conditions . . . . .	7-7

## 1. SUMMARY

This report, prepared for Dairyland Power Cooperative (DPC), presents the results of the structural analyses performed by Nuclear Energy Services, Inc. to verify the adequacy of the fuel storage pool structure to accommodate the additional dead weight, vertical and lateral seismic loads of the high density fuel storage racks. Detailed structural analyses of various structural members of the pool (pool floor, walls) have been performed to verify the adequacy of the design to withstand the loadings associated with normal operations, the severe and extreme environmental conditions of the 1/2 safe shutdown and safe shutdown earthquakes and the abnormal loading conditions of an accidental cask drop event.

The response of the fuel storage pool structure to the specified static loading conditions have been evaluated by means of linear elastic analysis using the finite element method. Applicable loads and load combinations have been considered using the guidelines given in USNRC Standard Review Plan Section 3.8.4. The allowable section strength of the reinforced concrete members have been calculated based on the ultimate strength design methods described in ACI-318-71. For the specified loading conditions, the maximum stresses of the storage pool structure have been calculated and shown to be less than the allowable values.

It has been concluded from the results of the structural analysis that the spent fuel storage pool design is sufficiently adequate to withstand the loadings associated with normal operating and abnormal conditions.

## 2. INTRODUCTION

Nuclear Energy Services, Inc. (NES) has designed the crash pad and the high density spent fuel storage racks for the Dairyland Power Cooperative to be installed in the LaCrosse Boiling Water Reactor fuel storage pool. The structural design of the high density spent fuel storage racks is given in NES document 81A0546, Rev. 2, dated August 7, 1978 (Reference 1). The spent fuel shipping cask drop analysis is given in NES document 81A0550, Rev. 2, dated September 20, 1978 (Reference 2).

This report (NES 81A0095) presents the results of the structural analysis that have been performed by Nuclear Energy Services, Inc. to evaluate the adequacy of the fuel storage pool structure to withstand loadings associated with the additional dead load and seismic response of the high density spent fuel storage racks and the reaction loads resulting from a cask drop event. The fuel storage pool floor and walls have been mathematically represented by a three dimensional finite element model consisting of plate elements and having appropriate boundary conditions. The response of the finite element model of the storage pool structures to the applicable loads have been determined using linear static analysis methods. Loads and load combinations have been developed based on the guidelines given in USNRC Standard Review Plan Section 3.8.4 (Reference 6). The adequacy of the reinforced concrete members have been evaluated using ultimate strength design methods for reinforced concrete structures. The applicable codes, regulatory standards, structural acceptance criteria are also presented in the report. The detail loading and structural calculations are given in Appendices A through D.

### 3. DESCRIPTION OF SPENT FUEL POOL STRUCTURE

The fuel storage pool is located inside the reactor containment building (south of the reactor pressure vessel) between elevation 659'-5-5/8" and 701'-3". The fuel storage pool is a 11' x 11' x 40' deep reinforced concrete structure lined with AISI Type 316 stainless steel plate. The 56 inch thick storage pool floor is lined with 3/8 inch thick stainless steel plate and is supported along its perimeter by the four pool walls and along its mid-span by a 29 inch thick wall. The pool walls, which vary in thickness, are lined with a 1/16 inch thick stainless steel sheet. A detailed layout of the pool floor and its supporting walls are shown in Reference 3. Elevation sections of the pool floor, the north, south, east and west walls including their detailed reinforcement patterns, changes in wall thickness and pool floor support walls are indicated in Figures 3.1 and 3.2.

In the arrangement of the storage racks, and crash pad in the fuel storage pool (shown in Figure 3.3), the two-tier 9 x 8 and 4 x 10 storage rack are located adjacent to the east, west and north walls of the pool and the crash pad is located adjacent to the south wall of the pool.

The horizontal seismic loads are transmitted from the rack structures to the fuel storage pool walls at three elevations (the top grid of the upper tier rack section, centerline of the inter-section of upper and lower rack tiers, and the bottom grid of the lower tier rack section) through adjustable pads attached to the rack structures. The vertical dead-weight and seismic loads are transmitted to the storage pool floor by the rack support feet. The impact loads associated with the cask drop event are transmitted to the pool floor by the crash pad.




FIGURE 3.1

FUEL STORAGE POOL ELEVATION - NORTH AND SOUTH WALLS




FIGURE 3.2

FUEL STORAGE POOL ELEVATION - EAST AND WEST WALL




FIGURE 3.3

SPENT FUEL STORAGE RACK ARRANGEMENT PLAN

#### 4. APPLICABLE CODES, STANDARDS AND SPECIFICATION

The following design codes, regulatory guides and references have been used in the structural analysis of the fuel storage pool structure.

1. ACI 318-71 - "Building Code Requirements for Reinforced Concrete" American Concrete Institute.
2. Uniform Building Code, 1973 Edition.
3. USNRC Standard Review Plan, Section 3.8.4.
4. "USNRC Proposed Position for Review and Acceptance of Spent Fuel Storage and Handling Application."
5. Nuclear Energy Services, Inc. document NES 81A0544, Rev. 0. "Quality Assurance Program Plan for the LaCrosse Boiling Water Reactor Spent Fuel Storage Rack Design Program", March 1978.
6. George Winter, et al - "Design of Concrete Structures", McGraw Hill Book Company, 1964.

## 5. LOADING CONDITIONS

The following load cases and load combinations have been considered in the analysis in accordance with the requirements of USNRC Standard Review Plan, Section 3.8.4 (Reference 6).

### 5.1 Load Cases

#### Load Case 1 - Dead Weight D (Normal Load)

The weight of the empty pool concrete structure is considered as the dead weight loading.

#### Load Case 2 - Live Load, L (Normal Load)

Under normal operations, the storage pool is subjected to the live loads associated with the hydrostatic pressure and the weights of the fully loaded racks, crash pad and spent fuel shipping cask.

#### Load Cases 3 to 6 - 1/2 Safe Shutdown Earthquake, E (Severe Environmental Load)

The fuel storage pool walls are individually subjected to the seismic inertia loading of the concrete walls, pool water mass, and the maximum seismic reaction loads of the fuel storage racks (Reference 1) for the 1/2 Safe Shutdown Earthquake event.

The load combinations (Section 5.2) involving the Safe Shutdown Earthquake (E') are less severe than those involving the 1/2 Safe Shutdown Earthquake (E) while the acceptance criteria for these load combinations are same. Therefore, the analyses have been performed for the 1/2 Safe Shutdown Earthquake loading condition only.

#### Load Case 7 - Thermal Loading, $T_0$ (Normal Load)

Clearances are provided between the individual racks and between the racks and the pool walls to allow unrestrained growth of the racks for the maximum temperature differential based on a maximum pool temperature of 150°F. Consequently the storage racks will not impose any thermal loading on the storage pool walls. The spent fuel pool cooling system analysis (Reference 7) of the storage pool for the high density storage rack application indicates that the pool water temperature will not be greater than 120°F for the maximum heat load condition. The Technical Specifications, however, permit the fuel pool to operate at temperatures up to 150°F. The pool floor and walls are conservatively analyzed (Appendix C) for a linear thermal gradient of

80°F (150°F inside pool temperature and 70°F ambient temperature outside the pool) across the thickness of concrete elements.

Load Case 8 - Spent Fuel Shipping Cask Drop Impact  
Load I.L. (Abnormal Load)

The maximum reaction load associated with the spent fuel shipping cask drop event (Reference 2) are applied to the affected area of the pool floor.

### 5.2 Load Combinations

- (a) For service load conditions, the following load combinations are considered using the ultimate strength design methods of ACI-318-71 (Reference 10).
  - (1) 1.4 D + 1.7 L
  - (2) 1.4 D + 1.7 L + 1.9 E
  - (3) 0.75 (1.4 D + 1.7 L + 1.7 T<sub>O</sub>)
  - (4) 0.75 (1.4 D + 1.7 L + 1.9 E + 1.7 T<sub>O</sub>)
- (b) For factored load conditions, the following load combinations are considered using the ultimate strength design methods of ACI-318-71 (Reference 10).
  - (2) 1.4 D + 1.7 L + 1.9 E > D + L + E'\*
  - (5) 1.4 D + 1.7 L + I.L.

The detail calculations for various loading data and load combinations are given in Appendix A and C.

---

\*Lateral seismic inertia loading of the concrete walls, pool water mass and the maximum seismic reaction loads of the fuel storage racks for the 1/2 Safe Shutdown Earthquake (E) are 73% that of the Safe Shutdown Earthquake (E') (page A-8 of Appendix A). Therefore, load combination 1.4D + 1.7L + 1.9E involving 1/2 Safe Shutdown Earthquake is more severe than load combination D + L + E' involving Safe Shutdown Earthquake.

## 6. STRUCTURAL ACCEPTANCE CRITERIA

The following allowable stress/load limits constitute the structural acceptance criteria used for each of the loading combinations presented in Section 5.2.

<u>Load Combinations</u>	<u>Limit</u>
1, 2, 3, 4, 5	U

Where U is the required section strength based on the ultimate strength design methods described in ACI-318-71. The compressive strength of concrete at 28 days is taken as 3500 psi (Reference 10).

## 7. METHOD OF ANALYSIS

### 7.1 Mathematical Models

In order to perform the linear static analysis of the fuel storage pool structure, the various structural components (pool floor and walls) of the pool structure are represented by a composite three dimensional finite element model. As shown in Figures 7.1.a through 7.1.c, the three-dimensional finite element model consists of plate elements interconnected at a finite number of nodal points. Stiffness characteristics of the structural elements are related to the plate thicknesses. Six degrees of freedom (three translational and three rotational) are permitted at each nodal point. Nodal points are selected to adequately represent the changes in the wall thicknesses, discontinuity effects, various loadings and boundary conditions.

Appropriate boundary conditions, as shown in Figure 7.2, have been assumed at the interface of the storage pool and shield building.

### 7.2 Mathematical Formulation of the Static Analysis

The static analysis of the finite element model has been performed using the direct stiffness methods of structural analysis. If the force displacement relationship of each of the discrete structural elements is known (the element stiffness matrix) then the force-displacement relationship for the entire structure can be assembled using standard matrix methods as shown below.

For each element

$$K u = f \quad (1)$$

where:

$K$  = Element stiffness matrix  
 $u$  = Element nodal displacement vector  
 $f$  = Element nodal force vector

For the idealized system the equation of equilibrium may be written, in matrix form, as follows:

$$K U = F \quad (2)$$

where:

$K$  = Assembled stiffness matrix for the system

$$= \sum_{i=1}^n k$$

$U$  = Nodal displacement vector for the system  
 $F$  = External nodal point force vector

If sufficient boundary conditions are specified on  $U$  to guarantee a unique solution, Equation (2) can be solved for the nodal point displacements at each node in the structure, knowing the system stiffness matrix and external force matrix. From the displacement response of the system, the internal forces and stresses in each structural element can be calculated.

### 7.3 Stress Analysis

For the plate element the internal forces and moments are related to the stresses by the following equations.

$$\begin{Bmatrix} MX \\ MY \\ MXY \end{Bmatrix} = \left( \frac{T^2}{12} \right) \left[ \begin{Bmatrix} SX \\ SY \\ SXY \end{Bmatrix}_{+Z} - \begin{Bmatrix} SX \\ SY \\ SXY \end{Bmatrix}_{-Z} \right]$$

$$\begin{Bmatrix} FX \\ FY \\ FXY \end{Bmatrix} = \left( \frac{T}{2} \right) \left[ \begin{Bmatrix} SX \\ SY \\ SXY \end{Bmatrix}_{+Z} + \begin{Bmatrix} SX \\ SY \\ SXY \end{Bmatrix}_{-Z} \right]$$

Where:

$T$  = Plate thickness

$+SX(\sigma_X)$  = Stress in element X direction on the positive Z surface.


$+SY(\sigma_Y)$  = Stress in element Y direction on positive Z surface.

$+SXY(\sigma_{XY})$  = Shear stress on positive Z surface.

$-SX(\sigma_X)$  = Stress in element X direction on negative Z surface.

$-SY(\sigma_Y)$  = Stress in element Y direction on negative Z surface.

$-SXY(\sigma_{XY})$  = Shear stress on negative Z surface.



$F_x, F_y, F_z$  = Element internal forces along element  
 $x, y$  and  $z$  axes.

$M_x, M_y, M_z$  = Element internal moments about element  
 $x, y$  and  $z$  axes.

The maximum shear and compressive stresses are compared to the allowable shear and compressive stress values for a reinforced concrete element. The maximum tensile stresses are converted to the equivalent internal moments and the internal moments are compared with the allowable ultimate moment carrying capacities of the reinforced concrete sections. The ultimate moment carrying capacities of the reinforced concrete sections for various reinforcement patterns and wall thicknesses are calculated using the ultimate strength design methods of ACI-318-71 (Reference 10). The calculations are presented in Appendix B. The structural analysis and stress analysis calculations are performed using the STARDYNE computer program (Reference 13).




FIGURE 7.1.a  
SPENT FUEL STORAGE POOL  
FINITE ELEMENT MODEL NODE NUMBERS AND DIMENSIONS




FIGURE 7.1.b

SPENT FUEL STORAGE POOL  
FINITE ELEMENT MODEL - PLATE ELEMENT NUMBERS




FIGURE 7.1:c

SPENT FUEL STORAGE POOL  
FINITE ELEMENT MODEL - PLATE ELEMENT NUMBERS




FIGURE 7.2

SPENT FUEL STORAGE POOL FINITE ELEMENT MODEL - APPROPRIATE BOUNDARY CONDITIONS

## 8. THE RESULTS OF THE ANALYSIS

The results of the static structural/stress analysis of the LaCrosse Boiling Water Reactor fuel storage pool performed with the STARDYNE computer code are contained in Reference 14.

Appendices A through D contain the loading data, allowable ultimate moment capacity of the pool floor and walls, thermal loading effects and seismic loading effects from other building structures.

### 8.1 Spent Fuel Storage Pool Structural Analysis

The results of the storage pool structural analysis for load combinations 1 and 2 which includes the effects of dead, live and earthquake loadings are summarized in Tables 8.1 and 8.2. These tables present the maximum shear stresses, compressive stresses and calculated design moments in each of the elements of different thickness in the pool structure and compares them with the allowable values as specified in the acceptance criteria of Section 6. From Table 8.1, it can be seen that for load combination 1, the maximum shear stress, compressive stress and critical design moments (for the horizontal and vertical reinforcements) are 0.058 ksi, 0.115 ksi, 243.6 K.in/ft and 18.14 K.in/ft respectively. These stress and moment values are considerably lower than the corresponding allowable values of 0.20 ksi, 2.082 ksi, 1260 K.in/ft and 528.6 K.in/ft respectively.

Table 8.2 presents the results for load combination #2. From this table it can be seen that the maximum shear stress, compressive stress, critical (horizontal and vertical reinforcements) design moment values of 0.075 ksi, 0.167 ksi, 695.3 K.in/ft and 77.8 K.in/ft respectively are lower than the corresponding allowable values of 0.20 ksi and 2.082 ksi, 2142.0 K.in/ft and 528.0 K.in/ft respectively.

The results of the storage pool structural analysis for load combinations 3 and 4 which includes the effects of dead, live, earthquake and thermal loadings are summarized in Table 8.3 and 8.4. These tables show that in the critical section (pool floor) the maximum moment of 702.9 K.in/ft for load combination 3 and 4 is lower than the allowable value of 1200 K.in/ft.

Table 8.5 presents the results for abnormal load combination 5 which includes the effects of dead, live and cask drop impact loads. From this table it can be seen that the maximum shear stress, compressive stress, critical (horizontal and vertical reinforcements) design moment values of 0.089 ksi, 0.153 ksi, 675.8 K in/ft and 149.5 K in/ft respectively are lower than their allowable values of 0.20 ksi, 2.082 ksi, 2142.0 K in/ft and 897.6 K in/ft respectively.

The effects of additional loadings from the adjacent building structures on the pool structures are evaluated in Appendix D. The sum of the ratios of maximum shear stress to allowable shear stress for the pool structure and for the over all building structure (Reference 15) is 0.479. Similarly, the sum of the ratios for the maximum moment to allowable moment is 0.432. Since these two ratios are less than 1, it can be concluded that the storage pool structures are adequate to withstand its own internal loadings as well as those from the adjacent building structures.

TABLE 8.1  
RESULTS OF THE STORAGE POOL STRUCTURAL ANALYSIS  
LOAD COMBINATION #1, 1.4 D + 1.7 L

STRUCTURAL ELEMENT DEA. REPTION	MAXIMUM SHEAR STRESS		MAXIMUM COMpressive STRESS		MAXIMUM TENSILE STRESS	DESIGN MOMENT	ALLOWABLE MOMENT	
	Element No.	Stress (Ksi)	Element No.	Stress (Ksi)		Element No.	Vertical Armt. (In.)	Horizontal Armt. (In.)
Pool Floor (56" Element)	161	0.033	167	0.051	162	0.068	-	-
North Wall								
E1, 680'-5" to 701'-3" (36" Elements)	61	0.029	61	0.046	61	0.041	-	1260.0
E1, 678'-5" to 680'-5" (36" Element)	78	0.027	80	0.068	77	0.056	77	528.0
E1, 659'-5-625" to 670'-5" (36" Element)	141	0.058	128	0.115	128	0.094	125.7	0.084
E1, 659'-5-625" to 678-5" (21" Element)	158	0.035	159	0.063	126	0.041	243.6	0.030
South Wall								
E1, 672'-3" to 701'-3" (18.0" Element)	86	0.023	71	0.072	70	0.011	18.14	519.6
E1, 659'-5-625" to 672-0" (57" Element)	133	0.029	138	0.059	149	0.009	243.0	0.102
East Wall								
E1, 680'-5" to 701'-3" (36" Element)	58	0.050	59	0.044	42	0.055	1260.0	0.113
E1, 659'-5-625" to 680'-5" (57" Element)	140	0.039	145	0.051	67	0.061	2142.0	0.185
West Wall								
E1, 680'-5" to 701'-3" (36" Element)	51	0.031	51	0.044	35	0.055	1260.0	0.113
E1, 659'-5-625" to 680'-5" (52" Element)	148	0.039	145	0.051	67	0.061	2142.0	0.185

\* Allowable Shear Stress = 0.201 ksi

\*\* Allowable Compressive Stress = 2.082 ksi

TABLE 8.2  
RESULTS OF THE STORAGE POOL ANALYSIS LOAD COMBINATION #2  
 $1.40 + 1.7 L + 1.9 E$  = OBE SEISMIC EVENT

STRUCTURAL ELEMENT DESCRIPTION	MAXIMUM SHEAR STRESS		MAXIMUM COMPRESSIVE STRESS		MAXIMUM TENSILE STRESS		DESIGN Vertical Load- Capacity (kips)	MAXIMUM Vertical Moment (kip-in/ft)	DESIGN Horizontal Moment (kip-in/ft)	DESIGN AVERAGE Vertical Reint. (k-uyr/ft)
	Element No.	Stress (ksi)	Element No.	Stress (ksi)	Element No.	Stress (ksi)				
Pool Floor	171	0.066	163	0.136	162	0.069				
North Wall										
El. 680'-0" to 701'-3" (36" Elements)	61	0.037	61	0.066	61	0.06	61	0.030	155.5	77.8
El. 680'-5" to 701'-3" (21" Elements)	TRPT #1	0.027	1	0.056	1	0.041	1	0.02	36.2	17.6
El. 678'-5" to 680'-5" (33.5" Elements)	72	0.045	78	0.104	78	0.088	77	0.018	197.5	40.4
El. 659'-5-625" to 678'-5" (36" Elements)	144	0.075	128	0.167	128	0.147	125	0.011	381.0	28.5
El. 659'-5-625" to 678'-5" (21" Elements)	143	0.046	127	0.131	126	0.102	126	0.026	90.0	22.93
South Wall										
El. 672'-0" to 701'-3" (18" Elements)	86	0.027	102	0.083	70	0.016	70	0.008	10.4	5.2
El. 659'-5-625" to 672'-0" (57.0 Element)	119	0.041	134	0.078	152	0.010	134	0.009	65.0	58.5
East Wall										
El. 680' to 701'-3" (36.0" Elements)	58	0.041	42	0.071	42	0.092	42	0.011	238.5	28.5
El. 659'-5-625" to 680' (57.0" Elements)	74	0.054	74	0.084	74	0.106	155	0.018	688.8	117.0
West Wall										
El. 680'-0" to 701'-3" (36.0" Element)	51	0.041	35	0.071	35	0.092	35	0.011	238.5	28.5
El. 659'-5-625" to 680'-0" (57" Elements)	67	0.056	67	0.084	67	0.107	146	0.018	695.3	117.0

\* Allowable Shear Stress = 0.201 ksi  
\*\* Allowable Compressive Stress = 2.082 ksi

TABLE 8.3

RESULTS OF THE STORAGE POOL STRUCTURAL ANALYSIS  
LOAD COMBINATION #3,  $0.75(1.4D + 1.7L + 1.7T_0)$

STRUCTURAL ELEMENT DESCRIPTION	MAXIMUM DESIGN MOMENT	ALLOWABLE MOMENT	DESIGN/ALLOWABLE MOMENT RATIO
	HORIZONTAL REINFORCEMENT (K-in/ft)	HORIZONTAL REINFORCEMENT (K-in/ft)	
Pool Floor (56"Element)	702.9	1200.0	0.586
<u>North Wall</u>			
El. 680'-5" to 701'-3" (36"Elements)	502.0	1260.0	0.398
El. 680'-5" to 701'-3" (21" Elements)	183.5	714.0	0.257
El. 678'-5" to 680'-5" (33.5" Elements)	451.4	1239.0	0.364
El. 659'-5.625" to 678'-5" (36" Elements)	605.0	1260.0	0.480
El. 659'-5.635" to 673'-5" (21" Elements)	210.8	714.0	0.295
<u>South Wall</u>			
El. 672'-0" to 701'-3" (18" Elements)	146.6	504.0	0.290
El. 659'-5.625" to 672'-0" (57" Elements)	774.2	2142.0	0.361
<u>East Wall</u>			
El. 680'-5" to 701'-3" (36" Elements)	529.2	1260.0	0.420
El. 659'-5.625" to 680'-5" (57" Elements)	1027.6	2142.0	0.488
<u>West Wall</u>			
El. 680'-5" to 701'-3" (36' Elements)	529.2	1260.0	0.420
El. 659'-5.625" to 680'-5" (57" Elements)	1027.6	2142.0	0.480

TABLE 8.4

RESULTS OF THE STORAGE POOL STRUCTURAL ANALYSIS  
 LOAD COMBINATION #4,  $0.75(1.4D + 1.7L + 1.9E + 1.7T_0)$

STRUCTURAL ELEMENT DESCRIPTION	MAXIMUM DESIGN MOMENT	ALLOWABLE MOMENT	DESIGN/ALLOWABLE MOMENT RATIO
	HORIZONTAL REINFORCEMENT (K-in/ft)	HORIZONTAL REINFORCEMENT (K-in/ft)	
Pool Floor (56" Element)	702.9	1200.0	0.586
<u>North Wall</u>			
El. 680'-5" to 701'-3" (36" Elements)	538.9	1260.0	0.428
El. 680'-5" to 701'-3" (21" Elements)	210.8	714.0	0.294
El. 678'-5" to 680'-5" (33.5" Elements)	505.3	1239.0	0.408
El. 659'5.625" to 678'-5" (36" Elements)	708.0	1260.0	0.562
El. 659'-5.625" to 678'-5" (21" Elements)	251.1	714.0	0.352
<u>South Wall</u>			
El. 672'-0" to 701'-3" (18" Elements)	149.1	504.0	0.296
El. 659'-5.625" to 672'-0" (57" Elements)	779.1	2142.0	0.364
<u>East Wall</u>			
El. 680'-5" to 701'-3" (36" Elements)	601.2	1260.0	0.477
El. 659'-5.625" to 680'-5" (57" Elements)	1246.9	2142.0	0.582
<u>West Wall</u>			
El. 680'-5" to 701'-3" (36" Elements)	601.2	1260.0	0.477
El. 659'-5.625" to 680'-5" (57" Elements)	1246.9	2142.0	0.582

TABLE 8.5  
RESULTS OF THE STORAGE POOL STRUCTURAL ANALYSIS  
LOAD COMBINATION #5, D + L + 1.25 E + I.L. - CASK DROP EVENT

STRUCTURAL ELEMENT DESCRIPTION	MAXIMUM SHEAR STRESS			MAXIMUM COMpressive STRESS			MAXIMUM TENSILE STRESS			DESIGN Vertical Load-Point No.	Vertical Element Count (No.)	Segmental Reinforcement (kips)	Horizontal Reinforcement (kips)	Maximum Moment (ft-in/tt)	Maximum Horizontal Spanwise Defl. (in/in/tt)	Vertical Defl. (in/in/tt)	Horizontal Defl. (in/in/tt)	Nodal Point Ratio	Vertical Defl. at Vertical Reinforcement Point (in/in/tt)
	Element No.	Stress (Ksi)	Element No.	Stress (Ksi)	Element No.	Stress (Ksi)	Element No.	Stress (Ksi)	Element No.										
Pool Floor	167	0.066	163	0.136	162	0.157													
North Wall																			
E1. 680'-5" to 701'-3" (36" Elements)	61	0.021	61	0.033	61	0.029													
E1. 680'-5" to 701'-3" (21" Elements)	1	0.024	1	0.039	1	0.027	1	0.009	23.8	8.0	714.0	229.2	0.033	0.035					
E1. 678'-5" to 680'-6" (23.25" Elements)	80	0.044	80	0.085	80	0.030	77	0.016	179.6	35.9	1239.0	519.6	0.145	0.069					
E1. 659'-5.625" to 678'-5" (36" Elements)	141	0.070	160	0.18	125	0.134	125	0.005	347.3	13.0	1260.0	528.0	0.276	0.025					
E1. 659'-5.625" to 678'-5" (21" Elements)	159	0.046	159	0.153	127	0.104	126	0.013	92.0	28.7	714.0	299.2	0.129	0.096					
South Wall																			
E1. 672'-0" to 701'-3" (16" Element)	102	0.027	103	0.075	70	0.006	70	0.001	4.0	1.0	504.0	211.2	0.008	0.005					
E1. 659'-5.625" to 672'-0" (57" Element)	152	0.089	149	0.139	152	0.019	152	0.015	123.5	97.5	2142.0	897.6	0.058	0.109					
East Wall																			
E1. 680'-5" to 701'-3" (36" Element)	58	0.014	42	0.044	42	0.046	42	0.014	119.2	36.3	1260.0	528.0	0.095	0.069					
E1. 659'-5.625" to 680'-5" (57" Element)	14	0.055	74	0.085	153	0.061	155	0.023	396.4	149.5	2142.0	897.6	0.185	0.167					
West Wall																			
E1. 680'-5" to 701'-3" (36" Element)	51	0.013	35	0.034	35	0.047	35	0.014	121.8	36.2	1260.0	528.0	0.096	0.069					
E1. 659'-5.625" to 680'-5" (57" Element)	67	0.053	67	0.086	67	0.104	146	0.023	675.8	149.5	2142.0	897.6	0.315	0.167					
* Allowable Shear Stress = 0.201 ksi ** Allowable Compressive Stress = 2.062 ksi																			

## 9. CONCLUSIONS

The results of the structural analysis of the fuel storage pool structure indicate that the maximum stresses and internal moments in the pool floor and walls resulting from the loadings including those associated with the augmented spent fuel storage requirements are within the allowable limits for Seismic Category 1 structure. It is, therefore, concluded that the design of the LaCrosse Boiling Water Reactor Spent Fuel Storage pool is adequate to withstand the normal and abnormal loading conditions.

## 10. REFERENCES

1. Nuclear Energy Services, Inc. "Structural Analysis Design Report for the LaCrosse Boiling Water Reactor High Density Spent Fuel Storage Racks, NES Document 81A0546 (Rev. 2), revision dated 8/7/78.
2. Nuclear Energy Services, Inc. "Spent Fuel Shipping Cask Drop Analysis for the LACBWR Nuclear Power Plant", NES Document 81A0550, (Rev. 2), September 20, 1978.
3. Sargent and Lundy Engineers "LACBWR" Project Drawings.
4. Nuclear Energy Services, Inc. Drawings for LaCrosse Boiling Water Reactor Spent Fuel Storage Racks.
5. Nuclear Energy Services, Inc. Document NES 81A0544, Rev. 0, "Quality Assurance Program Plan for the LaCrosse Boiling Water Reactor Spent Fuel Storage Rack Design Program", March 1978.
6. USNRC Standard Review Plan, Section 3.8.4.
7. Nuclear Energy Services, Inc. "Evaluation of the Spent Fuel Pool Cooling System LaCrosse Boiling Water Reactor High Density Fuel Storage Rack Program" NES Document 81A0549 (Rev. 1), July 1978.
8. Dairyland Power Cooperative, "LaCrosse Boiling Water Reactor Technical Specifications" DPRA-6 (Appendix A).
9. "USNRC Proposed Position for Review and Acceptance of Spent Fuel Storage and Handling Applications".
10. ACI 318-71 - "Building Code Requirements for Reinforced Concrete", American Concrete Institute.
11. Uniform Building Code, Volume 1, 1970 Edition.
12. George Winter, et.al. - "Design of Concrete Structures", McGraw Hill Book Company, 1964.
13. MRI/Stardyne 3 - Static and Dynamic Structural Analysis System for Scope 3.4 "Operating System User's Information Manual", Revision B, Control Data Corporation, April 1978.

14. "LaCrosse Boiling Water Reactor Spent Fuel Storage Pool  
Stardyne Structural Analysis Project 5101, Task 237",  
NES Computer Output Binder No. S32, June 1978.
15. Gulf United Services, Document SS-1162 "Seismic Evaluation  
of the LaCrosse Boiling Water Reactor".
16. "Structural Analysis and Design of Nuclear Plant Facilities",  
American Society of Civil Engineers, 1976.
17. ST-57 "Circular Concrete Tanks Without Prestressing"  
Portland Cement Associates, Chicago, Illinois.
18. BC-TOP-9A-Rev. 2 "Design of Structures for Missile Impact",  
Bechtel Power Corporation, San Francisco, California  
September 1974.
19. Roark, R. J., "Formulae for Stress and Strain" McGraw-Hill  
Book Company, 1965.

APPENDIX

- A. LOADING DATA
- B. SPENT FUEL STORAGE POOL FLOOR AND WALL ALLOWABLE ULTIMATE MOMENT CAPACITY
- C. EQUIVALENT THERMAL MOMENT CALCULATIONS
- D. EFFECTS OF SEISMIC LOADINGS FROM ADJACENT BUILDING STRUCTURES



## APPENDIX A

REF.

LOADING DATA

The loading cases to be applied to the spent fuel storage pool model are considered in accordance with the requirements of USNRC Standard Review Plan, Section 3.8.4 (reference #6).

For service load conditions - using ultimate strength design, the combinations of load cases as specified by section 3.8.4 for concrete structures are:

1.  $1.4D + 1.7L$
2.  $1.4D + 1.7L + 1.9E$  (ref #6)

WHERE:

D = Dead loads of the storage pool

L = Live loads associated with the weights of the fully-loaded racks, crash pad, spent fuel shipping cask and hydrostatic pressures.

For these load combinations, the stresses and moments generated must be less than 4 which is the ultimate section strength required to resist design loads based on the strength design moments described in ACI 318-71 (reference #10).

For service load conditions - using ultimate strength design and including the thermal



LOADING DATA	REF.
STRESSES GENERATED DUE TO TEMPERATURE DIFFERENTIAL ACROSS POOL FLOOR AND CUNNELS, THE LOAD COMBINATIONS AS PRESCRIBED BY SECTION 3.9.4 (REF #6) ARE:	
3. $0.75(1.4D + 1.7L + 1.7T_0)$	(REF #6)
4. $0.75(1.4D + 1.7L + 1.9E + 1.7T_0)$	
WHERE : $T_0$ = THERMAL EFFECTS AND LOADS DURING NORMAL OPERATING OR SHUTDOWN CONDITIONS, BASED ON MOST CRITICAL STATION-STATE CONDITIONS.	
E - LOADS GENERATED BY $\frac{1}{2}$ SAFE SHUTDOWN EARTHQUAKE.	
NOTE: The SPECIFIED COMBINATIONS TO INCLUDE THE SHUT DOWN EARTHQUAKE ( $D+L+E'$ ) IS LESS SEVERE THAN THOSE INCLUDING THE $\frac{1}{2}$ SAFE SHUTDOWN EARTHQUAKE $0.75(1.4D + 1.7L + 1.7T + 1.9E)$ AND THEREFORE IS NOT PERFORMED.	
FOR FACTOR LOAD CONDITIONS WHICH REPRESENT ABNORMAL LOADING CONDITIONS, USING ULTIMATE STRENGTH DESIGN METHODS, LOAD COMBINATIONS ARE:	
5. $D+L + 1.25E + I.L.$	
WHERE: I.L. - LOADS ASSOCIATED WITH CASE DROP EVENT.	

## LOADING DATA

REF.

## DEAD LOAD ANALYSIS 'D'

THE DEAD WEIGHT OF THE POOL INCLUDES THE WEIGHT OF THE REINFORCED CONCRETE WALLS AND FLOOR ONLY.

THE DEAD WEIGHT LOADS AND STRESSES IN THE POOL STRUCTURE ARE ANALYTICALLY DETERMINED BY APPLYING A VERTICAL 1 G ACCELERATION TO THE "SPENT FUEL POOL MODEL" WITH APPROPRIATE BOUNDARY CONDITIONS.

THE WEIGHT OF THE POOL IS DETERMINED BY APPLYING A REINFORCED CONCRETE DENSITY IN APPROPRIATE UNITS.

$$\text{CONCRETE DENSITY} = 144 \text{ lb/ft}^3$$

$$= \frac{144}{1000} \times \frac{\text{ft}^3}{1728} = 0.83 \times 10^{-4} \text{ k/in}^3$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY JR DATE 8/24/78 PROJ. S101 TASK 237  
CHKD. I.H DATE 8-25-78 PAGE A-4 OF A-9  
LACBWR


LOADING DATA	REF.
<u>LIVE LOAD ANALYSIS 'L'</u>	
<p>THE MAX. LIVE LOAD IN THE SPENT FUEL POOL FLOOR INCLUDES THE FULL POOL WATER WEIGHT, THE WEIGHT OF THE FULLY LOADED ROCKS, WEIGHT OF A SPENT FUEL SHIPPING CASK. THE LIVE LOAD ON THE SPENT FUEL POOL WALLS INCLUDES THE HYDROSTATIC PRESSURE OF THE WATER.</p> <p>THE WEIGHT OF EACH OF THE LOAD CONTRIBUTORS IS CONVERTED INTO A PRESSURE LOAD (P.A-4 &amp; A-5) AND APPLIED TO THE APPROPRIATE GRID-PLATE IN THE SPENT FUEL POOL MODEL.</p> <p><u>POOL FLOOR PRESSURE LOADING</u></p> <p>1. POOL WATER PRESSURE LOAD - (ASSUMING FULL POOL)      WATER DEPTH IN POOL = <math>(\text{EL. } 700' - 9") - (\text{EL. } 659' - 5625")</math>  <math>= 41.28125'</math>.      PRESSURE LOAD ON FLOOR = <math>\frac{11' \times 11' \times 41.28125 \times 62.4}{11' \times 11'}</math>  <math>= 2575.95 \frac{\text{kips}}{\text{sq. ft}}</math> OR <math>0.0179 \frac{\text{kips}}{\text{sq. in.}}</math></p> <p>2. WEIGHT OF FUEL STORAGE ROCKS + FUEL  <math>= 650.0 \frac{\text{lb}}{\text{cell}} (8 \times 9 \times 2 \text{ TIERS} \times 2 \text{ RACKS} + 4 \times 10 \times 2 \text{ TIERS} \times 2 \text{ RACKS}) = .650^k \times 440 \text{ CELLS} = .286.0 \text{ KIPS}</math></p> <p>PRESSURE LOAD ON FLOOR ASSUMED UNIFORM UNDER RACK  <math>\text{AREA} = 2 \times [8 \times 9 + 4 \times 10] \times (7" \text{ PITCH})^2 = 10976 \frac{\text{in}^2}{\text{in}^2}</math></p> <p>PRESSURE LOAD = <math>\frac{286}{10976 \frac{\text{in}^2}{\text{in}^2}} = 0.0265 \frac{\text{kips}}{\text{in}^2}</math></p>	
	REF.1

LOADING DATA		REF.																																	
(3) CASE WEIGHT = 100 K		REF. 2																																	
CASE CROWN POOL DEEDS $\approx 70'' \times 70'' = 4900 \text{ in}^2$		REF. 2																																	
CASE PRESSURE LOAD = $\frac{100 \text{ K}}{4900 \text{ in}^2} = 0.0204 \text{ K/in}^2$																																			
(4) CASE DROP REACTION LOAD = 7174.3 KIPS		REF. 2																																	
CASE DROP PRESSURE LOAD = $\frac{7174.3 \text{ K}}{4900 \text{ in}^2} = 1.464 \text{ K/in}^2$																																			
<u>POOL WATER PRESSURE LOADS</u>																																			
① HYDROSTATIC PRESSURE LOAD RESULTING FROM THE POOL WATER IS EQUAL TO $wh$ WHERE $w = 62.4 \frac{\text{ft}}{\text{ft}}$ TIMES THE HEIGHT FROM THE WATER SURFACE. THE AVG. PRESSURE LOAD ON QND PLATES AT EACH ELEVATION IS TAKEN AS THE $w$ TIMES THE HEIGHT TO THE MID-HEIGHT OF THE QND-PLATES.																																			
Therefore: HYDROSTATIC PRESSURE = $wh = \frac{62.4}{144} \times h (\text{feet})$																																			
<table border="1"> <thead> <tr> <th>QND PLATE NO.</th> <th>Avg. HEIGHT TO WATER SURFACE (Feet)</th> <th>PRESSURE LOAD (K/in<sup>2</sup>)</th> </tr> </thead> <tbody> <tr> <td>1 - 16</td> <td><math>6\frac{1}{2} = 3.0'</math></td> <td>0.0013 ✓</td> </tr> <tr> <td>17 - 32</td> <td><math>6.0' + 5\frac{1}{2}' = 8.5'</math></td> <td>0.00368 ✓</td> </tr> <tr> <td>33 - 49</td> <td><math>11.0' + 5\frac{1}{2}' = 13.5'</math></td> <td>0.00585 ✓</td> </tr> <tr> <td>48 - 64</td> <td><math>16.0' + 5\frac{1}{2}' = 18.5'</math></td> <td>0.00802 ✓</td> </tr> <tr> <td>65 - 80</td> <td><math>21.0' + 2\frac{1}{2}' = 22.0'</math></td> <td>0.00953 ✓</td> </tr> <tr> <td>81 - 96</td> <td><math>23.0' + 4\frac{1}{2}' = 25.0'</math></td> <td>0.0108 ✓</td> </tr> <tr> <td>97 - 112</td> <td><math>27.0' + 4\frac{1}{2}' = 29.0'</math></td> <td>0.01257 ✓</td> </tr> <tr> <td>113 - 128</td> <td><math>31.0' + 2\frac{1}{2}' = 32.0'</math></td> <td>0.01389 ✓</td> </tr> <tr> <td>129 - 144</td> <td><math>33.0' + 4\frac{1}{2}' = 35.0'</math></td> <td>0.01517 ✓</td> </tr> <tr> <td>145 - 160</td> <td><math>37.0' + 5\frac{1}{2}' = 39.5'</math></td> <td>0.01712 ✓</td> </tr> </tbody> </table>			QND PLATE NO.	Avg. HEIGHT TO WATER SURFACE (Feet)	PRESSURE LOAD (K/in <sup>2</sup> )	1 - 16	$6\frac{1}{2} = 3.0'$	0.0013 ✓	17 - 32	$6.0' + 5\frac{1}{2}' = 8.5'$	0.00368 ✓	33 - 49	$11.0' + 5\frac{1}{2}' = 13.5'$	0.00585 ✓	48 - 64	$16.0' + 5\frac{1}{2}' = 18.5'$	0.00802 ✓	65 - 80	$21.0' + 2\frac{1}{2}' = 22.0'$	0.00953 ✓	81 - 96	$23.0' + 4\frac{1}{2}' = 25.0'$	0.0108 ✓	97 - 112	$27.0' + 4\frac{1}{2}' = 29.0'$	0.01257 ✓	113 - 128	$31.0' + 2\frac{1}{2}' = 32.0'$	0.01389 ✓	129 - 144	$33.0' + 4\frac{1}{2}' = 35.0'$	0.01517 ✓	145 - 160	$37.0' + 5\frac{1}{2}' = 39.5'$	0.01712 ✓
QND PLATE NO.	Avg. HEIGHT TO WATER SURFACE (Feet)	PRESSURE LOAD (K/in <sup>2</sup> )																																	
1 - 16	$6\frac{1}{2} = 3.0'$	0.0013 ✓																																	
17 - 32	$6.0' + 5\frac{1}{2}' = 8.5'$	0.00368 ✓																																	
33 - 49	$11.0' + 5\frac{1}{2}' = 13.5'$	0.00585 ✓																																	
48 - 64	$16.0' + 5\frac{1}{2}' = 18.5'$	0.00802 ✓																																	
65 - 80	$21.0' + 2\frac{1}{2}' = 22.0'$	0.00953 ✓																																	
81 - 96	$23.0' + 4\frac{1}{2}' = 25.0'$	0.0108 ✓																																	
97 - 112	$27.0' + 4\frac{1}{2}' = 29.0'$	0.01257 ✓																																	
113 - 128	$31.0' + 2\frac{1}{2}' = 32.0'$	0.01389 ✓																																	
129 - 144	$33.0' + 4\frac{1}{2}' = 35.0'$	0.01517 ✓																																	
145 - 160	$37.0' + 5\frac{1}{2}' = 39.5'$	0.01712 ✓																																	



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY JR DATE 8/24/78 PROJ. 5101 TASK 237  
CHKD. J.H. DATE 8-26-78 PAGE A-1 OF A-3  
LACBUP

LOADING DATA	REF.
<u>FUEL POOL SEISMIC ANALYSIS</u>	
<p>A seismic analysis of the spent fuel pool including a full complement of fuel storage assemblies is completed by calculating the minimum wall frequency and determining a lateral acceleration from the response spectra at that elevation. This lateral G is then applied to the dead weight and live loads and combined with the seismic bracing loads calculated in Ref. 1, to determine the seismic stresses in the pool walls and floor generated by an earthquake.</p> <p><u>MINIMUM FREQUENCY OF WALL -</u> Assuming a 12" deep strip of wall 11' long fixed at both ends, and laterally loaded by a portion of water 11' long, 11' wide and 1' deep:</p>  $W = wl = \frac{62.4}{1000} \text{ k}_f \text{ ft}^3 \times 11' \times 11' \times 1'$ $+ \frac{144}{1000} \times 1.75' \times 11' = 10.332 \text{ k}_f$ <p>Moment of Inertia of 1.75' thick slab <math>I_c = \frac{1}{12}(12)(21.0)^3 = 9261.0 \text{ in}^4</math></p> <p>Lateral frequency = <math>3.55 \sqrt{\frac{384 EI}{Wl^3}}</math></p> $= 3.55 \sqrt{\frac{(384)(9261.0)(3000)}{(10.332)(11 \times 12)^3}} = 75.22 \text{ CPS}$	
	REF. 19



LOADING DATA	REF.
From Accelerations SPECIMEN:	REF 5
ACCELERATION VALUE $G_{SSE} = 0.45$ ; $G_{\frac{1}{2}SSE} = 0.33$	
② THE EQUIVALENT STATIC PRESSURE LOAD:	
PRESSURE LOAD ( $\frac{1}{2}SSE$ ) = $\frac{62.4}{1000} \times \frac{(11.0)(1.0)(1.0)}{144} \sqrt{0.33}$ = $0.001573 \text{ k/in}^2$	
PRESSURE LOAD ( $SSE$ ) = $0.001573 \times \frac{0.45}{0.33} = 0.002145 \text{ k/in}^2$	
③ Seismic Bracing Lateral Pressure Loads:	
THE SEISMIC BRACING IS LOCATED AT 2 ELEVATIONS. (SEE "NES SPENT FUEL ROCK DRAWINGS")	REF 4
THE TOTAL LATERAL WALL LOADS AT EACH ELEVATION IS CONVERTED INTO A PRESSURE LOAD AND APPLIED AT THE APPROPRIATE ELEVATIONS IN THE "POOL MODEL".	
A. <u>UPPER GRID</u> - MAX. WALL LOAD ( $SSE$ ) = $46.8 \text{ k}$ $(\frac{1}{2}SSE) = 34.3 \text{ k}$	REF 1
$SSE$ PRESSURE LOAD = $\frac{46.8 \text{ k}}{(11)(2.0)(144)} = 0.0148 \sqrt{\text{k/in}^2}$	
$\frac{1}{2}SSE$ PRESSURE LOAD = $\frac{34.3 \text{ k}}{(11)(2.0)(144)} = 0.0108 \sqrt{\text{k/in}^2}$	
NOTE: PRESSURE LOAD IS APPLIED AT UPPER GRID SEISMIC BRACING ELEVATION COINCIDING WITH QUAD-PLATES 65-80 (P-7-1, 7-6) AND THEREFORE THE PRESSURE LOAD IS DISTRIBUTED OVER THE 2' DEPTH (P-7-4).	
B. <u>INTERMEDIATE GRID</u> - MAX. WALL LOAD ( $SSE$ ) = $93.5 \text{ k}$ $(\frac{1}{2}SSE) = 69.5 \text{ k}$	
$SSE$ PRESSURE LOAD = $\frac{93.5 \text{ k}}{(11)(2.0)(144)} = 0.0275 \sqrt{\text{k/in}^2}$	



LOADING DATA.	REF.
$\frac{1}{2}$ SSE PRESSURE LOAD = $\frac{68.5}{(11)(2.0)144} = 0.0216^{\vee} \text{k/in}^2$	
c. LOWER GRID MNX. WALL LOAD (SSE) = 52.6 <sup>k</sup> ( $\frac{1}{2}$ SSE) = 38.6 <sup>k</sup>	
SSE PRESSURE LOAD = $\frac{52.6^k}{(11.0)(5.0)144} = 0.00664^{\vee} \text{k/in}^2$	
$\frac{1}{2}$ SSE PRESSURE LOAD = $\frac{39.6}{(11.0)(5.0)144} = 0.00487^{\vee} \text{k/in}^2$	
<u>COMPARISON OF Seismic Loadings FOR <math>\frac{1}{2}</math> SSE AND SSE EVENTS</u>	
RATIO OF Seismic INERTIA LOADING OF THE CONCRETE WALLS, AND POOL CENTER MASS FOR $\frac{1}{2}$ SSE AND DBE (Pg. A-7) = $\frac{0.001573}{0.002145} = 0.733 \text{ OR } 73.3\%$	
RATIO OF THE MNX. Seismic REACTION LOADS OF THE FUEL STORAGE RACKS FOR $\frac{1}{2}$ SSE AND SSE EVENT:	
UPPER GRID (Pg. A-7) = $\frac{34.3}{46.8} = 0.733 \text{ OR } 73.3\%$ (REF#1)	
INTERMEDIATE GRID (Pg. A-7) = $\frac{68.5}{93.5} = 0.733 \text{ OR } 73.3\%$ (REF#1)	
LOWER GRID (Pg. A-7) = $\frac{38.6}{52.6} = 0.734 \text{ OR } 73.4\%$	
SINCE THE RATIO OF THE $\frac{1}{2}$ SSE TO SSE SEISMIC LOADS IS APPROXIMATELY 73%, THE LOAD COMBINATIONS INVOLVING THE $\frac{1}{2}$ SSE EVENT WILL BE MORE SEVERE.	

## APPENDIX B

REF.

SPENT FUEL POOL FLUSH AND WALL ALLOWABLE  
ULTIMATE MOMENT CAPACITY

The structural acceptance criterion for the LOCBWR SPENT FUEL STORAGE, (SECTION 6 of REPORT) is specified in USNRC STANDARD REVIEW PAPER, SECTION 3.C.4 (REF. 6).

From (Ref # 6), for the factored load combinations, as specified in APPENDIX A, the allowable limits (shear, compression, tensile) which constitute the acceptance criteria are the ultimate section strength required to resist design loads and moments based on the ultimate strength design methods of ACI 318-71 (REF. 10).

From Ref #10, the allowable shear stress is  $4\bar{\phi}\sqrt{f'_c}$  [where:  $\bar{\phi} = 0.85$  &  $f'_c = 3500 \text{ psi}$ ] REF #10

or 201.6 psf. The allowable compression stress is  $0.85\phi f'_c$  [where:  $\phi = 0.7$  &  $f'_c = 3500 \text{ psi}$ ] REF #10

or  $(0.85)(0.7)/3500 = 2032.5 \text{ psf}$ . The allowable tensile stresses (ultimate strength designs) are represented by the allowable ultimate moment capacity of various concrete sections (a function of the steel area and slab thickness) and compared with the design moments obtained in the "SPENT FUEL STORAGE POOL ANALYSIS".



CONCRETE WALL Ultimate Moment Capacity		REF.
<u>EST WALL - EL. 680'-0.0" to 701'-3.0"</u>		
<p>ELEVATION WALL CROSS- SECTION (Typ)</p>	<p><u>DESCRIPTION</u></p> <p>THE EAST WALL FROM AN ELEVATION OF 680'-0.0" TO 701'-3.0" IS CONSTRUCTED OF REINFORCED CONCRETE 3.0' THICK. THE LATERAL REINFORCEMENT INCLUDES SIZE #9 @ 9" ON THE POOL SIDE OF THE WALL AND SIZE #8 @ 9" ON THE FAR SIDE. THE VERTICAL REINFORCEMENT INCLUDES SIZE #6 @ 12" ON BOTH SIDES ON THE WALL.</p>	REF.3
<u>Ultimate Moment Capacity (per linear foot of wall)</u>		
$M_u$ (ABOUT X2 AXIS)	TENSILE REINFORCEMENT RATIO $R_e = \frac{A_s}{bd}$ $R_e = 0.44 / (36)(12) = 0.001^*$	REF.12
<p><math>d = 36.0</math>"</p> <p><math>d_e = 30.0</math>"</p> <p><math>#6 @ 12"</math></p> <p><math>R_s = 0.44</math></p>	$P_b$ (BALANCED RATIO) = $(.85)^2 \frac{f_c}{f_y} \left( \frac{87000}{87000+f_y} \right)$ $= (.85)^2 \frac{3500}{40,000} \left( \frac{87000}{127000} \right) = 0.0433^*$	
$P_{max}$ (ALLOWABLE) = $.75 P_b = 0.032 > 0.001^*$ ENSURES STEEL YIELDING CONTROLS.		
ULTIMATE MOMENT (VERTICAL REINFORCEMENT) $M_{ult,x_2} = A_s f_y d_e$		REF.13
$M_{ult,x_2} = (0.44)(40 \text{ ksi}) / \left( \frac{30}{12} \right) = 44^* \text{ K-FT}$ OR $528 \text{ K-in} / \text{ft of wall}$ (Since tensile steel equals compression steel, no doubling moment capacity from concrete)		






CONCRETE WALL ULTIMATE MOMENT CAPACITY		REF.
M <sub>ult</sub> (ABOUT X3 AXIS)	TENSILE REINFORCEMENT RATIO	
<p><math>A_s = 1.33 \text{ in}^2</math></p>	$= \frac{A_s}{bd} = \frac{(1.33)}{(36)(12)} = 0.0031 \approx$	
$A_s = 1.05 \text{ in}^2$	STEEL YIELDING -	
BY ASSUMING THE SMALLER AMOUNT OF REINFORCEMENT YIELD IN TENSION.	THE MINIMUM ULTIMATE MOMENT CAPACITY OF THE WALL IS DETERMINED	
$M_{ult} (\text{HORIZONTAL REINFORCEMENT}) = A_s F_y d_t = (1.05)(40.0) \frac{30}{12} = 105 \text{ k-ft}$ OR $1260 \sqrt{\text{k-in/ft of wall}}$		
EAST WALL - EL. 659'-5.625" TO 680'0"		
<p>Pool side</p> <p>ELEVATION WALL CROSS-SECTION (TOP)</p>	THE POOL EAST WALL IS 57.0" THICK FROM AN ELEV. 680'-0.0" DOWN TO POOL FLOOR. SIMILAR REINFORCEMENT IS USED AS IS FOUND IN THE THINNER UPPER SECTION.	REF.3
	<u>ULTIMATE MOMENT CAPACITY</u> (ABOUT X1 AXIS)	
<p><math>A_s = 0.44 \text{ in}^2</math></p>	$P = \frac{A_s}{bd} = \frac{0.44}{(12)(57)} = 0.0006 \approx$	
<p><math>A_s = 0.44 \text{ in}^2</math></p>	$M_{ult} (\text{VERTICAL REINFORCEMENT}) = (0.44)(40)(\frac{51.0}{12}) = 74.8 \sqrt{\text{k-ft}}$ OR $897.6 \sqrt{\text{k-in/ft of wall}}$	



CONCRETE WALL ULTIMATE MOMENT CAPACITY		REF.
<p>MULT (ABOUT X3 AXIS) THE MIN. ULT. MOMENT CAPACITY RESULTS WHEN MIN. AREA OF REINFORCEMENT IS IN TENSION.</p> <p>#8 @ 9" As = 1.33 in²</p> <p>#8 @ 9" As = 1.05 in²</p> $\frac{P_e}{t} = \frac{1.05}{(57)(12)} = 0.00153 \text{ ok}$		
$M_{ULT}(\text{HORIZONTAL}) = As F_y d_t = (1.05)(40) \frac{51.0}{12} = 178.5 \text{ k-ft}$ <p>or 2142 k-in/ft of wall</p>		
WEST WALL ULTIMATE MOMENT CAPACITY	REF3	
<p>THE DIMENSIONS AND REINFORCEMENT ARE SIMILAR AT ALL ELEVATIONS TO THOSE OF THE EAST WALL. THEREFORE THE ULTIMATE MOMENT CAPACITIES OF THE SECTIONS WILL BE SIMILAR TO THE EAST WALL ULTIMATE MOMENT CAPACITIES.</p>	REF3	
NORTH WALL ULTIMATE MOMENT CAPACITY EL. 659'-5.625" TO	REF3	
<p>#8 @ 9" 21.0"</p> <p>#8 @ 9"</p> <p>#6 @ 12"</p> <p>#6 @ 12"</p> <p>ELEVATION</p> <p>MULT (ABOUT X2 AXIS)</p> $\frac{P_e}{t} = \frac{As}{bd} = \frac{0.44}{(12)(21.0)} = 0.00175 \text{ ok}$		
<p>EL. 678'-5" AND 680'-5" TO 701'-3"</p> <p>THE NORTH WALL FROM ELEV. 659'-5.625" TO 678'-5" AND 680'-5" TO 701'-3"</p> <p>is 21.0" THICK BEING LATERALLY REINFORCED WITH #8 @ 9" ALONG POOL SIDE AND #6 @ 12" ALONG FOR SIDE. THE WALL IS ALSO REINFORCED VERTICALLY WITH #6 @ 12".</p> <p>12"</p> <p>#6 @ 12"</p> <p>As = 0.44 in²</p> <p>#6 @ 12"</p> <p>As = 0.44 in²</p>		




CONCRETE WALL ULTIMATE MOMENT CAPACITY	REF.
MULT (VERTICAL REINFORCEMENT) = $A_s F_y d = (0.44)(40)(\frac{21-(2)3}{12}) = 22 \checkmark$ K-Ft OR $264 \text{ k-in}/\text{ft of wall}$	
MULT (ABOUT X3 AXIS) WHEN THE SMALLER REINFORCEMENT IS LOCATED IN TENSILE REGION.	MIN. MULT WILL RESULT
 $P_c = \frac{A_c}{bd} = \frac{1.33}{(12)(21)} = 0.00528 \checkmark$	
	MULT (HORIZONTAL REINF.) = $A_s F_y d$ $= (1.05)(40)(\frac{15}{12}) = 52.5 \checkmark$ K-FT OR $630 \text{ k-in}/\text{ft of wall}$
<u>NORTH WALL ULTIMATE MOMENT CAPACITY EL. 678'-5" TO 680'-5"</u> THE NORTH WALL IS CONSTRUCTED OF A 33.5" THICK WALL REINFORCED WITH SIMILAR SIZES AS UPPER PORTION. RET.3	
	FOR THE ULTIMATE MOMENT ABOUT THE X2 AXIS, TAKE A 1 FOOT SECTION: $P_c = \frac{A_c}{bd} = \frac{0.44}{(12)(33.5)} = 0.00105 \checkmark$
	
MULT (VERTICAL REINFORCEMENT) = $A_s F_y d = (0.44)(40)(\frac{29.5}{12}) = 43.3 \checkmark$ K-Ft OR $519.6 \text{ k-in}/\text{ft of wall}$	



CONCRETE Wall ULTIMATE MOMENT CAPACITY

REF.

ULTIMATE MOMENT ABOUT X3 AXIS




$$P_c = \frac{1.05}{(12)(33.5)} = 0.0026 \text{ ok}$$

MIN. MULT RESULTS WHEN  
THE SMALLER STEEL  
AREA IS IN TENSION.

$$\text{MULT (HORIZONTAL REINFORCEMENT)} = A_{st} f_y d = (1.05)(40.0)\left(\frac{29.5}{12}\right) = 103.25 \checkmark \text{ K-FT}$$

OR  $1239.0 \text{ k-in/ft}$  OF WALL

NORTH WALL ULTIMATE MOMENT CAPACITY EL 659'-5.625" TO 701'-3"



NOTE: THIS SECTION IS SIMILAR  
IN SIZE AND REINFORCEMENT TO  
THE 36" THICK SLAB OF  
THE EAST WALL. THEREFORE,  
THE MULT WILL BE THE SAME.

REF 3

$$\text{MULT (VERTICAL REINFORCEMENT)} = 528 \text{ k-in/ft} \quad (\text{Per B-2})$$

$$\text{MULT (HORIZ. REINFORCEMENT)} = 1260 \text{ k-in/ft}$$

SOUTH WALL ULTIMATE MOMENT CAPACITY EL 659'-5.625" TO 672'-0"

THE LOWER SECTION OF THE SOUTH WALL (EL. 659'-5.625"  
TO 672'-0") HAS A SIMILAR THICKNESS AND  
REINFORCEMENT AS THE EAST AND WEST WALLS.  
THEREFORE:

$$\text{MULT (VERTICAL REINFORCEMENT)} = 897.6 \text{ k-in/ft} \quad (\text{Per B-3})$$


$$\text{MULT (HORIZONTAL REINFORCEMENT)} = 2142 \text{ k-in/ft} \quad (\text{Per B-4})$$



CONCRETE Wall Ultimate Moment Calculations

REF.

South Wall Ultimate Moment Capacity - 672' TO 701'-3"




THE SOUTH WALL FROM ELEV. 672' TO 701'-3" IS 18.0" THICK AND SUPPORTED AT MID-POINT BY INTERSECTING WALL. THE SOUTH WALL IS LATERALLY REINFORCED WITH #9 @ 9" ON POOL SIDE AND #8 @ 9" ON FAR SIDE. THE WALL IS ALSO VERTICALLY REINFORCED WITH #6 @ 12".

REF.3


M<sub>ULT</sub> (x<sub>2</sub> axis)

(VERTICAL REINFORCEMENT)



$$\begin{aligned} M_{ult} (\text{VERTICAL REINFORCEMENT}) &= A_s F_y d \\ &= (0.44)(40)(18 - (2)(3)) = 17.6 \checkmark \text{ K-Ft} \\ \text{OR } & 211.2 \checkmark \text{ k-in / linear ft. of wall} \end{aligned}$$

M<sub>ULT</sub> (x<sub>3</sub> axis - HORIZONTAL REINFORCEMENT)



USING  $A_s \text{ min.} = 1.05 \text{ in}^2$


$$\begin{aligned} M_{ult} (\text{HORIZ. REINFORCEMENT}) &= A_s F_y d \\ &= (1.05)(40)(12) = 42.0 \checkmark \text{ K-Ft} \\ \text{OR } & 504 \checkmark \text{ k-in / ft. of wall.} \end{aligned}$$



## Pool Floor Ultimate Moment Capacity -

REF.

THE SPENT FUEL POOL FLOOR (EL. 654'-9" = 659'-5") CONSISTS OF A 56" REINFORCED CONCRETE SLAB SUPPORTED ALONG IT CENTERLINE IN THE E-W DIRECTION AND ALONG IT EDGES IN THE N-S DIRECTION. A TYPICAL 1 FT. CROSS-SECTION IS SHOWN BELOW.



$$\text{#7 @ 12"} \quad \text{As} = 0.6 \text{ in}^2/\text{in}$$
$$\text{Mult} = A_s F_y d$$

NOTE: THIS CROSS-SECTION IS TYPICAL IN BOTH DIRECTIONS.

REF. 3

$$M_{(\text{ult})} = (0.6)(40) \frac{50}{12} = 100 \sqrt{\text{k-in}}$$

$$\text{OR } 1200 \sqrt{\text{k-in}}/\text{ft. of floor}$$

ELEVATION



LOCBWR

## APPENDIX C

### - EQUIVALENT THICKNESS MOMENT CALCULATIONS -


REF.

The temperature differential across the pool floor and walls resulting from spent fuel assembly storage in the storage pool introduces thermal loads in the structure. The steady-state temperature gradient across the walls are determined assuming a bulk pool water temperature of 150°F and a air temperature behind the wall of 70°F.

An analysis of the temperature gradient in the fuel pool concrete wall (P.R.C-9, C-9) shows a fairly uniform decrease in temperature from the inner to outer faces of the pool walls and floor.

The thermal moments produced from this linear temperature gradient are a result of:

The inner fibers being hotter tend to expand more than the outer fibers, so if the segment is cut loose from the adjacent portions of the wall, Point A in Fig. 38 will move to A', B will move to B', and section



(REF #17)

FIG. 38

AB, which represents the stressless condition due to a uniform temperature change throughout, will move to a new position A'B'. Actually the movements from A to A' and B to B' are prevented since the circle must remain a circle, and stresses will be created that are proportional to the horizontal distances between AB and A'B'.



## EQUIVALENT THERMAL MOMENT CALCULATIONS

REF.

It is clear that  $AA' = BB' =$  movement due to a temperature change of  $\frac{1}{2}T$  or when  $\epsilon$  is the coefficient of expansion, that

$AA' = BB' = \frac{1}{2}T \times \epsilon$  per unit length of arc,  
and

$$\theta = \frac{AA'}{\frac{1}{2}t} = \frac{T \times \epsilon}{t} \quad (\text{REF. } \#17)$$

In a homogeneous section, the moment  $M$  required to produce an angle change  $\theta$  in an element of unit length may be written as

$$M_t = EI\theta$$

Eliminating  $\theta$  gives

$$M = \frac{EI \times T \times \epsilon}{t}$$

THE THERMAL GRADIENT INTRODUCES TENSILE STRESSES ON THE COLDER SIDE OF THE WALL PRODUCING HAZARDOUS CRACKING IN THE EXTREME FIBERS. THE POOL WALLS AND FLOOR ARE SUBJECT TO THIS HAZARDOUS CRACKING AND THEREFORE THE HEIGHTS OF INERTIA IN THESE SECTIONS WILL BE A FUNCTION OF A SECTION WITH THESE HAZARDOUS CRACKS. FROM REF # 18 "DESIGN OF STRUCTURES FOR MISSILE IMPACT", A COEFFICIENT FOR MOMENT OF INERTIA OF CRACKED SECTIONS IS OBTAINED FOR EACH WALL THICKNESS, APPLIED TO THE FULL SECTION MOMENT OF INERTIA TO CALCULATE A MODIFIED SECTION MOMENT OF INERTIA. This modified section I is then used in calculating THE THERMAL MOMENTS DEVELOPED DUE TO THE TEMPERATURE GRADIENT.

REF #  
18



EQUIVALENT THERMAL MOMENT CALCULATIONS

REF.

EAST WALL - THERMAL MOMENT CALC. WITH EL. 690'-0" TO EL. 701'-3"

FROM EL. 690'-0" TO 701'-3", THE EAST WALL IS 36" THICK. THE HORIZONTAL REINFORCEMENT ON THE POOL SIDE IS #9 @ 9" ( $A_s = 1.33 \text{ in}^2$ ) AND ON THE OPPOSITE SIDE #8 @ 9" ( $A_s = 1.05 \text{ in}^2$ ) (FIGURE 3.2V OF REPORT).

CRACKED SECTION MOMENT OF INERTIA CALCULATION

From "DESIGN OF STRUCTURES FOR IMPACT" (REF #18) REF<sub>PL</sub>, THE CRACKED SECTION MOMENT OF INERTIA ( $I_{cr}$ ) is:

$$I_{cr} = F b d^3$$

WHERE:  $b = 12.115$  (1ST SECTION OF WALL)

$d =$  DISTANCE FROM EXTREME COMPRESSION FIBER TO C OR TENSILE REINFORCEMENT

$F =$  COEFFICIENT FOR I OF CRACKED SECTION

$$P (\text{RATIO OF TENSILE REINFORCEMENT}) = \frac{A_s}{bd} = \frac{1.05}{(12)(36)} = 0.00243 \checkmark$$

$$P' (\text{RATIO OF COMPRESSIVE REINFORCEMENT}) = \frac{A_s'}{bd} = \frac{1.33}{(12)(36)} = 0.00303 \checkmark$$

$$n (\text{MODULAR RATIO}) = \frac{E_s}{E_c} = \frac{29 \times 10^6}{3.6 \times 10^6} \approx 8.0 \checkmark$$

WHERE:  $E_s = 29 \times 10^6 \text{ psi}$

$$E_c = 33 \omega^{3/2} \sqrt{f'_c} = (33)(150)^{3/2} \sqrt{3500} = 3.6 \times 10^6 \text{ psi} \text{ REF}_{PL}$$

$f'_c = 3500 \text{ psi}$

$\omega = 150 \text{ PCF}$

$$\text{RATIO } Pn = (0.00243)(8.0) = 0.0194 \checkmark$$

From CHART Pg 4-3 (REF #18)  $F = 0.016 \checkmark$

$$I_{cr} = F b d^3 = (0.016)(12)(36-3)^3 = 6722 \text{ in}^4 \checkmark$$



EQUIVALENT INTERNAL MOMENT CALCULATIONS	REF.
<p>Thermal Induced Moment = <math>\frac{EI_{cr} \times \Delta T \times \alpha_e}{t}</math></p> <p>WHERE: <math>E_c = 3.6 \times 10^6 \text{ psi}</math></p> <p><math>I_{cr} = 6900 \text{ in}^4</math></p> <p><math>\Delta T = \text{TEMPERATURE DIFFERENCE ACROSS WALL}</math> <math>= 150^\circ\text{F} - 70^\circ\text{F} = 80^\circ\text{F}</math></p> <p><math>t = \text{WALL THICKNESS} = 36.0"</math></p> <p><math>\alpha_e = \text{THERMAL EXPANSION COEFFICIENT}</math> <math>6.0 \times 10^{-6} \text{ in/in } /^\circ\text{F}</math></p> <p><math>\therefore M_t = \frac{(3.6 \times 10^6)(6900)(80^\circ\text{F})}{(36)(1000)} \frac{6.0 \times 10^{-6}}{} = 331.2 \text{ k-in}</math></p> <p><u>EAST WALL - EL 659'-5.625" TO 680'-0"</u></p> <p>THE EAST WALL FROM EL. 659'-5.625" TO 680'-0" IS 57" THICK. THE WALL'S HORIZONTAL REINFORCEMENT IS #9 @ 9" ON THE POOL SIDE AND #8 @ 9" ON THE OPPOSITE SIDE.</p> <p>THE TENSILE REINFORCEMENT RATIO (<math>P</math>) = <math>\frac{1.05}{(12)(57)} = 0.00153</math></p> <p>The <math>I_{cr} = Fb^3</math> (REF# 19)</p> <p><math>F = 0.01</math> (FOR <math>P_N = 0.00153 \times 8.0 = 0.0122</math>)</p> <p><math>I_{ce} = 0.01 (12) (57-3)^3 = 18,895.7 \text{ in}^4</math></p> <p>Thermal Induced Moment = <math>E \frac{I_{cr} \times \Delta T \times \alpha_e}{t}</math></p> <p><math>M_t = \frac{(3.6 \times 10^6)(18895.7)(80)(6 \times 10^{-6})}{(57)(1000)} = 572.8 \text{ k-in}</math></p>	REF#17



- EQUIVALENT THERMAL MOMENT CALCULATIONS -

REF.

WEST WALL THERMAL MOMENT CALCULATIONS

THE TEMPERATURE CHANGE, WALL THICKNESS AND REINFORCEMENT ARE SIMILAR TO THOSE OF THE EAST WALL. THEREFORE, THE THERMAL MOMENT WILL BE THE SAME AS IN THE EAST WALL.

NORTH WALL THERMAL MOMENTS- EL 659'-5.625" TO 701'-3"

A PORTION OF THE NORTH WALL FROM EL. 659'-5.625" TO 701'-3" IS 21" THICK AND IS HORIZONTALLY REINFORCED WITH #9 @ 9" ON POOL SIDE AND #8 @ 9" ON THE OPPOSITE SIDE. (SEE FIGURE 3.1)

THE TENSILE REINFORCEMENT RATIO ( $p$ ) =  $\frac{1.05}{(12)(21)} = 0.00417$  ✓  
ASSUMING A 1 FT SECTION OF WALL.

$F$  (COEFFICIENT OF CRACKED SECTIONS) FOR  $p_1$  RATIO =  
 $(.00417)9.0 = 0.033$  ✓ IS  $0.025$  ✓ (Pg. 4-8 OR RETTB)

CRACKED MOMENT OF INERTIA  $I_{cr} = (0.025)(12)(21.0 - 3)^3 = 1741.5 \text{ in}^4$  ✓

Thermal Moment =  $E \frac{I_{cr} \times \Delta T \times \Delta t}{t}$

REF #17

$$M_t = \frac{(3.6 \times 10^6)(1741.5)(80)(6.0 \times 10^{-6})}{(21.0)(1000)} = 144.0 \text{ k-in}$$

NORTH WALL THERMAL MOMENTS- EL. 678'-5" TO EL. 680'-5"

THE NORTH WALL FROM EL. 678'-5" TO 680'-5" IS COMPOSED OF A 33.5" THICK WALL HORIZONTALLY REINFORCED WITH #9 @ 9" ON POOL SIDE AND #8 @ 9" ON THE OPPOSITE SIDE. (SEE FIGURE 3.1)



EQUIVALENT THERMAL MOMENT CALCULATIONS		REF.
THE TENSILE REINFORCEMENT RATIO $p = \frac{A_s}{bd} = \frac{1.05}{(12)(33.5)} = 0.0026$		
THE RATIO $p_n = (0.0026)^8 = 0.0209$		
FROM THE "COEFFICIENT FOR MOMENT OF INERTIA OF CRACKED SECTIONS" (Pg. 4-8 OF REF# 18)		
$F = .0016$		
$\therefore I_{cr}$ (CRACKED SECTION I) $= (0.016)(12)(33.5)^3 = 5447.5 \text{ in}^4$		
Thermal Moment = $\frac{\bar{E} I_{cr} \times \Delta T \times d}{t}$		REF#17
$M_t = \frac{3.6 \times 10^6 \times (5447.5) \times 80 \times 6 \times 10^{-6}}{(33.5)(1000)} = 280.1 \text{ k-in}$		
NOTE: THE PORTION OF THE NORTH WALL WHICH IS 36" THICK, HAS SIMILAR REINFORCEMENT AS THE EAST WALL (36" THICK - Pg. 3). THEREFORE THERMAL moment WILL BE SIMILAR AND EQUAL TO <u>331.2</u> K-IN.		
SOUTH WALL THERMAL MOMENTS - EL 672' TO 701'-3"		
THE SOUTH WALL FROM EL. 672' TO 701'-3" IS 18.0" THICK AND REINFORCED ON THE POOL SIDE WITH #9 BARS @ 9" AND ON THE OPPOSITE SIDE WITH #8 BARS @ 9".		
THE TENSILE REINFORCEMENT RATIO $p = \frac{A_s}{bd} = \frac{1.05}{(12)(18)} = 0.00486$		
FROM REF# 18, THE COEFFICIENT FOR $I_{cr}$ IS OBTAINED AS $F = 0.0285$ (FOR $p_n = (0.00486)^8 = 0.039$ )		
THEREFORE: $I_{cr} = Fbd^3 = (0.0285)(12)(18)^3 = 1154.3 \text{ in}^4$		



EQUIVALENT THERMAL MOMENT CALCULATIONS

REF.

THE THERMAL MOMENT =  $\frac{E I_{cr} \times \Delta T \times \alpha t}{t}$

REF #7

$$M_t = \frac{(3.6 \times 10^6)(1154.3)(80)(6.0 \times 10^{-6})}{(18)(1000)} = 110.8 \text{ K-in} \quad \checkmark$$

SOUTH WALL THERMAL MOMENT EL. 659'-5.625" TO 672'-0"

THE LOWER SECTION (51" THICK) HAS SIMILAR DIMENSIONS AND REINFORCEMENT AS EAST WALL AND THEREFORE THERMAL MOMENT WILL BE SIMILAR.

$$M_t = 572.8 \text{ K-in}$$

POOL FLOOR THERMAL MOMENT

THE POOL FLOOR IS COMPOSED OF A 56" THICK SENG REINFORCED WITH #7 BAR @ 12" ( $A_s = 0.6 \text{ in}^2$ )

TENSILE STEEL REINFORCEMENT RATIO  $p = \frac{0.6}{(12)56} = 0.00089 \quad \checkmark$

$$\text{Ratio } p_n = (0.00089)(8.0) = .0071$$

THE CRACKED SECTION ( $I_{cr}$ ) =  $Fbd^3$ , WHERE  $F$  IS FUNCTION OF RATIO  $p_n$ . FROM Pg. 4-8 OF REF # 18,  $F = 0.01$  AND:

REF #8

$$I_{cr} = (0.01)(12)(56.3)^3 = 17865.2 \text{ in}^4 \quad \checkmark$$

THERMAL MOMENT =  $\frac{E I_{cr} \times \Delta T \times \alpha t}{t}$

REF #11

$$M_t = \frac{(3.6 \times 10^6)(17865.2)(80)(6.0 \times 10^{-6})}{(56)(1000)} = 551.3 \text{ K-in} \quad \checkmark$$




NUCLEAR ENERGY SERVICES INC. CHKD. BY I.H.  
NES DIVISION

BY 64 DATE 9-13-78 PROJ. 5101 TASK 237  
DATE 9-14-78 PAGE C-8 OF C-9  
LACOME FUEL POOL WHL TEST C-2001

TEMPERATURE GRADIENT (STEADY STATE)  
IN FUEL POOL CONCRETE WALL

ASSUMPTIONS

1. BULK POOL WATER TEMP. =  $150^{\circ}\text{F}$
2. BOUNDARY LAYER TEMP. DROP NEGLIGIBLE
3. AIR TEMP. =  $70^{\circ}\text{F}$  BEHIND WALL
4. AIR BOUNDARY LAYER TEMP. DROP CONSERVATIVELY IGNORED.
5. CONCRETE THERMAL CONDUCTIVITY ( $k$ ) CONSTANT, RESULTING IN LINEAR TEMP. DISTRIBUTION



$\Delta T$  BETWEEN CONCRETE LOCATION  $X$  AND BULK WATER TEMP. of  $150^{\circ}\text{F}$   
ON PAGE 2/2 IN TABLE 1.



NUCLEAR ENERGY SERVICES INC. CHKD. BY J.H.

DATE 9-15-73 PROJ 5101 TASK 237

NES DIVISION

DATE 9-15-73 PAGE C-9 OF C-9

LACBWR Final Startup Part

TABLE I

AT AS A FUNCTION OF WALL LOCATION (S)  
AND BULK POOL TEMP. OF 150°F

	$\delta = \Delta T / T$				
	1'-6"	1'-9"	3'-0"	4'-8"	
X	2"	9°	8°	4°	3°
	4"	18	15	9	6
	6"	27	23	13	9
	8"	36	30	18	11
	1'-0"	53	46	27	17
	1'-2"	62	53	31	20
	1'-4"	71	61	36	23
	1'-6"	80	69	40	26
	1'-8"		76	44	29
	1'-10"			49	31
	2'-0"			53	34
	2'-2"			58	37
	2'-4"			62	40
	2'-6"			67	43
	2'-8"			71	46
	2'-10"			76	49
	3'-0"			80	25
	3'-2"				54
	3'-4"				57
	3'-6"				60
	3'-8"				63
	3'-10"				66
	4'-0"				69
	4'-2"				71
	4'-4"				74
	4'-6"				77
	4'-8"				80



## APPENDIX D

REF.

EFFECTS OF SEISMIC LOADINGS FROM ADJACENT  
BUILDING STRUCTURES

The spent fuel storage pool is located inside the containment/shield building and it will be subjected to the seismic loads from the adjacent building structures. The effects of these additional loadings can be conservatively considered by determining the ratio of the design moment to the allowable moment capacity for the building structure at the fuel storage pool elevation and adding it to the similar ratio from the pool analysis and comparing the sum of these two ratios to 1.

Referring to pages 4-32 and 4-26 of the Gulf United Services Report SS-1162 "Seismic Evaluation of the LaCrosse Boiling Water Reactor" (Reference 15),

Ratio of maximum seismic moment to yield moment for element 17 (Nodes 19-20)  $R_{MB} = 0.285$

Ratio of the maximum seismic shear to ultimate shear strength for element 17,  $R_{VB} = 0.105$

REF.

From Table 8.2 of this report

Max. ratio of the design moments to allowable moment (Load Combination 2, element no.61)

$$\text{for vertical reinforcement} = R_{mb} = \frac{77.8}{5280} = 0.147$$

Max. ratio of the shear stress to allowable

$$\text{Shear stress } R_{Vp} = \frac{0.075}{0.201} = 0.373 \\ (\text{Load combination 2, Element 144})$$

∴ The sum of these two ratios

$$R_{mb} + R_{Vp} < 1.0$$

$$0.147 + 0.373 = 0.432 < 1.0 \quad O.K.$$

$$R_{Vb} + R_{Vp} < 1.0$$

$$0.106 + 0.373 = 0.479 < 1.0 \quad O.K.$$

CONCLUSIONS : The design of the pool structure is adequate to withstand the loadings from adjacent structure as well as its own loadings.



NUCLEAR ENERGY SERVICES, INC.

SPEC NO. 81A0095

PAGE Appendix

## REVISION LOG