

U-601460
LS-89-005
Page 4 of 6

RHR HX 1A Condensate Dump Vlv

TABLE 3.3.7.4-2

REMOTE SHUTDOWN SYSTEM CONTROLS

| CONTROL | EQUIPMENT NUMBER | MINIMUM CHANNELS OPERABLE | |
|---|------------------|---------------------------|-------------|
| | | DIVISION I | DIVISION II |
| 1. RHR Pmp | 1E12-C002A/B | 1 | 1 |
| 2. RHR Supp. Pool Suction Vlv | 1E12-F004A/B | 1 | 1 |
| 3. RHR Shutdown Cooling Supply Vlv | 1E12-F006A | 1 | NA |
| 4. RHR Shutdown Cooling Sply Otbd Isol Vlv | 1E12-F008 | 1 | NA |
| 5. RHR HX Bypass Vlv | 1E12-F048A/B | 1 | 1 |
| 6. RHR Test Line Vlv to Supp. Pool | 1E12-F024A/B | 1 | 1 |
| 7. RHR HX Dsch Vlv | 1E12-F003A/B | 1 | 1 |
| 8. RCIC Steam Inlet Vlv to RHR HX | 1E12-F052A/B* | 1* | 1* |
| 9. RHR HX Inlet Vlv | 1E12-F047A/B | 1 | 1 |
| 10. RHR HX SX Outlet Vlv | 1E12-F068A/B | 1 | 1 |
| 11. RHR Shutdown Cooling Return Vlv | 1E12-F053A/B | 1 | 1 |
| 12. RHR RPV Inboard Inject Vlv | 1E12-F042A/B | 1 | 1 |
| 13. RHR RPV Outboard Inject Vlv | 1E12-F027A | 1 | NA |
| 14. RHR Cnmt Spray Vlv | 1E12-F028A | 1 | NA |
| 15. RHR Supp Pool Cool Vlv | 1E12-F011A* | 1* | NA |
| 16. RHR HX 1A RCIC Shutoff Vlv | 1E12-F026A* | 1* | NA |
| 17. RHR FP/FC Sply Vlv | 1E12-F037A | 1 | NA |
| 18. RHR Pump Min Flow Recirc Vlv | 1E12-F064A/B | 1 | 1 |
| 19. RHR HX 1A SX Bypass Vlv | 1SX17A | 1 | NA |
| 20. RHR RR Sply Inbd Isol Vlv | 1E12-F006B | NA | 1 |
| 21. Shutdown Cooling Inbd Isol Vlv | 1E12-F009 | NA | 1 |
| 22. RPV Head Spray Vlv | 1E12-F023 | NA | 1 |
| 23. RCIC Stm Byps Vlv | 1E51-FL95 | 1 | NA |
| 24. RCIC Pump Cond Stg Tnk Suction Vlv | 1E51-F010 | 1 | NA |
| 25. RCIC Supp Pool Suction Vlv | 1E51-F031 | 1 | NA |
| 26. RCIC First Test Line Isol. Vlv to RCIC Storage Tank | 1E51-F022 | 1 | NA |
| 27. RCIC Inject Vlv | 1E51-F013 | 1 | NA |
| 28. RCIC Min Flow Recirc Vlv | 1E51-F019 | 1 | NA |
| 29. RCIC Second Test Line Isol Vlv to RCIC Stg Tnk | 1E51-F059 | 1 | NA |
| 30. RCIC Turbine L.O. Cool Wtr Sply Vlv | 1E51-F046 | 1 | NA |
| 31. RCIC Gland Seal Air Cmpsr | 1E51-C002F | 1 | NA |
| 32. RCIC Outbd Vac Bkr Vlv | 1E51-F077 | 1 | NA |
| 33. RHR RCIC Stm Sply Otbd Isol Vlv | 1E51-F064 | 1 | NA |
| 34. RCIC Turb Stm Sply Vlv | 1E51-F045 | 1 | NA |
| 35. RCIC Turb Xhst Stop Vlv | 1E51-F068 | 1 | NA |
| 36. RCIC Trip/Throttle Vlv | 1E51-C002E | 1 | NA |
| 37. RCIC Turb Stm Supply Warm-up Vlv | 1E51-F076 | NA | 1 |
| 38. SRV 51C | 1B21-F051C | 1 | 1 |
| 39. SRV 51D | 1B21-F051D | 1 | 1 |
| 40. SRV 51G | 1B21-F051G | 1 | 1 |
| 41. RCIC Stm Flow Cntrl | NA | 1 | NA |
| 42. RCIC Turb Trip | NA | 1 | NA |
| 43. DG 1A Vent Fan | 1V001CA | 1 | NA |

This page provided for information only

Attachment to
U-601740
Page 2 of 2

U-601460
LS-89-005
Page 6 of 6

TABLE 3.3.7.4-2 (Continued)

REMOTE SHUTDOWN SYSTEM CONTROLS

TABLE NOTATIONS

- * These controls are not required to be OPERABLE or tested as operation of the associated valves is precluded in accordance with Illinois Power Company's commitment to not utilize the steam condensing mode of the residual heat removal system.