

ID/2W,2X

EXERCISES AND DRILLS

<u>530-0</u> Exercises and Drills	Rev. 10	06-21-82
<u>530-1</u> Emergency Exercise	Rev. 1	12-16-80
<u>530-2</u> Emergency Drills	Rev. 6	06-07-82
<u>530-3</u> Off-Shift Augmentation Drill	Rev. 2	06-21-82
<u>530-S1</u> Monthly NARS Drill Quad-Cities Station	Rev. 3	10-06-81
<u>530-S2</u> Monthly Test of the NRC Health Physics Network	Rev. 1	01-05-82
<u>530-S3</u> Monthly Test of the NRC Emergency Notification System	Rev. 1	02-17-82

APPROVED
JUN 21 1982
Q.C.O.S.R.

OFF-SHIFT AUGMENTATION DRILL

QEP 530-3
Revision 2
June 1982

ID/5C

A. PURPOSE

The purpose of this procedure is to outline the method used to conduct the semi-annual off-shift augmentation drill.

B. REFERENCES

1. GSEP Table 6.1-1, Simplified Emergency Notification Scheme.
2. QEP 320-1, Activation of the Emergency Organization.
3. QEP 310-1, Initial Notification.
4. QEP 310-T1, Guidance for Augmentation of the On-Site Emergency Organization Within 30 Minutes.

C. PREREQUISITES

1. None.

D. PRECAUTIONS

1. None.

E. LIMITATIONS AND ACTIONS

1. Off-shift shall be any time other than regular working hours (0800-1630, Monday thru Friday).
2. If no Director for a given responsibility can be contacted, an appropriate Caller or a Station Director may be deputized to act as an interim Director.

F. PROCEDURE

1. On a semi-annual basis, the Quad-Cities Nuclear Power Station should conduct an off-shift augmentation drill in order to test the ability to staff the Station's emergency organization within the time frame necessary to adequately respond to an emergency.

APPROVED
JUN 21 1982
Q.C.O.S.R.

2. The drill should be initiated by handing the on-shift Shift Engineer a pre-written message. Beginning with the Shift Engineer, personnel are to relay the message in the sequence specified by QEP 310-T1. The message should be:

"This is a drill. A GSEP condition of General Emergency is being simulated. Please contact those individuals you are designated to contact as specified by your copy of the Prioritized Notification List. Indicate on the listing the times at which you contact the required personnel. Return your copy of the Prioritization Notification List to the GSEP Coordinator as soon as practical. Relay this message in the sequence specified by QEP 310-T1, until adequate staff augmentation is achieved."

3. The GSEP Coordinator will tabulate the data to determine if the drill was successful.
4. The drill is considered successful if the general emergency requirements of QEP 310-T1 are met. This is to be interpreted that the appropriate personnel would be able to be on-site within 30 minutes of being notified, and the appropriate notifications are all completed within 30 minutes from the start of the drill. If the drill is not successful, another drill should be conducted within a month.

G. CHECKLISTS

1. None.

H. TECHNICAL SPECIFICATION REFERENCES

1. None.

APPROVED
JUN 21 1982
Q.C.O.S.R.