

BDR

**Florida
Power**
CORPORATION

5 October 1978
CS-78-203
3-0-3-a-2

Mr. J. P. O'Reilly, Director
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
101 Marietta St., Suite 3100
Atlanta, GA 30303

Docket No. 50-302
Licensee No. DPR-72
Ref.: RII:JMF
50-302/78-17

Dear Mr. O'Reilly:

We offer the following supplemental information to the Item of Noncompliance and the Unresolved Item noted in the referenced Inspection Report.

In regard to the Item of Noncompliance, 78-17-02, temporary authorized (designated) vehicles are to be restricted to those which will remain on site in excess of twenty-four (24) hours. These vehicles are to be positively controlled by utilizing a locking device, or by removing the ignition keys and locking the vehicle.

Full compliance will be achieved no later than 23 February 1979.


In regard to Unresolved Item 78-17-08, all vehicles, be they authorized, temporary authorized, or visiting vehicles, will be positively controlled by utilizing a locking device or removal of the ignition keys and locking the vehicle.

Full compliance will be achieved no later than 23 February 1979.

Should you have further questions, please contact us.


Very truly yours,

FLORIDA POWER CORPORATION



W. P. Stewart
Director, Power Production

JC/rc


Nuclear Plant Manager

781010299

