

ADMINISTRATIVE CONTROLS

- e. The management position responsible for health physics shall have direct access to that onsite individual having responsibility for overall facility management. Health physics personnel shall have the authority to cease any work activity when worker safety is jeopardized or in the event of unnecessary personnel radiation exposures.

FACILITY STAFF

6.2.2 The Facility organization shall be as shown in the UFSAR.

- a. Each on duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1.
- b. At least one licensed Reactor Operator shall be in the control room when fuel is in the reactor. In addition, while the unit is in MODES 1, 2, 3 or 4, at least one licensed Senior Reactor Operator shall be in the Control Room.
- c. A health physics technician# shall be onsite when fuel is in the reactor.
- d. ALL CORE ALTERATIONS shall be observed and directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.

#The health physics technician composition may be less than the minimum requirements for a period of time not to exceed 2 hours in order to accommodate unexpected absence provided immediate action is taken to fill the required positions.

DATED: October 19, 1990

CORRECTION TO AMENDMENT NOS. 140 AND 123 TO NORTH ANNA UNITS 1&2

Docket File

NRC & Local PDRs

PDII-2 Reading

S. Varga, 14/E/4

G. Lainas, 14/H/3

H. Berkow

D. Miller

L. Engle

OGC-WF

D. Hagan, 3302 MNBB

E. Jordan, 3302 MNBB

B. Grimes, 9/A/2

G. Hill (8), P-137

Wanda Jones, P-130A

J. Calvo, 11/F/23

ACRS (10)

GPA/PA

OC/LFMB

M. Sinkule, R-II

Others as required

cc: Plant Service list