



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

October 11, 1978

Docket No. 50-409

Dairyland Power Cooperative  
ATTN: Mr. John P. Madgett  
General Manager  
2615 East Avenue, South  
La Crosse, Wisconsin 54601


Gentlemen:

The Commission has issued the enclosed Amendment No. 14 to Provisional Operating License No. DPR-45 for the La Crosse Boiling Water Reactor. The amendment consists of changes to the Technical Specifications in response to your application dated September 27, 1978.

This amendment deletes the requirement for operable fire detectors in the Reactor Containment Building during the performance of the containment integrated leak rate test.

Copies of the Safety Evaluation and Notice of Issuance are also enclosed.

Sincerely,

*for*   
Dennis L. Ziemann, Chief  
Operating Reactors Branch #2  
Division of Operating Reactors

Enclosures:

1. Amendment No. 14 to License No. DPR-45
2. Safety Evaluation
3. Notice of Issuance

cc w/enclosures:  
See next page

781020392

Dairyland Power Cooperative

- 2 -

October 11, 1978

cc w/enclosures:

Fritz Schubert, Esquire  
Staff Attorney  
Dairyland Power Cooperative  
2615 East Avenue, South  
La Crosse, Wisconsin 54601

O. S. Heistand, Jr., Esquire  
Morgan, Lewis & Bockius  
1800 M Street, N. W.  
Washington, D. C. 20036

Mr. R. E. Shimshak  
La Crosse Boiling Water Reactor  
Dairyland Power Cooperative  
P. O. Box 135  
Genoa, Wisconsin 54632

La Crosse Public Library  
800 Main Street  
La Crosse, Wisconsin 54601

Town Chairman  
Town of Genoa  
Route 1  
Genoa, Wisconsin 54632

\*\* Chairman, Public Service Commission  
of Wisconsin  
Hill Farms State Office Building  
Madison, Wisconsin 53702

Mrs. Ellen Sabelko  
Society Against Nuclear Energy  
929 Cameron Trail  
Eau Claire, Wisconsin 54701

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
US EPA  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection  
Agency  
Federal Activities Branch  
Region V Office  
ATTN: EIS COORDINATOR  
230 South Dearborn Street  
Chicago, Illinois 60604

Coulee Region Energy Coalition  
ATTN: George R. Nygaard  
P. O. Box 1583  
La Crosse, Wisconsin 54601

\*\*With DPC incoming d.l. 9/27/78