



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DAIRYLAND POWER COOPERATIVE

DOCKET NO. 50-409

LA CROSSE BOILING WATER REACTOR

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 14
License No. DPR-45

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Dairyland Power Cooperative (the licensee) dated September 27, 1978, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

7811030395


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Provisional Operating License No. DPR-45 is hereby amended to read as follows:

- (2) Technical Specifications

The Technical Specifications contained in Appendix A issued October 21, 1969, with Authorization No. DPRA-6, as revised through Amendment No. 14, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

for 
Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 11, 1978

ATTACHMENT TO LICENSE AMENDMENT NO. 14
LA CROSSE BOILING WATER REACTOR (LACBWR)
PROVISIONAL OPERATING LICENSE NO. DPR-45
DOCKET NO. 50-409

Revise Appendix A by replacing the following page with the enclosed page. The revised page is identified by the captioned amendment number and contains a marginal line indicating the area of change.

Remove

37b

Insert

37b

~~781102~~

TABLE 4.2.17
FIRE DETECTION INSTRUMENTS

<u>INSTRUMENT LOCATION</u>	<u>MINIMUM INSTRUMENTS OPERABLE</u>
1. Containment Building*	
Zone 19 Dome Level	2
Zone 19 Mezzanine Level	2
Zone 19 Grade Level	2
Zone 16 Basement Level	2
2. Electrical Equipment Room	
Zone 8	2
3. Crib House	
Zone 4	1
4. 1B Emergency Diesel Generator	
Building Battery Room	
Zone 16	1
5. Turbine Building Main Floor	
Zones 11 and 20	2
6. Diesel Generator Rooms	
1A Zone 17	1
1B Zone 16	1
7. Oil Storage Room	1

*Exception

The Containment Building Zone 19 fire detection instruments may be made INOPERABLE for performance of the Type A Containment Building Leak Rate Test, reducing the minimum instruments operable in Zone 19 to zero.