

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-361

SOUTHERN CALIFORNIA EDISON COMPANY, ET AL

NOTICE OF ISSUANCE OF AMENDMENT

FACILITY OPERATING LICENSE NO. NPF-10

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 4 to Facility Operating License No. NPF-10, issued to Southern California Edison Company, San Diego Gas and Electric Company, The City of Riverside, California and The City of Anaheim, California (licensees) for the San Onofre Nuclear Generating Station, Unit 2 (the facility) located in San Diego County, California. This amendment is effective as of the date of issuance.

Amendment No. 4 makes the following changes to the Facility Technical Specifications:

- (1) Adds three valves that were inadvertently omitted from a table of motor operated valves requiring surveillance to verify bypassing of thermal overload protection.
- (2) Adds special test exceptions to allow performance of natural circulation tests.
- (3) Makes various editorial and typographical corrections.
- (4) Clarifies certain administrative controls.
- (5) Requires sampling of the milk injection pathway when it is available.
- (6) Clarifies the containment air lock door seal pressure requirement.

Issuance of this amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations. The Commission has made appropriate findings as required by the Act and the Commission's regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.


The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR 51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) Southern California Edison Company's letter dated May 14, 1982, (2) Amendment No. 4 to Facility Operating License No. NPF-10, (3) the Commission's related Safety Evaluation, and (4) Supplement No. 6 to the Safety Evaluation Report.

These items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W. Washington, D. C., and the San Clemente Library, 242 Avenida Del Mar, San Clemente, California 02672. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 16 day of July, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION



Frank J. Moraglio, Chief  
Licensing Branch No. 3  
Division of Licensing

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-361

SOUTHERN CALIFORNIA EDISON COMPANY, ET AL

NOTICE OF ISSUANCE OF AMENDMENT

FACILITY OPERATING LICENSE NO. NPF-10

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 4 to Facility Operating License No. NPF-10, issued to Southern California Edison Company, San Diego Gas and Electric Company, The City of Riverside, California and The City of Anaheim, California (licensees) for the San Onofre Nuclear Generating Station, Unit 2 (the facility) located in San Diego County, California. This amendment is effective as of the date of issuance.

Amendment No. 4 makes the following changes to the Facility Technical Specifications:

- (1) Adds three valves that were inadvertently omitted from a table of motor operated valves requiring surveillance to verify bypassing of thermal overload protection.
- (2) Adds special test exceptions to allow performance of natural circulation tests.
- (3) Makes various editorial and typographical corrections.
- (4) Clarifies certain administrative controls.
- (5) Requires sampling of the milk injection pathway when it is available.
- (6) Clarifies the containment air lock door seal pressure requirement.

|           |       |       |       |       |       |       |       |
|-----------|-------|-------|-------|-------|-------|-------|-------|
| OFFICE ▶  | ..... | ..... | ..... | ..... | ..... | ..... | ..... |
| SURNAME ▶ | ..... | ..... | ..... | ..... | ..... | ..... | ..... |
| DATE ▶    | ..... | ..... | ..... | ..... | ..... | ..... | ..... |

Issuance of this amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations. The Commission has made appropriate findings as required by the Act and the Commission's regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR 51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) Southern California Edison Company's letter dated May 14, 1982, (2) Amendment No. 4 to Facility Operating License No. NPF-10, (3) the Commission's related Safety Evaluation, and (4) Supplement No. 6 to the Safety Evaluation Report.

These items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W. Washington, D. C., and the San Clemente Library, 242 Avenida Del Mar, San Clemente, California 02672. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 16 day of June, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by  
Frank J. Miraglia  
Frank J. Miraglia, Chief  
Licensing Branch No. 3  
Division of Licensing

*LR*

*Frank J. Miraglia*

|         |          |          |           |  |  |  |
|---------|----------|----------|-----------|--|--|--|
| OFFICE  | DL:LB#3  | DL:LB#3  | OELD      |  |  |  |
| SURNAME | HRood:ph | Miraglia | LChandler |  |  |  |
| DATE    | 6/30/82  | 6/30/82  | 6/8/82    |  |  |  |

Mr. Robert Dietch  
Vice President  
Southern California Edison Company  
2244 Walnut Grove Avenue  
P. O. Box 800  
Rosemead, California 91770

Mr. Gary D. Cotton  
Mr. Louis Bernath  
San Diego Gas & Electric Company  
101 Ash Street  
P. O. Box 1831  
San Diego, California 92112

cc: Charles R. Kocher, Esq.  
James A. Beoletto, Esq.  
Southern California Edison Company  
2244 Walnut Grove Avenue  
P. O. Box 800  
Rosemead, California 91770

Orrick, Herrington & Sutcliffe  
ATTN: David R. Pigott, Esq.  
600 Montgomery Street  
San Francisco, California 94111

Mr. George Carvalho  
City Manager  
City of San Clemente  
100 Avenida Presidio  
San Clemente, California 92672

Alan R. Watts, Esq.  
Rourke & Woodruff  
Suite 1020  
1055 North Main Street  
Santa Ana, California 92701

Lawrence Q. Garcia, Esq.  
California Public Utilities Commission  
5066 State Building  
San Francisco, California 94102

Mr. V. C. Hall  
Combustion Engineering, Incorporated  
1000 Prospect Hill Road  
Windsor, Connecticut 06095

cc: Mr. S. McClusky  
Bechtel Power Corporation  
P. O. Box 60860, Terminal Annex  
Los Angeles, California 90060

Mr. Mark Medford  
Southern California Edison Company  
2244 Walnut Grove Avenue  
P. O. Box 800  
Rosemead, California 91770

Henry Peters  
San Diego Gas & Electric Company  
P. O. Box 1831  
San Diego, California 92112

Ms. Lyn Harris Hicks  
Advocate for GUARD  
3908 Calle Ariana  
San Clemente, California 92672

Richard J. Wharton, Esq.  
University of San Diego School of Law  
Environmental Law Clinic  
San Diego, California 92110

Phyllis M. Gallagher, Esq.  
Suite 222  
1695 West Crescent Avenue  
Anaheim, California 92701

Mr. A. S. Carstens  
2071 Caminito Circulo Norte  
Mt. La Jolla, California 92037

Resident Inspector, San Onofre/NPS  
c/o U. S. Nuclear Regulatory Commission  
P. O. Box 4329  
San Clemente, California 92672

Charles E. McClung, Jr., Esq.  
Attorney at Law  
24012 Calle de la Plata  
Suite 330  
Laguna Hills, California 92653

cc: California Department of Health  
ATTN: Chief, Environmental Radiation  
Control Unit  
Radiological Health Section  
714 P Street, Room 498  
Sacramento, California 95814

Chairman, Board of Supervisors  
San Diego County  
San Diego, California 92412

Mayor, City of San Clemente  
San Clemente, California 92672

U. S. Environmental Protection Agency  
ATTN: EIS Coordinator  
Region IX Office  
215 Fremont Street  
San Francisco, California 94111

Energy Resources Conservation &  
Development Commission  
ATTN: Librarian  
1111 Howe Avenue  
Sacramento, California 95825