

AUG 02 1982

Docket No. 99900217/82-01

Westinghouse Electric Corporation
Electrical Systems Division-Hunt Valley
ATTN: Mr. J. F. Heins
General Manager
1111 Schilling Road
Hunt Valley, Maryland 21031

Gentlemen:

Thank you for your letter of July 7, 1982, in response to our letter of June 8, 1982. As a result of the discussion with your Mr. D. Cyford during a telephone call on July 20, 1982, we understand that:
(a) the operator identified in Item B of the Notice of Nonconformance was not recertified as a result of reassignment to another area; and (b) with respect to Item E.4 that when wrong parts are installed the condition is considered a deficiency and is controlled by being noted on the control tags rather than by the issuance of a D.A.R.

We have no further questions at this time and will review your corrective action and preventive measures during a future inspection.

Sincerely,

"Original Signed by:
C. J. HALE"

Uldis Potapovs, Chief
Vendor Program Branch

bcc: J. T. Collins
W. M. McNeill

RIV
CI: R&CPS
W. M. McNeill/rf
7/26/82

SC: R&CPS
IBarnes
7/26/82

BC: VPB
UPotapovs
7/27/82

D: IES
EHJohnson
7/30/82

7/29/82

12:09

8208050192 820802
PDR GA999 EMVWEST
99900217 PDR