

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | I | L | Z | I | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
0 1 | REPORT SOURCE | L | 6 | 0 | 1 | 5 | 0 | 0 | 0 | 2 | 9 | 5 | 7 | 0 | 7 | 0 | 9 | 8 | 2 | 8 | 0 | 7 | 2 | 8 | 8 | 2 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operation low pressure and high flow alarms were received
0 3 | on Zone 1 of the Penetration Pressurization (PP) system. Investigation
0 4 | revealed that the rupture disc on Zone 1 was leaking. This resulted in
0 5 | a violation of T.S. 3.9.2.A which requires each zone to be pressurized
0 6 | above 47 psig. The other 3 Zones of the PP system were operable. The
0 7 | total leakage rate of all areas supplied by the PP system was well with-
0 8 | in Tech Spec allowable limits. Previous LER's:50-295/77-14,50-304/76-13
7 8 9 80

0 9 | S | D | 11 | E | 12 | B | 13 | V | A | L | V | E | X | 14 | X | 15 | B | 16
7 8 9 10 11 12 13 18 19 20
17 | LER/RO REPORT NUMBER | 8 | 2 | 21 | 22 | 0 | 2 | 2 | 24 | 26 | 27 | 0 | 3 | 28 | 29 | L | 30 | 31 | 0 | 32
21 22 23 24 26 27 28 29 30 31 32
18 | A | 18 | Z | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | 22 | N | 23 | Y | 24 | A | 25 | B | 2 | 9 | 0 | 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause of the rupture disc (manufactured by B.S. and B. Safety
1 1 | Systems, model #RB-90) failure is unknown. The pressure control valve
1 2 | on Zone 1 was operating properly both before and after the event. The
1 3 | rupture disc was replaced and Zone 1 was returned to service in less
1 4 | than one day. This is not a recurring problem.
7 8 9 80

1 5 | E | 28 | 0 | 5 | 0 | 29 | NA | 30 | A | 31 | Control Room Alarm | 32
7 8 9 10 12 13 44 45 46 80

1 6 | Z | 33 | Z | 34 | NA | 35 | NA | 36
7 8 9 10 11 44 45 80

1 7 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39
7 8 9 11 12 13 80

1 8 | 0 | 0 | 0 | 40 | NA | 41
7 8 9 11 12 80

1 9 | Z | 42 | NA | 43
7 8 9 10 80

2 0 | N | 44 | S | 8208050236 820728 PDR ADOCK 05000295 PDR
7 8 9 10 80