



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

PDR

Docket No. 50-341

NOV 3 1978

The Detroit Edison Company
ATTN: Mr. Edward Hines, Assistant
Vice President and Manager
Quality Assurance
2000 Second Avenue
Detroit, MI 48226

Gentlemen:

Thank you for your interim report dated October 25, 1978, pursuant to 10 CFR 50.55(e) regarding cracks in the impeller vane of core spray pumps "B" and "C". We will review your final report on this matter upon receipt.

Your cooperation with us is appreciated.

Sincerely,

R. F. Heishman, Chief
Reactor Construction and
Engineering Support Branch

cc: Central Files
Reproduction Unit NRC 20b
PDR
Local PDR
NSIC
TIC
Ronald Callen, Michigan Public
Service Commission
Eugene B. Thomas, Jr.,
Attorney

781113 0104

S