

LICENSEE EVENT REPORT

CONTROL BLOCK / / / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

/0/1/ /V/A/N/A/S/2/ (2) /0/0/-/0/0/0/0/0/-/0/0/ (3) /4/1/1/1/1/ (4) / / / (5)
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

/0/1/ REPORT /L/ (6) /0/5/0/0/0/3/3/9/ (7) /0/7/0/4/8/2/ (8) /0/7/2/8/8/2/ (9)
SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

/0/2/ / On July 4, 1982, with Unit 2 at 75% power, the Axial Flux Difference (AFD) went /
/0/3/ / less than -5% from the target band for a duration of 1 minute. Since the /
/0/4/ / AFD was restored to within +/-5% of target as required by the Action Statement /
/0/5/ / of T.S. 3.2.1, the public health and safety were not affected. This event is /
/0/6/ / contrary to T.S. 3.2.1 and reportable pursuant to T.S. 6.9.1.9.b. There are no /
/0/7/ / generic implications to this event. /

/0/8/ /

SYSTEM CAUSE CAUSE COMP. VALVE
CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE

/0/9/ /R/C/ (11) /X/ (12) /Z/ (13) /Z/Z/Z/Z/Z/Z/ (14) /Z/ (15) /Z/ (16)
LER/RO EVENT YEAR SEQUENTIAL OCCURRENCE REPORT REVISION
REPORT NO. TYPE NO.
(17) NUMBER /8/2/ /-/ /0/4/0/ / \ / /0/3/ /L/ /-/ /0/

ACTION FUTURE EFFECT SHUTDOWN ATTACHMENT NFRD-4 PRIME COMP. COMPONENT
TAKEN ACTION ON PLANT METHOD HOURS SUBMITTED FORM SUB. SUPPLIER MANUFACTURER

/X/ (18) /Z/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /N/ (23) /N/ (24) /N/ (25) /W/1/2/G/ (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

/1/0/ / The AFD deviation occurred as a result of inserting "A" Rod Control Bank 18 /
/1/1/ / steps for a rod operability periodic test. The event was amplified because the /
/1/2/ / flux was depressed further due to a recent power increase from 30% to 70% power. /
/1/3/ / The rods were withdrawn and the AFD restored to within limits. /
/1/4/ /

FACILITY METHOD OF
STATUS %POWER OTHER STATUS DISCOVERY DISCOVERY DESCRIPTION (32)

/1/5/ /E/ (28) /0/7/5/ (29) / NA / (30) /A/ (31) / Operator Observation /

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

/1/6/ /Z/ (33) /Z/ (34) / NA / / NA /

PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION (39)

/1/7/ /0/0/0/ (37) /Z/ (38) / NA /

PERSONNEL INJURIES
NUMBER DESCRIPTION (41)

/1/8/ /0/0/0/ (40) / NA /

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION

/1/9/ /Z/ (42) / NA /

PUBLICITY
ISSUED DESCRIPTION (45)

/2/0/ /N/ (44) / NA /

NRC USE ONLY

NAME OF PREPARER W. R. CARTWRIGHT PHONE (703) 894-5151