



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

NR CDR

NOV 2 1978

Docket Nos: STN 50-488 STN 50-491  
STN 50-489 STN 50-492  
STN 50-490 STN 50-493

Mr. L. C. Dail, Vice President  
Design Engineering Department  
Duke Power Company  
P. O. Box 33189  
Charlotte, North Carolina 28242

50-491


Dear Mr. Dail:

SUBJECT: CRITERIA FOR PIPING MODELLING TECHNIQUE - STRUCTURAL OVERLAPPING  
(PROJECT 81 - PERKINS NUCLEAR STATION, UNITS 1, 2 AND 3, AND  
CHEROKEE NUCLEAR STATION, UNITS 1, 2 AND 3)

By our letter of October 3, 1978, from Robert Baer, Chief, Light Water Reactors Branch No. 2, Division of Project Management to William O. Parker, Jr., Vice President, Steam Production, Duke Power Company, we concluded that a method for modelling piping systems for static and dynamic analysis was acceptable for the criteria used in the analysis for the McGuire Nuclear Station, Units 1 and 2. We also stated that for all other Duke Power plants undergoing licensing review we shall require a commitment that whenever this technique is employed in the future the requirements listed in the letter be adopted and documented in the appropriate safety analysis report. A copy of the letter is enclosed.

Please advise whether this technique (structural overlapping) will be used in modelling and analyzing pipe systems for Project 81 (Perkins and Cherokee facilities). If it will, advise whether requirements 1 and 2 in the October 3, 1978 letter will be adopted and documented in the Final Safety Analysis Report(s).

Sincerely,

  
Steven A. Varga, Chief  
Light Water Reactors Branch No. 4  
Division of Project Management

Enclosure:  
As stated

cc: See next page

A

7811130377 suppl: 01  
02  
03

Duke Power Company

NOV 2 1978

ccs:

William L. Porter, Esq.  
Associate General Counsel  
Duke Power Company  
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.  
Debevoise & Liberman  
700 Shoreham Building  
806 Fifteenth Street, N. W.  
Washington, D. C. 20005

William A. Raney, Jr.  
Special Deputy Attorney General  
Attorney for the State of  
North Carolina  
Department of Justice  
P. O. Box 629  
Raleigh, North Carolina 27602

Mary Apperson Davis, Chairman  
Yadkin River Committee  
Route 4, Box 261  
Mocksville, North Carolina 27028

Thomas S. Erwin, Esq.  
P. O. Box 928  
Raleigh, North Carolina 27602

David Springer  
The Point Farm  
Route 4  
Mocksville, North Carolina 27028

William G. Pfefferkorn, Esq.  
2124 Wachovia Building  
Winston-Salem, North Carolina 27101

Richard P. Wilson, Esq.  
Assistant Attorney General  
S. C. Attorney General's Office  
P. O. Box 11549  
Columbia, South Carolina 29211

Elizabeth S. Bowers, Esq.  
Chairman  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Donald P. deSylva  
Associate Professor of Marine Science  
Rosenstiel School of Marine and  
Atmospheric Science  
University of Miami  
Miami, Florida 33149

Dr. Walter H. Jordan  
881 W. Outer Drive  
Oak Ridge, Tennessee 37830

Allan S. Rosenthal, Chairman  
Atomic Safety and Licensing  
Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. John H. Buck  
Atomic Safety and Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Richard S. Salzman, Esq.  
Atomic Safety and Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Enclosure

Distribution:

Docket File R. Baer  
 NRC PDR LR Birkell  
 Local PDR J. Lee  
 LWR #2 File OELD  
 D. Vassallo IE (3)  
 F. Williams M. Hartzman

F. Cherny  
 R. Kiessel  
 H. Brammer  
 V. Brounlee, Region II  
 G. Reinmuth, IE  
 E. Ketchen, (OELD)  
 E. Sullivan

NOV 2 1978

Docket Nos. 50-369  
and 50-370

OCT 3 1978

BCC: JBuchanan  
TAbernathy  
ACRS (16)

Mr. William O. Parker, Jr.  
 Vice President, Steam Production  
 Duke Power Company  
 P. O. Box 2178  
 422 South Church Street  
 Charlotte, North Carolina 28242

Dear Mr. Parker:

SUBJECT: CRITERIA FOR PIPING MODELLING TECHNIQUE - STRUCTURAL  
OVERLAPPING (MC GUIRE NUCLEAR STATION, UNITS 1 & 2)

We have completed our review of the methods which you use in modelling piping systems for static and dynamic system analysis for the Mc Guire Nuclear Station. We have concluded that this technique (structural overlapping) may be used in an acceptable fashion provided that the following considerations are satisfied:

1. Since the validity of the method is improved as the overlap region takes on the characteristics of a rigid section\*, a section of a piping system shall be defined as an overlap region if the following requirements are satisfied:
  - a. The section contains a minimum of four (4) restraints in each of three perpendicular directions.
  - b. The restraints in the section are so spaced that the pipe span between any two restraints, taken as simply supported beams, have a fundamental natural frequency (bending and torsion) not less than 33 Hz.
  - c. In lieu of the criterion in 1b, a dynamic analysis of the overlap region should be made with pinned boundaries extended beyond the overlap region either to the next actual support or to a span length equal to the largest span length within the region. The fundamental frequency determined from this analysis should be greater than 33 Hz.

DUPE : 7810110003      supp 01  
02  
03

\*A section may be considered rigid when subjected to seismic excitation if its natural frequencies are greater than 33 Hz.

OFFICE					
SURNAME					
DATE					

NOV 2 1978

Mr. William O. Parker, Jr.

- 2 -

OCT 3 1978

- 2. If a subsystem natural frequency falls in close proximity to a response spectrum peak, this peak value should be applied in the stress evaluation.

Although the criteria used for Mc Guire is acceptable and may be continued to be applied on this plant; for all other Duke Power plants undergoing licensing review we shall require a commitment that whenever this technique is employed in the future the requirements listed above be adopted and documented in the appropriate safety analysis report.

Sincerely,

Robert Baer, Chief  
 Light Water Reactors Branch No. 2  
 Division of Project Management

cc: See next page

	<i>RSB</i>					
OFFICE →	LWR #2:LPM	LWR #2:BC				
SURNAME →	RBirkell/LLM	RBaer <i>RSB</i>				
DATE →	10/ 5 /78	10/ 3 /78				

Mr. William O. Parker, Jr.  
Vice President, Steam Production  
Duke Power Company  
P. O. Box 2173  
422 South Church Street  
Charlotte, North Carolina 28242

NOV 2 1978

cc: Mr. W. L. Porter  
Duke Power Company  
P. O. Box 2178  
422 South Church Street  
Charlotte, North Carolina 28242

Mr. R. S. Howard  
Power Systems Division  
Westinghouse Electric Corporation  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

Mr. E. J. Keith  
EDS Nuclear Incorporated  
220 Montgomery Street  
San Francisco, California 94104

Mr. J. E. Houghtaling  
NUS Corporation  
2536 Countryside Boulevard  
Clearwater, Florida 33515

Mr. Jesse L. Riley, President  
The Carolina Environmental Study Group  
854 Henley Place  
Charlotte, North Carolina 28207

J. Michael McGarry, III, Esq.  
Debevoise & Liberman  
700 Shoreham Building  
806 15th Street, N. W.  
Washington, D. C. 20005

Shelley Blum, Esq.  
418 Law Building  
730 East Trade Street  
Charlotte, North Carolina 28202

NOV 2 1978

Mr. William O. Parker, Jr.

cc: Robert M. Lazo, Esq., Chairman  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Emmeth A. Luebke  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Cadet H. Hand, Jr., Director  
Bodega Marine Lab of California  
P. O. Box 247  
Bodega Bay, California 94923



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

NR CPDR

NOV 2 1978

Docket Nos: STN 50-488 STN 50-491  
STN 50-489 STN 50-492  
STN 50-490 STN 50-493

Mr. L. C. Dail, Vice President  
Design Engineering Department  
Duke Power Company  
P. O. Box 33189  
Charlotte, North Carolina 28242

50-491

Dear Mr. Dail:

SUBJECT: CRITERIA FOR PIPING MODELLING TECHNIQUE - STRUCTURAL OVERLAPPING  
(PROJECT 81 - PERKINS NUCLEAR STATION, UNITS 1, 2 AND 3, AND  
CHEROKEE NUCLEAR STATION, UNITS 1, 2 AND 3)

By our letter of October 3, 1978, from Robert Baer, Chief, Light Water Reactors Branch No. 2, Division of Project Management to William O. Parker, Jr., Vice President, Steam Production, Duke Power Company, we concluded that a method for modelling piping systems for static and dynamic analysis was acceptable for the criteria used in the analysis for the McGuire Nuclear Station, Units 1 and 2. We also stated that for all other Duke Power plants undergoing licensing review we shall require a commitment that whenever this technique is employed in the future the requirements listed in the letter be adopted and documented in the appropriate safety analysis report. A copy of the letter is enclosed.

Please advise whether this technique (structural overlapping) will be used in modelling and analyzing pipe systems for Project 81 (Perkins and Cherokee facilities). If it will, advise whether requirements 1 and 2 in the October 3, 1978 letter will be adopted and documented in the Final Safety Analysis Report(s).

Sincerely,

Steven A. Varga, Chief  
Light Water Reactors Branch No. 4  
Division of Project Management

Enclosure:  
As stated

cc: See next page

A

7811130377 suppl: 01  
02  
03

Duke Power Company

NOV 2 1978

ccs:  
William L. Porter, Esq.  
Associate General Counsel  
Duke Power Company  
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.  
Debevoise & Liberman  
700 Shoreham Building  
806 Fifteenth Street, N. W.  
Washington, D. C. 20005

William A. Raney, Jr.  
Special Deputy Attorney General  
Attorney for the State of  
North Carolina  
Department of Justice  
P. O. Box 629  
Raleigh, North Carolina 27602

Mary Apperson Davis, Chairman  
Yadkin River Committee  
Route 4, Box 261  
Mocksville, North Carolina 27028

Thomas S. Erwin, Esq.  
P. O. Box 928  
Raleigh, North Carolina 27602

David Springer  
The Point Farm  
Route 4  
Mocksville, North Carolina 27028

William G. Pfefferkorn, Esq.  
2124 Wachovia Building  
Winston-Salem, North Carolina 27101

Richard P. Wilson, Esq.  
Assistant Attorney General  
S. C. Attorney General's Office  
P. O. Box 11549  
Columbia, South Carolina 29211

Elizabeth S. Bowers, Esq.  
Chairman  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Donald P. deSylva  
Associate Professor of Marine Science  
Rosenstiel School of Marine and  
Atmospheric Science  
University of Miami  
Miami, Florida 33149

Dr. Walter H. Jordan  
881 W. Outer Drive  
Oak Ridge, Tennessee 37830

Allan S. Rosenthal, Chairman  
Atomic Safety and Licensing  
Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. John H. Buck  
Atomic Safety and Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Richard S. Salzman, Esq.  
Atomic Safety and Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555



Enclosure

Distribution:

Docket File R. Baer  
 NRC PDR ~~L.R.~~ Birkell  
 Local PDR J. Lee  
 LWR #2 File OELD  
 D. Vassallo IE (3)  
 F. Williams M. Hartzman

F. Cherny  
 R. Kiessel  
 H. Brammer  
 V. Brounlee, Region II  
 G. Reinmuth, IE  
 E. Ketchen, (OELD)  
 E. Sullivan

NOV 2 1978

Docket Nos. 50-369  
and 50-370

OCT 3 1978

BCC: JBuchanan  
 TAbernathy  
 ACRS (16)

Mr. William O. Parker, Jr.  
 Vice President, Steam Production  
 Duke Power Company  
 P. O. Box 2178  
 422 South Church Street  
 Charlotte, North Carolina 28242

Dear Mr. Parker:

SUBJECT: CRITERIA FOR PIPING MODELLING TECHNIQUE - STRUCTURAL  
 OVERLAPPING (MC GUIRE NUCLEAR STATION, UNITS 1 & 2)

We have completed our review of the methods which you use in modelling piping systems for static and dynamic system analysis for the Mc Guire Nuclear Station. We have concluded that this technique (structural overlapping) may be used in an acceptable fashion provided that the following considerations are satisfied:

1. Since the validity of the method is improved as the overlap region takes on the characteristics of a rigid section\*, a section of a piping system shall be defined as an overlap region if the following requirements are satisfied:
  - a. The section contains a minimum of four (4) restraints in each of three perpendicular directions.
  - b. The restraints in the section are so spaced that the pipe span between any two restraints, taken as simply supported beams, have a fundamental natural frequency (bending and torsion) not less than 33 Hz.
  - c. In lieu of the criterion in 1b, a dynamic analysis of the overlap region should be made with pinned boundaries extended beyond the overlap region either to the next actual support or to a span length equal to the largest span length within the region. The fundamental frequency determined from this analysis should be greater than 33 Hz.

DUPE : 7810110003 *supp* 01  
 02  
 03

\*A section may be considered rigid when subjected to seismic excitation if its natural frequencies are greater than 33 Hz.

OFFICE					
SURNAME					
DATE					

NOV 2 1978

Mr. William O. Parker, Jr.

- 2 -

OCT 3 1978

- 2. If a subsystem natural frequency falls in close proximity to a response spectrum peak, this peak value should be applied in the stress evaluation.

Although the criteria used for Mc Guire is acceptable and may be continued to be applied on this plant; for all other Duke Power plants undergoing licensing review we shall require a commitment that whenever this technique is employed in the future the requirements listed above be adopted and documented in the appropriate safety analysis report.

Sincerely,

Robert Baer, Chief  
 Light Water Reactors Branch No. 2  
 Division of Project Management

cc: See next page

OFFICE	LWR #2:LPM	LWR #2:BC				
SURNAME	RBirkell/LLM	RBaer <i>RB</i>				
DATE	10/ 5 /78	10/ 3 /78				

Mr. William O. Parker, Jr.  
Vice President, Steam Production  
Duke Power Company  
P. O. Box 2178  
422 South Church Street  
Charlotte, North Carolina 28242

NOV 2 1978

cc: Mr. W. L. Porter  
Duke Power Company  
P. O. Box 2178  
422 South Church Street  
Charlotte, North Carolina 28242

Mr. R. S. Howard  
Power Systems Division  
Westinghouse Electric Corporation  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

Mr. E. J. Keith  
EDS Nuclear Incorporated  
220 Montgomery Street  
San Francisco, California 94104

Mr. J. E. Houghtaling  
NUS Corporation  
2536 Countryside Boulevard  
Clearwater, Florida 33515

Mr. Jesse L. Riley, President  
The Carolina Environmental Study Group  
854 Henley Place  
Charlotte, North Carolina 28207

J. Michael McGarry, III, Esq.  
Debevoise & Liberian  
700 Shoreham Building  
806 15th Street, N. W.  
Washington, D. C. 20005

Shelley Blum, Esq.  
418 Law Building  
730 East Trade Street  
Charlotte, North Carolina 28202

NOV 2 1978

Mr. William O. Parker, Jr.

cc: Robert M. Lazo, Esq., Chairman  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Emmeth A. Luebke  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Cadet H. Hand, Jr., Director  
Bodega Marine Lab of California  
P. O. Box 247  
Bodega Bay, California 94923