

LICENSEE EVENT REPORT

Unit 1

CONTROL BLOCK:

| | | | | 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | T | N | S | N | P | | 1 | | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | | 3 | 4 | 1 | 1 | 1 | 1 | | 4 | | | 5

CONT

01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 2 | 7 | | 7 | 0 | 7 | 0 | 2 | 8 | 2 | | 8 | 0 | 7 | 3 | 0 | 8 | 2 | | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | With unit 1 in mode 1 (100% Rx power) at 1002 CST on 07/02/82, one containment
03 | hydrogen monitor (I-H₂A-43-210) was declared inoperable due to failure to meet
04 | surveillance requirements. This event placed the unit in the action statement of
05 | LCO 3.6.4.1. There was no effect upon public health and safety. Previous
06 | occurrences - five (SQRO-50-327/80182, 80198, 80124, 81039 and 81063).

09 | SYSTEM CODE | I | E | | 11 | CAUSE CODE | X | | 12 | CAUSE SUBCODE | Z | | 13 | COMPONENT CODE | I | N | S | T | R | U | | 14 | COMP. SUBCODE | E | | 15 | VALVE SUBCODE | Z | | 16

17 | LER/RO REPORT NUMBER | 8 | 2 | 21 | 22 | SEQUENTIAL REPORT NO. | 0 | 8 | 8 | 24 | 26 | OCCURRENCE CODE | 0 | 3 | 28 | 29 | REPORT TYPE | L | | 30 | REVISION NO. | 0 | 32 | ACTION TAKEN | X | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 37 | 40 | ATTACHMENT SUBMITTED | N | 23 | 41 | NFRD 4 FORM SUB. | N | 24 | 42 | PRIME COMP. SUPPLIER | L | 25 | 43 | COMPONENT MANUFACTURER | X | 9 | 9 | 9 | 44 | 48

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | During performance of surveillance instruction SI-287, the monitor would not respond
11 | to the sample gas. A calibration was performed and the monitor responded. The most
12 | probable cause for the failure is that the sample line orifice was clogged and during
13 | calibration the clog was blown loose. The monitor was verified to be within tolerance
14 | and returned to service at 1147 CST on 07/03/82.

15 | FACILITY STATUS | E | 28 | 7 | 8 | 9 | % POWER | 1 | 0 | 0 | 29 | 10 | 12 | OTHER STATUS | NA | 30 | 44 | METHOD OF DISCOVERY | B | 31 | 45 | DISCOVERY DESCRIPTION | Surveillance testing | 32 | 46 | 80

16 | ACTIVITY CONTENT | Z | 33 | 7 | 8 | 9 | RELEASED OF RELEASE | Z | 34 | 10 | AMOUNT OF ACTIVITY | NA | 35 | 44 | LOCATION OF RELEASE | NA | 36 | 45 | 80

17 | PERSONNEL EXPOSURES | 0 | 0 | 0 | 37 | 7 | 8 | 9 | TYPE | Z | 38 | 11 | DESCRIPTION | NA | 39 | 13 | 80

18 | PERSONNEL INJURIES | 0 | 0 | 0 | 40 | 7 | 8 | 9 | DESCRIPTION | NA | 41 | 11 | 12 | 80

19 | LOSS OF OR DAMAGE TO FACILITY | Z | 42 | 7 | 8 | 9 | TYPE | NA | 43 | 10 | 80

20 | PUBLICITY ISSUED | NA | 44 | 7 | 8 | 9 | DESCRIPTION | NA | 45 | 10 | 80

8208050342 820730
PDR ADOCK 05000327
S PDR

NRC USE ONLY