

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M E M Y P 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 0 0 3 0 9 7 0 7 0 7 8 2 8 0 7 2 3 8 2 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During steady state operation, while performing standard quarterly surveillance
0 3 testing the Reactor Coolant System Loop Fill and Loop Drain header cross tie valve
0 4 (CH-M-75) failed to open in three (3) repeated attempts. With the valve indicating
0 5 light showing the closed position, the control switch for the valve was placed in
0 6 the closed position and held there for approximately ten (10) seconds. The valve
0 7 was then cycled (open/close) four (4) times with the valve operating satisfactorily
0 8 each time. There was no effect on public health or safety.
7 8 9 80

0 9 C J 11 E 12 X 13 V A L V E X 14 E 15 A 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 8 2 21 22
EVENT YEAR 8 2
23
SEQUENTIAL REPORT NO. 0 1 8 24 26
27
OCCURRENCE CODE 0 3 28 29
REPORT TYPE L 30
REVISION NO. 0 32
ACTION TAKEN X 18 X 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED Y 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIE-1 N 25 COMPONENT MANUFACTURER V 0 8 5 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of the occurrence is unknown at this time due to the inaccessibility of
1 1 the valve. The valve was cycled four (4) times and operated satisfactorily. In
1 2 addition, the valve will be cycled once per week for a month. The first two (2)
1 3 weekly surveillances have been satisfactory. If CH-M-75 passes the four (4) weekly
1 4 surveillance tests, it will then return to its normal quarterly surveillance
7 8 9 80

(Continued)

1 5 FACILITY STATUS E 28 % POWER 0 9 8 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Operator observation 32
7 8 9 10 11 12 13 14 44 45 46 80

1 6 ACTIVITY CONTENT Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 12 13 14 44 45 80

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 10 11 12 13 80

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 10 11 12 80

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 80

2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45
7 8 9 10 80

8208050526 820723
PDR ADDCK 05000309
S PDR

LER #82-018/03L-0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (Continued)

frequency. A Maintenance Request (1607-82) has been generated for the next plant shutdown, to inspect and adjust limits if required. If adjustments or repairs are required an updated LER will be submitted.