

DISTRIBUTION:

NRC Docket Lewis
 LPDR Wilcove
 PDR Snyder
 FF (2) Chron.
 Rutberg
 Chandler
 Vogler
 Murray
 Crnistenbury/Scinto

July 30, 1982

John F. Wolf, Esq., Chairman
 Administrative Judge
 3409 Shepherd Street
 Chevy Chase, Md. 20015

Dr. Oscar H. Paris, Administrative
 Judge
 Atomic Safety & Licensing Board
 U.S. Nuclear Regulatory Commission
 Washington, D.C. 20555

Mr. Frederick J. Shon,
 Administrative Judge
 Atomic Safety & Licensing Board
 U.S. Nuclear Regulatory Commission
 Washington, D.C. 20555

In the matter of
 METROPOLITAN EDISON COMPANY, ET AL.
 (Three Mile Island Nuclear Station, Unit 2)
 Docket No. 50-320 OLA

Dear Administrative Judges:

On June 18, 1982, the Director of the NRC Office of Nuclear Reactor Regulation issued an Amendment of Order authorizing a change in supervisory authority with respect to TMI-2 Radiological Control Technician Training. The Staff, on July 13, 1982, submitted a motion to conform the proposed technical specifications with that Amendment of Order (NRC Staff Notice of Issuance of Amendment of Order and Motion to Conform Proposed Technical Specification Herewith).

However, as noted in the enclosed letter from Dr. Snyder to Mr. Barton, the attached pages of the proposed Technical Specifications as modified by the Amendment of Order were incorrect. I enclose, along with the above-mentioned letter, corrected pages.


Sincerely,



Michael N. Wilcove
 Counsel for NRC Staff


Enclosures: As stated




DESIGNATED ORIGINAL

Certified By 

cc w/enclosures:
 Karin W. Carter
 Dr. Judith H. Johnsrud
 George F. Trowbridge, Esq.
 Docketing & Service Section

Mr. William A. Lochstet
 Atomic Safety and Licensing Board
 Atomic Safety and Licensing Appeal Panel

 7 0507

OFC	: OELD 	: OELD 	: OELD 	:	:	:	:
NAME	: MWilcove:am	: LChandler	: JRutberg	:	:	:	:
DATE	: 7/29/82	: 7/29/82	: 7/1/82	:	:	:	:

JUL 7 1982

Docket No. 50-320

Mr. John J. Barton
Acting Director of TMI-2
GPU Nuclear Corporation
P.O. Box 480
Middletown, PA 17057

Dear Mr. Barton:

On June 18, 1982, the NRC issued an Amendment of Order for TMI-2 that changed supervisory authority relative to TMI-2 Radiological Control Technician training. However, the modified pages that were enclosed with the Amendment of Order were not correct. Enclosed in this letter are the correctly modified pages. They should be inserted in place of the enclosures from the June 18, 1982 letter.

Sincerely,

/s/

Bernard J. Snyder, Program Director
Three Mile Island Program Office
Office of Nuclear Reactor Regulation

Enclosures: As stated

cc w/encl.:
See next page
L. King
J. Larson

8207220693

cc w/enclosure(s):

Ronald C. Haynes
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
531 Park Ave.
King of Prussia, PA 19406

John F. Wolf, Esq., Chairman,
Administrative Judge
3409 Shepherd Street
Chevy Chase, MD 20015

Dr. Oscar H. Paris
Administrative Judge
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Frederick J. Shon
Administrative Judge
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Karin W. Carter
Assistant Attorney General
505 Executive House
P.O. Box 2357
Harrisburg, PA 17120

Dr. Judith H. Johnsrud
Environmental Coalition
on Nuclear Power
433 Orlando Avenue
State College, PA 16801

George F. Trowbridge, Esq.
Shaw, Pittman, Potts and
Trowbridge
1800 M Street, NW
Washington, DC 20036

Atomic Safety and Licensing
Board Panel
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Atomic Safety and Licensing
Appeal Panel
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Secretary
U.S. Nuclear Regulatory Commission
ATTN: Chief
Docketing & Service Branch
Washington, DC 20555

Mr. Larry Hochendoner
Dauphin County Commissioner
P.O. Box 1295
Harrisburg, PA 17108-1295

John E. Minnich, Chairperson
Dauphin County Board of Commissioners
Dauphin County Courthouse
Front and Market Streets
Harrisburg, PA 17101

Dauphin County Office of Emergency
Preparedness
Court House, Room 7
Front & Market Streets
Harrisburg, PA 17101

U.S. Environmental Protection Agency
Region III Office
ATTN: EIS Coordinator
Curtis Building (Sixth Floor)
6th and Walnut Streets
Philadelphia, PA 19106

Thomas M. Gerusky, Director
Bureau of Radiation Protection
Department of Environmental Resources
P.O. Box 2063
Harrisburg, PA 17120

David Hess
Office of Environmental Planning
Department of Environmental Resources
P.O. Box 2063
Harrisburg, PA 17120

Willis Bixby, Site Manager
U.S. Department of Energy
P.O. Box 88
Middletown, PA 17057-0311

Herbert Feinroth, Acting Deputy
Director of Coordination and
Special Projects, NE-550
U.S. Dept. of Energy
Washington, DC 20545

William Lochstat
104 Davey Laboratory
Pennsylvania State University
University Park, PA 16802

Randy Myers, Editorial
The Patriot
812 Market Street
Harrisburg, PA 17105

Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220
7910 Woodmont Ave.
Bethesda, MD 20814

Judith A. Dorsey
1315 Walnut Street
Suite 1632
Philadelphia, PA 19107

Linda W. Little
5000 Hermitage Drive
Raleigh, NC 27612

Marvin I. Lewis
5504 Bradford Terrace
Philadelphia, PA 19149

Jan Lee
183 May Road
Etter, PA 17109

J. B. Liberman, Esquire
Berlack, Isaacs, Liberman
26 Broadway
New York, NY 10004

Walter W. Cohen, Consumer Advocate
Department of Justice
Strawberry Square, 14th Floor
Harrisburg, PA 17127

Edward O. Swertz
Board of Supervisors
Londonderry Township
RFD #1 Geyers Church Road
Middletown, PA 17057

Robert L. Knupp, Esquire
Assistant Solicitor
Knupp and Andrews
P.O. Box P
407 N. Front Street
Harrisburg, PA 17108

Robert Q. Pollard
Chesapeake Energy Alliance
609 Montpelier Street
Baltimore, MD 21218

John Levin, Esquire
Pennsylvania Public Utilities
Commission
P.O. Box 3265

Honorable Mark Cohen
512 E-E Main Capital Building
Harrisburg, PA 17120

ADMINISTRATION CONTROLS

6.3 UNIT STAFF QUALIFICATIONS

6.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI-N 18.1 of 1971 for comparable positions unless otherwise noted in the Technical Specifications.

6.3.2 The Manager—Radiological Controls shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975. Each Radiological Controls Technician in responsible positions/Foreman shall meet or exceed the qualifications of ANSI 18.1-1971, paragraph 4.5.2/4.3.2, or be formally qualified through an NRC approved TMI-2 Radiation Controls training program. Individuals who do not meet ANSI 18.1-1971 Section 4.5.2 are not considered technicians for purposes of determining qualifications but are permitted to perform work for which qualification has been demonstrated. All Radiological Controls Technicians will be qualified through training and examination in each area or specific task related to their radiological controls functions prior to their performance of those tasks

6.4 TRAINING

6.4.1 A retraining and replacement training program for the unit staff shall be maintained under the direction of the Plant Training Manager - TMI-2 and shall meet or exceed the requirements and recommendations of Regulatory Guide 1.8 of 1977 and Appendix "A" of 10 CFR Part 55 except that Radiological Controls training may be under the direction of Vice President - Radiological and Environmental Controls.

6.4.2 A training program for the Fire Brigade shall be maintained under the direction of the Plant Training Manager - TMI-2 and shall meet or exceed the requirements of Section 27 of the NFPA Code - 1976.

6.5 REVIEW AND AUDIT

6.5.1 PLANT OPERATIONS REVIEW COMMITTEE (PORC)

FUNCTION

6.5.1.1 The Plant Operations Review Committee (PORC) shall function to advise the Director Site Operations on all matters related to nuclear safety and radioactive waste safety.

COMPOSITION

6.5.1.2 The Plant Operations Review Committee shall be composed of the:

- a. Chairman - who shall have an academic degree in engineering or physical science field and a minimum of five years of applicable experience.
- b. Member - who shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975.

ADMINISTRATIVE CONTROLS

- c. 7 Members - who shall meet or exceed the qualification requirements of Section 4.7.2 of ANSI/ANS-3.1-1978

The Director Site Operations shall designate the Chairman and the Vice Chairman from among the members of the Plant Operations Review Committee.