



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

November 7, 1990

Docket No. 50-285

LICENSEE: Omaha Public Power District
FACILITY: Fort Calhoun Station, Unit 1
SUBJECT: SUMMARY OF MEETING TO DISCUSS THE REVISING OF THE FUEL HANDLING
ACCIDENT IN THE UPDATED SAFETY ANALYSIS REPORT AS A RESULT OF
AIR BY-PASSING THE SPENT FUEL POOL CHARCOAL FILTER

On October 15, 1990, NRR staff members met with the licensee to discuss the revising of the Fuel Handling Accident (FHA) in Fort Calhoun's Updated Safety Analysis Report (USAR) as a result of the Spent Fuel Pool (SFP) charcoal filter by-pass. Enclosure 1 is a listing of the meeting attendees.

The licensee made an overview presentation on this issue as shown in Enclosure 2. The licensee indicated that during a recent refueling outage, it was discovered that in-leakage of air through a roll-up door to the Auxiliary Building, where the SFP is located, could disrupt airflow patterns and prevent suction of radiological releases from the SFP through its charcoal filter, VA-66. On January 1, 1990, the licensee performed a test which found air by-passing the SFP charcoal filter. Based on this test, the licensee determined that the plant was not within the design basis established by the USAR. The analysis in the USAR assumes that in the event of an FHA in the SFP, all the air in the vicinity of the pool passes through the charcoal filter. This item was also reported in the NRC Inspection Report 50-285/90-13 which stated that the issue was an unreviewed safety question; therefore, the licensee must reestablish the design configuration or obtain approval prior to moving spent fuel. Consequently, this meeting was held with NRR to resolve the issue.

In its presentation, the licensee indicated that it determined that the analysis for an FHA in the containment envelopes the consequences of an FHA in the SFP; hence, an FHA in the pool would not exceed regulatory requirements. Therefore, no actions are required to modify the ventilation system to ensure that the air passes through the charcoal filter. However, the staff stated that General Design Criteria 61 specifies that fuel storage systems should have

9011130266 901107
PDR ADOCK 05000285
P PDC

QF01
11

filtering systems. Therefore, this conclusion that no license action was required is not valid. The staff requires that the updated FHA be submitted for its review prior to its update in the USAR, and that the resolution of this item be in-place prior to the licensee's 1991 refueling outage.

Anthony Bournia

Anthony Bournia, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:
As stated

cc w/enclosures:
See next page

Mr. W. Gary Gates
Omaha Public Power District

Fort Calhoun Station, Unit No. 1

cc:

Harry H. Voigt, Esq.
LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, NW
Washington, D.C. 20036

Mr. Jack Jensen, Chairman
Washington County Board
of Supervisors
Blair, Nebraska 68008

Mr. Raymond P. Mullikin, Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 309
Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
Combustion Engineering, Inc.
12300 Twinbrook Parkway, Suite 330
Rockville, MD 20852

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Harold Borchert, Director
Division of Radiological Health
Nebraska Department of Health
301 Centennial Mall, South
Post Office Box 95007
Lincoln, Nebraska 68509

Mr. T. L. Patterson, Manager
Fort Calhoun Station
Post Office Box 399
Fort Calhoun, Nebraska 68023

November 7, 1990

filtering systems. Therefore, this conclusion that no license action was required is not valid. The staff requires that the updated FHA be submitted for its review prior to its update in the USAR, and that the resolution of this item be in-place prior to the licensee's 1991 refueling outage.

Original signed by:

Anthony Bournia, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:
As stated

cc w/enclosures:
See next page

DISTRIBUTION

- Docket File
- NRC PDR
- Local PDR
- PD4-1 Reading
- M. Virgilio MS 13E4
- T. Quay
- L. Berry
- A. Bournia
- OGC MS15B18
- E. Jordan MNBB 3701
- ACRS (10) MS P-315
- PD4-1 Plant File
- R. Mullikin, Region IV

OFC	: PD4-1/LA	: PD4-1/FM	: PD4-1/D	:	:	:
NAME	: L Berry <i>LB</i>	: A Bournia:lh	: T Quay <i>TQ</i>	:	:	:
DATE	: 11/6/90	: 11/6/90	: 11/7/90	:	:	:

OFFICIAL RECORD COPY
Document Name: MEETING SUMMARY FT CALHOUN

Meeting Attendees

<u>Name</u>	<u>Organization</u>
A. Bournia	NRR/DRSP/PDIV-1
C. R. Nichols	NRR/DST/SPLB
R. E. Architzel	NRR/DST/SPLB
J. Y. Lee	NRR/DREP/PRPB
T. R. Quay	NRR/DRSP/PDIV-1
J. W. Chase	OPPD
R. L. Phelps	OPPD
B. Van Sant	OPPD
B. Weber	OPPD

OPPD Meeting With NRC on Fort Calhoun

Fuel Handling Accident Analysis


October 15, 1990


1. Introduction J. Chase
2. Meeting Goals and Objectives R. Phelps
3. Review of VA-66 Issues B. VanSant
 - a. LER Submittal
 - b. Current Status
4. Review of Current FHA Analysis W. Weber
 - a. No Credit for VA-66
 - b. SAO Basis
 - c. USAR Revisions
5. Discussion of Changes to FHA for Next Reload W. Weber
6. Meeting Summary R. Phelps
7. Closing Remarks J. Chase

MEETING OBJECTIVES

- Clarify the design basis for our current Fuel Handling Accident (FHA) Analysis
 - VA-66 Performance
 - Reasons for LER and SAO
 - No USQ Involved

- Discuss potential FHA analysis changes for the next reload submittal





CYCLE 12 SHUTDOWN FUEL HANDLING ACCIDENT

CONTAINMENT


SPENT FUEL POOL

GAS GAP SOURCE TERM	SAME
DECONTAMINATION FACTOR	SAME
RADIOACTIVITY RELEASE POINT	SAME
X/Q DISPERSION FACTOR	SAME
NO IODINE FILTRATION	VA-66 FILTER


VENTILATION
DISCHARGE STACK

EXHAUST AIR
FROM
AUX. BLDG.



AIR
SUPPLY
PLENUM



CONTAINMENT
AIR COOLING &
FILTERING UNITS





CONTAINMENT
PURGE AIR
DISCHARGE
UNITS



FUEL HANDLING
BUILDING

CONTAINMENT



RESULTS

<u>EAB</u>	10CFR100	DOSE CONSEQUENCE
THYROID	300 REM	43.6 REM
WHOLE BODY	75 REM	0.75 REM
<u>LPZ</u>		
THYROID	300 REM	0.16 REM
WHOLE BODY	75 REM	0.03 REM

FUTURE CYCLE CHANGES

- HIGHER FUEL TEMPERATURES
- HIGHER PEAKING FACTORS
- HIGHER LINEAR HEAT RATES

CONSEQUENCE

- HIGHER GAS GAP ACTIVITY (SOURCE TERM)


GAS GAP COMPARISONS

<u>ISOTOPE</u>	<u>RELEASE FRACTION</u>	<u>CURRENT *</u>	<u>REVISED*</u>
I-131	0.122	1.93 E4	4.53 E4
Xe-131m	0.064	1.57 E2	9.41 E2
Xe-133	0.029	3.89 E4	2.00 E4
Kr-85	0.075	7.50 E2	1.58 E2

* ACTIVITY IN CURIES

FUEL HANDLING ANALYSIS

- PERFORMED BY CE (REG. GUIDE 1.25)
- BOUNDING FUEL TEMPERATURES
- BOUNDING DUTY CYCLES
- NO CREDIT FOR VA-66
- REVISED STRUCTURAL DROP ANALYSIS BY CE



RESULTS

10CFR 100 LIMITS

<u>EAB</u>	10CFR100	REVISED	CURRENT
THYROID	300 REM	52.0 REM	43.6 REM
WHOLE BODY	75 REM	0.07 REM	0.75 REM

<u>LPZ</u>	10CFR100	REVISED	CURRENT
THYROID	300 REM	1.83 REM	0.16 REM
WHOLE BODY	75 REM	0.003 REM	0.03 REM

MEETING SUMMARY

- Current FHA analysis will be documented through USAR revision
- Design basis for VA-66 clarified
- NRC document agreement that no USQ exists
- OPPD determine if reasonable alternatives exist to FHA analysis changes for next reload

November 7, 1990
Meeting Summary Ft Calhoun

DISTRIBUTION

Docket File

NRC PDR

Local PDR

PD4-1 Reading

M. Virgilio MS 13E4

T. Quay

L. Berry

A. Bournia

OGC MS15B18

E. Jordan MNBB 3701

ACRS (10) MS P-315

PD4-1 Plant File

R. Mullikin, Region IV