

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-346THE TOLEDO EDISON COMPANYANDTHE CLEVELAND ELECTRIC ILLUMINATING COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 45 to Facility Operating License No. NPF-3, issued to The Toledo Edison Company and The Cleveland Electric Illuminating Company (the licensees), which revised Technical Specifications (TSs) for operation of the Davis-Besse Nuclear Power Station, Unit No. 1 (the facility) located in Ottawa County, Ohio. The amendment is effective as of its date of issuance.

This amendment modifies the TSs to permit operation for a third cycle. This cycle has a design length of 230 Effective Full Power Days (EFPD), however, the TSs provide flexibility to permit an extension of cycle length to 268 ± 10 EFPD. The modified TSs also incorporate revised Reactor Protection System instrumentation trip setpoints, allowable values, and Reactor Protection System instrument response times.


The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated March 5, 1982, as revised and supplemented March 23, 1982, June 1, 1982, and June 21, 1982, (2) Amendment No. 45 to License No. NPF-3, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, NW, Washington, DC, and at the William Carlson Library, University of Toledo, 2801 Bancroft Avenue, Toledo, Ohio. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 28th day of July 1982.

FOR THE NUCLEAR REGULATORY COMMISSION



Sydney Miner, Acting Branch Chief
Operating Reactors Branch #4
Division of Licensing