

X



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

November 9, 1978

Docket No. 50-213

P

Connecticut Yankee Atomic Power Company
ATTN: Mr. W. G. Council, Vice President
Nuclear Engineering and Operations
Post Office Box 270
Hartford, Connecticut 06101

Gentlemen:

In the meeting on July 20, 1978, we advised your representatives of the status of our ongoing review of the environmental qualification of safety-related electrical equipment (SEP Topic III-12). We have completed the tabulation of the information from all SEP facilities using a standard format. The information provided in your submittals of March 6, 1978 and July 27, 1978, are listed in the enclosed table, including references and an explanation to the table.

So we can proceed with our review of this topic we request that you (a) complete as much of the table as possible, (b) identify appropriate references, and (c) confirm the accuracy and completeness of the table. Please provide the information within 30 days after receipt of this letter. If you have any questions regarding this request call the NRC Project Manager for your facility.

Sincerely,

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

Enclosure:
As stated

cc w/enclosure:
See next page

cc w/enclosure:
Day, Berry & Howard
Counselors at Law
One Constitution Plaza
Hartford, Connecticut 06103

Superintendent
Haddam Neck Plant
RFD #1
Post Office Box 127E
East Hampton, Connecticut 06424

Russell Library
119 Broad Street
Middletown, Connecticut 16457

Mr. James R. Himmelwright
Post Office Box 270
Hartford, Connecticut 06101

K M C, Inc.
ATTN: Jack McEwen
1747 Pennsylvania Avenue, NW
Suite 1050
Washington, D. C. 20006

Haddam Neck

Problems :

Time Needed: None

Spec. Data :

T :
P :
RH :
Ch :
Rad :

Qual. Data :

T : 5
P : 5, 10
RH : 5, 10, 16
Ch : 5, 16
Rad : 5

Qual Method :

T :
P :
RH :
Ch :
Rad :

Unqualified :

T : 12

S&T Submittal References 1, 2 and 3 do not address connections or splices.

Haddam Neck

SEP Submittal References:

1. Mar 6, 1972 Letter, D.C. Switzer to Dir., NRR
2. Mar. 27, 1972 Letter, D.C. Switzer to Dir., NRR
3. Jul. 27, 1972 Letter, W.G. Coursit to Dir., NRR

Haddam Neck

Documentation References:

1. Feb 1, '78 and Feb 2, '78
Care Letters
2. NUSCO Evaluations dated
7/20/78 and 7/21/78
3. FIRL T-22232-01
4. Jan 31, '78 Letter from Limitorque
5. Limitorque Test Report # 600198
6. FIRL T-23441
7. Apr 5, '78 Whouse Letter CYW-78-518
8. Southern Cal. Edison Report to NPC
dated Feb 24, '78
9. Collyer Technical Report # 67-2
10. IEEE Paper, R. Blodgett & R.G. Fisher,
May, 1967
11. NUSCO Evaluation dated 7/24/78
12. Okorite Resesick Report # 467
13. Stone and Webster Evaluation
dated 7/19/78
14. Mar 23, '78 Letter from General
Coble
15. Jan 15, '77 Collyer Letter
16. FIRL F-C2750
17. Johnson Service Co. Data Sheet V-21
18. Kirtner & Bowman, Effects of Radiation
on Materials and Components. New
York: Prentice Hall (1974)
19. FDCR # 270 Technical Rev.
20. Feb 2, '78 and Feb 10, '78 Letters,
D.C. Switzer to A. Schwercer
21. NUSCO Evaluation dated 3/27/78
22. Dec 12, '77 Letter, D.C. Switzer to
E.G. Case
23. NUSCO Evaluation dated 7/7/78
24. Jun 21, '78 Letter, R.H. Graves to
B.H. Grier

Location

Reactor: Haddam Neck

Systematic Evaluation Program

Equipment Type	SEP Submittal Reference	Loc	Time Needed	Environment			Qual. Method	Reference	
				Parameter	Spec.	Qual.			
1 Motor Operated Valve binister push No Part #	3-1/2	I	Long	Temp. Pr. (Aria) RH Chem Rad. Sub.	267°F 50 100% Yes 1.9x10 ⁶ No	5x10 ⁵ 125 125 SAT 5x10 ⁵	Test Test Test Test Test	3(12)4, 5076	
2 Motor Operated Valve binister push No Part #	3-1/3	I	Long	Temp. Pr. (Aria) RH Chem Rad. Sub.	267°F 50 100% Yes 1.9x10 ⁶ No	5x10 ⁵ 125 125 SAT 2x10 ⁸	Test Test Test Eval Test	4, 6(12)2	
3 Motor Operated Valve Teledyne/ T-4	3-1/1	I	Long	Temp. Pr. (Aria) RH Chem Rad. Sub.	267°F 50 100% Yes 2.9x10 ⁶ No	275°F 55 100% SAT 1x10 ⁷	Eval Eval Eval Eval Eval	42 4 2 2 2 2	
4 Motor Operated Valve Teledyne/ T-10	3-1/4	I	Long	Temp. Pr. (Aria) RH Chem Rad. Sub.	267°F 50 100% Yes 2.9x10 ⁶ No	275°F 55 100% SAT 1x10 ⁷	Eval Eval Eval Eval Eval	42 4 2 2 2	
5 Penetration, Elec. No Man listed/ No Part #	3-5/2	I	Long	Temp. Pr. (Aria) RH Chem Rad. Sub.	267°F 50 100% Yes 1.9x10 ⁶ No		Eval Eval Eval Eval Eval	42 23 23 23 23	4, 6(12)2 Currently being Tested

Reactor: Hudson Nest

Systematic Evaluation Program

Equipment Type	SEP Submittal Reference	Loc	Time Needed	Environment			Qual. Method	Reference
				Parameter	Spec	Qual.		
6 Terminal Block GE EP-85 (enclosed)	3-5/11	I	long	Temp. Pr. (Bia) RH Chem. Rad. Sub.	267°F 50 100% Yes 45x10 ⁶ No	286°F 55 100% Sat. 5x10 ⁶	Test Test Test Test Test	
7 Terminal Block Wrsingtonhouse/ 805452 (exposed)	3-5/11	I	long	Temp. Pr. (Bia) RH Chem. Rad. Sub.	267°F 50 100% Yes 1.3x10 ⁶ No	285°F 55 100% Sat. 5x10 ⁶	Eval Eval Eval Eval Eval	Rad. Qual.
8 Cable Copoly/ PE/PVC	3-2/4	I	<1	Temp. Pr. (Bia) RH Chem. Rad. Sub.	267°F 50 100% Yes 1.3x10 ⁶ No	262°F 56 100% Sat. 5x10 ⁶	Test Eval Eval Eval Eval	312/11
9 Cable Olonite/ Butyl/PVC	3-3/11	I	long	Temp. Pr. (Bia) RH Chem. Rad. Sub.	267°F 50 100% Yes 1.3x10 ⁶ No	286°F 55 100% Sat. 5x10 ⁶	Eval Eval Eval Eval Eval	10, 11, 12, 13
10 Cable Samuel Moore/ PVC/PVC Detoron 1853	3-3/2	I	<1	Temp. Pr. (Bia) RH Chem. Rad. Sub.	267°F 50 100% Yes 1.3x10 ⁶ No	281°F 50 100% Sat. 5x10 ⁶	Eval Eval Eval Eval Eval	11, 13

Reactor: Hadam Neck

Systematic Evaluation Program

Equipment Type	SEP Submittal Reference	Loc	Time Needed	Environment			Qual. Method	Reference
				Parameter	Spec	Qual.		
13 Cable General Cable MI	3-3/5	I	Long	Temp. Pr. (Bia) RH Chem Rad. Sub.	267°F 50 100% Yes 3x10 ⁶ No	302°F 5000 100% Sat 4x10 ⁹ —	Eval Eval Eval Eval Eval —	AS/LS
13 Cable Cable Shure Ampcor	3-4/1	I	Long	Temp. Pr. (Bia) RH Chem Rad. Sub.	267°F 50 100% Yes 3x10 ⁶ No	260°F 50 100% Sat 5x10 ⁹ —	Eval Eval Eval Eval Eval —	AS/LS
13 Transmitter, Pressure Fordov 6113M-A1	3-2/2	I	<1	Temp. Pr. (Bia) RH Chem Rad. Sub.	267°F 50 100% No 1.8x10 ⁶ No	244°F 75 100% — 1x10 ⁶ —	Test Test Test — Test —	— — — — — —
14 Transmitter, level Fordov 613HM-AS1-F	3-2/3	I	<1	Temp. Pr. (Bia) RH Chem Rad. Sub.	267°F 50 100% No 1.8x10 ⁶ No	244°F 75 100% — 1x10 ⁶ —	Test Test Test — Test —	— — — — — —
15 Motor, Iso Westinghouse No Part #	3-2/1	I	Long	Temp. Pr. (Bia) RH Chem Rad. Sub.	267°F 50 100% Yes 3x10 ⁶ No	320°F 75 100% Sat 2x10 ⁹ —	Eval Eval Eval Eval Eval —	— — — — — —

Reactor: Hydrogen Work

Systematic Evaluation Program

Equipment Type	SEP Submittal Reference	Loc	Time Needed	Environment			Qual. Method	Reference
				Parameter	Spec.	Qual.		
Air Solenoids Johnson Serv. Co. V-24-R	3-4/3	I	< 1	Temp. Pr. (Abs) RH Chem. Rad. Sub.	267°F 50 100% Yes 1420° No	140°F 45 1410° —	V.I.T. G.I.T. EVAL EVAL EVAL	M.I.Z. 18 — — — — —
Junction Box Steel Box Ac Man. Listed No. Part #	2-B	I	Long	Temp. Pr. (Abs) RH Chem. Rad. Sub.	267°F 50 100% Yes 4540° No	266°F 50 100% Sat. 5410° —	Test Test Test Test Test	— — — — — —
				Temp. Pr. (Abs) RH Chem. Rad. Sub.				
				Temp. Pr. (Abs) RH Chem. Rad. Sub.				
				Temp. Pr. (Abs) RH Chem. Rad. Sub.				