



CONNECTICUT YANKEE ATOMIC POWER COMPANY

HADDAM NECK PLANT

RR #1, BOX 127E, EAST HAMPTON, CONN. 06424

November 16, 1978
GTS-78-E-476

Mr. Boyce Grier, Director
Region 1
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Reference: Facility Operating License No. DPR-61
Docket No. 50-213
ETS/NR/50-213/78-11

Dear Mr. Grier:

Pursuant to Connecticut Yankee Environmental Technical Specifications (ETS) Section 3.1.1.3, Connecticut Yankee Atomic Power Company hereby forwards the following report regarding fish impingement overruns.


During power operations with four main circulators running, three species of fish exceeded their monthly limit as delineated in Environmental Technical Specification Table 3.1-1. An estimated 419 alewives (*ALOSA PSEUDCHARENGUS*) 3-6" were impinged exceeding their limit of 330 as of October 31, 1978. An estimated 1217 Glut Herring (*ALOSA AESTIVALIS*) 3-6", were impinged as of October 31, 1978, exceeding the monthly ETS limit (Table 3.1.1) of 710.

Also, an estimated 581 and 101 Hogchokers (*TRINECTES MACULATUS*) 0-3" and 3-6" respectively, were impinged as of October 31, 1978 thereby exceeding the monthly limits of 210 for the 0-3" class, and 25 for the 3-6" class as set forth in Environmental Technical Specifications, Table 3.1-1.

There is no apparent cause which could be related to changes in plant operations.

It is felt that the total numbers were small and do not reflect a trend towards increased impingement.

Very truly yours,


Richard H. Graves
Station Superintendent

RHG/jhb

cc: Dir., Office of Nuclear Reactor Regulation, Washington, D. C. (17)

50-213
P

C003
S/10