

ATTACHMENT A

COMANCHE PEAK STEAM  
ELECTRIC STATION  
UNIT ONE  
LOOSE PARTS MONITORING SYSTEM  
SPECIAL REPORT

9011190122 901112  
PDR ADDCK 05000445  
P PDC

ABSTRACT

Regulating Guide 1.133, Revision 1, May 1981. Section C.3.a.(2)(a) requires the power operation alert levels of the Loose Parts Monitoring System (LPMS) to be reported to the Nuclear Regulatory Commission following the initial startup program. This report was written to comply with this requirement.

The power operation alert levels for the individual LPMS channels were based on the comparison and analysis of;

- (1) The basic system sensitivity during plant shutdown, and
- (2) The background noise measured during normal plant power operation.

LPMS Special Report

Table of Contents

<u>Section</u>	<u>Page</u>
1.0 Introduction	1
1.1 System Description	1
Table 1 - CPSES LPM Sensor Location	1
2.0 Methodology	3
2.1 Data Acquisition	3
2.2 Data Analysis	3
Figure 1 - Hi-Alarm Process	7
3.0 Data	
3.1 Impact Amplitudes	8
3.2 Impact Frequency Spectrum	9
3.3 Background Amplitude (Power Operation)	10
3.4 Background Frequency Spectrum (100% Power)	11
3.5 Adjacent Channel Response	12
3.6 Calibration Traces	13
3.7 Data Summation	14
Table 2 - CPSES LPMS Data Summation	16
4.0 Discussion of Results	17

## 1.0 INTRODUCTION

The purpose of this report is to:

- o Describe the loose-parts monitor system for CPSES.
- o Describe the methodology used to measure impact energy sensitivity.
- o Discuss the results of LPMS associated test and data reduction.
- o Document the LPMS power operation alert levels at completion of the ISU test program.

### 1.1 System Description

The Loose Parts Monitoring System employed at CPSES is the Babcock & Wilcox (B&W) reactor diagnostic system (RDS). This system is designed to monitor, alarm and diagnose loose parts.

The Loose Parts Monitoring System uses an array of active and passive accelerometers to detect metal to metal impacts indicative of loose parts in the RCS. The accelerometers are permanently installed at selected locations where a loose part would tend to collect or impact. The locations of the accelerometers provide a high degree of reliability in the detection of metal to metal impact in the reactor coolant system. Two accelerometers are located at each of the following locations:

- o Reactor Pressure Vessel - Upper Head Region
- o Reactor Pressure Vessel - Lower Region
- o All Steam Generators - Primary Coolant Inlet Region

One accelerometer is located at each of the following locations:

- o All Reactor Coolant Pumps
- o All Steam Generators - Upper Region

The accelerometers operate on the piezoelectric crystal effect with deformation of the crystal producing a measurable proportional charge. This signal is amplified, filtered, and conditioned to accentuate the frequency band known by measurement to correspond to metal to metal impacts. The system is designed to alarm the presence of unusual noises above normal background noise present in the plant. The system comprises eight active and twelve passive accelerometer channels. The active channels are monitored continuously for detection of loose parts. The passive channels are used for diagnostics (location determination) of a loose part that has been detected.

Sensor locations and LPM used for signal processing are shown in Table 1.

TABLE 1  
**CPSES Loose Parts Monitoring Sensor Locations**

<u>SENSOR</u>	<u>PROCESS MODULE</u>	<u>TYPE</u>	<u>LOCATION</u>
1	LPM-1	ACTIVE	SG "A" Inlet
2	LPM-1	PASSIVE	SG "A" Inlet
3	LPM-2	PASSIVE	RCP "A"
4	LPM-3	PASSIVE	SG "A" Level Tap
5	LPM-2	ACTIVE	SG "B" Inlet
6	LPM-4	PASSIVE	SG "B" Inlet
7	LPM-5	PASSIVE	RCP "B"
8	LPM-6	PASSIVE	SG "B" Level Tap
9	LPM-3	ACTIVE	SG "C" Inlet
10	LPM-7	PASSIVE	SG "C" Inlet
11	LPM-8	PASSIVE	RCP "C"
12	LPM-1	PASSIVE	SG "C" Level Tap
13	LPM-4	ACTIVE	SG "D" Inlet
14	LPM-2	PASSIVE	SG "D" Inlet
15	LPM-3	PASSIVE	RCP "D"
16	LPM-4	PASSIVE	SG "D" Level Tap
17	LPM-5	ACTIVE	Reactor Cavity
18	LPM-6	ACTIVE	Reactor Cavity
19	LPM-7	ACTIVE	Reactor Head
20	LPM-8	ACTIVE	Reactor Head

## 2.0 METHODOLOGY

### 2.1 Data Acquisition

2.1.1 Impact energy data was collected during plant shutdown as part of the pre-operational test program under procedure ICP-PT-91-01 SFT. The data was directly recorded on magnetic tape using the integral four-channel reel-to-reel tape decks that were supplied with the LPMS. Impacts were imparted using calibrated weights of 0.25 lbm and 30 lbm within 3 feet of the sensor at a kinetic energy of 0.5 ft-lb (0.68 joules).

2.1.2 Operational baseline (background noise) data was recorded at reactor power levels of 0, 30, 50, 75 and 100% during the initial plant startup program under procedure ISU-211.

2.1.3 Procedure PPT-TP-90-025 documented the spectral comparison of data collected in 2.1.1 and 2.1.2, above. From this comparison, band pass filter "break frequencies" were determined. Filters were adjusted to band-limit the broad-band signal to that portion of the spectra that maximizes the signal-to-noise ratio. Following filter adjustments background noise was measured to establish alert levels per Reg. Guide 1.133, Section C.2.

### 2.2 Data Analysis

Procedure PPT-TP-90A-025 was developed to document data analysis and bandpass filter adjustments for determination of final alarm settings and power operation alert levels. The following is a chronological sequence on the performance of PPT-TP-90A-025.

2.2.1 Tapes recorded during the performance of pre-operational test ICP-PT-91-01 SFT were obtained from the document control center vault. Each tape had a calibration signal of 1KHz/1Vrms recorded as a predecessor to impact and background data.

Prior to tape analysis a 1KHz/1Vrms function generator signal was injected into a digital oscilloscope and spectrum analyzer with outputs routed to an X-Y plotter. Adjustments were made to the X-Y plotter to ensure linearity between graph paper scaling vs. actual signal to allow direct amplitude interpretation.

The taped 1KHz/1Vrms calibration signals were played back for each recorder channel and used to determine a "correction factor" to account for any losses associated between taped signals and actual field signal strength.

Following "correction factor" determination, recorded impact amplitude and transient capture frequency spectrum were plotted. Impact amplitudes (Vpp), with the 0.25 lbm weight, were normalized to g's p-p by multiplying each signal by the correction factor and module full scale range settings (g/v).

Sensor response to a 30 lbm weight impact was calculated by comparing the measured response difference between the 0.25 lbm and 30 lbm impacts at one of the sensor locations. This value was also normalized to g's p-p.

2.2.2 Tapes of background (baseline) data at 100% Reactor Power were played back and analyzed for frequency content. A spectral comparison was performed between the background and impact frequencies to determine "break frequencies" for bandpass filter adjustment.

After filter tuning, background noise was measured and normalized to g's p-p to provide a basis for alert level and alarm sensitivity settings.

2.2.3 In order to have a basic understanding of the LPMS signal processing at CPSES and the desired sensitivity requirements as stated in Reg. Guide 1.133 the following is provided:

NRC Regulatory Guide 1.133 makes the following statement concerning sensitivity.

"The on-line sensitivity of the automatic detection system should be such that, as a minimum, the system can detect a metallic loose part that weight from .25 lb (0.11 kg) to 30 lb (13.6 Kg) and impacts with a kinetic energy of 0.5 ft-lb (0.68 joules) on the inside surface of the reactor coolant pressure boundary within 3 feet (0.91 meter) of a sensor. If the recommended sensitivity cannot be achieved by automatic alert because of specific in-plant conditions, these conditions and the actual on-line sensitivity should be specified at the time the alert level is provided. As an example, one acceptable method of verifying this on-line sensitivity is to demonstrate (1) the basic system sensitivity during the plant shutdown and (2) that the background noise measured during normal plant operation is sufficiently small that the signal associated with the specified detectable loose-part impact would be clearly discernible in the presence of this background noise."

As the Commission position infers, the ability to detect a given impact energy is dependent on system background noise level and on the size of the impacting object. Typical background acceleration noise level (g) ranges from .1g to 2g peak to peak. During testing and calibration of B&W LPM Systems, acceleration response to a 0.5 ft-lb impact has been

measured from > 30g for a 0.25 lb ball down to 0.4g for a 30 lb. ball. Thus, the lower level 0.5 ft-lb impact responses could be masked by the background noise and therefore be undetectable. In this case the specific in-plant conditions and the actual on-line sensitivity would have to be specified.

The alarm threshold circuitry resides with the loose part detector module (LPM) for each of the eight active channels at CPSES (see Fig. 1). Each module contains an Automatic Gain Control (AGC) circuit which allows a floating alarm threshold. The AGC output signal is routed to the alarm comparator and is adjusted for an output of 5 volts d.c. The input to the AGC is a d.c. value proportional to the AC output of the sensor (accelerometer). The AGC output (5 Vd.c.) remains constant for slow changes or long term variations in the background noise levels due to plant operating parameters. If a loose-parts signal occurs, the AGC circuit is too slow to react so that the transient (impact signal) adds to the output of the AGC circuit. The reference or comparator setpoint, is determined by the HI-ALARM setting selected on the individual LPM. When the AGC output exceeds the alarm threshold, the comparator switches giving an alarm.

This explanation is to show that the high alarm threshold is actually a ratio of the normal operating background noise level to the impact amplitude. For example, if the alarm threshold (HI-ALARM) is set on 3 (or 7.0 volts) then the alarm ratio is 7 : 5 or 1.4:1 and the impact signal must exceed the background noise by 1.4:1 to trigger the alarm. Transients with amplitude less than background noise would not be detected.

The AGC circuit is part of the discrimination designed into the LPMS to help prevent spurious alarms. In addition there is logic discrimination within the Digital Loose Parts Locator (DLPL) that affects sensitivity. The DLPL requires at least two channels to alarm to consider an alarm condition to be valid. This two channel criteria means that sensitivity is determined by the adjacent sensor and not the sensor nearest the impact origin.

2.2.4 Alert levels that would provide early detection of a loose part with a minimum amount of false alarms were determined originally by adjusting the Hi-Alarm setpoint to the lowest non-alarming setting while operating at the 100% power plateau.

For the eight (8) active LPMS channels, adjacent sensors were monitored during impacts to determine if the sensitivity (Hi-Alarm) settings were adequate to automatically detect a loose part under power operation background noise levels. As an example, if the background noise signal after filter adjustments measured 100 millivolts p-p and the Full Scale (F.S.) Range LPM setting was 3 g/V, the background amplitude would be 0.3g p-p.

If the Hi-Alarm setting is at 5 which corresponds to 9.0 volts, the AGC is at 5.0 volts, then the alarm ratio would be 1.8:1 and the signal impact perturbation must be at least 1.8 times greater than background (0.54%; p-p in this example) to cause an alarm.

The adjacent sensor response can now be compared to this alert level to determine if the system is sensitive enough to detect a loose part above background noise levels.





FIGURE 1  
 SIMPLIFIED BLOCK DIAGRAM OF  
 LOOSE PARTS DETECTOR HI-ALARM PROCESS

### **3.0 Data**


#### **3.1 Impact Amplitudes**

The following X-Y plots were made using data collected during pre-operational test ICP-PT-91-01 SFT. Sensor settings and impact weight is listed in the upper right-hand corner of each graph. Highest peak-to-peak voltage levels are recorded on the y-axis. The peak voltage is then multiplied by the "tape loss" correction factor and the Full Scale Setting of the LPM to determine Impact Amplitude in g's(p-p).

(2w17)



(Line)



0.000 0.005 0.010 0.015 0.020 0.025 0.030


IMPACT IMPULSE TRANSIENT  
025147010.5 64.16

PPT - 10.90A - 025 R-0  
Range 2 - 100mV : 025 V/100mV : 5290  
Step 0.1 - Sine 100mV : 025 A/V  
WAV 0-1.30/B-33  
LPM FS. 10<sup>9</sup>

PPT-TP-90A-025 Rev. C  
STEP B. 1 - Sensor LPD-3  
Range Settings Nai = .05 V/DIV  
Nai GND 0/7190 / 8:42  
LEM FS. 3 g


IMPACT AMPLITUDE TRANSECT  
0.25 INCH / 0.13 MM

$$23.5 \times .05 = 1.17 \text{ VPP}$$



460780


H-E 10 X 10 TO THE INCHES



**H-E** 10 X 10 TO THE INCH • 7 X 10 INCHES  
 HUEFFEL & ESSER CO. NEW YORK

46 0780

(2602)



$$25.5 \times 0.05 = 1.275 \text{ ft}$$




IMPACT WAVE / 0.05 G. 16.  
IMPACT WAVE / 0.05 G. 16.

Lam 33 39  
Wad 8.7-10 / 0.49  
Raing 25.51 - 5m  
Str 8.31 - 5m  
Port-1P-4D-0.025 Pm

PPT-TP-90A-025 REV.O  
STEP 2.3.1 - Series 600-6  
Range Setting 1N11 = .03 V/DIV  
MUL 8.7-90 / 8.53  
LPM F.S 7.9

IMPACT MEASUREMENT TEST  
0.25 lbm / 0.5 ft. lb.

27.8.65 - 1.35 V/PF




PPT. TO .90A .025 REV O  
 STEP 8.3. - Sensor 4PD-7  
 Range Setting 100mV/div  
 Mags 8-7: 9D / 9: 0.9  
 LPM F, S, 3 g

IMPACT AMPLITUDE TRANSIENT


0.25 10 sec. / 0.5 & 1 lb.

$$33 \times 0.2 = 0.66 \text{ V} \rightarrow 0.66 \text{ V}$$



PPT: RP 40R - 025 Rev 0  
 STEP B.3 - Sensor LPD 8  
 Range Setting IVXZ = 0.1 V/d.v  
 MNG 8-7-60 / 9-11  
 LPM F.S. 10 g  
 Impact Amplitude Transient T  
 0.25 lb.m / 0.3 ft-lb.


$$2.3 \times 0.1 = 2.3 \text{ V p-p}$$




PDT-TP-20A 025 Rev. C  
STEP B-3.1 - Sensor LPD-2  
Range setting 1Vx1 = .05 V/div  
MFR 8.7-90 / 9.16  
LPM PS. -3g

IMPACT AMPLITUDE TRANSIENT  
0.25 lb.m / 0.5 ft.lb.

$$20 \times 0.05 = 1.0 \text{ Vr.p}$$





$$39 \times 0.025 = 0.975 \text{ Kp}$$


WAVELET AMPLITUDE IN INCHES / 0.05 IN.

$$\frac{100-10}{10} = 90 \text{ IN.}$$
$$90 \times 0.025 = 2.25 \text{ IN.}$$
$$2.25 \times 8.31 = 18.6825 \text{ IN.}$$
$$18.6825 \times 0.025 = 0.4670625 \text{ IN.}$$
$$0.4670625 / 0.05 = 9.34125 \text{ IN.}$$

PDT-TP-90A-025 Rev. C  
STEP B-3.1 - Sensor LPD-11  
Range Setting 1V/d.v.  
MIDS 8-7-40 / 9-19  
LPM F.S. 3 g

IMPACT AMPLITUDE: TRANSIENT  
0.25 lbm / 0.5 lb.

$$23 \times .05 = 1.15 \text{ V p-p}$$




(time)

PRT - 10 - 10A - 026 Rev. C  
STEP 0.3.1 - Sensor 1 P.D. 1/2  
Range setting 1Vx2 = 0.1 V/div.  
MNB 8.7 - PD / 9.21  
LPM F.5. 10.9


IMPACT AMPLITUDE TRANSIENT  
0.25 lbm / 0.5 ft. b.

20 x 0.1 = 2.0 Vpp



PPT-IV-10A-025 Dec. 0  
STER 8.3. - Sensor 16D-13  
Range Setting 1000V ± 4 - 2250V ± 4000V  
MIND 8-7-90 / 9:25  
LPH 15.5. 3g  
IMPACT AMPLITUDE TRANSIENT  
0.25 lbm / 0.5 ft. lb.


$$0.02 = 0.54 \frac{V_p-p}{V_p} \times 12.5 \sqrt{V_p} p = 0.032 - 0.016$$



PORT - TP - 10K - 0.25 R = 0  
STEP B. 3.1 - SENSOR LPD-14  
Range Setting  $|V_{ref}| = .05 V$   
MAG 8 - 7.20 / 9.20  
LPM F. 5. - 3.9  
0.25 lb/m / 0.5 lb/m

IMPACT MAGNITUDE TRANSMISSION

$$18 \times .05 V = 0.7119$$



46 0780


K-E 10 X 10 TO THE INCH • 7 X 10 INCHES

KELFFEL & ESSER CO. MADE IN U.S.A.

PPT-TP-90A-025 Rev. C  
STEP 0.3 1 - Sensor LPD-15  
Range setting 1V x 1 = 0.05 V/div  
WAB 0-7-90 / 9:31  
LPM, F.S. : 3.9

W<sup>2</sup>ACT AMPLITUDE TRANSIENT  
0.25 lbm / 0.544 lb.

$$25 \times .05 = 1.25 \text{ VPP}$$




460780

KEL 10 X 10 TO THE INCH • 7 X 10 INCHES  
KURTZ & ESSER CO. KODAK SAFETY FILM  
SERIES

PDT-TP-901-025 Rd. C  
STEP B. 3.1 - Range 1 V<sub>2</sub> = 0.171 div.  
Range 2 V<sub>2</sub> = 0.34  
N.D. 0.1 - 30 / 0.34  
L.C.M. F. 3. 10<sup>6</sup>

IMPACT AMPLITUDE TRANSMISSION  
0.2516m / 0.344. Wb.

$$27.5 \times 0.1 = 2.75 \text{ Vpp}$$



(2mV)

460780

K-E 10 X 10 TO THE INCH • 2 X 10 INCHES  
KEUFFEL & ESSER CO., NEW YORK

PPI-TP-90A - 025 Rev. O  
SFTI 8.3.1 - Sensor LPD: 17  
Range Setting 1V/Hz: 0. V/d.v.  
DPS 8-7-90 / 9:50  
LPM F.S. 3.9

IMPACT AMPLITUDE TRANSIENT  
0.25 lb.m / 0.5 ft.lb.

20 x 0.1 = 2.0 N.s.g


3.2  
V

46 0780

K-E MEASUREMENTS INC. • 7 X 10 INCHES

PPT - TP - 10A - 025 Rev. 0  
STEP S. 3.1 - Sensor LPO - 12  
Range Setting 1VR2 = 0.1V/div  
MDO 8-7-90 / 9.52  
LPM F.S. 10 g  
IMPACT AMPLITUDE, TRANSIENT  
0.23 mm / 0.5 ft. lb


$$18.5 \times 0.1 = 1.85 \text{ VPP}$$



POT-TP-90A-025 RDJ-O  
STEEL E. 3. 1 - Sensor LPO-12  
Range Setting IV x 2 x 2 = 500 V/din  
was 0.7-20 / 7.57  
LPM F.5. 10g


IMPACT AMPLITUDE TESTS  
0.25 lbm / 0.54 lb

$$24 \times 0.05 = 1.2 \text{ Vpp}$$




PDT	TP	90 A	0.25	Rev. O
STPS	8.3.1	- Sensor	LPD-20	
Ferry	Settings	1Vx2	0.1V	/di/dj
Wad	8.7.10	/	10.00	
LIM	F.S.	- 3g		
MARKET MOELTITUDE TRANSIENT				
0.25	lbm	/ 0.5	ft#	.1lb.

$$V_{\text{S}} \times 0.1 = 1.5 V_{\text{P}} \cdot p$$



K-E 10 X 10 TO THE INCH • 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

46 0780



46 0780

H.E. 10 X 10 TO THE INCH • 7 X 10 INCHES  
KELFEL & SISK CO. MADE IN U.S.A.

### 3.2 Impact Frequency Spectrum

The following X-Y plots were made using data collected during pre-operational test ICP-PT-91-01 SFT. Sensor settings and determined break frequencies are listed.

25KHz

12.5m<sup>2</sup>  
(KHz)

10<sup>4</sup>

1.5<sup>4</sup>

5<sup>4</sup>


2.5<sup>4</sup>

0

Lower frequency [20Hz]

Upper frequency [15kHz]

-73.1 dBV




(dB)

THREE SEPARATE INPUTS AND THREE SEPARATE MEASUREMENTS

STP 8.3.1. 1W/10Hz/m/0.25m  
STP 8.3.1. 1W/10Hz/m/0.25m

PPT - IP - 90A - 0.25 R1.0  
STEP 8.3.1 - Sensor - LPD-2  
Sens. t.v. typ 1V/u, form 1/0.25mV  
MAG 0.2110 12.4.0  
LPM - 10g


TRANSIENT CAPTURE SPECTRUM



46 0780

K-E 10 X 10 TO THE INCHES

PPT-TIP 0.085 deg O  
 STEP 0.31 - Sensor LPD-3  
 Sustaining IV/Uniform / 0-25 kHz  
 148 8/21/90 / 12:45  
 LPM F.S. 3.8  
 TRANSIENT CAPTURE SPECTRUM



25L2  
12.5 SCALE (KHZ)  
10 KHZ

(DB)

10000

10000

-64.3 dBV

10000

-12.7 dBV

TRANSIENT CAPTURE SPECTRUM

PPR-TP-100A-025 PNU 0  
STEP 8.3.1 - Sensors LPD4  
Sens. Th. 1/4 Uniform 10-25 kHz  
NMO 8/2/10 1.250  
LNU F5 - 10<sup>3</sup>

KOE 10 X 10 TO THE INCH • 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

46 0780




(dB)

PPT-TP-90A-025 Rev C  
STEP 2 3-1 Sensor LPO-5  
Sensitivity 1W/Uniburly 70-25/42  
Waves 8/21/90 12:55  
LPM F.S. 3.8g  
TRANSMITTER CAPTURE SPECTRUM

PPT-TP-40A-025 Rev. 0  
SITE# 8.3 Sensor - LPD 6  
Sensitivity 1V/Volt/mV 0-25000  
WAO 8/21/90 12:39  
LPN FS. 3.9

TRANSIENT CAPTURE SPECTRUM




460780

46° E 10 X 10 TO THE INCH • 7 X 10 INCHES  
HEUPEL & ESSER CO. MUNICH GERMANY

2152

PPT-TP-90A-025 Rev 0  
Step 8 3 1 Sensor LPD-1  
Amesbury 14 14 Uniform / D-25KHz  
Mass 8/27/90 13:05  
LPM F-3 3g

TRANSMISSION CAPTURE SPECTRUM



K-E 10 X 10 TO THE INCH • 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

46 0780

KOE 10 X 10 TO THE INCH • 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

46 0780

250Hz

12.5 kHz

1000 Hz

1000 Hz

-52.2 dBV

1000 Hz


(dB)

TRANSIENT GROWTH SPECTRUM

PPT-TD 10A C25 Rev ~  
SITES 3, 3, 1 - 100 %  
Gage 1, 3, 4, 1 Uniform / 0-25000  
Time 8/21/80 13:10  
LDM 55 10%

PPT-TP-90A-025 Rev. C  
S/N# 8.3.1 Sensor L0D-9  
Serial No. 14/40001/015500  
Date 012/1980 - 13/15  
LPM FS 353

TRANSIENT CONDUCTIVE SPECTRUM




KOE 10 X 10 TO THE INCHES 7 X 10 INCHES  
KELUFF & ESSER CO.  
MADE IN U.S.A.

46 0780

PPT-TP 90A-025 Rev D  
 STEP 8.3.1 Sensor 19D-40  
 Sensor 4.0.45 18Junction 10-250mA  
 Mod 8121.40 13.20  
 Long F.S. 37

TRANSIENT CONSTRUCTION SPECTRUM




K-E 10 TO THE INDUSTRIAL 10 IN INCHES  
KELFER & ESSER CO. MADE IN U.S.A.

46 075

2582


(K+E)  
12.5 mils

0



POT-TP-90A-025 Rev. C  
STEP 8.3 | System 12D-12  
Sensitivity 1V/10mV 0-100000  
Input Impedance 1M $\Omega$   
Range 1000 - 10000  
Lane E.S. 10.8


TRANSGEST CURRENT SPECTRUM



23002


PPT-TP-30A-025 Rev. O  
ST500 E. S. 1 Sensor LID-13  
Sens. + J. H. 1V/Unit/cm<sup>2</sup> 0-25000  
Mno 3121/10 - 13:35  
LPM 13 3g

TRANSIENT CAPTURE SPECTRUM



POT-TP-10A-025 Rev 0  
STEL 8.3.1 Series LPD-14  
Sensitivity 1V/Unitam / 0.25mV  
MAP 9121/90-13-40  
LPM FG. 3g


TRANSIENT CAPTURES SPECTRUM



15

PPT - 11 - 90 A 0.25 P.A. 0  
 STTP 8.3.1 Sensor 4PD - 15  
 Sensitivity 1V/Unitform / 0-256ms  
 MADS 8/21/90 - 13:45  
 LPM F.S. 320

Transient Capture Spectra.




46 0780

H-E 10 X 10 TO THE INCH • 7 X 10 INCHES  
HEUER & ESSER CO. MADE IN U.S.A.

46 0780


25 kHz  
12.5 kHz (kHz)



17

PPT: TD 90A .025 044 0  
 STAB 0 3 1 - 1000-17  
 sensitivity 1V/Unit/m 0.05m  
 HPS 0121/10 - 13:55  
 LPM FS 38

TRANSIENT AND TONE SPECTRUM




2500

2500

460780

PPT - TP 10A-015 200.0  
SITE 8.3.1 - Secca LPD-18  
Sensitivity 1V/Unitary 10-2300  
NFB 8/21/90 - 4:00  
LPM 65 10g

TRANSMITTER CAPTURE SPECTRUM




46 0780

10 X 10 INCHES  
10 X 10 INCHES  
10 X 10 INCHES  
10 X 10 INCHES

Z5442


PRT-TP 90A 0.25 Rev 0  
STEP 8.3.1 Spans 0.0-12  
Sens. 1.0V/m N/ Unif. 0.25ms  
Pins 3/2, 1/2 14.05  
LPM F3 10g

TRANSIENT CAPTURE SPECTRUM



K-E TO X 10 TO THE INCH • 2 X 10 INCHES  
KELFER & ESSER CO. MADE IN U.S.A.

46 0780



### 3.3 Background Amplitude (Power Operation)

The following X-Y plots were made directly off an oscilloscope output while measuring filtered background noise levels at 95% power operation.

FILTERED BACKSCATTER NOISE AT  
POWER ORIENTATION - SENSOR 1  
LPAI-1 F.S. 0.3

(velocity)

100


(time)

20 m sec.

46 0780

304

FILTERED BACKSCATTER NOISE AT  
POWER OPERATION - SENSE 2  
LPAI - 1 F.S. - 0.3



FILTERED BACKGROUND NOISE AT  
POWER OPERATION - SENSOR 3  
LON - Z M. S. - 1.0

(Velocity)

-0.255 V

20 m sec.

(t, sec.)

46 0780

K-E 10 X 10 TO THE INCH • X 10 AND 100

FILTERED BACKGROUND NOISE AT  
POWER OPERATION - SENSE 4  
EPM-3 F.S. 0.3

(velocity)

1.2 + 1


20 mm

(time)

46 Q780

MEASURED AT 2400 CPS. 100% DOWNSCALE

FILTERED BACKGROUND NOISE AT  
POWER OPERATION - SENSOR 5  
LPU-2 E.S. 0.3



46 0780

H-E 10 X 10 TO THE INCH • 1 X 10 INCHES

FILTERED BACKGROUND NOISE AT  
POWER OBSERVATION - SENSOR 6  
LPM: 4 F.S. - 0.3


(volts)

1.51V

20 sec.

(time)

FILTERED BACKGROUND NOISE AT  
POWER OPERATION - SENSOR 7  
LPM - 5 F.S. 0.1



RECORDED BACKGROUND NOISE AT  
POWER OPERATION - SENSOR A  
LPT-6 F.S. 0.3

H&E 10 X 10 TO THE INCHES 1 X 10 INCHES  
HARVEY & ESSER CO. MADE IN U.S.A.

46 0780

(velocity)

100

(time)

20 msec.

STRUCTURE AND GROUND NOISE AT  
POWER GENERATION - SESSION 2  
CPM-3 F.S. 1.0

(RMS)

1556 0.96


13.3 msec

(time)

46 0780

KOE 10 X 10 TO THE INCHES X 10 INCHES  
KELFEL & SEDEN CO. MADE IN U.S.A.

FILTERED BACKGROUND NOISE AT  
POWER OPERATION - SENSOR 10  
CPG. 7 F.S. 1.0



FILTERED BACKGROUND NOISE AT  
PUNKT 2 OBSERVATION + SENSITIVITÄT 11  
LPM 8 F.S. - 3.0

(10/10)


-1.1587

20 m sec.

(time)


460780

1/2 X 10 TO LINE INCHES / X 1000 FEET




FILTER BACKWASH AND AIR RELEASE  
POND OPERATION - SEAWALL 13  
L.D.M. = 4 R.F.S. = 0.3

(Velocity)



(time)

5msec




2.07 Vads

(Voltage)

LPM-2 FS-03

FILTERED BACK GROUND NOISE AT  
POWER OF 14 - SENSITIVITY 14


FILTERED BACKGROUND NOISE AT  
POWER OPERATION - SENSOR 15  
LPR-3 F.S. : 0.1



46 0780


K-E TO K-E TO THE IRISH • 1 X 10 INCH 300

FILTERED BACKGROUND NOISE AT  
POWER OPERATION + SEASIDE 14  
COND. 4 F.S. 0.3



46 0780

H-E-3  
10 X 10  
• ESSER CO.  
PRINTED IN U.S.A.



PIRELO Background noise at  
Power operation - SENSIT 10  
LPIEL-6 F:5.0.3

13.3.0.26

(6.2a)


(VOLTS)

1 sec

K-E 10 X 10 TO THE INCH • 7 X 10 INCHES  
KNUFF & KESSER CO. MADE IN U.S.A.

46 0780

FILTERED BACK GROUND NOISE AT  
POWER OPERATION - SEPTEMBER 19  
L.P.T. = 7 F.S. = 1.0



FILTERED BACKSCATTER NOISE AT  
DOME OPERATION - SENSOR 20  
Long = 8 F.S. 1.0

(Volts)

2.02

(time)

13.3 msec.

K-E 10 X 10 TO THE INCH • 7 X 10 INCHES  
KELIFF & ESSER CO. MADE IN U.S.A.

46 0780

### 3.4 Background Frequency Spectrum (100% Power)

The following X-Y plots were made using tapes recorded during initial startup test ISU-211A. The background frequency content was compared to the impact frequencies (see Section 3.2) to determine "break frequencies" for bandpass filter adjustments.


K•E 10 X 10 TO THE INCH • 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

46.0780

FREQUENCY


17.5KHz

25KHz



PPT-1P-90A-005 Rev 0  
SPECS 8.5.1 - Sensor LPD-1  
Power Settings - 1V Sin Frequency 0-25KHz  
Watts 0-1-100, 6-15  
LPM F.S. - 0.1 g  
TIME AND FREQUENCY PLOT (256)  
BACKGOUND - 100% Power Operation

PDT-TP 9DA -025 Rev. 0  
 STEP 0.5.1 Sensor LPD-2  
 Range settings 11 sent / unsend 0.25mm  
 MED 0.1-10 / 0.44  
 LSM F.S. - 3.0 g  
 TIME AVG MEASUREMENT POUT (250)  
 BACKGROUNDS - 100%. Power Operation



KOE 10 X 10 TO THE INCH • 1 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

46 0780

FREQUENCY  
12.5 KHZ

25000




PDT 0  
PDT - 10 - 90 - 025  
STEP 0.5 - 1 Super LPD : 2  
Range 30m/s - 315m/s / 0.15mm / 0.25mm  
WHD 0.9 ad / 8.47  
LGM F5 - 50.9  
Tilt Reel RUL Frequency 2501 (250)

FREQUENCY

12.5 kHz


25 kHz



FREQUENCY

17.5 kHz

250 Hz




PPT-TP-104-025 Radio  
STEP 05.7 Sine 1PD-5  
Range Settings - 1V Sensitivity / 0.25ms  
LNU - F.15, 0.38  
WAG 0.19-50 / 0.54  
Searched Auto: 100% Run Operation  
Time: 00:00:00.000000 (256)

REEAUENCI

12.5KHz

0



frequency

12.5 kcs.

25 kcs.



DATA FROM 100% STATION  
TIME MILE PER HOUR (29)

LM E. S. - 10.9  
MWS 8.1-10 / 9.00  
SCL 8.5-7 Severe, LM-2  
PPR-10-4-025 E. 0.025  
PML-10-4-025 E. 0.025  
PML-10-4-025 E. 0.025

PDT - TR - 90A - D25 621.0  
STEP 0.5.1 Scanner LPO-B  
Range Settings - 11 1/2 in / 100% / 1/0.25%  
WMS 6.9 - D / 1:25  
LPM F.3. - 1.0g

TIME A/D. FREQUENCY PLOT (238)  
BACKGROUNDS - 100%. Page 2 operation

25KHz.

FREQUENCY


12.5KHz.

46 0780

H.E. 10 X 10 TO THE INCH • 7 X 10 INCHES  
HELFER & EISNER CO. MADE IN U.S.A.

2000.

FREQUENCY  
12.5 cps.



ppr-18-001-025 Rev. 0  
STEP 8.5.7 Sensor LPD-9  
Range Settings DIV 1000000000/10-1250000  
MAG 8.7-80/7.52  
LPM F.S. - 1.0,


K-E 10 X 10 TO THE INCH • 7 X 10 INCHES  
KUFPFEL & ESSER CO. MADE IN U.S.A.

46 0780

FREQUENCY

12.5 kHz.


25ms



POT-TP-901-075 POT-0  
STEP 8.5.7 SWAR 100-10  
POT-25MS 0.01V/sec 10000/0.25MS  
WING 0.9-1.0 / 0.38  
LGA E5 - 1.0 g  
DUE DUE FREQUENCY PLOT (25s)  
GALLERIAD - 100% Real Operation

PPT-TP-90A-025 RUE 0  
JTEP 8.5.7 Seaver 190-11  
Renee Seaver 0.3754 / 0.1626 10-2518  
MID 8-10 / 9-37

TIME AND FREQUENCY APP. (356)  
CALLIGAMO-100% Low Direction



25me.

12.5 Che.

FRÉQUENCE

46 0780


KOEHLER INC. / KOEHLER VALVES  
KELFEL & ESSER CO. MADE IN U.S.A.

K-E 10 X 10 TO THE INCH = 2 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

46 0780

## FREQUENCY

25242.




FREQUENCY

12.5 kHz

25 kHz

0  
1000




PP-TP-QD4-QD5 Run O  
STEP 8.5.3 Survey LPD-13  
Range Stations 0350m/0400m/0425m  
MWD 15-9-90 / 9:42  
LDM E.S. - 1109  
TIME MIG. FREQUENCY (Hz) (125)

FREQUENCY

12.5 kHz

2 sec.



PAT-P1-10A-005 REV. O  
SAGE 8.5.1 - Survey LDO-1A  
LPM E1 - 30  
LPM E1 - 30 / 9.51  
Rams 8.4-10 / 9.51  
Rams 0.1V1m / 0.1V1m / 0.1V1m  
TIME RATE FREQUENCY 10T (15s)

2 sec.


KoE 10 X 10 TO THE INCH • 7 X 10 INCHES  
KEUPPEL & ESSER CO. MADE IN U.S.A.

46 0780

FREQUENCY

12.5 KHz

25cm.



FREQUENCY:




Wavelength - 100-200 kHz  
The following point (225)  
was obtained from the  
same source as the one  
above.  
SAR 8.5.1 SAR 0  
100-100-200 kHz 0

H<sup>o</sup>E 10 X 10 TO THE INCH • 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.


46 0780

25MS.

1/2 SCALE  
FREQUENCY



PT-TP-90A-025 Rev. 0  
STEP 8.5, 7 Sensor LPD-11  
PULSE RATIO 11.545/UNIPLEX 10.25000.  
MAGS 8-9-10 / 10-05  
LGM F.5 - 0.1 g



PNT-1P-90A-025 Rev. O  
Senser 150-17  
SFS 8.5.7  
Range 50 Hz 250 0.315 rad/sec/min<sup>1/2</sup>  
VIBR 0-9-10 / 10-54  
LPM F.3 - 10 g  
LINE AXL. FREQUENCY 200 (220)  
EXCITER NO - 1007.6 mm position

2900.

FREQUENCY

12.5 KHz

46 0780

KELVIN & SHERE CO. NEW YORK U.S.A.


H.E. 10 X 10 TO THE INCHES

46 0780

FREQUENCY

12.5KHz

25Hz




PPT - TP - 0.25  
STEP B - S - 7 - Sensor 1P0 - 10  
Range Setting: 0.35  
Pins: 0.7 - 1.0  
TPA: 0.5 - 1.0  
TIME AND FREQUENCY (12.5K)


### 3.5 Adjacent Channel Response

The following X-Y plots were made using tapes recorded during pre-operational test 1-CP-PT-91-01 SFT. During impacts, the three closest adjacent channel sensors were recorded. The strongest signal was then compared to the background noise level on each of the 8 active sensors to determine system sensitivity.

K-E 10 X 10 TO THE INCH • 7 X 10 INCHES  
KELLELL & ESSER CO. MADE IN U.S.A.

46 0780






K-E 10 X 10 TO THE INCH • 7 X 10 INCHES  
KEUFFEL & ESSEN CO. MADE IN U.S.A.

46 0780


**K+E** 10 X 10 TO THE INCH. X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

46 0780

(240, 2)




PDT-1P-90A-0705 Rev.0  
STEP 3.9  
Range Setting: 1000mV/2 = 0.001V/D.  
Line Output: 0.001V/D x 1000 = 1V  
DC Output: 1V



K-2. 0 X 10 TO THE INCH = 2 X .30 INCHES  
LUFKIN & SONS CO. MADE IN U.S.A.

46 0780

(2nd)



3.5

27.000 = 0.222

DEHN 205 ± 5  
LDP ± 1.6 / SEC ± 2  
ADJUST CIRCUIT - REVERSE  
STR 8.9.4  
DOWNSCALE 324.000 ± 0.014

LPM 15.3


HOLD 122.96

PPR - TR. 0.6A - OUTS 0.10  
O


POT - 19 - 00A - 025 Rev. 0  
STEP 8.9.4  
Pant - Setting 1V x 2 + 0.1 / div  
HOLD 8/2/01  
LNU FS 1

ADJUST CIRCUIT SCALE  
LNU 20 / 100 • 2 sec  
DARK STEP 0.5

1150 = 1.0 RE




(2m)



46 0780

DATE 6 \* FEB 1958  
TIME 10:00 A.M.  
ADMITTED 10:00 A.M.  
STREPS 6.9.2.  
DOSAGE 32 mg.  
HOSPITAL NO. 1000002 = 01000002  
PDT - TR - 400, 0.22 600, 0




POT - TR 10A - 0.025 IN. 0  
STEP 0.9.4  
POT - TR 10A - 0.025 IN. 0  
0.0145  
100 + 20 / 100 = 0.2 IN.  
100 + 20 / 100 = 0.2 IN.  
0.0145


NOTES ON PRACTICE REPORT

10A 10A

(cm.)




PPI - 10' 90° 025 Bars 0  
STE 8.9.4  
Range Setting 100mV = 0.01V/mm  
LVA = 5.0.3  
Date Set 13  
ADJUST SWING PSC



20.5 ± 0.6 = 0.025


PDT TP-40A-025 Rev. C  
STED B-9-4  
Range Setting: 1000Vx2m/sec  
Mag Scale: 1000  
Len FS 3  
AVERAGE CHANNEL FREQUENCY  
DMM SET ± 13  
LDR: 91.142 ± 2 sec


(2m)




K-E 10 X 10 TO THE INCHES / X 10 INCHES  
KELFEL & ESSER CO. MADE IN U.S.A.

46 0780






46 0780



PPT-TP-90A-025 Rev 0  
STEP 8.9.6  
Range setting N<sub>21</sub> = 0.05 V/d.c.  
MWS 8/11/60  
LPM 15 3g

ADJUSTED SPURIOUS RESPONSE  
120 x 19 Tape of ADC  
DATA SET # 20

16 X .05 - 0.80 VPP



46 0780

K-E 10 X 10 TO THE INCHES • 7 X 10 INCHES  
KELFEL & ESSER CO. MADE IN U.S.A.

### 3.6 Calibration Traces

The following X-Y plots show X-Y plotter response to a 1 KHz/1 volt signal being injected from a signal generator and each respective tape channel response when playing back a recorded 1KHz/1 volt signal. The difference between the two were used to determine a correction factor.

PPI-TP-90N-025 Rev. Q  
X-Y Plotter Calibration Trace  
1 V/div / 10 sec (function generator)  
Settings 1V<sub>X</sub> & 2 = 0.1 V/d.v  
Speed 0.7-40

2.9 Vpp

V105


(time)

08/07/80


H-3  
MURRAY • CO. INC.  
10 X 10 TO THE INCHES

PPR-TP-90A-025 Rev. C  
STEP No. 8.2.4  
TAPE #1 Chubberton Standard White  
Channel #1 (SFT)  
Settings:  $|V_x| = .05 \text{ V/div}$   
MAG 8.7-70

$$.925 \times .05 = .046 \text{ Vpp}$$




PPT-TP-10A-025 Rev. D  
 Step No. 89.7  
 Test of Calibration Signal 1 (V/cm)  
 CHANNEL # 2 (SPR)  
 Settings  $V_{X2} = 0.1 \text{ V/dm}$   
 Time 48-7-90




K-E 10 X 10 TO THE INCH • 7 X 10 INCHES  
KEUFFEL & SORRENS CO. NEW YORK U.S.A.

46 0780



ME 10 X 10 TO THE INCH • 7 X 10 INCHES  
 HELIFEL & ESSER CO. MADE IN U.S.A.

46 0780



POT - IP - 40A - 025 Rev. 0

STEP NO.


calib/beam load/strucural 1 u/s 1 u/s

Settings: IVX 2 = 0.1 V/d.s

Tape 2 (STEP) - Channel 1

MDS 3/22/90


10x0.1=1.48




46 0780

ME TO THE RESERVE CO. \* 10 INCHES

PPT-TP "10A 025 220 0  
STEP No. 8.9 L  
~~CHARGE/CONDITIONS~~  
Scaling: 1V x 2 = 0.1V/div  
Label: 2 (SET) Channel 1/2  
04/22/80 9PM



PPT-TP-96A-025 Rev 0  
STEP NO. 8.9.1  
CAREER TEST RECORD SHEET  
Setting 1/2  $\times$  2 = 0.1611  
Tape 1/2 (SPT) (channel 3)  
Date 8/22/80



PPT - 1P - 90A - 0.25 PLS 0

STEP NO. 842

CURRENT MEASURED 1V / 100A

SETTHINGS - 1V x 2 = 0.1V/d.s.

Tape 2 (BFT) - Channel 4


MAG 812210

BEST = 0.84V

5101


time

PPT-TP-90A-025 Rev.0  
X-Y Plotter Calibration Trace  
Step No. 8.5/2  
Channel 1 - (150)  
Settings  $|V_{x1}| = 0.05$  V/div  
MAB 8-8-90



time


20x0.05 + 1N71




V015

PPT-TP-PHASE5\_EU.C  
X-H PHASE (calibration trace)  
Step Ato 8.52  
Channel 2 - (15u) Tape 1  
X-H PHASE 1  
MAG 0.05u  
X-MAG 0.05u

OPT TIP - 90A - 025 Rev C  
X-Y Plotter (calibration trace)  
Step No: 8, S.2  
Channel 3 - (1sw) Tape 1  
Setting:  $|V_{RT}| = 0.054/\text{div}$   
Mags: 8-10






K-E 10 X 10 TO THE INCH • 7 X 10 INCHES  
KEUFFEL & SASSER CO. MADE IN U.S.A.

46 0780

54108

PPT - TP-9001-025 Rev 0  
Plotter Calibration Sheet  
X-Y Plotter No. 55  
Step No. 8.55  
Channel 1 (TP-2)  
Settings 1 V/div.  
Scales 1-10

$$22.5 \times 0.05 = 1.125 \text{ V/gp}$$



V=1.5


time

460780

10 X 10 INCHES

PPT TP-90A-025 Rev 0  
X-Y Plotter Calibration Trace  
Chart No. 8.5-  
Form 2 (Rev) Type 2

$$1/8.5 \times 0.05 = 0.005714$$




8104

K-E 10 X 10 TO THE INCH • X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

46 0780

PPT-TV : 1CA-025  
 X-7 01 once (alimino-Trace  
 Step No. 8.5  
 (Chiral 1-3 Cis) Taper 2  
 24 min. 2 UV 1 = 0.05 V/16.  
 NDS 8.8 40



516


K-E 10 X 10 TO THE INCH = 2 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

46 0780

PPT TP-90A-025 Rev. O  
X-2 Plotted Calibration Trace  
No 8:5.5  
SK 4 (150) Tape 2  
SK 2 NXL = 0.0546 ft  
m/s 8.20

$$ZS.5R \times 0.5 = 1.025 \text{ V.F}$$

V.O.H.S



time

46 0780

K.E. MEASURES & EQUIPMENT INC. 10 X 10 INCHES

### 3.7 Data Summation

Table 2 documents a detailed breakdown of each sensors frequency and amplitude response and individual characteristics. Description of each column is listed below:

Sensor - Sensor I.D. for which data is applicable for.

LPM - Loose Parts Module used for processing sensor signal during data collection and analysis.

Filter Settings - Based on the average values of low and high break frequencies for the active sensor channels.

High Pass - Low end "break frequency" given in Kilohertz (KHz). The high-pass filter is adjusted so that the processed signal is attenuated to 70.7% at this frequency. Frequencies lower than this value will be attenuated even greater. Processed signal strength at twice this frequency will be approximately 100%.

Low Pass - High end "break frequency" given in Kilohertz (KHz). The low-pass filter is adjusted so that the processed signal is attenuated to 70.7% at this frequency. Frequencies higher than this value will be attenuated even greater. Processed signal strength at one-half this frequency will be approximately 100%.

Background Noise Level - This value, given in g's peak-to-peak, is the normal operating background noise level. This value was determined after bandpass filters where adjusted.

Hi-Alarm Setting - This setting (1 thru 6) indicates the input ratio value required to bring in an alarm. Alarm settings and equivalent ratios are listed below.

<u>Hi-Alarm Setting</u>	<u>Ratio</u>
1	1.2
2	1.3
3	1.4
4	1.6
5	1.8
6	2.0

Alert Level - This value, given in g's peak-to-peak, is the required signal strength at power operation, to bring in an alarm. The value is a direct function of the normal operating background signal strength times the Hi-Alarm equivalent ratio.

Sensor Response .

0.25 lbm - This value, in g's peak-to-peak, was the measured response when impacting the associated piping within 3 feet of the listed sensor with a calibrated weight of 0.25 lbm at a kinetic energy of 0.5ft/lbs.

30 lbm - This value, in g's peak-to-peak, was the calculated response for impacting the associated piping within 3 feet of the listed sensor with a calibrated weight of 30 lbm at a kinetic energy of 0.5 ft./lbs. Calculated response was based on the ratio of the actual measure response between the 0.25 lbm and 30 lbm impacts for Sensor 3.

Adjacent Sensor Response

0.25 lbm - This value, in g's peak-to-peak, was the strongest measured response for an adjacent sensor when impacting the associated piping within 3 feet of the listed sensor with a calibrated weight of 0.25 lbm at a kinetic energy of 0.5 ft./lbs.

30 lbm - This value, in g's peak-to-peak, was the calculated response for an adjacent sensor when impacting the associated piping within 3 feet of the listed sensor with a calibrated with of 30 lbm at a kinetic energy of 0.5 ft/lbs. Calculated response was based on the same ratio as the actual measured response between the 0.25 lbm and 30 lbm impacts for Sensor 3.

Notes

1. - Active sensor, continuously monitored for detection of loose parts
2. - Adjacent sensor response not required for passive sensors since no automatic alarm detection is involved.
3. - Passive sensor, used for diagnostics after a loose part.
4. - Sensor response for 30 lbm object is actual measured value.
5. - Highest adjacent sensor response measured on Sensor #19.
6. - Highest adjacent sensor response measured on Sensor #17.
7. - Highest adjacent sensor response measured on Sensor #18.
8. - Highest adjacent sensor response measured on Sensor #20.

Table 2  
CPSES LPMS Data Summation

Sensor	LPM	FILTER SETTINGS		Background		Alert Level (s.p-p)	SENSOR RESPONSE		ADJACENT SENSOR RESPONSE		Notes
		High Pass (KHz)	Low Pass (KHz)	Noise Level (s.p-p)	Hi-Alarm Setting		0.25 lbm (s.p-p)	30 lbm (s.p-p)	0.25 lbm (s.p-p)	30 lbm (s.p-p)	
1	1	2	11	0.55	5	0.99	11.52	5.76	3.23	1.62	1,5
2	1	2	11	0.32			18.90	9.45	N/A	N/A	2,3
3	2	2	11	0.86			13.71	6.86	N/A	N/A	2,3,4
4	3	2	11	0.43			85.60	42.80	N/A	N/A	2,3
5	2	2	11	0.27	5	0.49	12.84	6.42	3.31	1.66	1,5
6	4	2	11	0.45			13.29	6.65	N/A	N/A	2,3
7	5	2	11	0.03			6.54	3.27	N/A	N/A	2,3
8	6	2	11	0.32			73.80	36.90	N/A	N/A	2,3
9	3	2	11	0.97	5	1.75	8.35	4.43	2.89	1.45	1,5
10	7	2	11	0.99			8.85	4.43	N/A	N/A	2,3
11	8	2	11	2.57			13.71	6.86	N/A	N/A	2,3
12	1	2	11	0.31			73.80	36.90	N/A	N/A	2,3
13	4	2	11	0.38	5	0.68	4.77	2.39	2.80	1.40	1,5
14	2	2	11	0.62			8.85	4.43	N/A	N/A	2,3
15	3	2	11	0.10			14.16	7.08	N/A	N/A	2,3
16	4	2	11	0.47			100.30	50.15	N/A	N/A	2,3
17	5	2	11	0.14	5	0.25	28.32	14.16	2.46	1.23	1,7
18	6	2	11	0.46	5	0.83	91.50	45.75	2.38	1.19	1,6
19	7	2	11	1.10	4	1.76	48.70	24.35	3.57	1.79	1,8
20	8	2	11	2.02	4	0.23	14.16	7.08	8.07	4.04	1,5

#### 4.0 Results

As can be seen from results documented in Table 2 the normal operating background levels for the active sensors range from 0.14 to 2.02 g's peak-to-peak. The noisiest data was obtained from sensors located on the reactor head. Based on the final HI-ALARM settings recorded in ISU-211A it was determined that system performance would be improved if sensitivity was increased on the two sensors located on the reactor head.

Work Order C90-7073 was issued to increase the sensitivity of these sensors by decreasing the HI-ALARM settings from 5 to 4.

Sensor response indicates that each active LPM module will alarm when the piping is impacted with an object weighing 0.25 lbms to 30 lbms at an impact energy of 0.5 ft. lbs. within 3 feet of the sensor. The 30 lbm response was calculated based on the ratio of an actual 30 lbm to 0.25 lbm impact at the #3 sensor location. This ratio was determined to be approximately 1:2 which would indicate that the 30 lbm impact accelerometer response (output) would be approximately one-half of the 0.25 lbm impact. When looking at actual alert levels for each of the active channels the 30 lbm response ratio could be as low as 1:4.3 (or 23% of the 0.25 lbm response) and still result in an alarm condition.

Adjacent sensor response, which would be required to automatically initiate the main control room annunciation, indicates that an object weighing 0.25 lbms impacting at an energy of 0.5 ft. lbs. within 3 ft. of the sensor would easily be detected. 30 lbm objects impacting at the same location and with the same energy are less likely to bring in the main control board annunciation as can be seen from the adjacent sensor response column in Table 2. This decrease in overall system sensitivity can be attributed to "active" sensor location. All four steam generator inlets have one active sensor. The best adjacent sensor response was measured at sensor 19 on the reactor head when impacting near the SG inlet sensors.