General Offices • Selden Street, Berlin, Connecticut

(203) 666-6911

P.O. BOX 270 HARTFORD, CONNECTICUT 06101



July 28, 1982

Docket Nos. 50-213 50-336 A02544

Mr. Ronald C. Haynes
Regional Administrator
Region 1
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Reference: (1) I&E Bulletin No. 82-02 dated June 2, 1982.

Gentlemen:

Haddam Neck Plant
Millstone Nuclear Power Station, Unit No. 2
Response to I&E Bulletin No. 82-02

In reference (1), Connecticut Yankee Atomic Power Company (CYAPCO) and Northeast Nuclear Energy Company (NNECO), were requested to take certain actions with respect to degradation of threaded fasteners in the reactor coolant boundary of the Haddam Neck Plant and Millstone Unit No. 2, respectively.

Confirming a telephone conversation between the Technical Contact identifed in reference (1) (W. J. Collins) and my staff (W. D. Bartron) on July 16, 1982, regarding clarification of the requested due dates for the I&E Bulletin No. 82-02 Action Items, it is our understanding that Action Item 1 is to be completed prior to the performance of Action Item 2, but not necessarily before the completion of Action Item 3. That is, the Action Item 1 procedures for threaded fastener practices shall be implemented prior to the performance of the Action Item 2 inspections. The report of the completion of Action Items 1 and 2 shall be submitted within 60 days following the completion of the outage during which Action Item 2 was performed. Action Item 3 shall be completed and a report submitted within 60 days of the date of the bulletin.

If you have any questions in this regard, please contact me.

Very truly yours,

CONNECTICUT YANKEE ATOMIC POWER COMPANY NORTHEAST NUCLEAR ENERGY COMPANY

W. G. Counsil

Senior Vice President

By:

yice President

Nuclear & Environmental Engineering