

**FGE**



Portland General Electric Company  
Trojan Nuclear Plant  
P.O. Box 439  
Rainier, Oregon 97048  
(503) 556-3713

RECEIVED  
NRG

1982 JUL 23 AM 10:00  
July 20, 1982  
CPY-580-82

REGION V IIR

Mr. R. H. Engelken  
Regional Administrator  
US Nuclear Regulatory Commission  
1450 Maria Lane - Suite 210  
Walnut Creek, California 94596-5368

Dear Sir:

In reference to our letter dated June 15, 1982 to R. H. Engelken (CPY-465-82) concerning the nonoperability of certain seismic monitoring equipment, construction delays for the design change to the mounting pedestal have delayed the return of the instruments to service. It is estimated the seismic monitoring instruments affected will be returned to service by August 12, 1982. The instruments out of service are:

- ST-6336 - Containment Base Slab Triaxial Time History Recording Accelerograph
- SR-6340 - Bottom of Containment Triaxial Peak Accelerograph
- SR-6341 - Containment Foundation Triaxial Response Spectrum Recorder.

Sincerely,

C. F. Yundt  
General Manager

*CPY*  
CPY/DWS/JCP:ga

c: LER Distribution  
File 93.24a(Q)

*Berry*

**GE**



Portland General Electric Company  
Trojan Nuclear Plant  
P.O. Box 439  
Rainier, Oregon 97048  
(503) 556-3713

June 15, 1982  
CPY-465-82

Mr. R. H. Engelken, Director  
US Nuclear Regulatory Commission  
Creekside Oaks Office Park  
1450 Maria Lane - Suite 260  
Walnut Creek, CA 94596-5368

Dear Sir:

Limiting Condition for Operation (LCO) 3.3.3.3. of the Trojan Technical Specifications requires that a Special Report be provided if certain seismic monitoring instruments are to be inoperable for more than 30 days. Seismic monitoring operability will not be met due to 1) annual calibration, 2) a design change to the mounting base, and 3) the Containment Integrated Leak Rate Test.

The following seismic monitoring instrumentation will be out of service for more than 30 days: ST-6336 Containment Base Slab Triaxial Time History Recording Accelerograph, taken out of service on June 7, 1982; SR-6340 Bottom of Containment Triaxial Peak Accelerograph, taken out of service on June 7, 1982; SR-6341 Containment Foundation Triaxial Response-Spectrum Recorder, taken out of service on May 17, 1982.

It is estimated that all of the above instruments will be back in service by July 12, 1982.

Sincerely,

*C. P. Yundt*

C. P. Yundt  
General Manager

*B*  
CPY/GGB/JCP:bb

c: LER Distribution List  
File 93.24a (Q)

8207080104