

**YANKEE ATOMIC ELECTRIC COMPANY**

Telephone (508) 779-6711  
TWX 710-380-7619



580 Main Street, Bolton, Massachusetts 01740-1398

November 9, 1990  
BYR 90-149

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Dear Sir:

Submitted herewith is the monthly Statistical Report for the Yankee Atomic Power Station for the month of October, 1990.

Very truly yours,

YANKEE ATOMIC ELECTRIC COMPANY

R. L. Berry  
Assistant to Vice President-Operations

RLB/gbc

Enclosure

cc: Region I  
Resident Inspector - YNPS

9011260071 901031  
PDR ADCK 05000029  
R FDC

*LEDA*  
*11*

YANKEE ATOMIC NUCLEAR POWER STATION  
MONTHLY STATISTICAL REPORT 90-10  
FOR THE MONTH OF OCTOBER, 1990

OPERATING DATA REPORT

DOCKET NO. 60-29  
 DATE 901116  
 COMPLETED BY K. CARROLL  
 TELEPHONE (508) 779-6711

OPERATING STATUS

1. Unit Name: Yankee Rowe
2. Reporting Period: October, 1990
3. Licensed Thermal Power (MWt): 600
4. Nameplate Rating (Gross MWe): 185
5. Design Electrical Rating (Net MWe): 175
6. Maximum Dependable Capacity (Gross MWe): 180
7. Maximum Dependable Capacity (Net MWe): 167
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level To Which Restricted. If Any (Net MWe):

10. Reasons For Restrictions. If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	745.00	7,295.00	---
12. Number of Hours Reactor Was Critical	0.00	4,150.70	210,896.97
13. Reactor Reserve Shutdown Hours	0.00	0.00	0.00
14. Hours Generator On-Line	0.00	4,156.80	205,645.51
15. Unit Reserve Shutdown Hours	0.00	0.00	0.00
16. Gross Thermal Energy Generated (MWH)	0.00	2,347,067.00	112,641,009.92
17. Gross Electrical Energy Generated (MWH)	0.00	702,887.00	34,081,916.50
18. Net Electrical Energy Generated (MWH)	0.00	656,097.87	31,884,642.77
19. Unit Service Factor	0.00	56.98	78.28
20. Unit Availability Factor	0.00	56.98	78.28
21. Unit Capacity Factor (Using MDC Net)	0.00	63.86	74.32
22. Unit Capacity Factor (Using DER Net)	0.00	51.39	70.85
23. Unit Forced Outage Rate	NA	0.00	4.88
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):	Core 21 Refueling June 23, 1990, Twenty Weeks.		

25. If Shutdown At End of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION		

INITIAL CRITICALITY  
 INITIAL ELECTRICITY  
 COMMERCIAL OPERATION

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 60-29  
 UNIT YANKEE ROWE  
 DAT 001116  
 COMPLETED BY K. CARROLL  
 TELEPHONE (608) 779-6711

MONTH October, 1990

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	0.0	17	0.0
2	0.0	18	0.0
3	0.0	19	0.0
4	0.0	20	0.0
5	0.0	21	0.0
6	0.0	22	0.0
7	0.0	23	0.0
8	0.0	24	0.0
9	0.0	25	0.0
10	0.0	26	0.0
11	0.0	27	0.0
12	0.0	28	0.0
13	0.0	29	0.0
14	0.0	30	0.0
15	0.0	31	0.0
16	0.0		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH October, 1990

DOCKET NO. 50-29  
 UNIT YANKEE ROWE  
 DATE 901116  
 COMPLETED BY K. CARROLL  
 TELEPHONE (508) 779-6711

No.	Date	1 Type	Duration (Hours)	2 Reason	Method Of Shutting Down Reactor	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
90-04	06/23/90	S	745.00	C	1	N/A	N/A	N/A	Core 21 Refueling outage extended to repair an instrument spire and an unlatched control rod.

- |   |   |  |  |
|---|---|--|--|
| <p>1<br/>F: Forced<br/>S: Scheduled</p> | <p>2<br/>Reason:<br/>A-Equipment Failure (Explain)<br/>B-Maintenance or Test<br/>C-Refueling<br/>D-Regulatory Restriction<br/>E-Operator Training &amp; Licensed Examination<br/>F-Administrative<br/>G-Operational Error (Explain)<br/>H-Other (Explain)</p> | <p>3<br/>Method:<br/>1-Manual<br/>2-Manual Scram.<br/>3-Automatic Scram.<br/>4-Other (Explain)</p> | <p>4<br/>Exhibit G-Instructions for Preparation of Data Entry Sheets for License Event Report (LER) File (NUREG-0161)</p> <p>5<br/>Exhibit I - Same Source</p> |
|---|---|--|--|

DOCKET NO. 60-29  
UNIT YANKEE ROWE  
DATE 901116  
COMPLETED BY K. CARROLL  
TELEPHONE (508) 779-6711

REPORT MONTH October, 1990

SUMMARY OF OPERATING EXPERIENCES

-----  
Core 21 refueling outage extended for repairs to an instrument spire  
and to an unlatched control rod.