



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

DOCKET NO. 50-369

McGUIRE NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 115
License No. NPF-9

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility) Facility Operating License No. NPF-9 filed by the Duke Power Company (the licensee) dated August 30, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-9 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 115, are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: November 15, 1990



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUKE POWER COMPANY
DOCKET NO. 50-370
McGUIRE NUCLEAR STATION, UNIT 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 97
License No. NPF-17

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 2 (the facility) Facility Operating License No. NPF-17 filed by the Duke Power Company (the licensee) dated August 30, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-17 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 97, are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: November 15, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 115

FACILITY OPERATING LICENSE NO. NPF-9

DOCKET NO. 50-369

AND

TO LICENSE AMENDMENT NO. 97

FACILITY OPERATING LICENSE NO. NPF-17

DOCKET NO. 50-370


Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Remove Pages

3/4 4-31
3/4 4-32
3/4 4-33
3/4 4-34
3/4 4-35

Insert Pages

3/4 4-31
3/4 4-32
3/4 4-33
3/4 4-34
3/4 4-35




CURVE APPLICABLE FOR HEATUP RATES UP TO 99°F/MR FOR THE SERVICE PERIOD UP TO 10 EFPY. CONTAINS MARGINS OF 10°F AND 50 PSIG FOR POSSIBLE INSTRUMENT ERRORS.

MATERIAL BASIS
 CONTROLLING MATERIAL—LONGITUDINAL
 COPPER CONTENT: 0.21 WIS WELD
 RT NDT INITIAL: -50°F
 RT NDT AFTER 10 EFPY: 1/4T, 108.6°F
 3/4T, 113°F

FIGURE 3.4-2

McGUIRE UNIT 1 REACTOR COOLANT SYSTEM HEATUP LIMITATIONS
 NRC RG 1.99 REV 2
 APPLICABLE FOR THE FIRST 10 EFPY




CURVES APPLICABLE FOR HEATUP RATES UP TO 60°F/HR FOR THE SERVICE PERIOD UP TO 10 EFPY. CONTAINS MARGINS OF 10°F AND 60 PSIG FOR POSSIBLE INSTRUMENT ERROR.

MATERIAL BASIS
 CONTROLLING MATERIAL: LOWER SHELL
 COPPER CONTENT: 0.15wt%
 RT_{NDT} INITIAL: -30°F
 RT_{NDT} AFTER 10 EFPY: 1/4T, 90°F
 3/4T, 91°F

FIGURE 3.4.3


McGUIRE UNIT 2 REACTOR COOLANT SYSTEM HEATUP LIMITATIONS
 NRC RG 1.88 REV 2
 APPLICABLE FOR THE FIRST 10 EFPY
 Amendment No. 115 (Unit 1)
 Amendment No. 97 (Unit 2)



CURVE APPLICABLE FOR COOLDOWN RATES UP TO 100 °F/HR FOR THE SERVICE PERIOD UP TO 10 EFPY. CONTAINS MARGINS OF 10 °F AND 66 PSIG FOR POSSIBLE INSTRUMENT ERROR.

MATERIAL BASIS
 CONTROLLING MATERIAL - LONGITUDINAL
 COPPER CONTENT: 0.21 Wt% WELD
 RT NDT INITIAL: -50 °F
 RT NDT AFTER 10 EFPY: 1/4T, 165.5 °F
 3/4T, 113 °F

FIGURE 3.4-4 MCGUIRE UNIT 1, REACTOR COOLANT SYSTEM, COOLDOWN LIMITATIONS NRC RG 1.90 REV 2 APPLICABLE FOR THE FIRST 10 EFPY



CURVES APPLICABLE FOR COOLDOWN RATES UP TO 100°F/HR FOR THE SERVICE PERIOD UP TO 10 EFPY AND CONTAINS MARGINS OF 10°F AND 60 PSIG FOR POSSIBLE INSTRUMENT ERRORS.

MATERIAL BASIS
CONTROLLING MATERIAL - LOWER SHELL
COPPER CONTENT: 0.10 Wt%
RTNDY INITIAL: - 90°F
RTNDY AFTER 10 EFPY: 1/4T, 90°F
3/4T, 81°F

FIGURE 3.4-5 MCGUIRE UNIT 2, REACTOR COOLANT SYSTEM, COOLDOWN LIMITATIONS
NRC RG 1.60 REV 2
APPLICABLE FOR THE FIRST 10 EFPY

MCGUIRE - UNITS 1 and 2
3/4 4-35

TABLE 4.4-5

REACTOR VESSEL MATERIAL SURVEILLANCE PROGRAM - WITHDRAWAL SCHEDULE

CAPSULE NUMBER	VESSEL LOCATION	LEAD FACTOR		WITHDRAWAL TIME (EFPY)*	
		UNIT 1	UNIT 2	UNIT 1	UNIT 2
1. U	56°	4.76	5.28	Removed	6
2. V	58.5°	4.06	4.62	8	Removed
3. W	124°	4.76	5.28	Standby	10
4. X	236°	4.76	5.28	Removed	Removed
5. Y	238.5°	4.06	4.67	15	Standby
6. Z	304°	4.76	5.28	Standby	Standby

Amendment No. 115 (Unit 1)
Amendment No. 97 (Unit 2)

*Withdrawal time may be modified to coincide with those refueling outages or plant shutdowns most closely approaching the withdrawal schedule.