LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M D C C N 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 1 8 (7) | 1 1 2 6 7 8 (8) | 1 2 0 7 7 8 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During performance of monthly surveillance testing CEA #3 dropped to
03 the bottom of the core at 0049. Power was reduced to 70% in accordance
04 with T.S. 3.3.3.1 until CEA 3 was restored to its group position at
05 0158. LER 78-22 (U-2) and 78-48 (U-1) describe similar events.
06
07
08

09 SYSTEM CODE R B (11) | CAUSE CODE E (12) | CAUSE SUBCODE A (13) | COMPONENT CODE C R D R V E (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 8 | — | SEQUENTIAL REPORT NO. 0 4 3 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN Z (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT B (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 1 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER P 3 1 4 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Since CEA #3 was immediately returned to service, no further mainten-
11 ance action was deemed necessary. The dropped rod is assumed to be
12 the result of a spike in the 15 volt power supply. A design modifica-
13 tion (FCR 78-72) is under review to improve the reliability of the
14 system.

15 FACILITY STATUS E (28) | % POWER 1 0 0 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Surveillance Test

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

17 PERSONNEL EXPOSURES: NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

18 PERSONNEL INJURIES: NUMBER 0 0 0 (40) | DESCRIPTION (41) N/A

19 LOSS OF OR DAMAGE TO FACILITY: TYPE Z (42) | DESCRIPTION (43) N/A

20 PUBLICITY: ISSUED Z (44) | DESCRIPTION (45) N/A | NRC USE ONLY

NAME OF PREPARER J. T. Carroll/M. J. Miernicki PHONE: 301 234-7943/7960

7812130187