

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M | D | C | C | N | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 30 37 40 47 54 57 58
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T

0 1 | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 1 | 7 | 7 | 1 | 1 | 1 | 3 | 7 | 8 | 8 | 1 | 2 | 0 | 7 | 7 | 8 | 9
60 61 68 69 74 75 80
 REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operation the containment particulate radioactivity monitor
 0 3 | failed low at 1110. Corrective action was initiated immediately and the
 0 4 | monitor was returned to service at 1135. Both the containment sump level
 0 5 | alarm system and containment atmosphere gaseous activity monitor remained
 0 6 | operable throughout this event. This is not a repetitive event.
 0 7 | _____
 7 8 9

0 9 | B | B | 11 | A | 12 | C | 13 | I | N | S | T | R | U | 14 | E | 15 | Z | 16 |
9 10 11 12 13 18 19 20
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
 17 | 7 | 8 | - | 0 | 5 | 3 | / | 0 | 3 | L | - | 0 |
21 22 23 24 26 27 28 29 30 31 32
 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
 18 | X | 19 | H | 20 | Z | 21 | Z | 22 | 0 | 9 | 9 | 9 | 23 | N | 24 | N | 25 | A | 26 | W | 1 | 2 | 0 | 26 |
33 34 35 36 37 40 41 42 43 44 47
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Signal cable to monitor was discovered disconnected with no apparent cause.
 1 1 | Cable was connected and monitor returned to service. Possible cause was
 1 2 | that cable was not connected properly when maintenance was last performed
 1 3 | on monitor. Appropriate maintenance personnel were instructed to ensure
 1 4 | cable connectors lock when connecting cables on this equipment.
 7 8 9

1 5 | E | 28 | 0 | 8 | 0 | 29 | N/A | 30 | A | 31 | Operator Observation | 32
7 8 9 10 12 13 44 45 46
 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 | Z | 33 | Z | 34 | N/A | 35 | N/A | 36 |
7 8 9 10 11 44 45
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 | 0 | 0 | 0 | 37 | Z | 38 | N/A | 39
7 8 9 11 12 13
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 | 0 | 0 | 0 | 40 | N/A | 41
7 8 9 11 12
 PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 | Z | 42 | N/A | 43
7 8 9 10 12
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

2 0 | Z | 44 | N/A | 45
7 8 9 10
 PUBLICITY ISSUED DESCRIPTION

NAME OF PREPARER J. T. Carroll/M. J. Miernicki

PHONE: 301 234-7943/7960

7812130194