NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M N P I N 2 (2) LICENSEE CODE | 0 0 - 0 0 0 0 0 - 0 0 (3) LICENSE NUMBER | 4 1 1 1 1 (4) LICENSE TYPE | CAT (5)

CON'T 0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 0 6 (7) DOCKET NUMBER | 1 1 2 8 7 8 (8) EVENT DATE | 1 2 1 2 7 8 (9) REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During refueling, local leak rate testing revealed leakage in excess of Tech Spec

0 3 limits through valves in penetrations #25A, Containment Purge Exhaust, and #25B,

0 4 Containment Purge Supply. Repetitive. Update Report will be submitted.

0 5

0 6

0 7

0 8

0 9 SYSTEM CODE: S D (11) | CAUSE CODE: E (12) | CAUSE SUBCODE: X (13) | COMPONENT CODE: V A L V E X (14) | COMP. SUBCODE: E (15) | VALVE SUBCODE: D (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 8 | — | SEQUENTIAL REPORT NO. 0 2 1 | / | OCCURRENCE CODE 0 1 | REPORT TYPE T | — | REVISION NO. 0

ACTION TAKEN: E (18) | FUTURE ACTION: (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 0 | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB.: Y (24) | PRIME COMP. SUPPLIER: A (25) | COMPONENT MANUFACTURER: P 3 4 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Cause description and corrective actions will be given in the Update Report.

1 1

1 2

1 3

1 4

1 5 FACILITY STATUS: H (28) | % POWER: 0 0 0 (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: B (31) | DISCOVERY DESCRIPTION (32): Local Leakage Rate Test

1 6 ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES

1 7 NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

PERSONNEL INJURIES

1 8 NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

LOSS OF OR DAMAGE TO FACILITY (43)

1 9 TYPE: Z (42) | DESCRIPTION: NA

PUBLICITY

2 0 ISSUED: N (44) | DESCRIPTION (45): NA

7812140161

NRC USE ONLY

NAME OF PREPARER: A A Hunstad

PHONE: 612-388-4767

GPO 917-926