

SEISMIC AND STRUCTURAL ANALYSIS  
FOR THE  
LACBWR CONTAINMENT BUILDING

Prepared For

**CONTROLLED COPY**  
**VALID ONLY IF THIS STAMP IS RED**

Project Application 5101	Prepared By N. Cao	<u>Chuhan</u>	Date 7/27/82
APPROVALS			
TITLE/DEPT.	SIGNATURE	DATE	
Manager, Structural Engineering General Manager, General Engineering Svcs.	E.W.Martzen theatrical C.L.Foxhan	7/27/82 7/28/82	
Project Engineer Vice President, Engineering Service Operations	J.Williams Jr. W.J.Potent	7/28/82 7/28/82	
Quality Assurance Mgr.		7/28/82	



## REVISION LOG

## NUCLEAR ENERGY SERVICES, INC.

DOCUMENT NO. 81A0049

PAGE 2 OF 36

## TABLE OF CONTENTS

	<u>PAGE</u>
1. Summary .....	5
2. Description of the Building .....	5
3. Applicable Codes, Standards & Specifications .....	6
4. Loads & Loading Combinations.....	7
5. Structural Acceptance Criteria .....	9
6. Analytical Procedures .....	10
6.1 Seismic Analysis .....	10
6.1.1 Mathematical Model .....	11
6.1.2 Foundation Spring Stiffness .....	12
6.1.3 Eigenvalue Analysis .....	12
6.1.4 Dynamic (Seismic) Load Analysis.....	12
7. Results of Analysis and Conclusions.....	29
8. References .....	35

Appendix A      Analysis Assumptions

Appendix B      Detailed Calculations.

## LIST OF TABLES

- 6.1 Foundation Spring Constants
- 6.2 Natural Frequencies of Vibration-LACBWR Containment Bldg.
- 7.1 Summary of Seismic/Structural Evaluation (Normal Stress)
- 7.2 Summary of Seismic/Structural Evaluation (Shear Stress)
- 7.3 Containment Shell Seismic/Structural Evaluation

## LIST OF FIGURES

- 4.1 LACBWR Site-specific Response Spectra
- 6.1d Mathematical Model of LACBWR Containment Building
  - 6.1.a Mathematical Model of Steel Containment
  - 6.1.b Mathematical Model of Outer Shield Building
  - 6.1.c Mathematical Model of Inner Shield Building and Reactor Vessel
- 6.2.a Effect of Variation of Soil Properties on Deflection Response  
(Containment Shell and Outer Shield)
- 6.2.b Effect of Variation of Soil Properties on Deflection Response  
(Inner Shield and Reactor Vessel)
- 6.2.c Effect of Variation of Soil Properties on Acceleration Response  
(Containment Shell and Outer Shield)
- 6.2.d Effect of Variation of Soil Properties on Acceleration Response  
(Inner Shield and Reactor Vessel)
- 6.2.e Effect of Variation of Soil Properties on Moment Response  
(Containment Shell)
- 6.2.f Effect of Variation of Soil Properties on Moment Response  
(Inner Shield)
- 6.2.g Effect of Variation of Soil Properties on Shear Response  
(Containment Shell and Outer Shield)
- 6.2.h Effect of Variation of Soil Properties on Shear Response  
(Inner Shield and Reactor Vessel)
- 6.3 Foundation Spring Stiffness

## 1. SUMMARY

This report, prepared for Dairyland Power Cooperative (DPC), presents the results of the seismic/structural analysis of the LACBWR containment building using the NRC site-specific ground response spectra for the Safe Shutdown Earthquake event (SSE).

Linear seismic analysis, using the site specific spectra and modal superposition methods, was performed to determine the response of the LACBWR containment building for the SSE event. Soil structure interaction effects were included using the information provided by Dames & Moore. The foundation springs reflect the updated information from the most recent boring program. The combination of deadload and seismic stress of the containment building is compared to the allowable stress. From the results of the analysis, it has been concluded that the containment building is capable of withstanding the specified Safe Shutdown Earthquake. Forces, moments and stresses in all structural elements of the building were determined. All member stresses were found to be less than their allowable values.

## 2. DESCRIPTION OF THE BUILDING

The Containment Building is a multiple story 30 feet radius structure. It consists of a basement floor (El. 621'), ground floor (El. 642.75'), intermediate floor (El. 667'), and main floor (El. 701.0'). In addition to those floors, an overhead crane is at (El. 726.5') and a water storage tank is located at the top of the building (El. 756.5'). The structure, with a total height of 135.5 ft. is supported by 228 concrete filled pipe piles with a design load capacity of 100k/pile.

For the purpose of analysis the Containment Building can be sub-divided into four component parts: the containment shell, the outer shield building, the inner shield building and the reactor vessel. All other dead and live loads are calculated and are lumped in the appropriate nodes of the model.

**The Containment Shell:** This is the outer steel shell and represents the pressure retaining component of the Containment Building.

It is made of ASTM A201, Grade B steel with a thickness of 1.16", a height of 144 feet and an inside radius of 30 feet. The hemispherical dome of the containment shell is constructed of 0.60 inch steel and contains an elliptical water storage tank with a capacity of 42,500 gallons.

**Outer Shield Building:** The containment shell is lined on the inside by the outer shield building which consists of 9" of reinforced concrete. This structure has a 30 foot radius, 105.5 foot height (from basement floor to crane level), and supports a crane with capacity of 50 Tons/5 Tons at El. 726.5'.

**Inner Shield Building:** The inner shield structure consists of an octagonal shaped reinforced concrete wall around the reactor. The inner and outer shield structures are connected to each other by reinforced concrete floors at four elevations.

**Reactor Vessel:** The reactor vessel generates steam for the turbine generator and is located inside the inner shield building core. It is made of ASTM A302 Grade B steel, with 4.125 feet inside radius, 4 inch thickness, and 37 feet height (from ground floor to El. 684.75 feet). The vessel is seated on a skirt support which is anchored to the inner shield building at the ground floor. Also at El. 680.77 feet, the vessel is supported by the inner shield building via an expansion joint (bellows). The Reactor Vessel is included in the mathematical model of the Containment Building to evaluate the effect of its mass on the other components.

### 3. APPLICABLE CODES, STANDARDS AND SPECIFICATIONS

The following codes of practice and regulatory guides were used in the analysis of the LACBWR Containment Building.

1. USNRC Regulatory Guide 1.92, "Combination of Modes and Spatial Components in Seismic Reponse Analysis", Revision 1, February, 1976.
2. USNRC Standard Review Plan Section 3.7.2.

3. USNRC Reg. Guide 1.61, "Damping Values For Seismic Design of Nuclear Power Plants", October, 1973.
4. Code Requirements for Nuclear Safety Related Concrete Structures (ACI 349-76), American Concrete Institute, Detroit, MI., 1978.
5. USNRC Standard Review Plan Section 3.8.2.
6. USNRC Standard Review Plan Section 3.8.3.
7. Building Code Requirements for Reinforced Concrete, (ACI 318-77), American Concrete Institute, Detroit, MI., 1977.
8. ASME Boiler and Pressure Vessel Code, Section VIII, DIV.2, Alternate Rules, 1977 Edition.

#### 4. LOADS AND LOADING COMBINATIONS

The lateral seismic inertia loading on the coupled model of the containment building and its foundation is in the form of the ground acceleration response spectrum (Figure 4.1) given in Reference 1. The free field ground response spectrum for the Safe Shutdown Earthquake for 5 percent structural damping was modified to the appropriate percent of combined damping (output of LANCZOS run) and used in the seismic analysis. (See USNRC Reg. Guide 1.61).

In addition to the seismic inertia loading, the dead loads and their resulting moments have also been included in the analysis. The following load combination equations from SRP 3.8.2 and 3.8.3 were used in evaluating the adequacy of the containment building to withstand a seismic event.

##### Containment Shell

1.  $D + L + E' + P_a$




FIGURE 4.1

LACBWR SITE-SPECIFIC RESPONSE SPECTRA

Reinforced Concrete Shield Structure2.  $D + L + E'$ 

Where:

 $D$  = Dead loads and their resulting moments $L$  = Live loads $E$  = Loads and moments generated by the Operating Basis Earthquake $E'$  = Loads and moments generated by the Safe Shutdown Earthquake $P_a$  = Pressure load generated by loss-of-coolant accident (LOCA)

For the reinforced concrete shield structure the load combination containing the OBE earthquake,  $1.4D + 1.7L + E$ , was determined not be critical compared to the combination containing the SSE earthquake. The load factors applied to the dead and live loads increase the axial compression in the concrete shield structure. When this compressive stress is combined with the OBE induced bending stress, the resulting concrete tension stress is less than the tension stress developed by the SSE earthquake load combination.

**5. STRUCTURAL ACCEPTANCE CRITERIA**

The following allowable limits constitute the structural acceptance criteria for each of the loading combinations presented in Section 4.

Containment Shell

Stresses in the containment shell shall meet the requirements of the ASME Boiler and Pressure Vessel Code, Section VIII, Div. 2., 1977 Edition.

<u>Stress Intensity</u>	<u>Limit</u>
$P_m$	$K S_m$
$P_m + P_b$	$1.5K S_m$

Where  $P_m$  = General Primary Membrane Stress

$P_b$  = Primary Bending Stress

$S_m$  = Design Stress Intensity

$K$  = Factors given in Table AD-150.0

Reinforced Concrete

<u>Load Combinations</u>	<u>Limit</u>
$D + L + E'$	$U$

Where  $U$  is required section strength based on the ultimate strength design method defined in the ACI. 318-77 code

## 6. ANALYTICAL PROCEDURES

### 6.1 SEISMIC ANALYSIS:

The seismic analysis of the Containment Building was performed using NRC site-specific ground response spectra. Damping values of 4% and 7% were used for steel and reinforced concrete respectively. (See NRC Reg Guide 1.61). The vertical response spectra was

taken as 2/3 of the horizontal response spectra for the whole range of frequency, as stated in Reference 9.

#### 6.1.1 Mathematical Model

In order to perform the seismic analysis, the containment building is mathematically modeled as an assembly of elastic structural elements interconnected at discrete nodal points. The three dimensional, multidegree of freedom model of the containment building is attached to the ground by means of foundation springs, representing the deformations of the soil under the containment building foundation. Lateral, as well as rocking springs, have been provided in the LACBWR Containment Building mathematical model (Figure 6.1) to account for the shear and vertical deformation of the soil under the LACBWR Containment Building foundation. To account for the variation in the soil properties and to evaluate the effect of the foundation spring constants on the seismic response of the Containment Building, the foundation springs were varied using information supplied by Dames and Moore. The frequencies found using this data are shown in Table 6.2. The effect of the variation on deflections, accelerations, moments and shears can be seen in Figure 6.2.a - 6.2.h .

The distributed mass of the Containment Building is lumped at the system nodal points. Each mass represents the tributary weight of the Containment Building walls above and below the nodal point. Masses are lumped so that the lumped mass, multidegree of freedom model represents the dynamic characteristics of the Containment Building. In order to reduce the number of dynamic degrees of freedom, only translational degrees-of-freedom are considered at each mass point. (The masses associated with the rotational degrees-of-freedom are set to zero).

#### 6.1.2 Foundation Spring Stiffness

The stiffness of the lateral and rocking springs representing the shear and vertical deformation of the soil beneath the foundation mat are obtained using the equations shown in Table 6.1 and Figure 6.3. These equations are taken from Reference 4.

#### 6.1.3 Eigenvalue Analysis

The eigenvalues (natural frequencies) and the eigenvectors (mode shapes) for each of the natural modes of vibration are calculated by solving the following frequency equation:

$$(K - \omega_n^2 M) \{ \phi_n \} = \{ 0 \} \quad (1)$$

Where:

$\omega_n$  = Natural angular frequency for the  $n^{th}$  mode

M = System mass matrix

$\phi_n$  = Mode shape vector for the  $n^{th}$  mode

0 = Null vector

The eigenvalue/eigenvector extraction was performed using the Lanczos Modal Extraction Method.

#### 6.1.4 Dynamic (Seismic) Load Analysis

Considering only translational degrees of freedom and assuming viscous (velocity proportional) form of damping, the equation of motion in matrix form can be expressed as follows:

$$M(\ddot{U}_t + \ddot{U}_{gt}) + C\dot{U}_t + KU_t = 0 \quad (2)$$

Where:

$\ddot{U}_t$  = Relative acceleration time history vector

$\ddot{U}_{gt}$  = Ground acceleration time history vector

$C$  = Damping matrix

$\dot{U}_t$  = Relative velocity time history vector

$U_t$  = Relative displacement time history vector

Rearranging equation (2):

$$MU_t + C\dot{U}_t + KU_t = -M\ddot{U}_{gt} = P_{eff} \quad (3)$$

To uncouple equation (3), assume:

$$U = \phi Y_t$$

Where:

$\phi$  = Characteristic free vibration mode shapes matrix

$Y_t$  = Generalized coordinate displacement time history vector

Pre- and post- multiplying equation (3) by the transpose of  $\phi$  and  $\phi$  respectively and using orthogonality conditions, the following uncoupled equations of motion are obtained:

$$\ddot{Y}_{nt} + 2 \omega_n \lambda_n \dot{Y}_{nt} + \omega_n^2 Y_{nt} = M_n^{*-1} R_n \ddot{U}_{gt} \quad (4)$$

Where:

$Y_{nt}$  = Generalized displacement coordinate time history  
for  $n^{\text{th}}$  mode.

$\lambda_n$  = Damping ratio for the  $n^{\text{th}}$  mode expressed as percent of  
critical damping.

$M_n^*$  = Generalized mass for the  $n^{\text{th}}$  mode

$$= \phi_n^T M \phi_n = \sum M_i \phi_{in}^2$$

The mode shape  $\phi_n$  is normalized such that  $M_n^* = 1$

$R_n$  = Participation factor for the  $n^{\text{th}}$  mode.

$$= \phi_n^T M I = \sum M_i \phi_{in}$$

I = Column vector whose elements are generally unity

The solution for the differential equation (4) is given by the Duhamel Integral:

$$Y_{nt} = \frac{R_n}{M_n^* \omega_n} \int_0^t \ddot{U}_{gt} e^{-\lambda_n \omega_n (t-\tau)} \sin \omega_n (t-\tau) d\tau$$

Using the response spectrum method of analysis, the maximum values of the generalized response for each mode is given by:

$$\ddot{Y}_{n \text{ max}} = \frac{R_n S_{an}}{M_n^*} \quad (5)$$




FIGURE 6.1a  
MATHEMATICAL MODEL OF STEEL CONTAINMENT




FIGURE 6.1b  
MATHEMATICAL MODEL OF OUTER SHIELD BUILDING




FIGURE 6.1c  
MATHEMATICAL MODEL OF INNER SHIELD BUILDING  
AND REACTOR VESSEL




FIGURE 6.1d - MATHEMATICAL MODEL OF LACBWR CONTAINMENT BUILDING




FIGURE 6.2a - EFFECT OF VARIATION OF SOIL PROPERTIES  
ON DEFLECTION RESPONSE

(Containment Shell & Outer Shield Bldg.)




FIGURE 6.2b - EFFECT OF VARIATION OF SOIL PROPERTIES ON DEFLECTION RESPONSE

(Inner Shield Bldg. & Reactor Vessel)




FIGURE 6.2c - EFFECT ON VARIATION OF SOIL PROPERTIES ON ACCELERATION RESPONSE

(Containment Shell & Outer Shield Bldg.)




FIGURE 6.2d - EFFECT OF VARIATION OF SOIL PROPERTIES  
ON ACCELERATION RESPONSE

(Inner Shield Bldg. & Reactor Vessel)




FIGURE 6.2e - EFFECT OF VARIATION OF SOIL PROPERTIES ON MOMENT RESPONSE (Containment Shell)




FIGURE 6.2f - EFFECT OF VARIATION OF SOIL PROPERTIES  
ON MOMENT RESPONSE  
(Inner Shield Bldg.)




FIGURE 6.2g - EFFECT OF VARIATION OF SOIL PROPERTIES  
ON SHEAR RESPONSE  
(Containment Shell & Outer Shield Bldg.)




FIGURE 6.2h - EFFECT OF VARIATION OF SOIL PROPERTIES  
ON SHEAR RESPONSE


(Inner Shield & Reactor Vessel)

TABLE 6.1  
FOUNDATION SPRING CONSTANTS

Spring Constants for Rigid Rectangular Footing  
Resting on Elastic Half-Space

Motion	Spring Constant	Reference
Vertical	$k_z = \frac{G}{1-\nu} \beta_z \sqrt{4cd}$	Barkan (1962)
Horizontal	$k_x = 4(1+\nu)G\beta_x \sqrt{cd}$	Barkan (1962)
Rocking	$k_\psi = \frac{G}{1-\nu} \beta_\psi 8cd^2$	Gorbunov-Possadov (1961)

(Note: values for  $\beta_z$ ,  $\beta_x$ , and  $\beta_\psi$  are given in Fig. 6.3 for various values of  $d/c$ )



Coefficients  $\beta_z$ ,  $\beta_x$ , and  $\beta_\psi$  for rectangular footings (after Whitman and Richart, 1967).

FIGURE 6.3 - FOUNDATION SPRING STIFFNESS

TABLE 6.2

## NATURAL FREQUENCIES OF VIBRATION - LACBWR CONTAINMENT BLDG.

Model 1

G=1600ksf (softer)

Model 2

G=3600ksf (stiffened)

Mode No.	Frequency (Hz)	Modal Direction	Frequency (Hz)	Modal Direction
1	1.550	X <sub>2</sub>	2.244	X <sub>2</sub>
2	1.552	X <sub>1</sub>	2.253	X <sub>1</sub>
3	4.085	X <sub>3</sub>	6.033	X <sub>3</sub>
4	6.290	X <sub>2</sub>	6.507	X <sub>2</sub>
5	6.327	X <sub>1</sub>	6.552	X <sub>1</sub>
6	8.379	X <sub>2</sub>	11.591	X <sub>2</sub>
7	8.494	X <sub>1</sub>	11.807	X <sub>1</sub>
8	16.467	X <sub>1</sub>	16.540	X <sub>1</sub>
9	21.434	X <sub>2</sub>	21.601	X <sub>2</sub>
10	23.693	X <sub>2</sub>	23.849	X <sub>3</sub>
11	23.814	X <sub>3</sub>	24.295	X <sub>2</sub>
12	24.528	X <sub>1</sub>	24.577	X <sub>1</sub>
13	24.812	X <sub>2</sub>	25.991	X <sub>2</sub>
14	28.774	X <sub>1</sub>	28.849	X <sub>1</sub>
15	32.410	X <sub>1</sub>	32.431	X <sub>1</sub>

Where:

$\ddot{Y}_{n \max}$  = Maximum generalized coordinate acceleration response for the  $n^{\text{th}}$  mode.

$S_{an}$  = Spectral acceleration value for the  $n^{\text{th}}$  mode (from the applicable response spectrum curve)

From the maximum generalized coordinate response the maximum acceleration ( $\ddot{U}_{n \max}$ ) and maximum inertia forces ( $F_{n \max}$ ) at each mass point are given by:

$$\ddot{U}_{n \max} = \ddot{Y}_{n \max} \phi_{in}$$

$$F_{n \max} = M_n \ddot{U}_{n \max}$$

The inertia forces ( $F_{n \max}$ ) for each of the systems' natural modes were applied as external static forces, and system response (displacements, member internal forces and stresses) were calculated. Total system response was then obtained by combining the individual modal response values by the square root of the sum of the squares method; lower modes having large contribution to the response (all modes having natural frequency under 35 cycles per second) were included and higher modes with negligible participation were neglected.

## 7. RESULTS OF ANALYSIS AND CONCLUSIONS

The results of the seismic analysis of the LACBWR Containment building performed with the STARDYNE computer code are contained in Reference 5. Appendix A contains the assumptions used in the analysis. Detailed calculations are included in Appendix B.

The natural frequencies of vibration of the LACBWR containment building are given in Table 6.2. From this table, it can be seen that the containment building is a low frequency system (fundamental frequency of 1.550 Hz and 2.244 Hz in accordance with soil constant  $G=1600\text{Ksf}$  and  $G=3600\text{Ksf}$ ), and the variation in the fundamental

Frequencies is 45% (1.550 HZ to 2.244 Hz) as compared to the 125% variation in the foundation soil constants (1600 ksi to 3600 ksi). Through Figure 6.2c to Figure 6.2h, we can see that acceleration induced, moment induced, shear induced are greater for stiffened foundation soil constant ( $G = 3600$  ksi). Hence the results for the analysis for softer foundation soil constant ( $G = 1600$  ksi) are not reported since the analysis of normal foundation soil constant ( $G = 2400$  ksi) and stiffened foundation soil constant ( $G=3600$  ksi) are more conservative. The results of the seismic and structural analysis, which are taken as the more conservative results of either the normal or stiffened cases, are summarized in Table 7.1 thru Table 7.3 and discussed below.

Steel Containment Shell:

The maximum shear, compressive and tensile bending stresses in the steel containment shell are significantly lower than the allowable values. The maximum hoop and longitudinal tensile stresses in the containment shell resulting from LOCA event (52 psi, maximum internal pressure) are 16.1 ksi and 15.6 ksi respectively.

Concrete Outer Shield Building:

The maximum shear and compressive stresses in the outer shield building and the maximum tensile stresses in the reinforcing bar are within the allowable values.

Concrete Inner Shield Building:

The maximum shear and compressive stresses in the inner shield building and the maximum tensile stresses in the reinforcing bar are within the allowable values.

Foundation Mat:

The maximum shear and compressive stress in the foundation mat are lower than the allowable values. There is no reinforcement in the foundation mat to carry any tensile load, however, the foundation mat will not rupture because the modulus of rupture for the concrete (0.377 ksi) is much greater than the maximum tensile stress (.00360 ksi)

Pile Foundation:

The maximum compressive load on a pile is 191.55k, greater than its rated capacity of 100k and lower than the ultimate load capacity of 400k Ref. (10). The maximum tensile load on a pile is 41.75k. No pull out load tests have been performed, however, the skin frictional resistance load of 74.8k calculated from pile driving data, is more than adequate to resist the calculated pull out force.

TABLE 7.1

## SUMMARY OF SEISMIC/STRUCTURAL EVALUATION (NORMAL STRESS)

Node	Component	Elevation	Allowable normal stress		Calculated normal stress	
			Tension	Compression	Tension	Compression
35 (For 36 thru 45 & 35)	Outer Shield Bldg.	621.0'	.230 ksi	2.975 ksi	0.069 ksi	.369 ksi
47	Inner Shield Bldg.	690.875'	-	2.975 ksi	-	.038 ksi
49	Inner Shield Bldg.	667'	.0515 ksi	2.975 ksi	.030 ksi	.144 ksi
51	Inner Shield Bldg.	642.75'	.118 ksi	2.975 ksi	.054 ksi	.223 ksi
66	Inner Shield Bldg.	621.0'	.118	2.975 ksi	.076 ksi	.430 ksi
54	Pile	Under 621.0'	*	*	41.75k/pile	191.55k/pile

\* See Pile Foundation Section.

TABLE 7.2

## SUMMARY OF SEISMIC/STRUCTURAL EVALUATION (SHEAR STRESS).

<u>Node</u>	<u>Component</u>	<u>Elevation</u>	<u>Allowable Shear Stress (ksi)</u>	<u>Calculated Shear Stress (ksi)</u>
35 (For 36 thru 45 & 35)	Outer Shield Bldg.	621.0'	.118 ksi	.042 ksi
66 (For 46 thru 53 & 66)	Inner Shield Bldg.	621.0'	.100 ksi	.044 ksi

TABLE 7.3  
**Containment Shell Seismic/Structural Evaluation**  
At Node 35 (For 1 thru 35) Elevation 621.0'

<u>Load Combination</u>	<u>P<sub>m</sub></u>	<u>Limit</u>	<u>P<sub>b</sub></u>	<u>P<sub>m</sub> + P<sub>b</sub></u>	<u>Limit</u>
D + L + P <sub>a</sub>	16.828 ksi	(1.0)(18.9)= 18.9 ksi	0	16.828	(1.5)(1.0)(18.9)= 28.35 ksi
D + L + P <sub>a</sub> + E'	16.828 ksi	18.9 ksi	2.602	19.43	28.35 ksi

K=1.0 for both load combinations

Plate material A515, A516

S<sub>m</sub>=18.9 ksi @ 300°F for A515, Grade 60

## 8. REFERENCES

1. NRC Letter to Dairyland Power Cooperative, Docket No. 50-409 (August 4, 1980)
2. Dames & Moore: Liquefaction Potential under Genoa -3 Stack Adjacent to LaCrosse Boiling Water Reactor, Genoa, Wisconsin (October, 1980)
3. LACBWR Containment Building Drawings, Sargent & Lundy, LACBWR Containment Building Drawing Nos. 41-503430 thru 41-503477
4. Richart, F. E., Hall, Jr., and Woods, Rd. Vibrations of Soils and Foundations, Prentice-Hall, Inc., Englewood Cliffs, N.J. (1970)
5. LACBWR Containment Building, Stardyne Structural Analysis Project 5101, Task 247, NES Computer Output Binder S67.
6. Chu kia Wang, Charles G. Salmon: Reinforced Concrete Design, Thomas Y. Crowell Company, Harper & Row Publishers, Third Edition • 1979.
7. ASME Boiler and Pressure Vessel Code, Division I - Appendixes, 1980 Edition
8. ASCE, "Journal of the Geotechnical Engineering" Volume 102 No. GT3 March 1976
9. NUREG/CR-0098 N.M. Newmark, W.J. Hall, "Development of Criteria for Seismic Review of Selected Nuclear Power Plants", May 1978.
10. Specification A-4109, "Foundation Piles, LaCross Boiling Water Reactor Project Dairyland Power Cooperative Association", Sargent and Lundy Engineers, Chicago, IL, January 1975.

## APENDIX A

## Containment Building Analysis

## Assumptions:

1. The assumptions used for ultimate strength design and compatibility of strains are the same as those given in ACI Building Code (318-77).
2. Maximum steel stress at ultimate capacity is assumed as "fy".
3. Compressive reinforcement is not considered.
4. Inner shield building and reactor vessel are eccentric with Outer Shield building by their calculated centroid.



NUCLEAR ENERGY SERVICES, INC.

DOCUMENT NO. \_\_\_\_\_

PAGE B-1 OF 258

APPENDIX B

DETAILED  
CALCULATIONS

TABLE OF CONTENTS FOR APPENDIX B

	<u>PAGE</u>
Mathematical Model	B-3
Containment Shell and Water Tank	B-7
Outer Shield Building	B-25
Inner Shield Building	B-36
Reactor Vessel	B-159
Foundation	B-170
Site Specific Spectra	B-172
Response Spectra	B-175
Analysis and Results	B-181
General	B-182
Containment Shell	B-196
Outer Shield Building	B-202
Inner Shield Building	B-206
Reactor Vessel	B-223
Piles and Foundation	B-235



NUCLEAR ENERGY SERVICES

BY R.R. DATE 6/27/81 PROJ. 5101 TASK 026  
CHKD. NC DATE 1/29/82 PAGE 1 OF 1  
LACBWR CONTAINMENT BLDG.

Page B-3 of 258

## INTRODUCTION

REF.


THE CONTAINMENT BUILDING ANALYSIS WAS ACCOMPLISHED THROUGH THE USE OF A 66 NODE FINITE ELEMENT LUMPED MASS MODEL. THE BUILDING WAS BROKE UP INTO FIVE MAJOR PARTS: THE CONTAINMENT SHELL, THE OUTER SHIELD BLDG, THE INNER SHIELD BUILDING, REACTOR VESSEL; AND THE FOUNDATION.

THE CONTAINMENT SHELL WAS MODELED USING 34 MASSES. PROPERTIES AND WEIGHTS WERE CALCULATED IN SECTION 2 OF THIS NOTEBOOK. THE OUTER SHIELD BUILDING WAS MODELED USING 11 NODES. PROPERTIES AND WEIGHTS WERE CALCULATED AND PRESENTED IN SECTION 3 OF THIS NOTEBOOK. THE INNER SHIELD BUILDING WAS MODELED USING 9 NODES. PROPERTIES AND WEIGHTS WERE CALCULATED AND PRESENTED IN SECTION 4 OF THIS NOTEBOOK. THE REACTOR VESSEL ITSELF WAS MODELED USING 11 NODES. PROPERTIES AND WEIGHTS WERE CALCULATED AND ARE PRESENTED IN SECTION 5 OF THIS NOTEBOOK. FOUNDATION WEIGHTS AND SOIL SPRING STIFFNESS WERE CALCULATED AND PRESENTED IN SECTION 6 OF THIS NOTEBOOK.

**1125**

NUCLEAR ENERGY SERVICES

BY R.R. DATE 6-23-81 PROJ. 5101 TASK 026  
CHKD. NC DATE 1/29/92 PAGE OF  
LACBWR CONTAINMENT BLDG.  
page B-4 of 258



3-D MODEL USED IN DYNAMIC ANALYSIS

## CONTAINMENT BUILDING - BEAM PROPERTIES TABLE

REF.

PROPERTY N°	$H_2$ (in)	$H_3$ (in)	$A$ (in <sup>2</sup> )	$J$ (in <sup>4</sup> )	$I_2$ (in <sup>4</sup> )	$I_3$ (in <sup>4</sup> )	CTORS	SF2	SF3	SF2	SF3
1	227.84 ✓	227.84 ✓	428.33 ✓	.0573E8 ✓	.0277E8 ✓	.0277E8 ✓	113.92 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
2	317.01 ✓	317.01 ✓	586.43 ✓	.1493E8 ✓	.0744E8 ✓	.0744E8 ✓	158.51 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
3	436.38 ✓	436.38 ✓	821.43 ✓	.39E8 ✓	.195E8 ✓	.195E8 ✓	218.19 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
4	408.49 ✓	408.49 ✓	768.86 ✓	.3198E8 ✓	.1599E8 ✓	.1599E8 ✓	204.25 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
5	323.19 ✓	323.19 ✓	608.07 ✓	.1562E8 ✓	.0791E8 ✓	.0791E8 ✓	161.6 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
6	240. ✓	240. ✓	451.25 ✓	.0647E8 ✓	.0323E8 ✓	.0323E8 ✓	120. ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
7	517.52 ✓	517.52 ✓	173.87 ✓	.65E8 ✓	.325E8 ✓	.325E8 ✓	258.76 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
8	578.26 ✓	578.28 ✓	1068.9 ✓	.9084E8 ✓	.4542E8 ✓	.4542E8 ✓	289.14 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
9	625.29 ✓	625.29 ✓	1177.52 ✓	1.1488E8 ✓	.5744E8 ✓	.5744E8 ✓	312.65 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
10	668.45 ✓	668.45 ✓	1259.81 ✓	1.4068E8 ✓	.7034E8 ✓	.7034E8 ✓	374.48 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
11	698.46 ✓	698.46 ✓	1315.44 ✓	1.6016E8 ✓	.8008E8 ✓	.8008E8 ✓	349.23 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
12	715.58 ✓	715.58 ✓	1347.71 ✓	1.7224E8 ✓	.8612E8 ✓	.8612E8 ✓	357.79 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
13	722.32 ✓	722.32 ✓	1355.66 ✓	1.753E8 ✓	.8765E8 ✓	.8765E8 ✓	361.16 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
14	722.32 ✓	722.32 ✓	2627.63 ✓	3.4164E8 ✓	1.7082E8 ✓	1.7082E8 ✓	361.16 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
15	722.32 ✓	722.32 ✓	2467.26 ✓	3.1925E8 ✓	1.4976E8 ✓	1.4976E8 ✓	361.16 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
16	718.1 ✓	718.1 ✓	2627.63 ✓	3.416E8 ✓	1.708E8 ✓	1.708E8 ✓	359.05 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
17	705.42 ✓	705.42 ✓	2562.08 ✓	3.1768E8 ✓	1.5884E8 ✓	1.5884E8 ✓	352.71 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
18	720 ✓	720 ✓	20075 ✓	25.033E8 ✓	12.6517E8 ✓	12.6517E8 ✓	360 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
19	720 ✓	720 ✓	18852 ✓	25.266E8 ✓	12.633E8 ✓	12.633E8 ✓	360 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
20	552 ✓	301.7 ✓	73028 ✓	5.1768E8 ✓	5.3114E8 ✓	5.3114E8 ✓	150 ✓	.517 ✓	.706 ✓	✓	✓

Ref: 100B Rule Net book Calculation

CONTAINMENT BUILDING - COMPUTER DATA

Page B-5 of 258

REF. BY UC DATE 2/2/92 PROJ. 5101 TASK 026  
CHKD. JC DATE 3/23/82 PAGE 0F

NUCLEAR ENERGY SERVICES



## CONTAINMENT BUILDING - BEAM PROPERTIES TABLE (CONTINUE)

PROPERTY N <sup>o</sup>	H <sub>2</sub> (in)	H <sub>3</sub> (in)	A(in <sup>2</sup> )	T(in <sup>4</sup> )	I <sub>2</sub> (in <sup>4</sup> )	I <sub>3</sub> (in <sup>4</sup> )	CROSS	SF2	SF3	SF2	SF3
21											
22											
23	53.9 ✓	301.7 ✓	89.232 ✓	6.49171E8 ✓	6.49395E8 ✓	15.94625E8 ✓	15D. ✓	.52 ✓	.635 ✓		
24	670 ✓	564 ✓	874.03 ✓	11.05474E8 ✓	11.5B07E8 ✓	14.8361E8 ✓	171.4 ✓	.433 ✓	.477 ✓		
25	904.8 ✓	564 ✓	70205 ✓	3.0733E8 ✓	16.8204E8 ✓	19.7665E8 ✓	171.4 ✓	.786 ✓	.703 ✓		
26	641.5 ✓	564 ✓	70205 ✓	1.0733E8 ✓	16.8204E8 ✓	19.7665E8 ✓	42. ✓	.786 ✓	.703 ✓		
27	641.5 ✓	564 ✓	5472 ✓	2726E8 ✓	12.4895E8 ✓	14.0501E8 ✓	42. ✓	.764 ✓	.759 ✓		
28	76.2 ✓	76.2 ✓	1237.36 ✓	1.6046E06 ✓	8.023E6 ✓	8.023E6 ✓	18.1 ✓	.63 ✓	.53 ✓	2. ✓	2. ✓
29	106.92 ✓	106.92 ✓	1280.88 ✓	3.3716E6 ✓	1.6019E6 ✓	1.6019E6 ✓	53146 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
30											
31	115. ✓	115. ✓	368.44 ✓	976.44 ✓	4.681E6 ✓	4.681E6 ✓	57.5 ✓	.53 ✓	.53 ✓	2. ✓	2. ✓
32											
33							Rigid beam				
34	798	798	50.01E4	398.12E8 ✓	199.06E8 ✓	199.06E8 ✓	399 ✓	.89 ✓	.89 ✓		

## CONTAMINANT BUILDUP - COMPUTER DATA

NUCLEAR ENERGY SERVICES



BY 11/2 DATE 11/18/82 PROJ. # 101 TASK # A26  
CHKD. JC, AZ DATE 3/23/82 PAGE OF 7/1/82 Page 3-6 of 258



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 3-19-79 PROJ. 5101 TASK 026  
CHKD. (B) DATE 6-8-81 PAGE 1 OF 18  
LACBWR SEP

Page B-7 of 258

REF.

CONTAINMENT SHELL  
AND  
WATER TANK



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION


BY R.R. DATE 3-19-74 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-8-81 PAGE 2 OF         
LACBWR SEP

Page B-8 of 258

SCALE 1:20

REF.

GEOMETRY OF CONTAINMENT VESSEL





REF.

### MATERIAL PROPERTIES

$$f_c' = 3500 \text{ psi}$$

REINFORCING BARS

DESIGNATION A-15 (INTERMEDIATE GRADE  
BARS, DEFORMED)

$$f_y = 40,000 \text{ psi}$$

#### REFERENCE

ALLIS-CHALMERS SPECIFICATION 41-551

S&L No W1735

STANDARD SPECIFICATION FOR  
REINFORCED CONCRETE WORK  
(FORM 1715P)

ACI  
318-77  
SEC 8.5  
Pg 26

ACI  
318-77  
SEC 8.5  
Pg 26

AISC  
7TH ED  
Pg IX

$$E_c = 57,000\sqrt{f_c'}$$

$$E_c = 57,000\sqrt{3500} = 3372 \text{ ksl}$$

$$E_s = 29,000 \text{ ksl} \quad \text{FOR STEEL}$$

Poisson's RATIO  $\nu = .17$  FOR CONCRETE

$\nu = .3$  FOR STEEL

REF DESIGN OF CONCRETE

STRUCTURES

By G. WINTER  
A. NILSON 8TH ED


2.



**NUCLEAR ENERGY SERVICES INC.  
NES DIVISION**

BY RR DATE 3-19-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-8-81 PAGE 4 OF \_\_\_\_\_  
LACBWR SEP

PAGE B-10 of 258





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-24-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-8-81 PAGE 5 OF         
LACBWR SEP

Page B-11 of 258

CONTAINMENT BLDG					REF.
PROPERTIES					
NODE NO	AREA	I <sub>x2</sub>	I <sub>x3</sub>	DEAD WEIGHT	WATER
3BA	7.7711	638.2853		5.46"	
37A	10.7011	1666.6662		15.00"	
36A	14.2970	47.0629		20.04"	
35	16.4451	6098.7157		24.62"	65.12" ADD TO FWDN ON NODE 35
34	17.7922	7660.2866		28.33"	
33	18.1133	8082.5704		28.83"	
32	18.2474	8236.8458		28.79"	
31	18.2474	8236.8458		28.79"	
30	18.2474	8236.8458		28.79"	
29	17.1200	8173.8600	7222.39	23.02"	
28				22.36"	
27				29.83"	
26				29.83"	
-25	17.1200	8173.8600	7222.39	26.14"	
29	18.2474	8236.8458		27.45"	
23				27.45"	
22				27.45"	
21				27.36"	
20				51.64"	
19				76.00"	
18				76.00"	
17				76.00"	
16				76.00"	
15				76.00"	
14	18.2474	8236.8458		76.00"	
13	9.4143	4227.0294		46.00"	
12	9.3591	4153.1125		15.91"	
11	9.1350	3861.8270		15.53"	
10	8.7487	3392.3118		19.88"	
9	8.1772	2770.0236		13.30"	
8	7.5618	2190.4951		11.04"	
7	6.7630	1567.0966		9.86"	
3	5.7044	940.3590		6.42" 9.3.91"	
2	4.1419	359.9645		6.20"	
1	1.487	133.3300		1.12"	
4	5.3393	771.1298		7.80 163.29"	
5	4.2227	381.4658		6.17 95.00"	
6	3.1337	155.5790		1.14 10.56"	



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 5-10-79 PROJ. 5101 TASK 026  
CHKD. AS DATE 6-8-81 PAGE 6 OF 1  
LACBWR SEP

page B-12 of 258

OUTER CONTAINMENT SHELL

REF.

NODE No.	WEIGHT	WATER AREA $\times 10^{12}$	$\text{Tx}_2 \times 10^{10}$	$\text{Tx}_3 \times 10^{10}$	$K \times 10^{10}$	$H_2 = H_3 \times 10^2$
1	1.12	4.2833	0.02771	0.02765	0.0563	2.2784
2	6.20	5.9643	0.07464	0.07464	0.1493	3.1701
3	<del>8.43</del> > 10.34	8.2143	0.1950	0.1950	0.3900	4.3638
4	<del>9.39</del> > 11.09	7.6886	0.1599	0.1599	0.3198	4.0849
5	<del>10.32</del> > 10.17	6.0807	0.0791	0.0791	0.1582	3.2319
6	<del>11.14</del> > 11.7	4.5125	0.03233	0.03233	0.0647	2.4000
7	7.86	9.7387	0.3250	0.3250	0.6500	5.1752
8	11.04	10.8890	0.4542	0.4542	0.9084	5.7828
9	13.30	11.7752	0.5744	0.5744	1.1488	6.2529
10	14.88	12.5981	0.7034	0.7034	1.4069	6.6895
11	15.53	13.1544	0.8008	0.8008	1.6016	6.9846
12	15.71	13.4771	0.8612	0.8612	1.7224	7.1558
13	46.00	13.5566	0.8765	0.8765	1.7530	7.2232
14	76.00	26.2763	1.7082	1.7082	3.4164	7.2232
15	76.00	26.2763	1.7082	1.7082	3.4164	7.2232
16	76.00	26.2763	1.7082	1.7082	3.4164	7.2232
17	76.00	26.2763	1.7082	1.7082	3.4164	7.2232
18	51.64	26.2763	1.7082	1.7082	3.4164	7.2232
19	27.45	26.2763	1.7082	1.7082	3.4164	7.2232
20						
21						

## OUTER CONTAINMENT SHELL

REF.

NODE NO	WEIGHT	AREA $\times 10^2$ IN $^2$	$I_{yz} \times 10^5$ IN $^4$	$I_{xz} \times 10^5$ IN $^4$	K $\times 10^8$ IN $^9$	H <sub>2</sub> +H <sub>3</sub>
22	27.45"	26.2763	1.7082	1.7082	3.4164	7.2232
23	27.45"	26.2763	1.7082	1.7082	3.4164	7.2232
24	27.95"	26.2763	1.7082	1.7082	3.4164	7.2232
25	26.19"	24.6528	1.6949	1.4976	3.1925	7.2232
26	24.83"	24.6528	1.6949	1.4976	3.1925	7.2232
27	24.83"	24.6528	1.6949	1.4976	3.1925	7.2232
28	22.36"	24.6528	1.6949	1.4976	3.1925	7.2232
29	23.02"	24.6528	1.6949	1.4976	3.1925	7.2232
30	28.79"	26.2763	1.7080	1.7080	3.4160	7.2232✓
31	28.79"	26.2763	1.7080	1.7080	3.4160	7.2232✓
32	28.79"	26.2763	1.7080	1.7080	3.4160	7.2232✓
33	29.53"	26.2763	1.7080	1.7080	3.4160	7.181✓
37	28.83"	25.6208	1.5884	1.5884	3.17681	7.0592✓
35	29.62" 15.00 5.46	23.6809 45.08"	1.2543	1.2543	2.50851	7.5209✓

NODE	WEIGHT	AREA $\times 10^4 \text{ in}^2$	$I_{x_2} \times 10^8 \text{ in}^4$	$I_{x_3} \times 10^8 \text{ in}^4$	$K \times 10^6 \text{ in}^4$	$SF_2 = SF_3 =$
36	133.31	2.0075	12.6517	12.6517	25.3033	0.53
37	266.62	2.0075	12.6517	12.6517	25.3033	
38	251.77	2.0075	12.6517	12.6517	25.3033	
39	236.93	2.0075	12.6517	12.6517	25.3033	
40	237.03	2.0075	12.6517	12.6517	25.3033	
41	245.40	2.0075	12.6517	12.6517	25.3033	
42	248.51	1.8852	12.6330	12.6330	25.2660	
43	206.99	1.8852	12.6330	12.6330	25.2660	
44	159.45	2.0075	12.6517	12.6517	25.3033	
45	209.50	2.0075	12.6517	12.6517	25.3033	

OUTER SHIELD BLDG

REF.

BY R.R. DATE 5-10-79 PROJ. 5101 TASK 026  
 CHKD. QD DATE 6-9-81 PAGE 8 OF         
LACBWR SEP  
 Page 8-14 of 258


 NUCLEAR ENERGY SERVICES INC.  
 NES DIVISION



PROPERTIES OF HEMISPHERICAL TOP & ELLIPTICAL WATER TANK

REF.

HEMISPHERICAL TOP

AT NODE 12

$$y = 3.74'$$

$$w = 3.74$$

$$d_1 = 59.5319'$$

$$d = 59.6319' \rightarrow 7.1558 \times 10^2 \text{ IN}$$

$$A = 9.3591 \text{ FT}^2$$

$$I = 4153.1125 \text{ FT}^4$$

$$M = 17.15 \text{ K}$$

AT NODE 11

$$y = 7.48'$$

$$w = 3.74$$

$$d_1 = 58.1051'$$

$$d = 58.2051' \rightarrow 6.9846 \times 10^2 \text{ IN}$$

$$A = 9.1350 \text{ FT}^2$$

$$I = 3861.8270 \text{ FT}^4$$

$$M = 16.74 \text{ K}$$

AT NODE 10

$$y = 11.22'$$

$$w = 3.74$$

$$d_1 = 55.6457'$$

$$d = 55.7457' \rightarrow 6.6895 \times 10^2 \text{ IN}$$

$$A = 8.7487 \text{ FT}^2$$

$$I = 3392.3118$$

$$M = 16.03 \text{ K}$$

AT NODE 9

$$y = 14.96$$

$$d_1 = 52.0076'$$

$$w = 3.36$$

$$d = 52.1076' = 6.2529 \times 10^2 \text{ IN}$$

$$A = 8.1772 \text{ FT}^2$$

$$I = 2770.0236 \text{ FT}^4$$

$$M = 12.46 \text{ K}$$

AT NODE 8

$$y = 17.94'$$

$$d_1 = 48.0898'$$

$$w = 2.98$$

$$d = 48.1898' = 5.7828 \times 10^2 \text{ IN}$$

$$A = 7.5618 \text{ FT}^2$$

$$I = 2190.9951 \text{ FT}^4$$

$$M = 11.04 \text{ K}$$

AT NODE 7

$$y = 20.92'$$

$$w = 2.98$$

$$d_1 = 43.0048'$$

$$d = 43.1048' = 5.1726 \times 10^2 \text{ IN}$$

$$A = 6.7630 \text{ FT}^2$$

$$I = 1567.0966 \text{ FT}^4$$

$$M = 9.88 \text{ K}$$

AT NODE 3

$$y = 23.90'$$

$$w = 3.015$$

$$d_1 = 36.2651'$$

$$d = 36.3651' = 4.3638 \times 10^2 \text{ IN}$$

$$A = 5.7094 \text{ FT}^2$$

$$I = 990.3590 \text{ FT}^4$$

$$M = 8.43 \text{ K}$$

AT NODE 2

$$y = 26.95'$$

$$w = 3.05$$

$$d_1 = 26.3589$$

$$d = 26.4589 = 3.1701 \times 10^2 \text{ IN}$$

$$A = 4.1419$$

$$I = 359.9495 \text{ FT}^4$$

$$M = 6.19 \text{ K}$$

HALF WAY BETWEEN 2 & 1

$$y = 28.475$$

$$w = 1.525$$

$$d_1 = 18.8864$$

$$d = 18.9864 = 2.2784 \times 10^2 \text{ IN}^2$$

$$A = 2.9745 \text{ FT}^2$$

$$I = 133.3300 \text{ FT}^4$$

$$M = 1.11 \text{ K}$$

HALF WAY BETWEEN 13 & 12

$$y = 1.87$$

$$w = 1.97$$

$$d_1 = 59.8833$$

$$d = 59.9833$$

$$A = 9.9143 \text{ FT}^2$$

$$I = 4227.0294 \text{ FT}^4$$

$$M = 8.6263$$




NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 3-26-79 PROJ. 5101 TASK 026  
CHKD. AR DATE 6-8-81 PAGE 10 OF 10  
LACBWR SEP

Page B-16 of 258

MASS CALCULATION FOR CONTAINMENT VESSEL

REF.



NODE 1

$$\begin{aligned} A_1 &= 0 \\ A_2 &= 29745 \text{ FT}^2 \end{aligned}$$

$$\text{AVERAGE} = 1.487 \text{ FT}^2 = 2.14130 \times 10^2 \text{ IN}^2$$

$$\text{VOLUME} = (1.4875)(1.53) = 2.2759 \text{ FT}^3$$

$$\text{WEIGHT} = (.490)(2.2759) = 1.12 \text{ k}$$

NODE 2

$$\begin{aligned} A &= 4.1419 \text{ FT}^2 \\ V &= 12.6328 \text{ FT}^3 \\ W &= 6.190 \text{ k} \xrightarrow{\text{use}} 6.20 \text{ k} \end{aligned}$$

NODE 3 (+ WATER TANK)

$$\begin{aligned} A &= 5.7044 \text{ FT}^2 \\ V &= 17.3984 \text{ FT}^3 \\ W &= 8.43 \text{ k} + 93.912 \text{ k} = 101.34 \text{ k} \\ &\text{* SEE WATER TANK} \end{aligned}$$

NODE 7

$$\begin{aligned} A &= 6.7630 \text{ FT}^2 \\ V &= 20.1537 \text{ FT}^3 \\ W &= 9.86 \text{ k} \end{aligned}$$

NODE 8

$$\begin{aligned} A &= 7.5618 \text{ FT}^2 \\ V &= 22.5341 \text{ FT}^3 \\ W &= 11.04 \text{ k} \end{aligned}$$

NODE 9

$$\begin{aligned} A &= 8.1772 \text{ FT}^2 \\ V &= 27.1483 \text{ FT}^3 \\ W &= 13.30 \text{ k} \end{aligned}$$

NODE 10

$$\begin{aligned} A &= 8.7487 \text{ FT}^2 \\ V &= 30.3580 \text{ FT}^3 \\ W &= 14.88 \text{ k} \end{aligned}$$

NODE 11

$$\begin{aligned} A &= 9.1350 \text{ FT}^2 \\ V &= 31.6985 \text{ FT}^3 \\ W &= 15.53 \text{ k} \end{aligned}$$


NODE 12

$$\begin{aligned} A &= 9.3591 \text{ FT}^2 \\ V &= 32.4761 \text{ FT}^3 \\ W &= 15.91 \text{ k} \end{aligned}$$



PROPERTIES OF HEMISpherical TOP & ELLIPTICAL WATER TANK

REF.



T1

PROPERTIES OF WATER TANK ELLipse

$$y = 1.49'$$

$$y = 7.95'$$

$$y \text{ STO 1}$$

$$B = 8.94 \text{ STO 2}$$

$$H = 18.0 \text{ STO 3}$$

$$2d = .1 \text{ STO 6}$$

$$d_1 = 35.4965'$$

$$d_1 = 19.8997'$$

$$d = 35.5965' = 4.2716 \times 10^2$$

$$d = 19.9997' = 2.400 \times 10^2$$

$$A = 5.5836 \text{ FT}^2$$

$$A = 3.1337 \text{ FT}^2$$

$$I = 881.9023 \text{ FT}^4$$

$$I = 155.8996 \text{ FT}^4$$

$$\Delta t \text{ NODE 4 } y = 2.98'$$

$$y = 0$$

$$d_1 = 33.9411'$$

$$d_1 = 36'$$

$$d = 34.0411' = 9.0849 \times 10^2 \text{ IN}$$

$$d = 36.1'$$

$$A = 5.3393 \text{ FT}^2$$

$$A = 5.6627 \text{ FT}^2$$

$$I = 771.1298 \text{ FT}^4$$

$$I = 919.9125$$

$$\Delta t \text{ NODE 5 } y = 5.96'$$

$$d_1 = 26.8328'$$

$$d = 26.9328 = 3.2319 \times 10^2 \text{ IN}$$

$$A = 4.2227 \text{ FT}^2$$

$$I = 381.4658 \text{ FT}^4$$



PROPERTIES OF OUTER CYLINDRICAL STEEL CONTAINMENT SHELL

REF.

PROPERTIES OF ELEMENTS OF SIDES

FROM NODE 14 TO 24


AREA

$$A = \frac{\pi (d^2 - d_1^2)}{4} = \frac{\pi (60.193^2 - 60^2)}{4}$$

$$A = 18.2474 \text{ FT}^2$$

MOMENT OF INERTIA

$$I = \frac{\pi (d^4 - d_1^4)}{64} = 8237.8458 \text{ FT}^4$$



TORSIONAL CONSTANT

$$K = \frac{1}{2} \pi (r_1^4 - r_0^4) \quad r_0 = 30^\circ$$

$$K = \frac{1}{2} \pi (30.0967^4 - 30^4) \quad r_1 = 30.0967^\circ$$

$$K = 16484.2562 \text{ FT}^4$$

FROM NODE 25 TO 29

$$A_1 \quad A_2 \\ A = \left[ 2 \times 2 \times \frac{79.1932\pi}{360} + 2 \times \frac{10.81}{360}(2\pi) \right] 30 \frac{1.16}{12}$$

$$\checkmark A = 17.12 \text{ FT}^2 \quad \text{— AREA}$$


$$L_1 = 8.015 \text{ FT}^2$$

$$A_2 = 1.09 \text{ FT}^2$$

$$\text{FOR } A_1 \quad y_1 = R \left( 1 - \frac{\sin \alpha}{\alpha} \right)$$

$$y_1 = 30 \left( 1 - \frac{0.9823}{1.382} \right)$$

$$y_1 = 8.68 \text{ FT}$$



$$I_{11} = R^3 t (\alpha + \sin \alpha \cos \alpha - \frac{2 \sin^2 \alpha}{\alpha})$$

$$I_{11} = 30 \frac{1.16}{12} \left( 1.382 + \sin 79.193 \cos 79.193 - \frac{2 \sin^2 79.193}{1.382} \right) = 438 \text{ FT}^4$$

$$I_{22} = R^3 t (\alpha - \sin \alpha \cos \alpha)$$

$$I_{22} = 30 \frac{1.16}{12} \left( 1.382 - \sin 79.193 \cos 79.193 \right) = 3126.32 \text{ FT}^4$$

FOR A\_2

$$I_{11} = R^3 t (\alpha - \sin \alpha \cos \alpha)$$

$$I_{11} = 30^3 \frac{1.16}{12} (0.1886 - \sin 10.807 \cos 10.807) = 11.55 \text{ FT}^4$$

$$I_{22} = 30 \left( 1 - \frac{\sin 10.807}{0.1886} \right) = 0.175 \text{ FT}$$



## PROPERTIES OF OUTER CYLINDRICAL STEEL CONTAINMENT SHELL

REF.

$$I_z = R^3 \left( \alpha + \sin \alpha \cos \alpha - \frac{2 \sin^2 \alpha}{\alpha} \right) / 12$$

$$I_z = 30^3 \frac{1.16}{12} \left( 0.1886 + \sin 10.805 \cos 10.805 - \frac{2 \sin^2 10.805}{0.1886} \right) = .16 \text{ ft}^4$$

$$I_{xx} = 2(438) + 2(8.015) \times 21.32^2 + 11.55 = 8173.86 \text{ ft}^4 \checkmark$$

ASSUME F AT CENTROID

$$I_{yy} = 2 \times 3126.32 + .16 + 1.09 \times 29.825^2 = 7222.39 \text{ ft}^4 \checkmark$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 3-26-74 PROJ. S101 TASK 026  
CHKD. AB DATE 6-8-81 PAGE 14 OF 14  
LACENWR SEP

Page B-20 of 258


MASS CALCULATION FOR WATER TANK				REF.
By USING AN APPROXIMATE VOLUME CALCULATION				
$P_{H_2O} = 62.4$				
<u>NODE 3.</u>				
$d_1 = 36.0$	$y = 0$	$\Delta = .5$	$A_1 = 5.6627$	
$d_1 = 35.9436$	$y = .5$	$\Delta = .5$	$A_2 = 5.5836$	
$d_1 = 35.7741$	$y = 1.0$	$\Delta = .5$	$A_{av} = 5.6232 \text{ FT}^2$	
$d_1 = 35.4965$	$y = 1.49$	$\Delta = .5$	$V = 8.3785 \text{ FT}^3$	
			$W = 4.11 \text{ K STEEL}$	
WEIGHT $H_2O$				
$d_1 = 35.0876$	$y = 2.00$	$\Delta = .5$	$A_1 = 5.3393 \text{ FT}^2$	
$d_1 = 34.5638$	$y = 2.50$	$\Delta = .5$	$V = 15.9111 \text{ FT}^3$	
$d_1 = 33.9125$	$y = 3.0$	$\Delta = .5$	$W = 7.80 \text{ K STEEL}$	
$d_1 = 33.1269$	$y = 3.5$	$\Delta = .5$		
$d_1 = 32.1955$	$y = 4.0$	$\Delta = .47$		
$d_1 = 31.1769$	$y = 4.47$			
<u>98.02 K TOTAL</u>				
<u>NODE 4</u>				
$d_1 = 29.8431$	$y = 5.0$	$\Delta = .5$	$WEIGHT H_2O$	
$d_1 = 28.3810$	$y = 5.5$	$\Delta = .5$	$A_1 = 4.2227$	
$d_1 = 26.6879$	$y = 6.0$	$\Delta = .5$	$V = 12.5836$	
$d_1 = 24.7163$	$y = 6.5$	$\Delta = .5$	$W = 6.17 \text{ K STEEL}$	
$d_1 = 22.3929$	$y = 7.0$	$\Delta = .5$		
$d_1 = 19.8997$	$y = 7.45$	$\Delta = .45$		
<u>163.29 K <math>H_2O</math></u>				
<u>171.09 K TOTAL</u>				
<u>NODE 5.</u>				
$d_1 = 16.0689$	$y = 8.0$	$\Delta = .55$	$WEIGHT H_2O$	
$d_1 = 11.1549$	$y = 8.5$	$\Delta = .5$	$A = 0$	
$d_1 = 7.38$	$y = 8.75$	$\Delta = .44$	$A = 3.1337 \text{ FT}^2$	
<u>95.00 K <math>H_2O</math></u>				
<u>101.17 K TOTAL</u>				
<u>NODE 6</u>				
$d_1 = 16.0689$	$y = 8.0$	$\Delta = .55$	$WEIGHT H_2O$	
$d_1 = 11.1549$	$y = 8.5$	$\Delta = .5$	$A = 3.1337 \text{ FT}^2$	
$d_1 = 7.38$	$y = 8.75$	$\Delta = .44$	$V = 2.33 \text{ FT}^3$	
<u>10.56 K <math>H_2O</math></u>				
<u>11.7 K TOTAL</u>				
3.2776				



PROPERTIES OF OUTER ELIPTICAL STEEL CONTAINMENT SHELL BOTTOM

REF.

ELIPTICAL BOTTOM SHELL



$$H = 30'$$

$$B = 15.09'$$

$$2t = \frac{2(1.16)}{12} = .193 \text{ FT}$$

$$\frac{x^2}{H^2} + \frac{y^2}{B^2} = 1$$

$$x^2 = \left[ 1 - \frac{y^2}{B^2} \right] H^2$$

$$x = \sqrt{\left[ 1 - \frac{y^2}{B^2} \right] H^2}$$

1/2 BETWEEN NODE 34 & 33  $y = 1.625$

$$d_i = 59.651 \text{ IN} \quad \text{INSIDE DIAMETER}$$

$$d = 59.844 \text{ IN} \quad \text{INSIDE DIAMETER} = 7.181 \times 10^2 \text{ IN}$$

$$A = 18.1133 \text{ FT}^2$$

$$I = 8082.5704$$

NODE 34

$$d_i = 58.5919 \text{ IN} \quad y = 3.25$$

$$d = 58.7849 \text{ IN} \quad 7.0542 \times 10^2 \text{ IN}$$

$$A = 17.7922 \text{ FT}^2$$

$$I = 7660.2866 \text{ FT}^4$$

NODE 35

$$d_i = 54.1983 \text{ IN} \quad y = 6.50$$

$$d = 54.3413 \text{ IN} \quad 7.5209 \times 10^2 \text{ IN}$$

$$A = 16.4451 \text{ FT}^2$$

$$I = 6048.7157 \text{ FT}^4$$

NODE 36A

$$d_i = 47.0629 \text{ IN} \quad y = 9.36$$

$$d = 47.2559$$

$$A = 14.2970 \text{ FT}^2$$

$$I = 470629 \text{ FT}^4$$

NODE 37A  $y = 12.22$

$$d_i = 35.2017 \text{ IN}$$

$$d = 35.3947 \text{ IN}$$

$$A = 10.7011 \text{ FT}^2$$

$$I = 1666.6662 \text{ FT}^4$$

1/2 WAY BETWEEN NODE 38A & 37A

$$d_i = 25.5370 \text{ IN} \quad y = 13.655$$

$$d = 25.7500$$

$$A = 7.7711 \text{ FT}^2$$

$$I = 638.2853 \text{ FT}^4$$



REF.

WEIGHTS

NODE 38A

$$18.7711 F_t^2 (2.87) \frac{1}{2} (.490) = 5.46^k /$$

NODE 37A

$$10.7011 F_t^2 (2.86) (.490) = 15.00^k /$$

NODE 36A

$$14.5197 F_t^2 (2.86) (.490) = 20.35^k \checkmark$$

NODE 35

$$16.4451 F_t^2 \left( \frac{2.86+3.25}{2} \right) (.490) = 24.62^k -$$

NODE 34

$$17.7922 F_t^2 (3.25) (.490) = 28.33^k$$

NODE 33

$$18.133 F_t^2 \left( \frac{3.25}{2} \right) (.490) = 14.43^k > 28.83^k$$
$$18.2474 F_t^2 \left( \frac{3.22}{2} \right) (.490) = 14.40^k >$$

NODE 32

$$18.2474 F_t^2 (3.22) (.490) = 28.79^k$$

NODE 31

$$18.2474 F_t^2 (3.22) (.490) = 28.79^k$$

NODE 30

$$18.2474 F_t^2 (3.22) (.490) = 28.79^k$$

NODE 29

$$18.2474 F_t^2 \left( \frac{2.37}{2} \right) (.490) = 10.60^k$$
$$17.12 F_t^2 \left( \frac{2.96}{2} \right) (.490) = 12.42^k > 23.02 -$$

NODE 28

$$17.12 F_t^2 \left( \frac{2.37+2.96}{2} \right) (.490) = 22.36^k$$

NODE 27

$$17.12 F_t^2 (2.96) (.490) = 24.83^k$$

NODE 26

$$17.12 F_t^2 (2.96) (.490) = 24.83^k$$

NODE 25

$$17.12 F_t^2 \left( \frac{2.96}{2} \right) (.490) = 12.42^k > 26.14$$
$$18.2474 F_t^2 \left( \frac{3.07}{2} \right) (.490) = 13.72^k >$$

NODE 24

$$18.2474 F_t^2 (3.07) (.490) = \underline{\underline{27.45^k}}$$
$$357.28^k$$



REF.

## WEIGHTS (CONT)

NODE 23

$$18.2474 \text{ FT}^2 (3.07) (.490) = 27.45^w \checkmark$$

NODE 22

$$18.2474 \text{ FT}^2 (3.07) (.490) = 27.45^w \checkmark$$

NODE 21

$$18.2474 \text{ FT}^2 \left( \frac{3.07+3.09}{2} \right) (.490) = 27.59^w \checkmark$$

NODE 20

$$18.2474 \text{ FT}^2 \left( \frac{3.09+8.5}{2} \right) (.490) = 51.81^w \checkmark$$

NODE 19

$$18.2474 \text{ FT}^2 (8.50) (.490) = 76.00^w \checkmark$$

NODE 18

$$18.2474 \text{ FT}^2 (8.50) (.490) = 76.00^w \checkmark$$

NODE 17

$$18.2474 \text{ FT}^2 (8.50) (.490) = 76.00^w \checkmark$$

NODE 16

$$18.2474 \text{ FT}^2 (8.50) (.490) = 76.00^w \checkmark$$

NODE 15

$$18.2474 \text{ FT}^2 (8.50) (.490) = 76.00^w \checkmark$$

NODE 14

$$18.2474 \text{ FT}^2 (8.50) (.490) = 76.00^w \checkmark$$

NODE 13

$$\begin{aligned} 18.2474 \left( \frac{8.50}{2} \right) (.490) &= 38.00^w \\ 9.4143 \text{ FT}^2 \left( \frac{3.47}{2} \right) (.490) &= 8.00 \end{aligned} \quad > 46.00 \checkmark$$

NODE 12

$$9.3591 \text{ FT}^2 (3.47) (.490) = 15.91^w \checkmark$$

NODE 11

$$9.1350 \text{ FT}^2 (3.47) (.490) = 15.53^w \checkmark$$

NODE 10

$$8.7487 \text{ FT}^2 (3.47) (.490) = 14.88^w \checkmark$$

NODE 9

$$8.1772 \text{ FT}^2 (3.32) (.490) = 13.20^w$$

NODE 8

$$\begin{aligned} 7.5618 \text{ FT}^2 (2.95) (.490) &= 11.04^w \\ &\underline{\underline{706.56}} \end{aligned} \checkmark$$



REF.

## WEIGHTS (CONT)

NODE 7

$$6.7630 \text{ FT}^2 (2.95)(.490) = 9.86^{\text{u}}$$

NODE 3

$$= 12.64^{\text{u}} /$$

WATER

$$93.91^{\text{u}} \xrightarrow{\text{USE (Conervative)}} 106.55$$

NODE 2

$$= 6.60^{\text{k}}$$

NODE 1

$$= 1.12^{\text{k}}$$

NODE 4

$$= 7.80^{\text{k}}$$

$$163.29^{\text{k}} \rightarrow 171.09^{\text{k}}$$

NODE 5

$$= 6.17^{\text{k}}$$

$$95.00^{\text{k}}$$

NODE 6

$$= 1.14^{\text{k}}$$

$$\frac{10.56^{\text{k}}}{362.78^{\text{k}}}$$

$$\underline{45.33^{\text{k}}}$$

TOTAL WEIGHT CONTAINMENT SHELL  
AND WATER TANK

$$\begin{array}{rcl} 45.33^{\text{k}} & & 362.78^{\text{k}} \text{ H2O} \\ 706.56 & & \\ \hline 357.28 & & \\ \hline 1109.17 & \text{STEEL} & \end{array}$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 3-29-79 PROJ. 5101 TASK 026  
CHKD. TR DATE 6-8-81 PAGE 1 OF         
LACBWR SEP

Page B-25 of 258

REF.

BIOLOGICAL SHIELD  
BUILDING




NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 3-29-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-8-81 PAGE 2 OF  
LACBWR SEP

Page B-26 of 258

OUTER SHIELD BLDG.

REF.





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 5-1-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-9-81 PAGE 3 OF 1  
LACBWR SEP

Page B-27 of 258

OUTER SHIELD BLDG.

REF.

NODE NO	AREA	$I_{x_2}$	$I_{x_3}$	DEAD WEIGHT ^
36	139.41 $\text{ft}^2$	61013.08	61013.08	93 K CRANE 133.31 / 226.31
37	139.41	61013.08	61013.08	266.62
38	139.41	61013.08	61013.08	251.77
39	139.41	61013.08	61013.08	236.93
40	139.41	61013.08	61013.08	237.03
41	139.41	61013.08	61013.08	245.40
42	130.92	60923.06	53483.03	248.51 ✓
43	130.92	60923.06	53483.03	206.99
44	139.41	61013.08	61013.08	159.45
45	139.41	61013.08	61013.08	<u>209.50</u> 2195.51

$$J = I_2 + I_3 \approx$$

$$H_2 = 60' ; H_3 = 60'$$

$$C = 30'$$

$$SFZ =$$

CHANGE  $\text{ft}^2$  TO  $\text{m}^2$


NODE No	Area( $\text{in}^2$ )	$I_{x_2} (\text{in}^4)$	$I_{x_3} (\text{in}^4)$	$K \times 10^3$	$\text{in}^4$
36	$2,0075 \times 10^4$	$12.6517 \times 10^8$	$12.6517 \times 10^8$	$25.3033$	
37					
38					
39					
40					
41					
42	$1.8852 \times 10^4$	$12.633 \times 10^8$	$11.0902 \times 10^8$	$23.723$	
43	$1.8852 \times 10^4$	$12.633 \times 10^8$	$11.0902 \times 10^8$	$23.723$	
44	$2,0075 \times 10^4$	$12.6517 \times 10^8$	$12.6517 \times 10^8$	$25.303$	
45	$2,0075 \times 10^4$	$12.6517 \times 10^8$	$12.6517 \times 10^8$	$25.303$	



OUTER SHIELD BLDG.

REF.

PROPERTIES OF CRANE COLUMNS



$$I_3 = I_x \sin^2 \alpha + I_y \cos^2 \alpha$$

$$I_q = I_x \cos^2 \alpha + I_y \sin^2 \alpha$$

PROPERTIES FOR WF14x43

$$A = 12.6 \text{ in}^2$$

$$I_{xx} = 429.0 \text{ in}^4 \quad r_c = 1.89 \text{ in}$$

$$I_{yy} = 95.1 \text{ in}^4$$

$$S_{xx} = 62.97 \text{ in}^3$$

$$S_{yy} = 11.3 \text{ in}^3$$

PROPERTIES FOR C15x33.9

$$A = 9.96 \text{ in}^2 \quad r_c = 5.62 \text{ in}$$

$$I_{xx} = 315 \text{ in}^4$$

$$I_{yy} = 8.13 \text{ in}^4$$

$$S_{xx} = 42.0 \text{ in}^3$$

$$S_{yy} = 3.11 \text{ in}^3$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 3-23-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-9-81 PAGE 5 OF —  
LACBWR SEP

Page B-29 of 258

OUTER SHIELD BLDG

REF.

CALCULATE CONTRIBUTION OF CRANE COLUMNS.

WF COLUMN

DEGREE OF CENTER	$I_{x_2}$	$I_{x_3}$	$4 I_{x_2}$	$4 I_{x_3}$
$18^\circ$	0.08192	0.003943	0.7568	0.1577
$36^\circ$	0.01429	0.008571	0.05717	0.03429
$54^\circ$	0.008571	0.01429	0.03429	0.05712
$72^\circ$	0.003943	0.08192	0.01577	0.07568
$90^\circ$	0.002175	0.02069	0.00870	0.08275
$0^\circ$	0.020689	0.00217	<u>0.08275</u>	<u>0.00870</u>
			<u>0.27436 ft<sup>4</sup></u>	<u>0.27436 ft<sup>4</sup></u>

$$m = \frac{E_s}{E_c} \quad E_c = 57,000 \sqrt{f_c}$$

$$E_c = 3122 \text{ KSI}$$

$$E_s = 29,000 \text{ KSI}$$

$$f_c = 3000^*$$

ACI-71  
Sec 8.3

\* ASSUMED

$$m = \frac{29000}{3122} = 9.29$$

USING A RELATIVE STIFFNESS FACTOR OF 9.29 THE  
MI<sup>2</sup> FACTOR OF THE COLUMNS = 2.55 FT<sup>4</sup> WHICH  
IS VERY SMALL AS COMPARED TO THAT OF THE CONCRETE  
CYLINDER.

TORSIONAL STIFFNESS CONSTANT

$$K = 105 \text{ in}^4 \text{ FOR W19x43}$$

$$\frac{(9.29)20K}{12^4} = 0.9383 \quad \text{NEGLCT}$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 3-23-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-9-81 PAGE 6 OF 1  
LACBWR SEP  
Page B-30 of F25B

OUTER SHIELD BLDG

REF.

PROPERTIES OF CONCRETE CYLINDER @ EL 726-6"

$$A = \frac{\pi}{4} (d^2 - d_1^2) \quad \text{WHERE } d = 59.9167 \text{ FT}$$

$$A = \frac{\pi}{4} (59.9167^2 - 58.4167^2)$$

$$A = 139.4082 \text{ FT}^2$$

$$I = \frac{\pi}{64} (d^4 - d_1^4)$$

$$I = \frac{\pi}{64} (59.9167^4 - 58.4167^4)$$

$$I_c = 6103.0828 \text{ FT}^4$$

$$\text{WEIGHT } 99' @ 139.4082 \times .15 = 2070.21 \text{ k}$$

CONCRETE CYLINDER 9."

AREA: 139.4082

MOMENT INERTIA = 6103.0828<sup>4</sup> FT

WEIGHT: 2070.21<sup>k</sup>



OUTER SHIELD BLDG

REF.

WEIGHT CALCNODE 36

$$\text{WEIGHT} = \frac{(12.75)}{2} (139.41) (.150) = 133.31^{\text{K}}$$

NODE 37

$$\text{WEIGHT} = (12.75) (139.41) (.150) = 266.62^{\text{K}}$$

NODE 38

$$\text{WEIGHT} = \left( \frac{12.75 + 11.33}{2} \right) (139.41) (.150) = 251.77^{\text{K}}$$

NODE 39

$$\text{WEIGHT} = (11.33) (139.41) (.150) = 236.93^{\text{K}}$$

NODE 40

$$\text{WEIGHT} = \left( \frac{11.33 + 11.33}{2} \right) (139.41) (.150) = 237.03^{\text{K}}$$

NODE 41

$$\text{WEIGHT} = \left( \frac{11.33 + 12.13}{2} \right) (139.41) (.150) = 245.40^{\text{K}}$$

NODE 42

$$\text{WEIGHT} = \left[ 3.88 (130.92) + \left[ \frac{12.13}{2} + \left( \frac{12.13}{2} - 3.88 \right) \right] (139.41) \right] .15 = 298.51^{\text{K}}$$

NODE 43

$$\text{WEIGHT} = \left[ \left( \frac{12.12}{2} + 2.75 \right) (130.92) + \left( \frac{12.12}{2} - 2.75 \right) (139.41) \right] .15 = 206.99^{\text{K}}$$

NODE 44

$$\text{WEIGHT} = \left( \frac{8.75 + 6.5}{2} \right) (139.41) (.150) = 159.45^{\text{K}}$$

NODE 45

$$\text{WEIGHT} = \left( \frac{6.5}{2} \right) (139.41) (.15) + 141.54^{\text{K}} = 209.50^{\text{K}}$$


2195.51<sup>K</sup> = TOTAL WEIGHT ✓



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION


BY R.R. DATE 3-23-79 PROJ. 5101 TASK 026  
CHKD. AJ DATE 6-9-81 PAGE 9 OF 1  
LACBWR SEP

Page B-32 of 258





REF.



VOLUME V<sub>1</sub>

$$A = \frac{\pi}{4} (d_o^2 - d_i^2) = \frac{\pi}{4} (29.25^2 - 27.25^2) = 203.07 \text{ FT}^2$$

$$V_1 = \frac{1}{2} (4.75) (203.07) = 482.29 \text{ FT}^3$$

WEIGHT = 72.34<sup>k</sup>

VOLUME V<sub>2</sub>

$$A = \frac{\pi}{4} (d_o^2 - d_i^2) = \frac{\pi}{4} (29.25^2 - 27.25^2) = 88.75 \text{ FT}^2$$

$$V_2 = 2.25 (88.75) = 199.69 \text{ FT}^3$$

WEIGHT = 29.95<sup>k</sup>

VOLUME V<sub>3</sub>

$$A = \frac{\pi}{4} (29.25^2 - 27.25^2) = 88.75 \text{ FT}^2$$

$$V_3 = \frac{1}{2} (2.5) (88.75) = 110.94 \text{ FT}^3$$

WEIGHT = 16.64<sup>k</sup>

VOLUME V<sub>4</sub>

$$A = 88.75 \text{ FT}^2$$

$$V_4 = \frac{1}{2} (1.75) (88.75) = 77.66 \text{ FT}^3$$

WEIGHT = 11.65<sup>k</sup>

VOLUME V<sub>5</sub>

$$A = \frac{\pi}{4} (30^2 - 29.25^2) = 34.90 \text{ FT}^2$$

$$V_5 = 1.75 (34.90) = 61.08 \text{ FT}^3$$

WEIGHT = 9.16<sup>k</sup>

VOLUME V<sub>6</sub>

$$A = \frac{\pi}{4} (29.75^2 - 29.25^2) = 23.17 \text{ FT}^2$$

$$V_6 = \frac{1}{2} (2.25) (23.17) = 26.07 \text{ FT}^3$$

WEIGHT = 3.91<sup>k</sup>

TOTAL WEIGHT = 193.65<sup>k</sup>



OUTTER SHIELD BLDG.

REF.

FOR AREA A<sub>2</sub>

$$\kappa = 0.18867 \text{ RAD} \\ 2\alpha = 0.37734 \text{ RAD.}$$

$$A_2: 2\alpha R^2$$

$$A_2 = 2 \left( \frac{10.81}{360} \right) (2\pi)(30)(.75) = 8.49 \text{ FT}^2$$

$$y_1 = R \left( 1 - \frac{\sin \alpha}{\alpha} \right)$$

$$y_1 = 30 \left( 1 - \frac{\sin .18867}{.18867} \right) = 0.1777$$

$$I_1 = R^3 t \left( \alpha + \sin \alpha \cos \alpha - \frac{2 \sin^2 \alpha}{\alpha} \right)$$

$$I_1 = 30^3 (.75) \left( .18867 + \sin .18867 \cos .18867 - \frac{2 \sin^2 .18867}{.18867} \right)$$


$$I_1 = 30^3 (.75) [ .18867 + .18422 - .37288 ]$$

$$I_1 = 0.2025 \text{ FT}^4$$

$$I_2 = R^3 t (\alpha - \sin \alpha \cos \alpha)$$

$$I_2 = 30^3 (.75) (.18867 - \sin .18867 \cos .18867)$$

$$I_2 = 90.02 \text{ FT}^4$$



FOR FULL CIRCLE

$$A = \frac{\pi}{4} (d_o^2 - d_i^2) = 139.4082 \text{ FT}^2$$

$$I = \frac{\pi}{64} (d_o^4 - d_i^4) = 61013.0828 \text{ FT}^4$$

PROPERTIES FOR SECTION

$$A = 139.41 - 8.49 \text{ FT}^2 = 130.92 \text{ FT}^2$$

$$I_{x_2} = 61013.08 - 90.02 = 60923.06 \text{ FT}^4$$

$$I_{x_3} = 61013.08 - 0.20 - 8.49 (29.781)^2 = 53483.03 \text{ FT}^4$$




NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-30-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-9-81 PAGE 12 OF         
LACBWR SEP  
Page B-35 OF 258

OUTTER SHIELD BLDG.

REF.






NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 5-1-79 PROJ. 5101 TASK 026  
CHKD. WJ DATE 6-8-81 PAGE 7 OF         
LACBWR SEP  
Page B-36 of 258

INNER SHIELD BLDG

REF.

MODEL





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-10-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-25-81 PAGE 2 OF 1  
LA CBWR SEP

Page B-37 OF 258

Summary For INNER SHIELD BHg

REF.

NODE No	TRIBUTARY WEIGHT	LIVE LOAD	AREA (in <sup>2</sup> )	$\bar{I}_{xz} \times 10^8$	$\bar{I}_{yz} \times 10^8$	K. x 10 <sup>8</sup>	S.F. 2.
4-C	909.44 "	1065.01 "	$7.3028 \times 10^4$	5.3114 ✓	11.7458 ✓	5.9785 ✓	0.527 ✓ 0.706 ✓
47	2-C	923.75 "	—	$7.3028 \times 10^4$ ✓	5.3114 ✓	11.7458 ✓	5.9788 ✓
48	3-C	Fuel 116.31 " (187.81)	—	$7.3028 \times 10^4$ ✓	$5.3114$ ✓	11.7458 ✓	5.9788 ✓
49	4-C	Fuel 146.17 " (163.17) 603.94 "	—	$8.9232 \times 10^4$ ✓	6.4939 ✓	15.9625 ✓	6.9977 ✓
50	5-C	Fuel 892.77 " (164.27)	—	$8.7783 \times 10^4$	11.5807 ✓	14.8361 ✓	11.0547 ✓
51	6-C	1330.18 " ✓ 640.32 "	—	$7.0205 \times 10^4$ ✓	16.8304 ✓	19.7665 ✓	(3.0733 ✓ 0.786 ✓
52	7-C	557.53 "	—	$7.0205 \times 10^4$	16.8304 ✓	19.7665 ✓	(3.0733 ✓) 0.786 ✓
53	8-C	527.67 "	—	$5.4972 \times 10^4$ ✓	12.4895 ✓	19.0501 ✓	0.2726 ✓ 0.769 ✓



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-5-79 PROJ. 5105 TASK 026  
CHKD. AB DATE 6-12-81 PAGE 1 OF         
LACBWR SEP  
Page B-38 of 258

INNER SHIELD BLDG

REF.


NODE 1-C

INNER SHIELD BLDG

NODE(1-c)

REF.

MODEL






**NUCLEAR ENERGY SERVICES INC.  
NES DIVISION**

BY RR DATE 3-30-79 PROJ. 5101 TASK 026  
CHKD. ap DATE 6-10-81 PAGE        OF         
LACBWR SEP  
Page B-40 of 258

INNER SHIELD BLDG (WEIGHTS MAIN FLOOR NODE 1-C)

REF.





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-5-79 PROJ. 5101 TASK 026  
CHKD. ab DATE 6-10-81 PAGE        OF         
LACBWVR SEP

Page B-41 of 258


INNER SHIELD BLDG

(NODE 1-C)

REF.

PROPERTIES FOR NODE 1-C

DWG  
71-503443



$$H_2 = (30 - 7)^2 + 1^2 = 552''$$
$$H_1 = 32(1.7)^2 + 1^2 = 32(1.7)^2 = 157.26''$$
$$C_1 = 32(1.7)^2 = 32(1.7)^2 = 157.26''$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-2-79 PROJ. 5101 TASK 026  
CHKD. AJ DATE 6-10-81 PAGE 2 OF 2  
LACBWR SEP

Page B-42 OF 258


INNER SHIELD BLDG

NODE 1-C

REF.

DWG  
91-50348

PROPERTIES FOR MAIN FLOOR



RED INDICATES OPENINGS &  
NEGATIVE AREAS


SCALE  $\frac{1}{6}$  = 1'-0"



**NUCLEAR ENERGY SERVICES INC.  
NES DIVISION**

BY RR DATE 4-2-79 PROJ. 5101 TASK 026  
CHKD. ABY DATE 6-10-81 PAGE        OF         
LACBWR SEP

Page B-43 of 258





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-5-79 PROJ. 5101 TASK 026  
CHKD. AZ DATE 6-10-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-44 of 258

INNER SHIELD BLDG.					NODE I-C	REF.
PROPERTIES FOR MAIN FLOOR						
AREA	b	h	d <sub>x2</sub>	d <sub>x3</sub>		
REC + A1	12.57 ✓	25.19 ✓	0 ✓	3.79 ✓✓		
TRI - A2	7.36 ✓	7.36 ✓	10.12 ✓	7.61 ✓✓		
TRI - A3	7.36 ✓	7.36 ✓	10.12 ✓	7.61 ✓✓		
CIR - A4	R=6.25 ✓		0 ✓	2.5 ✓✓		
- REC + A5	9.28 ✓	25.14 ✓	0 ✓	7.14 ✓✓		
TRI - A6	4.07 ✓	4.07 ✓	11.21 ✓	10.92 ✓✓		
TRI - A7	4.07 ✓	4.07 ✓	11.21 ✓	10.42 ✓✓		
- REC + A8	16.17 ✓	17.00 ✓	0 ✓	19.87 ✓✓		
- REC - A9	11.00 ✓	11.00 ✓	0 ✓	18.79 ✓✓		
REC - A10	2.00 ✓	4.25 ✓	3.38 ✓	26.67 ✓✓		
- A11	2.00 ✓	4.25 ✓	3.38 ✓	26.67 ✓✓		
REC + A12	R=29.21 ✓	t <sub>CHORD</sub> =8.5 ✓	0 ✓	25.96 ✓		
	RF 6.25 ✓					
	CIRCLE = A = $\pi r^2 = 122.72 \text{ ft}^2$ ✓					
	I = $.785398R^4 = 1198.42 \text{ ft}^4$ ✓					
	AISC					
	705378					



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-4-79 PROJ. 510 TASK 026  
CHKD. BB DATE 6-11-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWN SEP  
Page B-45 OF 258

INNER SHIELD BLDG. (PROPERTIES FOR MAIN FLOOR) (NODE 1C)

REF.

AREA	$d_{xz}$	$I_{xz}$	$A_{d_{xz}}^2$	$I_{xz} + A_{d_{xz}}^2$	$d_{x3}$	$I_{x3}$	$A_{d_{x3}}^2$	$I_{x3} + A_{d_{x3}}^2$
$A_1 = 316.01$	0	16643.70	0	16643.70	3.79 ✓	4160.92	4539.20	8700.12
$A_2 = 27.08$	-10.12	81.51	2773.87	-2855.38	7.61 ✓	81.51	1568.53	-1650.04
$A_3 = 27.08$	10.12	81.51	2773.87	-2855.38	7.61 ✓	81.51	1568.53	-1650.04
$A_4 = 127.72$	0	1198.92	0	-1198.92	2.5 ✓	1198.92	767 ✓	-1965.42
$A_5 = 233.30$	0	12287.47	0	12287.47	7.14 ✓	679.28	11893.50	13567.78
$A_6 = 8.28$	11.21	7.62	1040.50	-1048.42	10.42 ✓	7.62	899.01	-906.63
$A_7 = 8.28$	11.21	7.62	1040.50	-1048.42	10.42 ✓	7.62	899.01	-906.63
$A_8 = 274.89$	0	6620.27	0	6620.27	19.87 ✓	5989.60	108531.21	114520.82
$A_9 = 121.00$	0	1220.68	0	-1220.08	18.79 ✓	1220.00	42720.76	-43940.84
$A_{10} = 8.50$	3.38	12.79	97.11	-109.90 ✓	26.67 ✓	2.83 ✓	6045.96	-6048.79
$A_{11} = 8.5$	3.38	12.79	97.11	-109.90 ✓	26.67 ✓	2.83 ✓	6095.96	-6048.79
$A_{12} = 1438$	0	208.98	0 ✓	208.98 ✓	25.96 ✓	1.57 ✓	9690.99	9692.56
				25819.52				<del>83325.70</del>

SEE NEXT  
SHEET

$$A = 507.14 \text{ FT}^2 \checkmark \quad 7.303 \times 10^4 \text{ IN}^2$$

$$I_{xz} = 25319.52 \text{ FT}^4 \checkmark \quad 5.3114 \times 10^8 \text{ IN}^4$$

$$I_{x3} = 56649.66 \text{ FT}^4 \text{ FROM NEXT SHEET} \quad 11.7458 \times 10^8 \text{ IN}^4$$

$$K = 28833.18 \text{ FT}^6 \quad 5.9788 \times 10^6$$

$$SF2 = 0.527 \checkmark$$

$$SF3 = 0.706 \checkmark$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-3-79 PROJ. 5101 TASK 026  
CHKD. ABY DATE 4-11-81 PAGE        OF         
LACBWR SEP

Page B-46 OF 258

INNER SHIELD BLDG. (FOR EXCENTRIC MODEL) (NODE 1-C)

REF.

No Area	AREA	$\bar{y}$	A <sub>g</sub>	$d_{x_3}$	$A_{dr_3}^2$	$I_{r_1} + A_{dr_3}^2$
A <sub>1</sub>	316.01	6.29	1987.70	10.77 ✓	36659.92	4081584
A <sub>2</sub>	-27.08	2.45	-66.35	14.61 ✓	-5780.28	-5861.79
A <sub>3</sub>	-27.08	2.45	-66.35	14.61 ✓	-5780.28	-5861.79
A <sub>4</sub>	-122.72	12.57	-1542.59	4.49 ✓	-2474.05	-3672.47
A <sub>5</sub>	233.30	17.21	4015.09	0.15 ✓	5.25	1203.67
A <sub>6</sub>	-8.28	20.49	-169.66	3.43 ✓	-97.41	-1771.69
A <sub>7</sub>	-8.28	20.49	-169.66	3.43 ✓	-97.41	-1771.69
A <sub>8</sub>	274.89	29.94	8230.21	12.88	45602.71	51592.31
A <sub>9</sub>	-121.00	28.86	-3492.06	11.80 ✓	-16848.09	-18068.12
A <sub>10</sub>	-8.50	36.74	-312.29	19.68 ✓	-3292.07	-3294.9
A <sub>11</sub>	-8.50	36.74	-312.29	19.68 ✓	-3292.07	-3294.9
A <sub>12</sub>	<u>14.38</u>	<u>38.53</u>	<u>554.06</u>	<u>21.47</u> ✓	<u>6628.62</u>	<u>6620.19</u>
	<u>EA = 507.14</u>	<u>EAY = 8655.81</u>			<u><math>I_{x_3} = 56644.66 \text{ FT}^4</math></u>	

$$\bar{y} = \frac{\sum A_i y_i}{\sum A_i} = \frac{8655.81}{507.14} = 17.06'$$

CENTROID LIES 6.99 FT TO RIGHT SIDE OF  
CENTERLINE CONTAINMENT VESSEL SHELL

USE 7.0' = 89" ✓

PROPERTIES FOR EXCENTRIC MODEL

AREA = 507.14  $\text{FT}^2$  ✓

$I_{x_3} = 56644.66 \text{ FT}^4$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 5-9-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-11-81 PAGE        OF         
LACBWR SEP

Page B-47 OF 258


INNER SHIELD BLOC

(NODE 1-C)

REF.

N-S

TORSIONAL CONSTANT



CIRCLE

$$r_o = 6.25 \\ r_i = 11.0$$

$$K_{CIR} = \frac{1}{2}\pi(r_o^4 - r_i^4) = 20601.18 \text{ FT}^4$$

$$\text{RECTANGLE } a=17, \\ t=t_1=3.0, b=17$$

$$K_{REC} = \frac{2t\pi((a-t)^2(b-t)^2)}{a^2+b^2-t^2-t_1^2}$$

$$K_{REC} = \frac{2(3)^2(17-3)^2(17-3)^2}{17(3)+17(3)-3^2-3^2}$$

$$K_{REC} = 8232 \text{ FT}^4$$

$$K_{TOTAL} = 28833.18 \text{ FT}^4$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-9-79 PROJ. S101 TASK 026  
CHKD. obj DATE 6-11-81 PAGE — OF —  
LACBWR SEP


Page B-18 OF 258

INNER SHIELD BLDG

(Node 1-C)

REF.

SHEAR AREA FACTOR



$$\text{TOTAL AREA} = 507.14 \text{ ft}^2$$

SHEAR AREA For  $X_3$  EARTHQUAKE

$$2 A_{X_3} = \frac{1}{2} (25+11)(7.5) = 135 \text{ ft}^2$$
$$= \frac{1}{2} (15.5+14)(3.0) = \frac{44.25}{2} \text{ ft}^2 = 22.125 \text{ ft}^2$$
$$2(179.25 \text{ ft}^2) = 358.0 \text{ ft}^2$$

$$S.F.3 = \frac{358.0}{507.14} = 0.706$$

$$SF3 = 0.706$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-9-79 PROJ. 5101 TASK 026  
CHKD. WY DATE 6-12-81 PAGE        OF         
LACBWR SEP


Page B-49 OF 258

INNER SHIELD BLDG

(Node I-C)

REF.

SHEAR AREA FACTOR



$$\text{TOTAL AREA} = 507.19 \text{ in}^2$$

SHEAR AREA FOR  $X_2$  EARTHQUAKE

$$A_{X_2} = \frac{1}{2} (11+25)(25) = 99.25$$

$$\frac{1}{2}(14+25)(6) = 117.00 \checkmark$$

$$(17)(4) - 2(2 \times 4.25) = \frac{51.00}{267.25} \checkmark$$

$$S.F. 2 = \frac{267.25}{507.19} = 0.527$$

SF2 = 0.527



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-18-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-12-81 PAGE        OF         
LACBWR SEP  
Page B-50 OF 258

NODE 1-C

REF.

CENTER OF MASS CALCULATION

DEAD LOAD

	WEIGHT	X <sub>3</sub>	WX <sub>3</sub>
POOL WATER	38.21 "	18.79 "	717.91 ✓
CORE WATER	38.75 "	2.5 "	96.88 ✓
CORE	383.65 " ✓	6.99 " ✓	2681.71 ✓
PLUGS	186.00 ✓	2.5 ✓	465.00 ✓
	<u>646.61 ✓</u>		<u>3961.56 ✓</u>

$$X_3 = \frac{3961.56}{646.61} = 6.13 \text{ FT ✓}$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-5-79 PROJ. S101 TASK 026  
CHKD. ABY DATE 6-10-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-51 OF 258

INNER SHIELD BLDG.

(NODE. LEG)

REF.

PROPERTIES FOR MAIN FLOOR

$$\frac{1}{2} \text{ CHORD LENGTH} = 8.5'$$

$$\text{RADIUS} = 29.21'$$

$$A_{12} = \frac{1}{2} R^2 (2\alpha - \sin 2\alpha)$$

$$\alpha = 16.91$$

$$\alpha = 16.91 \quad \frac{2\pi}{360} = 0.295268$$

$$A = 14.38 \text{ FT}^2 \checkmark$$

$$y_2 = R \left( \frac{4 \sin^3 \alpha}{6\alpha - 2 \sin 2\alpha} - \cos \alpha \right)$$

$$y_2 = (29.21) \left( \frac{0.0985649}{1.771608 - 1.670919} - 0.95672419 \right)$$

$$y_2 = 0.5066 \text{ FT} \checkmark$$

$$2\alpha = 0.590536 \quad \cos \alpha = 0.956724$$

$$\sin \alpha = 0.2909963 \quad \sin 2\alpha = 0.556806 \quad \sin^3 \alpha = 0.0246412$$

$$I_2 = R^4 \left[ \frac{1}{8} (2\alpha - \sin 2\alpha) - \frac{1}{12} \left( \frac{(2\alpha - \sin 2\alpha) \sin^3 \alpha \cos \alpha}{\alpha - \sin \alpha \cos \alpha} \right) \right]$$

$$I_2 = 29.21^4 \left[ \frac{1}{8} (0.03373) - \frac{1}{12} \left( \frac{(0.03373)(0.0235748)}{0.01686486} \right) \right]$$

$$29.21 \left[ (0.00421625) - (0.00392917) \right]$$


$$I_2 = 208.99 \checkmark$$

$$I_1 = R^4 \left[ \frac{1}{8} (2\alpha - \sin 2\alpha) \left( 1 + \frac{2 \sin^3 \alpha \cos \alpha}{\alpha - \sin \alpha \cos \alpha} \right) - \frac{8 \sin^6 \alpha}{9 (2\alpha - \sin 2\alpha)} \right] -$$

$$I_1 = 29.21^4 \left[ (0.00421625) \left( 1 + \frac{0.0571697054}{0.016864864} \right) - \frac{.0005397242}{0.0357296725} \right]$$

$$I_1 = 29.21^4 [ (0.00421625) (3.795740453) - 0.160014656 ]$$

$$I_1 = 1.63 \text{ FT}^4$$





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-2-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-17-91 PAGE        OF         
LACBWR SEP

Page B-52 of 258

INNER SHIELD BLDG.


(WEIGHTS MAIN FLOOR NODE 1-C)

REF.

BEAM WEIGHTS

ASSUME 7" SLAB & PROGRAM FOR BEAM WEIGHTS

QUAN:	BEAM NO	SIZE	LENGTH	WEIGHT	X <sub>E</sub>	X <sub>S</sub>
1	MB-1	12x16 ✓	7.5 ✓	0.844		
1	MB-2	18x20 ✓	12.75 ✓	3.108 ✓		
1	MB-3	18x20 ✓	11.00 ✓	2.681 ✓		
3	MB-4	12x16 ✓	7.75 ✓	2.616 ✓		
—	MB-5	- ✓	- ✓			
1	MB-6	12x16 ✓	9.50 ✓	1.069 ✓		
1	MB-7	18x30 ✓	12.00 ✓	5.175 ✓		
1	MB-8	24x36 ✓	18.00 ✓	13.050 ✓		
1	MB-9	24.36 ✓	16.75 ✓	12.144 ✓		
1	MB-10	18x33 ✓	23.50 ✓	11.456 ✓		
1	MB-11	24x36 ✓	22.50 ✓	16.313 ✓		
1	MB-12	12x16 ✓	12.50 ✓	1.406 ✓		
1	MB-13	12x16 ✓	7.35 ✓	0.825 ✓		
1	MB-14	18x33 ✓	17.16 ✓	8.366 ✓		
1	MB-15	12x21 ✓	10.00 ✓	1.750 ✓		
1	MB-16	12x21 ✓	15.00 ✓	2.625 ✓		
1	MB-17	24x36 ✓	20.50 ✓	14.863 ✓		
1	MB-18	12x24 ✓	12.25 ✓	2.603 ✓		
1	MB-19	24x36 ✓	17.00 ✓	<u>12.325</u>		
				113.219 TOTAL BM. WT.		

INNER SHEILD BLDG	WEIGHTS MAINFLOOR	REF.
LARGE NORTHERN OPENING		
$S = \frac{\pi}{4}(29.21) = 22.99'$		
AREA OF SECTOR 335.06		
AREA OF OBTUSE $\Delta_1$ = 11.74		
AREA OF RIGHT $\Delta_2$ = 28.125		
AREA OF 67.5 - 95 - 67.5 $\Delta_3$ = 94.31		
AREA OF OPENING		
335.06 - 11.74 + 28.125 - 94.31 <hr/> 257.14'	PERTAINANT FORMULII ARE $S = r\theta$ SECTOR AREA = $\frac{sr^2}{2}$ AREA OF OBTUSE $\Delta$ $\sqrt{s(s-a)(s-b)(s-c)}$ WHERE $s = \frac{a+b+c}{2}$ AREA OF OTHER $\Delta$ 'S = $\frac{bh}{2}$	



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-2-79 PROJ. 5701 TASK 026  
CHKD. WY DATE 6-17-81 PAGE        OF         
LACBWR SEP  
Page B-54 of 258

INNER SHIELD BLDG	(WEIGHTS MAINFLOOR NODE 1C)	REF.
<p><u>SLAB WEIGHT</u></p> <p>TOTAL FLOOR AREA = <math>\pi R^2 = \pi (29.4)^2 = 2680.48 \text{ ft}^2</math></p> <p>OPENINGS      <math>\frac{1}{2}(23+15) \times 13.5 = 256.50</math></p> <p>                <math>3 \times 2.67 = 8.01 \checkmark</math></p> <p>                <math>6.25 \times 11.25 = 70.31 \checkmark</math></p> <p>                <math>7.0 \times 7.5 = 52.50</math></p> <p>                <math>11 \times 11 = 121.00 \checkmark</math></p> <p>                <math>7.0 \times 7.5 = 52.50</math></p> <p>                <math>3 \times 2.67 = 8.01 \checkmark</math></p> <p>                <math>3.75 \times 2.75 = 10.30 \checkmark</math></p> <p>10" SLABS      <math>10 \times 15 = 150.00 \checkmark</math></p> <p>                <math>10 \times 12 = 120.00 \checkmark</math></p> <p>CORE AREA      <math>\underline{= 507.14 \checkmark}</math></p> <p>                <math>\underline{1356.27 \square}</math></p> <p>7" SLABS WEIGHT = <math>(2680.48 - 1356.27)(\frac{7}{12})(.150) = 115.87 \text{ k}</math></p> <p>10" SLAB WEIGHT = <math>(270)(.15)(\frac{10}{12}) = 33.75 \text{ k} \checkmark</math></p> <p><u>TOTAL SLAB WEIGHT = 149.61 \text{ k} \checkmark</u></p>		



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-5-79 PROJ. 5101 TASK 026  
CHKD. AZ DATE 6-12-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-55 of 258

INNER SHIELD BLDG. (WEIGHTS MAIN FLOOR NODE 1-C)

REF.

CORE CONCRETE

AREA FROM PREVIOUS CALCULATIONS =  $505.47 \text{ FT}^2$

HEIGHT OF CONCRETE =  $5.06'$

$$\text{WEIGHT} = (505.47)(5.06)(.150) = 383.65 \text{ k } \checkmark$$

CONCRETE PLUG A, B & C  
FROM DWG 91-503464

$$\begin{aligned} \text{WT WATER} &= (11 \times 11 \times 5.06)(0.0624) = 38.21 \\ &\quad (5.06) \pi (6.25^2) (0.0624) \underline{\underline{38.75}} \\ &\quad \underline{\underline{76.96}} \end{aligned}$$

$$A = 64 \text{ k } \checkmark$$

$$B = 62 \text{ k } \checkmark$$

$$C = 60 \text{ k } \checkmark$$

$$\text{TOTAL PLUGS} = 186 \text{ k } \checkmark$$

$$\text{CORE} \quad 383.65 \text{ k } \checkmark$$

$$\text{SLABS} \quad 149.61 \text{ k } \checkmark$$

$$\text{BEAMS} \quad 113.22 \text{ k } \checkmark$$

$$\text{WATER} \quad 38.21 \text{ k } \checkmark$$

$$\begin{array}{r} 38.75 \text{ k } \checkmark \\ \hline 909.44 \text{ k } \checkmark \end{array}$$

$$\begin{array}{l} \text{TOTAL DEAD WEIGHT} \\ \text{FOR NODE 1C} = 909.44 \text{ k } \checkmark \end{array}$$




NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-18-79 PROJ. 5101 TASK D26  
CHKD. obj DATE 6-11-81 PAGE        OF         
LACBWR SEP  
Page B-56 of 258

(NODE I-C)

REF.

LIVE LOAD



CONTAINMENT VESSEL

MAIN FLOOR

EL. 701'-0"

FROM DWG 41-503477



**NUCLEAR ENERGY SERVICES INC.  
NES DIVISION**

BY RR DATE 4-18-79 PROJ. 5101 TASK 026  
CHKD. DFg DATE 6-12-81 PAGE        OF         
LACBWR SEP  
Page B-57 of 258

MAIN FLOOR (NODE I-C)	REF.
<u>LIVE LOAD WEIGHTS</u>	
GRATING AREA	
AREA = $2 \times 10.25 \times 8.5 = 174.25$ $\frac{\text{ft}^2}{}$	
LOAD = 200 PSF ✓	34.85 ✓
OVER FUEL POOL	
AREA $11 \times 11 = 121$ $\frac{\text{ft}^2}{}$	
LOAD = 50 PSF =	6.05 ✓
NEW FUEL	
AREA = $2 \times 2 \times 4.25 = 17$ $\frac{\text{ft}^2}{}$	
LOAD 200 PSF	3.40 ✓
TOTAL AREA = $\pi R^2 = \pi 29.21^2$	
= 2680.48	
SEE PREVIOUS CALC	MISC OPENINGS = 256.50
	<u>70.31 ✓</u>
	326.81
NET AREA = 2680.48 - 326.81	
	- 174.25
	- 121.00
	<u>- 17.00</u>
NET AREA =	2041.42 $\frac{\text{ft}^2}{}$ ✓
LOAD = 500 PSF	1020.71 $\frac{\text{k}}{\text{ft}^2}$ ✓
	<u>1065.01 <math>\frac{\text{k}}{\text{ft}^2}</math></u>
	<u>TOTAL LIVE LOAD ✓</u>



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-10-79 PROJ. 5101 TASK 026  
CHKD. 79 DATE 6-12-81 PAGE — OF —  
LACBWR SEP

Page B-58 of 258

INNER SHIELD PLDG.

(46) NODE 1-C

REF.

SUMMARY FOR NODE 1-C (46)

DEAD LOAD = 909.44<sup>K</sup> ✓

LIVE LOAD: 1065.01<sup>K</sup> ✓

Core Only

AREA =	$7.3028 \times 10^4 \text{ IN}^2$
$\bar{x}_2$ =	84 IN ✓
$I_{x2}$ =	$5.3114 \times 10^8 \text{ IN}^4$ ✓
$I_{x3}$ =	$11.7458 \times 10^8 \text{ IN}^4$ ✓
K =	$5.9788 \times 10^8 \text{ IN}^4$ ✓
SF2 =	0.527 ✓
SF3 =	0.706 ✓



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-9-79 PROJ. 5105 TASK 026  
CHKD. CD DATE 6-12-81 PAGE        OF         
LACBWR SEP  
Page B-59 of 258

INNER SHIELD BLDG	NODE Z-C	REF.
	<u>NODE Z-C</u>	




NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 5-1-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-8-81 PAGE — OF —  
LACBWR SEP  
Page B-60 of 258

INNER SHIELD BLDG

REF.

MODEL





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-18-79 PROJ. 5101 TASK 026  
CHKD. AJ DATE 6-12-81 PAGE — OF —  
LACBWR SET  
Page B-61 of 258

NODE 2-C		REF.
PROPERTIES - FROM NODE 1-C	$\checkmark A = 507.14 \text{ FT}^2$ $\checkmark I_{yz} = 25614.52 \text{ FT}^4$ $\checkmark I_{xz} = 56694.66 \text{ FT}^4$ $\checkmark K = 28833.18 \text{ FT}$ $\checkmark SF_2 = 0.527$ $\checkmark SF_3 = 0.706$	$7.3028 \times 10^4 \text{ IN}^2$ $5.3114 \times 10^8 \text{ IN}^4$ $11.7458 \times 10^8 \text{ IN}^4$ $5.9788 \times 10^8$ ✓



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-9-79 PROJ. 5105 TASK 026  
CHKD. 057 DATE 6-17-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-62 of 258

INNER SHIELD BLDG.	NODE - Z-C	REF.
CORE AREA IS APPROXIMATELY EQUAL TO THAT AT NODE 1-C.  AREA = $507.14 \text{ ft}^2$ ✓ LENGTH = $10.12'$ ✓  WEIGHT = $507.14 \times 10.12 \times .15 = 769.84 \text{ k}$ ✓ WATER = $11 \times 11 \times 10.12 \times .0624 = 76.41 \text{ k}$ ✓ $\pi 6.25^2 \times 10.12 \times 0.0624 = 77.50 \text{ k}$ ✓ <u><math>923.75 \text{ k}</math> TOTAL WEIGHT</u>		



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-8-79 PROJ. 5101 TASK 026  
CHKD. O.P. DATE 6-12-81 PAGE        OF         
LACBWR SEP  
Page B-63 of 258

INNER SHIELD BLDG

(NODE 2-C)

REF.

CENTER OF MASS CALCULATION

DEAD LOAD	WEIGHT	X <sub>3</sub>	WX <sub>3</sub>
POOL WATER	76.41 ✓	18.79 ✓	1435.79 ✓
CORE WATER	77.50 ✓	2.5 ✓	193.75 ✓
CORE WT	<u>769.84 ✓</u>	<u>6.99 ✓</u>	<u>5381.18 ✓</u>
	923.75		7010.67 ✓

$$\bar{X}_3 = \frac{7010.67}{923.75} = 7.59 \text{ FT} \checkmark$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 5-10-79 PROJ. S101 TASK 026  
CHKD. 038 DATE 6-12-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-61 of 258

INNER SHIELD BLDG.	(47) NODE Z-C	REF.

SUMMARY For NODE Z-C (47)

DEAD LOAD = 923.75"

LIVE LOAD = —

AREA =  $7.3028 \times 10^4 \text{ IN}^2$

$\bar{x}_z$  = 84 IN

$I_{yz}$  =  $5.3119 \times 10^8 \text{ IN}^4$

$I_{xz}$  =  $11.7458 \times 10^8 \text{ IN}^4$

$K$  =  $5.9788 \times 10^8 \text{ IN}^4$

S.F.2 = 0.527

S.F.3 = 0.706



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-9-79 PROJ. 5105 TASK 026  
CHKD. O.P. DATE 6-12-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-65 of 258

INNER SHIELD BLDG	NODE 3-C	REF.
	<u>NODE 3-C</u>	



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 5-1-79 PROJ. 5101 TASK 026  
CHKD. AW DATE 6-9-81 PAGE — OF —  
LACSWR SEF


Page B-66 of 258

INNER SHIELD BLDG

(NODE 3-C)

REF.

MODEL





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-18-79 PROJ. 5701 TASK D26  
CHKD. GSF DATE 6-12-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-67 of 258

NODE 3-C

REF.

PROPERTIES - FROM NODE 1-C

$$\checkmark A = 507.14 \text{ FT}^2 = 7.3028 \times 10^4 \text{ IN}^2$$

$$\checkmark I_{xz} = 26614.52 \text{ FT}^4 = 5.3119 \times 10^8 \text{ IN}^4$$

$$I_{x_3} = 56644.66 \text{ FT}^4 = 11.7458 \times 10^8 \text{ IN}^4$$

$$\checkmark K = 2883316 \text{ FT}^4 = 5.9788 \times 10^8 \text{ IN}^4$$

$$SF_2 = 0.527$$

$$\checkmark SF_3 = 0.706$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-9-79 PROJ. 5105 TASK 026  
CHKD. Ary DATE 6-16-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-68 of 258

INNER SHIELD BLDG.

NODE 3-C

REF.

CORE AREA = TOP 5.07' SAME AS NODE 4C  
 $5.07 \times 507.14^2 \times .15 = 385.68^2$  ✓

BOTTOM 6.88 SAME AS NODE 4C  
 $6.88 \times 582.93^2 \times .15 = \frac{601.58^2}{987.26}$  ✓

WATER  $11 \times 11 \times 11.95 \times .0625 = 90.23^2$  ✓  
 $\frac{\pi 6.25^2 \times 507 \times .0625}{38.82^2} = \frac{1116.31^2}{\text{TOTAL DEAD LOAD}}$  ✓

CORE PROPERTIES USE THOSE FROM 1-C

LOAD



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-27-79 PROJ. 5101 TASK 026  
CHKD. AS DATE 6-16-81 PAGE        OF         
LAC BWR SEP  
Page 68a of 258


REF.

SPENT FUEL RACK

WEIGHT OF FUEL STORAGE RACK + FUEL = 2860 ✓  
PRESSURE LOAD 0.026K  $\text{lb/in}^2$

CASK WEIGHT = 100K ✓

REF: "STRUCTURAL ANALYSIS REPORT  
FOR THE LACROSSE BOILING WATER  
REACTOR SPENT FUEL POOL STRUCTURE  
BY NES INC





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-8-79 PROJ. 5101 TASK 026  
CHKD. OY DATE 6-16-81 PAGE — OF —  
LACBWR SEP  
Page B-69 of 258

INNER SHIELD BLDG

(HOPE 3-C)

REF.

CENTER OF MASS CALCULATION

DEAD LOAD	WEIGHT	X <sub>3</sub>	WX <sub>3</sub>
POOLWATER	90.23 ✓	18.79 ✓	1695.42 ✓
CORE WATER	38.82 ✓	2.5 ✓	97.05 ✓
COREWT.	385.68 ✓	-6.99 ✓	2695.90 ✓
SPENT FUEL	601.58 ✓	7.53	4525.53
	71.50 ✓	18.79 ✓	1343.49 ✓
	1187.81		10357.39

$$\bar{X}_3 = \frac{10357.39}{1187.81} = 8.72'$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 5-10-79 PROJ. 5101 TASK 026  
CHKD. CGY DATE 6-16-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-70 of 258

INNER SHIELD BLDG.

(48) NODE 3-C

REF.

SUMMARY FOR NODE 3C (48)

DEAD LOAD = 1116.31<sup>k</sup> ✓

✓ LIVE LOAD = —

✓ AREA =  $7.3028 \times 10^4$  IN<sup>2</sup>

✓  $\bar{x}_z$  = 84 IN

✓  $I_{xz}$  =  $5.3114 \times 10^8$  IN<sup>4</sup>

✓  $I_{xz}$  =  $11.7458 \times 10^8$  IN<sup>4</sup>

✓ K =  $5.9788 \times 10^8$  IN<sup>4</sup>

✓ SF. 2 = 0.527

✓ SF. 3 = 0.706



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-5-79 PROJ. 5105 TASK 026  
CHKD. 02 DATE 6-16-81 PAGE        OF         
LACBWR SEP

Page B-71 of 258


INNER SHIELD BLDG	NODE 4-C	REF.
	<u>NODE 4-C</u>	



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-1-79 PROJ. 5101 TASK 026  
CHKD. QD DATE 6-8-81 PAGE        OF         
LACBWR SEP

Page B-72 of 258






NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-3-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-15-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-73 of 258

INNER SHIELD BLDG. (WEIGHTS FOR INTERMEDIATE FLOOR)

REF.



PLAN INTERMEDIATE FLOOR



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION


BY R.R. DATE 4-2-79 PROJ. 5101 TASK 026  
CHKD. AR DATE 6-15-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-74 of 258

INNER SHIELD BLDG

NODE A-C

REF.

PROPERTIES FOR INTERMEDIATE FLOOR.



$H_2 = 2(30 - 7.53)12'' = 539.3''$   
 $H_2 = 22.57'$   
 $H_2 = 12.57'$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-19-77 PROJ. 5101 TASK 026  
CHKD. ASy DATE 6-15-81 PAGE        OF         
LACBWR SEP

Page B-75 of 258

INNER SHIELD BLDG.

NODE 4-L


REF.

PROPERTIES FOR AREA A<sub>4</sub>

$$A = \pi R^2 = 83.65 \checkmark$$

$$I = .785398 R^4 \checkmark$$

$$I = 556.79 \text{ FT}^4 \checkmark$$





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 9-5-79 PROJ. 5101 TASK 026  
CHKD. DG DATE 6-15-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-76 of 258

(NODE 4-C)

REF.

$\frac{1}{2}$  CHORD LENGTH 10.25'

RADIUS = 29.21

$$y_2 = R \left( \frac{4 \sin \alpha}{6R - 3 \sin 2\alpha} - \cos \alpha \right)$$

$$\sin \alpha = \frac{10.25}{29.21} = .350907 \Rightarrow \alpha = .358510$$

$$y_2 = \left( \frac{.1728374}{2.15124 - 1.97156} - .93641 \right) 29.21$$


$$y_2 = 0.74508 \text{ ft}$$

$$A = 25.55 \text{ ft}^2$$

$$I_x = 540.94 \text{ ft}^4$$

$$I_y = 6.05 \text{ ft}^4$$

COMPUTER  
PROG TI-59






NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-2-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-16-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-77 of 258

INNER SHIELD PLDG

REF.






NUCLEAR ENERGY SERVICE, INC.  
NES DIVISION

BY R.R. DATE 4-5-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-15-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR. SEP

Page B-78 of 258





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-679 PROJ. 5105 TASK 026  
 CHKD. AB DATE 6-15-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
 Page B-79 of 258

INNER SHIELD BLDG					(NODE 4-C)	REF.
PROPERTIES FOR NODE						
AREA	b	h	d <sub>xz</sub>	d <sub>x3</sub>		
REC A <sub>1</sub>	12.57 ✓	25.14 ✓	0 "	3.79 ✓		
TRI A <sub>2</sub>	7.36 ✓	7.36 ✓	10.12	7.62 ✓		
TRI A <sub>3</sub>	7.36 ✓	7.36 ✓	10.12	7.62 ✓		
CIRCLE A <sub>4</sub>	R=5.16 ✓	- ✓	0 "	2.5 -		
REC A <sub>5</sub>	7.71 ✓	25.14	0	6.36		
TRI A <sub>6</sub>	2.32	2.5	11.80	9.38 ✓		
TRI A <sub>7</sub>	2.32	2.5	11.80	9.38 ✓		
REC A <sub>8</sub>	17.02 ✓	20.5 ✓	0	18.72 =		
REC A <sub>9</sub>	11.0 ✓	11.0 ✓	0	18.79 ✓		
CHORD A <sub>10</sub>	R=29.21 ✓	$\frac{1}{2}$ CHORD=18.25 ✓	28.1 "			
$y_2 = R \left( \frac{4 \sin^3 \alpha}{6\alpha - 3 \sin 2\alpha} - \cos \alpha \right)$						
$y_2 = .75$						
TRI	$I = \frac{bh^3}{36}$					
REC	$I = \frac{b_2 h^3}{12}$					



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-6-79 PROJ. 5101 TASK 026  
CHKD. OB DATE 6-15-81 PAGE        OF         
LACBWR SEP

Page B-80 of 258

INNER SHIELD BLDG. (PROPERTIES FOR NODE 4-C)

REF.

AREA	$d_{x2}$	$I_{y2}$	$Ad_{x2}^2$	$I_{y2} + Ad_{x2}^2$	$d_{x3}$	$I_{x3}$	$Ad_{x3}^2$	$I_{x3} + Ad_{x3}^2$	
$\checkmark A_1 = 316.0$	0	16643.70	0	16643.70	3.79	4160.92	4539.20	8700.12	
$\checkmark A_2 = -27.08$	10.12	81.51	2773.37	-2855.38	7.62	81.51	1572.66	-1654.17	
$\checkmark A_3 = -27.08$	10.12	81.51	2773.37	-2855.38	7.62	81.51	1572.66	-1654.17	
$A_4 = -83.55$	0	556.79	0	-556.79	7.5	556.79	0	-556.79	
$\checkmark A_5 = 193.82$	0	10208.66	0	10208.66	6.36	960.16	7840.32	8800.48	
$-A_6 = -2.90$	11.80	NEG	403.80	-403.80	9.38	NEG	-255.15	-255.15	
$-A_7 = -2.90$	11.80	NEG	403.80	-403.80	9.38	NEG	255.15	-255.15	
$A_8 = 348.91$	0	12219.12	0	12219.12	18.72	8472.70	122271.46	130699.16	
$\checkmark A_9 = 121$	0	1220.08	0	-1220.08	18.79	1220.08	42720.76	-43940.84	
$A_{10} = 25.55$	0	540.94	0	540.94	28.1	6.05	20179.59	20180.59	
				31317.19					<u>120259.08</u>
									SEE ADD CALC

$$AREA = 619.67 \text{ FT}^2 = 8.9232 \times 10^9 \text{ IN}^2$$

$$I_{x2} = 31317.19 \text{ FT}^4 = 6.4939 \times 10^8 \text{ IN}^4$$


$$\sqrt{I_{x3}} = 76979.60 \text{ FT}^4 = 15.9625 \text{ IN}^4$$



**NUCLEAR ENERGY SERVICES INC.  
NES DIVISION**

BY R.R. DATE 4-5-79 PROJ. 5101 TASK 026  
CHKD. OSJ DATE 6-15-81 PAGE        OF         
LACEWR. SEP

Page B-81 of 258





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-3-79 PROJ. 5101 TASK 026  
CHKD. ABY DATE 6-15-81 PAGE — OF —  
LACBWR SEP

Page B-82 of 258

INNER SHIELD ISLDG.		(NODE 4-C)						REF.
No	AREA	AREA	y	A <sub>y</sub>	d <sub>x3</sub>	A d <sub>x3</sub> <sup>2</sup>	I <sub>x3</sub>	I <sub>x3+A d<sub>x3</sub><sup>2</sup></sub>
A <sub>1</sub>	3/6.0	6.24	/ 1987.70	/ 11.32	40493.00	4160.92	44653.92	
A <sub>2</sub>	- 27.08	2.45	- 68.78	15.15	6215.47	- 81.51	- 6296.98	
A <sub>3</sub>	- 27.08	2.45	- 68.78	15.15	6215.47	- 81.51	- 6296.98	
A <sub>4</sub>	- 83.65	12.57	- 1542.59	5.03	2116.42	- 556.79	- 2673.21	
A <sub>5</sub>	193.82	16.43	3184.46	1.17	265.32	960.16	1225.49	
A <sub>6</sub>	- 2.90	19.45	- 56.41	1.85	NEG	- NEG	NEG	
A <sub>7</sub>	- 2.90	19.45	- 56.41	1.85	NEG	- NEG	NEG	
A <sub>8</sub>	348.91	28.79	10045.12	11.19	43689.15	8422.70	52111.85	
A <sub>9</sub>	- 121.00	28.86	- 2492.06	11.26	15341.30	- 1220.08	16561.38	
A <sub>10</sub>	<u>25.55</u>	<u>38.17</u>	<u>975.24</u>	<u>20.57</u>	<u>10810.84</u>	<u>6.05</u>	<u>10816.89</u>	
EA	<u>619.67</u>		<u><math>\Sigma A_y</math></u>	<u>10907.49</u>			<u>I<sub>x3</sub></u>	<u>76979.60</u> FT <sup>4</sup>
$\bar{y}$	$\frac{\Sigma A_y}{\Sigma A}$	=	$\frac{10907.49}{619.67}$	= 17.60				
Cg is 17.60 - 10.07 = 7.53" TO RIGHT OF & CONTAINMENT								
USE 90"								



**NUCLEAR ENERGY SERVICES INC.  
NES DIVISION**

BY R.R. DATE 5-3-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-15-81 PAGE        OF         
LACBWR SEP

Page B-83 of 258



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 5-9-79 PROJ. 5101 TASK 026  
CHKD. Og DATE 6-15-81 PAGE 1 OF 1  
LAC BWR SEP


Page B-84 of 258

INNER SHIELD BLDG.

NODE 4-C

REF.

TORSIONAL CONSTANT



$K_{int}$

$$R_1 = 11.0$$

$$R_2 = 5.16$$

$$K = \frac{1}{2} \pi (R_1^4 - R_2^4)$$

$$K = \frac{1}{2} \pi (11.0^4 - 5.16^4)$$

$$K = 21884.46 \text{ FT}^4$$

$K_{ext}$

$$K = \frac{2\pi t_1 (a-t)^2 (b-t)^2}{a^2 + b^2 - t^2 - t_1^2}$$

$$t_1 = 4.75 \quad t = 3.0$$

$$a = 17 \quad b = 20.5$$

$$K = \frac{2(4.75)(3)(17-3)^2(20.5-4.75)}{17(3) + 20.5(4.75) - 3^2 - 4.75^2}$$


$$K_{tot} = 33796.86 \text{ FT}^4 + 6.9977 \times 10^8 \text{ in.}^4 = 11862.90 \text{ FT}^4$$



INNER SHIELD BLDG.

(NODE 4-C)

REF.

SHEAR AREA FACTOR

$$\text{TOTAL AREA} = 619.67 \text{ FT}^2$$

SHEAR AREA FOR  $X_2$  EARTH QUART

$$2[A_{x_2} = \frac{1}{2}(11+25)(7.5) = 135.0 \\ + \frac{1}{2}(12+15.5)(4.5) = 61.88 \\ \frac{2(196.88)}{619.67} = 0.635]$$

$$S.F. 3 = \frac{393.76}{619.67} = 0.635$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION


BY K.K. DATE 5-4-74 PROJ. 5101 TASK 026  
CHKD. GW DATE 6-15-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-86 of 258

INNER SHIELD BLDG.

(NODE 4-C)

REF.

SHEAR AREA FACTOR



TOTAL AREA =  $619.67 \text{ ft}^2$   
SHEAR AREA For  $X_3$  FACE SURFACE

$$\begin{aligned} A_{x_3} &= \frac{1}{2}(11+25)(7.5) = 125.0 \\ &+ \frac{1}{2}(14+25)(6) = 117.0 \\ &+ 20(3.5) = \frac{70.0}{322.0 \text{ ft}} \end{aligned}$$

$$SF, Z = \frac{322.0}{619.67} = 0.520$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-9-79 PROJ. 5101 TASK 026  
CHKD. CG DATE 6-15-81 PAGE        OF         
LAC BWR SEP  
Page B-B7 of 258

INNER SHIELD BLDG (WEIGHT INTERMEDIATE FLOOR)					REF.
<u>BEAM WEIGHTS</u>					
QUANTITY	BEAM NO	SIZE	LENGTH	WEIGHT	
8"	IB-1	17x21	9.75 "	2.245 -	
8"	IB-2	9x15	7.50 "	0.492 -	
8"	IB-3	18x21	12.00 "	2.925 -	
8"	IB-4	21x27	15.50 "	6.442 -	
7'	IB-5	9x15	12.50 "	0.938 -	
7'	IB-6	18x29	23.00 "	7.33	
8"	IB-7	36x27	21.50 "	15.32 -	
7'	IB-8	9x15	8.50 "	0.638 -	
7'	IB-9	9x15	8.00 "	0.600 -	
7'	IB-10	20x30	16.75 "	8.026 -	
7'	IB-11	36x15	15.00 "	4.500 -	
7'	IB-12	27x33	17.75 "	12.980 -	
7'	IB-13	18x24	13.00 "	4.144	
8"	IB-14	17x21	13.50	3.108	
8"	IB-15	21x24	15.00 "	5.250 -	
				74.938 ✓	



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 5-8-79 PROJ. 5101 TASK 026  
CHKD. BS DATE 6-16-81 PAGE 1 OF 1  
LACBWR SEP

Page B-88 of 258

INNER SHIELD BLOC

(NODE 4-C)

REF.

CENTER OF MASS CALCULATION

DEAD LOAD	WEIGHT	X <sub>3</sub>	W X <sub>3</sub>
POOL WATER	89.62 ✓	18.79 ✓	1683.96 ✓
CORE	1037.91	7.53	7815.46
SPENT FUEL	<u>143.00 ✓</u>	<u>18.79 ✓</u>	<u>2685.97 ✓</u>
	1270.53		12185.39

$$\bar{X}_3 = \frac{12185.39}{1270.53} = 9.59' \checkmark$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-9-79 PROJ. 5105 TASK 024  
CHKD. CR DATE 6-16-81 PAGE        OF         
LACBWR SEP

Page B-89 of 258

REF.

$$10'' \text{ SLAB} \quad 16 \times 6 \times \frac{10}{12} \times .150 = 12.0^{\text{k}} \checkmark$$

$$7'' \text{ SLAB} \quad \text{APPROXIMATELY } 312^{\text{sq}} \times \frac{7}{12} \times .150 = 27.3^{\text{k}} \checkmark$$

$$8'' \text{ SLAB} \quad \text{APPROXIMATELY } 525^{\text{sq}} \times \frac{8}{12} \times .150 = 52.5^{\text{k}} \checkmark$$

$$6'0'' \text{ SLAB} = 224^{\text{sq}} - 2\pi \frac{(7.0)^2}{4} = 147.4^{\text{sq}} \times 6 \times .15 = 132.3^{\text{k}} \checkmark$$

$$7'0'' \text{ PLUGS} = 2\pi \frac{(7.0)^2}{4} \times 2.83 \times .15 = 32.67^{\text{k}} \checkmark$$

$$\text{TOTAL SLAB WT} \quad 256.77^{\text{k}}$$

$$\text{CORE CONCRETE} \quad 11.87' \text{ HEIGHT} \quad \text{AREA} = 582.93^{\text{sq}}$$

$$\text{CORE WEIGHT} = 11.87 \times 582.93 \times .15 = 1037.91^{\text{k}} \checkmark$$

$$\text{SLAB WEIGHT} = = 257.70^{\text{k}}$$

$$\text{BEAM WEIGHT} = = 74.94^{\text{k}}$$

$$\text{WATER WT} = 11 \times 11 \times 11.87 \times .0624 = 89.62^{\text{k}}$$

$$\underline{1460.17^{\text{k}}} \quad \underline{\text{TOTAL DEAD LOAD}}$$




NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-18-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-16-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-90 of 258

9-C

REF.

LIVE LOAD



CONTAINMENT VESSEL  
INTERMEDIATE FLOOR  
EL. 667-0



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-18-79 PROJ. 5101 TASK 026  
CHKD. QSY DATE 6-16-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-91 of 258

INNER SHIELD BLDG	INTERMEDIATE FLOOR	NODE 4-C	REF.
<u>LIVE LOAD WEIGHTS</u>			
TOTAL AREA = $\pi r^2 = \pi 29.21 = 2680.48 \frac{\text{ft}^2}{\text{}}$			
CORE AREA	= - 507.14		
POOL AREA	= - 121.00 ✓		
OPENINGS	= - 256.50		
	= <u>- 70.31 /</u>		
	1725.53 $\frac{\text{ft}^2}{\text{}}$		
LOAD = 350 PSF			
<u>603.94 K TOTAL ✓</u>			
<u>FLOOR LIVE LOAD</u>			



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-10-79 PROJ. 5101 TASK 026  
CHKD. CR DATE 6-16-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-92 of 258

INNER SHIELD BLDG

(49) NODE 4-C

REF.

SUMMARY FOR NODE 4-C (49)

DEAD LOAD =  $1460.17^{\text{in}}$

LIVE LOAD =  $603.94^{\text{in}}$

AREA =  $8.9232 \times 10^9 \text{ in}^2$

$\bar{x}_2$  = 90 IN

$I_{x2}$  =  $6.4939 \times 10^8 \text{ in}^4$

$I_{x3}$  =  $15.9625 \times 10^8 \text{ in}^4$

$K$  =  $6.9977 \times 10^8 \text{ in}^4$

$SF_2$  = 0.520

$SF_3$  = 0.635



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-19-79 PROJ. 5101 TASK D 26  
CHKD. ASZ DATE 6-16-81 PAGE        OF       

LACBWR SEP

Page B-93 of 258

REF.

NODE 5-C



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-1-79 PROJ. 5101 TASK 026  
CHKD. ASX DATE 6-8-81 PAGE        OF         
LACBWR SEP


Page B-94 of 258

INNER SHIELD BLDG

(NODE 5-C)

REF.


MODEL





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-17-79 PROJ. 5101 TASK 026  
CHKD. ABY DATE 4-16-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-95 of 258





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-17-79 PROJ. 5101 TASK 026  
CHKD. WY DATE 6-16-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-96 of 258

INNER SHIELD BLDG	NODE 5-C	REF.
<p>AREA A, OUTSIDE A REGULAR POLYGON</p> <p><math>m = \text{NUMBER OF SIDES} * 8</math></p> <p><math>R = 14.28 \checkmark</math>  <math>R_1 = 15.46 \checkmark</math>  <math>a = 11.89 \checkmark</math></p> <p><math>\tan \phi = \frac{a}{2R_1} = \frac{11.89}{2 \times 15.46} = 0.3829 \sim</math>  <math>\phi = 20.9502603 \sim</math></p> <p><math>A = n R_1^2 \tan \phi = 732.19 \text{ FT}^2 \sim</math>  <math>I_{I_o} = \frac{A (GR^2 - a^2)}{24} \sim</math>  <math>I_o = \frac{732.19 (6 \times 14.28^2 - 11.89^2)}{24} \sim</math>  <math>I_o = 33049.98 \checkmark</math></p> <p><math>A = A_o - A_i</math>  <math>A = 418.17 \text{ FT}^2</math>  <math>Ad_{x_3}^2 = 2613.56 \checkmark</math></p> <p><math>I = I_o - I_{I_n}</math>  <math>I_{I_n} = \frac{314.02 (6 \times 10.59^2 - 8.06^2)}{24} \sim</math>  <math>I_{I_n} = 7871.25 \checkmark</math></p> <p><math>I_{x_3} = I_o + 25178.73 \text{ FT}^4 \checkmark</math>  <math>I_{x_3} + Ad_{x_3}^2 = 27792.29 \text{ FT}^4 \sim</math></p>	<p>Node 5-C</p>	



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-17-79 PROJ. 5101 TASK 026  
CHKD. QY / DATE 6-19-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-97 of 258

INNER SHIELD BLDG.

NODE 5-C

REF.

AREA A<sub>2</sub>


$$A = b d r \quad 2.83 \times 11.0 = 31.13 \text{ FT}^2$$

$$C = \frac{b s_i n \alpha + d \cos \alpha}{2}$$

$$C = \frac{(2.83 + 11.0) . 707}{2} = 9.89$$

$$I = \frac{bd(b^2 \sin^2 \alpha + d^2 \cos^2 \alpha)}{12}$$

$$I = \frac{2.83 \times 11.0 (2.83^2 + 11.0^2) (.707)^2}{12} = 167.28 \checkmark$$



$$d_{x_2} = 12.28 \text{ FT}$$

$$Ad_{x_2}^2 = 4694.35$$

$$Ix_{x_2} + Ad_{x_2}^2 = 4861.63 \text{ FT}^4$$

$$d_{x_3} = 8.92 \text{ FT}$$

$$Ad_{x_3}^2 = 2207.00$$

$$Ix_{x_3} + Ad_{x_3}^2 = 2379.28 \text{ FT}^4$$

AREA A<sub>2</sub>

$$A = 2.42 \times 10.25 = 24.81 \checkmark$$


$$Ix_{x_2} = \frac{bd^3}{12} = 12.1 \text{ FT}^4 \checkmark$$

$$Ix_{x_3} = \frac{bd^3}{12} = 217.17 \text{ FT}^4 \checkmark$$

$$d_{x_3} = 13.55$$

$$Ad_{x_3}^2 = 4555.18 \text{ FT}^4$$

$$Ix_{x_3} + Ad_{x_3}^2 = 4772.35$$



AREA A<sub>4</sub>


USE AREA A<sub>12</sub> OF BASEMENT

$$A = 105.75 \text{ FT}^2$$

$$Ix_{x_2} + Ad_{x_2}^2 = 20934.17 \text{ FT}^4$$

$$Ix_{x_3} + Ad_{x_3}^2 = 60357.69 \text{ FT}^4$$

$$A_1 = 2A_2 + A_3 + A_4 + A_5$$



<u>AREA</u>	<u><math>I_{x_L}</math></u>	<u><math>I_{x_2}</math></u>
610.99 $\text{FT}^2$	$55848.26 \text{ FT}^4$ $11.5807 \times 10^8 \text{ IN}^4$	



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-17-79 PROJ. 5101 TASK 026  
CHKD. Q3 DATE 6-19-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page 3-98 of 258

NODES-C

REF.

AREA No	AREA	y	Ay	$d_{x_3}$	$A_{d_{x_3}}^2$	$I_{x_3}$	$I_{x_3} + A_{d_{x_3}}^2$
$A_1 =$	418.17	14.28	5971.47	5.36	12013.86	27792.29	3980615
$2 A_2 =$	2(31.13)	(25.09)	156210	5.45	1849.28	167.28	2016.56
$A_3 =$	24.81	28.69	711.80	9.05	2082.00	217.17	2249.17
$A_4 =$	<u>105.75</u>	<u>35.49</u>	<u>3753.07</u>	<u>15.85</u>	<u>26566.78</u>	<u>908.84</u>	<u>2747562</u>
	<u>610.99</u>		<u>11998.45</u>				$I_{x_3} = 71547.5 \text{ FT}^4$

$$\bar{y} = \frac{EA_y}{EA} = \frac{1199845}{610.99} = 19.64'$$

$\bar{y} = 19.64 - 11.78 = 7.86'$  TO RIGHT OF E OF  
CONTAINMENT BDGS.

USE 94IN ✓

$$I_{x_3} = 71547.50 \text{ FT}^4 = 14.8361 \times 10^8 \text{ IN}^4$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION


BY R.R DATE 5-9-79 PROJ. 5101 TASK 026  
CHKD. 03 DATE 6-11-81 PAGE        OF         
LACBWR SEP  
Page B-99 of 258

INNER SHIELD BLDG

(NODES-C)

REF.

TORSIONAL CONSTANT



$$K_{C,I,R} = \frac{1}{2}\pi(R_i^4 - R_o^4)$$

$$K_{C,I,R} = \frac{1}{2}\pi(14^4 - 11^4) = 37345.68 \text{ FT}^4$$

$$K_{REC} \quad t = 2.04 \quad t_1 = 2.83 \\ a = 16.5 \quad b = 29$$

$$K = \frac{2\pi t(a-t)^2(b-t)^2}{at + bt_1 - t^2 - t_1^2}$$

$$K = \frac{2(2.04)(16.5-2.04)^2(29-2.83)^2(2.83)}{16.5(2.04) + (29)(2.83) - 2.83^2 - 2.04^2} \\ 82.07 \quad 8.01 - 4.16$$

$$K = 15,966.01$$

$$K_{TOTAL} = 53311.77 \text{ FT}^4 \\ 11.0547 \times 10^8 \text{ IN}^4$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION


BY K.K. DATE 4-17-79 PROJ. 5101 TASK 026  
CHKD. CBY DATE 6-16-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-100 of 258

INNER SHIELD BLDG

NODE 5-C

REF.






NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-17-79 PROJ. 5101 TASK 026  
CHKD. QSY DATE 6-16-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-101 of 258





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY K.A. DATE 6-14-81  
CHKD. AZ DATE 6-14-81 PAGE 8-102 OF 258  
LACBWR SEP  
Page 8-102 of 258

INNER SHIELD BLDG	(NODE 5-C)	REF.
$A_1 = \frac{1}{2}(12+21)(4.5)(2) = 148.5 \checkmark$ $A_2 = 2(0.707)(31.13) = 44.02 \checkmark$ $A_3 = 24.81 \checkmark$ $A_4 = (\cos 63.5)(105.75) = \frac{47.19}{264.52}$  TOTAL AREA = 610.99 ft <sup>2</sup>  $SF. 3 = \frac{264.52}{610.99} = 0.433 \checkmark$ $A_1 = \frac{1}{2}(12+21)(4.5)(2) = 148.5 \checkmark$ $A_2 (0.707)(2)(31.13) = 44.02 \checkmark$ $A_4 (\sin 63.5)(105.70) = \frac{94.59}{287.11} \checkmark$  $S.F. 2 = \frac{287.11}{610.99} = 0.470 \checkmark$  SF.3. = 0.433 ✓ SF.2 = 0.470 ✓		



NUCLEAR ENERGY SERVICES


BY AZ DATE 6-22-71 PROJ. S101 TASK 026  
 CHKD. NC DATE 7/12/71 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
 LAICB WR SEP

Page B-103 of 258

INNER SHEILD BLDG

NODE 5-C

REF.



NODE 5-C

WEIGHT CALCULATION

150#

$$\begin{aligned} \text{SLAB} & \quad 1-C \quad 5' @ 619.67^{\$} \\ \text{ABOVE 5-C} & \quad 1.92' @ 121.00^{\$} \end{aligned}$$

$$\text{SLAB} \quad \text{BELOW 5-C} \quad 2.75' @ (10.5 \times 17.5)^{\$}$$

$$= 164.75 \text{ k}$$

$$= 34.85 \text{ k}$$

$$= 75.80 \text{ k}$$

TOTAL 5-C AREA IS 187.50<sup>4</sup>

SUBTRACTED

$$\begin{aligned} \text{AREA} \quad ZA_6 & = 23.50^{\$} \\ ZA_5 & = 29.72^{\$} \\ A_{12} & = 105.75^{\$} \\ \hline & 158.97 \end{aligned}$$

 DATA  
FROM  
NODE  
6-C

232#

$$\begin{aligned} \text{EL 654.75'} & \quad \text{TO EL 657.5'} \quad 2.75' @ (187.50 - 158.97)^{\$} \\ & = 209.60 \text{ k} \end{aligned}$$

$$5-C \quad 4.38' @ 487.50^{\$}$$

$$= 495.38 \text{ k}$$

$$\begin{aligned} \text{POOL} \quad 3.08' & @ 121^{\$} \times 62.4^{\#} \\ \text{WATER} & = 23.26 \text{ k} \end{aligned}$$

$$\begin{aligned} \hline & \text{TOTAL DEAD WEIGHT} \\ & 1268.79 \text{ k} \end{aligned}$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 5-8-79 PROJ. S101 TASK D26  
CHKD. WY DATE 6-22-81 PAGE        OF         
LACBWR SEP  
Page B-104 of 258

INNER SHIELD BLDG

(NODE 5-C)

REF.

CENTER OF MASS CALCULATION

DEAD LOAD	WEIGHT	X <sub>3</sub>	WX <sub>3</sub>
4-C	POOL WATER	18.27	343.29
		225.79	1700.20
5-C	FUEL CASK	171.50	3222.49
	CORE & SLAD	648.71	6753.07
		1069.27	12019.05

$$\bar{X}_3 = \frac{12019.05}{1069.27} = 11.29 \text{ FT}$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-10-79 PROJ. 5101 TASK 026  
CHKD. PZ DATE 6-27-81 PAGE 1 OF 1  
LACBWR SEP  
Page B-105 of 258

INNER SHIELD BLDG

NODE 5-C 50

REF.

SUMMARY FOR NODE 5-C 50

DEAD LOAD = 1268.79<sup>K</sup>

- LIVE LOAD - —

AREA =  $8.7983 \times 10^4$

$I_{x_2}$  = 94 IN

$I_{x_2} = 11.5807 \times 10^9$  IN<sup>4</sup>

$I_{x_3} = 14.8361 \times 10^8$  IN<sup>4</sup>

$K = 11.0547 \times 10^8$  IN<sup>4</sup>

$S.F.2 = 0.933$

$S.F.3 = 0.470$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-19-79 PROJ. 5101 TASK 026  
CHKD. AS DATE 6-22-81 PAGE 1 OF 1  
LACBWR SEP  
Page B-106 of 258

REF.


NODE 6-C



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-1-79 PROJ. 5101 TASK 026  
CHKD. ABY DATE 6-8-81 PAGE 1 OF 1  
LACBWR SEP


Page B-107 of 258



INNER SHIELD BLDG

NODE 6-C

REF.



PLAN C GROUND FLOOR

$$H_2 = (30 + 7.7) 24/12 = 904.8''$$

$$H_3 = 2 \cdot 23.5 \times 12 = 564''$$

$$C =$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-25-79 PROJ. 5101 TASK 026  
CHKD. JR DATE 6-19-81 PAGE OF  
LACBWR SEP

Page B-109 of 258

INNER SHIELD BLDG					(NODE G-C)		REF.
TAKEN FROM $\bar{y} = 25.03$ TO LEFT & CONTAINMENT							
AREA No	AREA	$y$	$A_y$	$d_{x3}$	$Ad_{x3}^2$	$I_{x3}$	$Ad_{x3}^2 + I_{x3}$
A <sub>1</sub>	2(23.25) ✓	34.91 ✓	1623.32 ✓	2.18 ✓	220.99 ✓	2(34.99) ✓	290.97 ✓
A <sub>2</sub>	2(15.17) ✓	34.91 ✓	1059.17 ✓	2.18 ✓	144.19 ✓	2(22.84) ✓	189.87 ✓
A <sub>3</sub>	2(3.26) ✓	39.93 ✓	257.08 ✓	6.7 ✓	292.68 ✓	2(6.23) ✓	305.14 ✓
A <sub>4</sub>	0.83 ✓	32.37 ✓	26.87 ✓	0.36 ✓	NEG ✓	NEG ✓	NEG ✓
A <sub>5</sub>	2(14.86) ✓	41.08 ✓	1220.90 ✓	8.35 ✓	2072.15 ✓	2(9.92) ✓	2091.99 ✓
A <sub>6</sub>	2(11.75) ✓	47.35 ✓	1112.73 ✓	14.62 ✓	5022.99 ✓	2(9.23) ✓	5207.61 ✓
A <sub>7</sub>	2(11.47) ✓	38.63 ✓	886.17 ✓	5.90 ✓	798.54 ✓	2(4.62) ✓	827.78 ✓
A <sub>8</sub>	0.34 ✓	32.50 ✓	11.05 ✓	0.23 ✓	NEG ✓	NEG ✓	NEG ✓
A <sub>9</sub>	2(1.60) ✓	34.64 ✓	110.85 ✓	1.91 ✓	11.67 ✓	NEG ✓	11.67 ✓
A <sub>10</sub>	2(1.60) ✓	35.64 ✓	114.05 ✓	2.91 ✓	27.10 ✓	NEG ✓	27.10 ✓
A <sub>11</sub>	2(24.06) ✓	41.03 ✓	1979.36 ✓	8.3 ✓	3314.99 ✓	2(80.42) ✓	3475.83 ✓
A <sub>12</sub>	105.75 ✓	48.74	5154.26 ✓	16.01 ✓	27105.85 ✓	9088.9	28014.69 ✓
A <sub>13</sub>	2(6.15) ✓	21.94 ✓	269.86 ✓	10.77 ✓	1932.12 ✓	NEG ✓	1432.12 ✓
A <sub>14</sub>	2(5.68) ✓	18.10 ✓	205.62 ✓	14.63 ✓	2431.46 ✓	2(33.10) ✓	2497.66 ✓
A <sub>15</sub>	2(34.94) ✓	18.81 ✓	1314.44 ✓	13.92 ✓	13590.90 ✓	2(35.68) ✓	13811.76 ✓
							58184.19
A <sub>17</sub>	7.33 ✓	19.34	105.11 ✓	18.39	2478.95 ✓	200.52	2679.47
A <sub>18</sub>	25.00 ✓	10.15 ✓	253.75 ✓	22.58 ✓	12746.41 ✓	166.88 ✓	12913.29 ✓
A <sub>19</sub>	13.60 ✓	10.69 ✓	144.32 ✓	22.04 ✓	6557.78 ✓	27.87 ✓	6585.65 ✓
A <sub>20</sub>	5.50	4.85 ✓	26.68 ✓	27.88 ✓	4275.12 ✓	2.65 ✓	4277.77 ✓
A <sub>21</sub>	7.50	0 ✓	- ✓	32.73 ✓	8034.40 ✓	5.64 ✓	85.98
A <sub>22</sub>	12.71 ✓	4.19 ✓	52.62 ✓	28.59 ✓	10387.00 ✓	59.12 ✓	10498.12 ✓
A <sub>23</sub>	1.00	22.78 ✓	22.78 ✓	9.95 ✓	99.00 ✓	NEG ✓	99.00 ✓
A <sub>24</sub>	0.50	22.61 ✓	11.31 ✓	10.12 ✓	51.21 ✓	NEG ✓	51.21 ✓
Σ A	487.54 ✓	Σ A <sub>y</sub> 15957.3					<u><math>I_{x3} = 9532468 \text{ ft}^8</math></u>
$\bar{y}$	$\frac{\Sigma A_y}{\Sigma A} = \frac{15957.3}{487.54} = 32.73 ✓$						$I_{x3} = 19.7665 \times 10^8 \text{ in}^8$
							↗ 92 IN
							32.73 - 25.03 = 7.7 c.g. is <u>7.7</u> TO RIGHT & CONTAINMENT



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-17-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-19-81 PAGE 1 OF 1  
LACOMUR SEP

Page B-110 of 258

INNER SHIELD BLDG		NODE 6-C							REF.
AREA	$I_{x2}$	$I_{x2}$	$A_{dx2}$	$I_{x2} + A_{dx2}$	$dx_3$	$I_3$	$A_{dx3}$	$I_{13} + A_{dx3}$	
REL 1	$A_1 = 23.25$	7.99	57.97	1484.12	1542.09	9.88	34.99	2269.29	2304.28
2	$A_2 = 15.17$	12.51	16.11	2374.50	2390.61	9.88	22.84	1481.05	1503.89
2	$A_3 = 3.26$	5.59	NEG	101.78	101.78	14.90	6.23	101.75	108.01
2	$A_4 = 0.83$	13.79	NEG	157.84	157.84	7.34	NEG	44.72	44.72
2	$A_5 = 19.86$	2.63	34.13	102.77	136.89	16.05	9.92	3827.33	3837.25
2	$A_6 = 11.75$	0.61	1.43	4.37	5.81	22.32	92.31	5853.19	5945.51
TRI 2	$A_7 = 11.97$	7.52	14.62	648.75	663.37	13.60	14.62	2121.87	2136.49
2	$A_8 = 134$	13.01	NEG	58.30	58.30	7.47	NEG	19.22	19.22
2	$A_9 = 1.60$	14.89	NEG	355.19	355.19	9.61	NEG	147.95	147.95
2	$A_{10} = 1.6$	14.39	NEG	355.19	355.19	10.61	NEG	180.35	180.35
2	$A_{11} = 29.06$	18.24	80.42	8048.65	8129.07	16.0	80.42	6159.36	6239.78
2	$A_{12} = 105.75$	0	20939.17	0	20934.17	23.71	903.88	59448.85	60357.69
	320.96			48510.31					105228.65
REL	$A_{13} = 6.15$	9.77	41.84	586.77	628.63	3.09	NEG	58.69	58.69
REL	$A_{14} = 5.68$	5.59	NEG	177.64	177.64	6.93	33.10	273.01	306.12
TRI	$A_{15} = 24.44$	8.72	135.68	2657.15	2792.83	6.22	135.68	1351.96	1487.64
	9254			7198.2					3704.9
	$A_{16} = 223$	15.19	200.52	1691.30	1851.82	8.19	200.52	491.67	642.19
	$A_{17} = 7.33$	12.69	200.52	1180.39	1380.91	10.69	200.52	836.64	1038.16
	$A_{18} = 25.0$	14.63	166.88	5350.92	5577.80	19.88	166.88	5535.36	5702.24
	$A_{19} = 13.5$	29.59	27.87	11870.17	11898.04	14.34	27.87	2276.03	2303.95
	$A_{20} = 5.5$	12.68	2.65	884.30	886.95	20.18	2.65	2239.79	2242.44
	$A_{21} = 7.5$	11.03	5.64	912.46	918.10	25.03	5.64	4698.76	4704.40
	$A_{22} = 12.71$	18.89	59.12	4535.34	4594.46	20.89	59.12	5546.54	5605.66
	$A_{23} = 1.0$	13.79	NEG	190.16	190.16	2.25	NEG	5.06	5.06
	$A_{24} = 0.5$	10.96	NEG	60.06	60.06	1.42	NEG	2.93	2.93
	73.04			25456.48					21604.89
	<u>A 48750</u>			<u>I<sub>x2</sub> 81164.99</u>	<u>F<sub>T4</sub></u>				<u>130528.39</u>



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-17-79 PROJ. 5101 TASK 026  
CHKD. DB DATE 6-18-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
PAGE B-111 OF 258

INNER SHIELD BLDG

(NODE 6-C)

REF.

PROPERTIES

FOR AREAS A<sub>1</sub> THRU A<sub>12</sub>

USE TWICE THE VALUES EXCEPT A<sub>9</sub>, A<sub>12</sub> & A<sub>8</sub>

USE TWICE A<sub>13</sub>, A<sub>14</sub>, A<sub>15</sub>

✓



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-16-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-18-81 PAGE 1 OF 1  
LACBWR SEP  
Page B-112 of 258

REF.

PROPERTIES FOR


AREA	b	h	d <sub>x2</sub>	d <sub>x3</sub>
REC A <sub>1</sub>	4.25 ✓	5.47 ✓	7.99 ✓	9.88 ✓
A <sub>2</sub>	4.25 ✓	3.57 ✓	12.51 ✓	9.88 ✓
A <sub>3</sub>	4.79 ✓	0.68 ✓	5.59 ✓	14.40 ✓
A <sub>4</sub>	0.83 ✓	1.0 ✓	13.79 ✓	7.39 ✓
A <sub>5</sub>	2.83 ✓	5.25 ✓	2.63 ✓	16.05 ✓
A <sub>6</sub>	9.71 ✓	1.21 ✓	0.61 ✓	22.32 ✓
TRI A <sub>7</sub>	4.79 ✓	4.79 ✓	7.52 ✓	13.60 ✓
A <sub>8</sub>	0.83 ✓	0.83 ✓	13.01 ✓	7.47 ✓
A <sub>9</sub>	1.79 ✓	1.79 ✓	14.89 ✓	9.61 ✓
A <sub>10</sub>	1.79 ✓	1.79 ✓	14.89 ✓	10.61 ✓



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-16-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-18-81 PAGE 2 OF 1  
LACBWR SEP


Page B-113 of 258





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-16-79 PROJ. 5701 WORK 026  
CHKD. 08 DATE 6-19-81 PAGE 1 OF 1  
LACBWR SEP  
Page B-119 of 258





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-16-79 PROJ. 5101 TASK 026  
CHKD. AW DATE 6-18-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-115 of 258

INNER SHIELD BLDG	(NODE G-C)	REF.
<p>AREA A<sub>11</sub></p> <p><math>A = bd \checkmark</math>  <math>c = \frac{b \sin \alpha + d \cos \alpha}{2} \checkmark</math>  <math>I = \frac{bd(b^2 \sin^2 \alpha + d^2 \cos^2 \alpha)}{12} \checkmark</math></p> <p>REF: AISC 7<sup>TH</sup> ED Pg 6-25</p>		

$$C = \frac{2.85(.707) + (8.5)(.707)}{2} = 9.0 \text{ FT} \quad \checkmark$$

$$I_{x_2} = \frac{(2.85)(8.5)(2.85^2(.707)^2 + (8.5)^2(.707)^2)}{12} = 80.42 \text{ FT}^4 \quad \checkmark$$

$$A = 24.06 \text{ FT}^2 \quad \checkmark$$

$$I_{x_2} = 80.42 \text{ FT}^4 \quad \checkmark$$

$$d \times z = 18.29 \text{ FT}$$

$$d \times z = 16.0 \text{ FT} \quad \checkmark$$

$$Ad_{x_2}^2 = 8098.65 \text{ FT}^4 \quad \checkmark$$

$$Ad_{x_3} = 6159.36 \quad \checkmark$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-6-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-18-81 PAGE 1 OF 1  
LACBWR SEP

Page B-116 of 258

INNER SHIELD BLDG

NODE 6-C

REF.

AREA A<sub>12</sub>

REF R.J. ROARK FORMULAS FOR STRESS AND STRAIN

Pg 76 4<sup>TH</sup> ED

$$A = 2 \alpha R t \quad \alpha = 95^\circ = 0.7854 \text{ RAD} /$$

$$A = 2(0.7854)33(2.04) /$$

$$A = 105.75 \text{ FT}^2 /$$

$$y_1 = R(1 - \sin \alpha) /$$

$$y_1 = 3.29 \text{ FT} /$$

$$I_1 = R^3 (\alpha + \sin \alpha \cos \alpha - \frac{2 \sin^2 \alpha}{\alpha}) /$$

$$I_1 = 33^3 \cdot 2.04 \left( 0.7854 + .707 \cdot .707 - \frac{2(0.707)^2}{0.7854} \right) /$$


$$I_1 = 908.89 \text{ FT}^4 /$$

$$I_2 = R^3 (\alpha - \sin \alpha \cos \alpha) /$$

$$I_2 = 33^3 \cdot 2.04 (.7854 - .707^2) /$$

$$I_2 = 20934.17 \text{ FT}^4 /$$

$$d \times 3 = 23.71 \text{ FT} /$$







NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-16-79 PROJ. 5101 TASK 026  
CHKD. AW DATE 6-19-81 PAGE 1 OF 1  
LACBWR SEP

Page B-117 of 258



Page B-118 of 258







NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-16-79 PROJ. 5101 TASK 026  
CHKD. AS DATE 6-19-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page B-119 of 258

INNER SHIELD BLOC	Node 6-C	REF.
<u>AREA A<sub>20</sub></u> $A = 550 \checkmark$ $C = \frac{b \sin \alpha + d \cos \alpha}{z} \quad \alpha = 45^\circ \checkmark$ $C = \frac{2.0 \times .707 + 2.75 \times .707}{2} = 1.68' \checkmark$ $I = \frac{bd(b^2 \sin^2 \alpha + d^2 \cos^2 \alpha)}{12} \checkmark$ $I = \frac{2 \times 2.75(2^2 \times .707^2 + 2.75^2 \times .707^2)}{12} = 2.65' \checkmark$ $d_{x_2} = 11.0 + 1.68 = 12.68 \text{ FT} \checkmark \quad Ad_{x_2}^2 = 884.30 \text{ FT}^4 \quad I + Ad_{x_2}^2 = 886.95 \text{ FT}^4$ $d_{x_3} = 18.5 + 1.68 = 20.18 \text{ FT} \checkmark \quad Ad_{x_3}^2 = 2239.79 \text{ FT}^4 \quad I + Ad_{x_3}^2 = 2242.49 \text{ FT}^4$		
<u>AREA A<sub>21</sub></u> $A = 7.5 \text{ FT}^2 \checkmark$ $C = \frac{2 \times .707 + 3.75 \times .707}{2} = 2.03 \checkmark$ $I = \frac{2 \times 3.75[2^2 \times .707^2 + 3.75^2 \times .707^2]}{12} = 5.64 \checkmark$ $d_{x_2} = 9.0 + 2.03 = 11.03 \checkmark \quad Ad_{x_2}^2 = 912.46 \checkmark$ $d_{x_3} = 23 + 2.03 = 25.03 \checkmark \quad Ad_{x_3}^2 = 4698.76 \checkmark$ $I + Ad_{x_2}^2 = 918.1 \text{ FT}^4 \checkmark$ $I + Ad_{x_3}^2 = 4709.4 \text{ FT}^4 \checkmark$		



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-16-79 PROJ. 5101 TASK 026  
CHKD. ABY DATE 6-19-81 PAGE        OF         
LACBWR SEP

Page B-120 of 258

INNER SHIELD BLDG	NODE 6C	REF.
<u>AREA A<sub>22</sub></u> APPROXIMATE WITH RECTANGLE AT 45° $A = 12.71 \text{ FT}^2 \checkmark$ $C = \frac{b \sin a + d \cos a}{2}$ $C = \frac{1.21 \times .707 + 10.5 \times .707}{2} = 4.14 \checkmark$ $I = \frac{bd(b^2 \sin^2 a + d^2 \cos^2 a)}{12}$ $I = \frac{1.21(10.5)[1.21^2 \times .707^2 + 10.5^2 \times .707^2]}{12}$ $I = 59.12 \text{ FT}^4 \checkmark$ $dx_2 = 14.75 + 4.14 = 18.89 \text{ FT} \checkmark$ $dx_3 = 16.75 + 4.14 = 20.89 \text{ FT} \checkmark$ $Ad_{x_2}^2 = 4535.34 \text{ FT}^4 \checkmark$ $I + Ad_{x_2}^2 = 4599.46 \text{ FT}^4 \checkmark$ $Ad_{x_3}^2 = 5546.54 \text{ FT}^4 \checkmark$ $I + Ad_{x_3}^2 = 5605.66 \text{ FT}^4 \checkmark$		
<u>AREA A<sub>23</sub></u> $A = 1 \text{ FT}^2 \checkmark$ $I = \frac{bd^3}{12}, \text{ NEC} \checkmark$ $dx_2 = 13.79 \checkmark$ $Ad_{x_2}^2 = 190.16 \text{ FT}^4 \checkmark$ $dx_3 = 2.25 \checkmark$ $Ad_{x_3}^2 = 5.06 \text{ FT}^4 \checkmark$		
<u>AREA A<sub>24</sub></u> $A = .5 \text{ FT}^2 \checkmark$ $dx_2 = 10.96 \checkmark$ $Ad_{x_2}^2 = 60.06 \text{ FT}^4 \checkmark$ $dx_3 = 2.42 \checkmark$ $Ad_{x_3}^2 = 2.93 \text{ FT}^4 \checkmark$		

INNER SHEILD BLDG

NODE G-C

REF.

AREA A<sub>17</sub>

$$A = 7.33 \text{ FT}^2 \checkmark$$

$$C = \frac{bs\sin\alpha + d\cos\alpha}{z}$$

$$= \frac{1(1.707) + 7.33(.707)}{z} = 2.94 \text{ FT} \checkmark$$


$$I = bd(b^2\sin^2\alpha + d^2\cos^2\alpha)$$

$$= \frac{1(7.33)(1.707^2 + 7.33^2(.707^2))}{12} = 16.72 \text{ FT}^4 \checkmark$$

$$I = 16.72 \text{ FT}^4 \checkmark$$

$$d_{x_2} = 12.25 + 2.94 = 15.19 \checkmark \quad Ad_{x_2}^2 = 1691.30 \checkmark \quad I + Ad_{x_2}^2 = 1708.02 \checkmark$$

$$d_{x_3} = 4.33 + 2.94 = 7.27 \checkmark \quad Ad_{x_3}^2 = 387.71 \checkmark \quad I + Ad_{x_3}^2 = 409.13 \checkmark$$





INNER SHIELD BLDG

(NODE G-C)

REF.

AREA A18

$$A = 25 \text{ FT}^2 \checkmark$$


$$C = \frac{b \sin \alpha + d \cos \alpha}{2} \quad \alpha = 45^\circ \checkmark$$

$$L = \frac{z(707) + 12.5(707)}{2} = 5.13' \checkmark$$

$$I = \frac{b d (b^2 \sin^2 \alpha + d^2 \cos^2 \alpha)}{12}$$

$$I = \frac{2(12.5)(2^2 \cdot .707^2 + 12.5^2 \cdot .707^2)}{12}$$

$$I = 166.88 \text{ FT}^4 \checkmark$$



$$d_{x2} = 9.5 + 5.13 = 14.63 \text{ FT} \checkmark$$

$$Ad_{x2}^2 = 5350.92 \text{ FT}^2 \checkmark \quad I + Ad_{x2}^2 = 5577.80 \text{ -}$$

$$d_{x3} = 9.75 + 5.13 = 14.88 \text{ FT} \checkmark$$

$$Ad_{x3}^2 = 5535.36 \text{ FT}^2 \checkmark \quad I + Ad_{x3}^2 = 5702.24 \text{ -}$$

AREA 19

$$A = 13.5 \checkmark$$


$$C = \frac{b \sin \alpha + d \cos \alpha}{2}$$

$$L = \frac{2 \cdot .707 + 6.75 \cdot .707}{2} = 3.09 \text{ FT} \checkmark$$

$$I = \frac{2 \times 6.75 (2^2 \cdot .707^2 + 6.75^2 \cdot .707^2)}{12} = 27.87 \text{ FT}^4 \checkmark$$

$$d_{x2} = 18.50 + 3.09 = 21.59 \text{ FT} \checkmark \quad Ad_{x2}^2 = 11820.17 \text{ FT}^4 \text{ -}$$

$$d_{x3} = 11.25 + 3.09 = 14.34 \text{ FT} \checkmark \quad Ad_{x3}^2 = 2276.08 \text{ FT}^4 \text{ -}$$



$$I_{x2} + Ad_{x2}^2 = 11848.04 \text{ -}$$

$$I_{x2} + Ad_{x3}^2 = 2303.95 \text{ FT}^4 \text{ -}$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION


BY R.R. DATE 5-9-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-22-81 PAGE        OF         
LAC BWR SEP  
Page B-123 of 258

INNER SHIELD BLDG.	NODE 6-C	REF.
<p style="text-align: center;">TORSIONAL CONSTANT</p>	<p style="text-align: center;">K FOR ISOSCELES TRIANGLES</p> $K = \frac{a^3 b^3}{15a^2 + 20b^2}$ $K = \frac{(7^3)(14^3)}{15(14^2) + 20(7)^2} = 240.1$ $4K = 960.4 \text{ FT}^4$ <p style="text-align: center;">K FOR RECTANGLE</p> $K = \frac{2t t_1 (a-t)^2 (b-t_1)^2}{a t + b t_1 - t^2 - t_1^2}$ $t = 2.83 \quad t_1 = 2.04$ $b = 14 \quad a = 20.5$ $K = \frac{2(2.83)(2.04)(20.5-2.83)(14-2.04)^2}{20.5(2.83) + 14(2.04) - 2.04^2 - 2.83^2} = 58.02$ $K = 6930.28 \text{ FT}^4$ $2K = 13860.56 \text{ FT}^4$	



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION


BY R.R. DATE 5-9-79 PROJ. 5101 TASK 026  
CHKD. af DATE 6-22-81 PAGE 1 OF 1  
LACBWR SEP  
Page B-129 of 258





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY DJD DATE 2-7-77 PROJ. 2101 TASK U-20  
CHKD. afy DATE 6-22-81 PAGE 1 OF 1  
LACBWR SEP  
Page B-125 of 258





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-10-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-22-81 PAGE        OF         
LACBWR SEP  
Page B-126 of 258

INNER SHIELD BLDG.	NODE 6-C	REF.
SHEAR AREA FACTORS		
USE $\frac{1}{2}$ THE AREAS OF 4-CENTRAL TRIANGLES AND ANGULAR COMPONENTS OF REMAINDER OF AREA.		
FOR EARTH QUAKE ALONG $X_3$ AXIS - SF2		
$\text{Area Triangle} = \frac{1}{2} b h = \frac{1}{2}(14)(7) = 49 \checkmark$ $\frac{1}{2} \text{ TRIANGLES} = 98 \checkmark$ $\text{SUBTRACT } 2 A_6 = \frac{23.5}{79.5} \checkmark$ $\text{TOTAL AREA} = \underline{487.5} \checkmark$ $\text{REMAINING AREA} = 413 \checkmark$ $\text{AREA } A_{12} = \frac{105.75}{307.25} \checkmark$  $\text{USE } \sin 45^\circ (307.25) + \sin 60^\circ (105.75) = 308.81 \leftarrow$ $\frac{79.5}{383.30} \checkmark$ $\text{SF. } 2 = \frac{383.30}{487.50} = 0.786 \checkmark$		
FOR EARTH QUAKE ALONG $X_2$ AXIS SF. 3		
$\frac{1}{2} \text{ TRIANGLES} = 98 \checkmark$ $\text{SUBTRACT } 2 A_5 = \frac{29.72}{68.28} \checkmark$ $\text{TOTAL AREA} = \underline{487.5} \checkmark$ $\text{REMAINING AREA} = 419.22 \checkmark$ $\text{AREA } A_{12} = \frac{105.75}{313.47} \checkmark$  $\text{USE } \sin 45^\circ (313.47) + \cos 60^\circ (105.75) = 274.50 \checkmark$ $\frac{68.28}{342.78} \checkmark$ $\text{SF. } 3 = \frac{342.78}{487.50} = 0.703 \checkmark$ $\checkmark \text{SF. } 2 = 0.786$ $\checkmark \text{SF. } 3 = 0.703$		



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-25-79 PROJ. 5101 TASK 026  
CHKD. Ally DATE 6-17-81 PAGE 1 OF 1  
LACBWP SEP  
Page B-127 of 258

GROUND FLOOR

REF.

SLAB WEIGHT

$$12'' \text{ APPROX. } \frac{1}{2}(4+34)(.15)(1)(.15) = 54^{\text{K}} \checkmark$$

$$7'' \text{ APPROX. } \frac{7}{12} \frac{1}{2}(13)(10+15)(.15) = 14.2188$$

$$\frac{7}{12} \frac{1}{2}(8)(8)(.15) = 2.800$$

$$\frac{7}{12} (13)(8)(.15) = 9.100$$

$$\frac{7}{12} \frac{1}{2}(8)(9)(.15) = 3.150$$

$$\frac{7}{12} \frac{1}{2}(8)(3)(.15) = 1.050$$

$$\frac{7}{12} (11)(16)(.15) = 15.400$$

$$6'' \text{ APPROX. } \frac{6}{12} (15 \times 10)(.15) = 11.25 \checkmark$$

$$\frac{6}{12} (10 \times 10)(.5)(.15) = \underline{3.75 \checkmark}$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-25-79 PROJ. 5101 TASK 026  
CHKD. DPX DATE 6-17-81 PAGE        OF         
LACBWR SEP  
Page B-128 of 258

GROUND FLOOR

REF.

BEAM WEIGHTS

SLAB	BEAM	b	h	L	WEIGHT
	B-1	12 ✓	9 ✓	8.75 ✓	0.3281 ✓
	B-2	9 ✓	9 ✓	7' ✓	0.1969 ✓
6"	B-3	9 ✓	9 ✓	6' ✓	0.1688 ✓
	B-4	9 ✓	9 ✓	45' ✓	0.1266 ✓
—	B-5	21 ✓	24 ✓	20' ✓	7.8750 ✓
	B-6	24 ✓	27 ✓	16' ✓	8.4000 ✓
7"	B-7	18 ✓	21 ✓	15' ✓	3.9375 ✓
	B-8	24 ✓	27 ✓	19.5 ✓	9.7500 ✓
	B-9	24 ✓	21 ✓	12.75 ✓	4.4625 ✓
	B-10	12 ✓	18 ✓	12.50 ✓	1.7188 ✓
	B-11	15 ✓	18 ✓	10.75 ✓	1.8476 ✓
	B-12	24 ✓	21 ✓	12.75 ✓	4.4625 ✓
12	B-13	12 ✓	21 ✓	15.25 ✓	1.7156 ✓
					44.9899 ✓



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-25-79 PROJ. 5101 TASK 026  
CHKD. OSy DATE 6-22-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-129 of 258

GROUND FLOOR	(NODE 6-C)	REF.
<u>CORE WEIGHT</u>		
232 <sup>#</sup> / <sub>ft<sup>3</sup></sub> FROM 5-C 7.13' @ 610.97 FT <sup>2</sup> = 1010.68 <sup>K</sup> ✓		
150 <sup>#</sup> / <sub>ft<sup>3</sup></sub> FROM 6-C <u>4.37</u> @ 487.50 FT <sup>2</sup> = 159.79 <sup>K</sup> ✓		
<u>DEAD WEIGHT</u> <u>TOTAL WT</u> <u>TOTAL</u> ✓ SLAB WT                          114.72 <sup>K</sup> ✓ BEAM WT                          49.99 <sup>K</sup> ✓ _____ 1330.18 <sup>K</sup> TOTAL ✓ DEAD LOAD		



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION


BY R.R DATE 5-8-79 PROJ. 5101 TASK 026  
CHKD. afy DATE 6-18-81 PAGE 1 OF 1  
LACBNR SEP  
Page B-130 of 258

INNER SHIELD BLDG.	(NODE 6-C)	REF.
<u>CENTER OF MASS CALCULATION</u>		
* APPROXIMATION		
DEAD LOAD	WEIGHT	X <sub>3</sub> WX <sub>3</sub>
5-C CORE AREA	1016.68	10.91 10583.64
7" SLAB & BEAMS	-90.76 <sup>#</sup> ✓	-20 <sup>#</sup> ✓ -1815.2
6-C CORE AREA	<u>159.79</u> ✓ <u>1267.23</u>	77 ✓ <u>1230.38</u> ✓ <u>7538.06</u>
$\bar{X}_3 = \frac{7538.06}{1267.23} = 5.95 \text{ FT}$		
<i>RICH HATNER → &lt;Hackney</i>		



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-13-79 PROJ. 5101 TASK 626  
CHKD. AB DATE 6-17-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-131 of 258





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-25-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-18-81 PAGE 1 OF 1  
LACBWR SEP  
Page B-132 of 258

GROUND FLOOR	(NODE G-C)	REF.
<u>LIVE LOAD</u>		
TOTAL AREA = $\pi R^2 = \pi 29.21^2 = 2680.48 \text{ ft}^2$ ✓		
CORE AREA (FROM NODE 5-C) = $610.99 \text{ ft}^2$		
$2(9 \times 10) = (5+10)(10) = 330 \text{ ft}^2$		
350 PSF AREA = $2680.48 - 610.99 - 330.00 = 1739.49 \text{ ft}^2$		
175 PSF AREA = $180 \text{ ft}^2$		
TOTAL LIVE LOAD = $(1739.49)(.350) + (180)(.175) = 640.3215 \text{ kN}$ ✓		



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-10-79 PROJ. 5101 TASK 026  
CHKD. AW DATE 6-22-81 PAGE        OF         
LACBIVR SEP  
Page B-133 of 258

INNER SHIELD BLDG	NODE 6-C (5)	REF.
<p><u>SUMMARY FOR NODE 6-C 50</u></p> <p>✓DEAD LOAD = 1330.18 K ✓LIVE LOAD = 640.32 K ✓AREA = <math>7.0205 \times 10^4 \text{ IN}^2</math> ✓<math>\bar{x}_2 = 92 \text{ IN}</math> ✓<math>I_{x_2} = 16.8304 \times 10^8 \text{ IN}^4</math> ✓<math>I_{x_3} = 19.7665 \times 10^8 \text{ IN}^4</math> ✓<math>K = 3.0733 \times 10^8 \text{ IN}^4</math> ✓<math>SF_2 = 0.786</math> ✓<math>SF_3 = 0.703</math></p>		



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 5-1-79 PROJ. 5101 TASK 026  
CHKD. ABY DATE 6-22-81 PAGE 1 OF 1  
LACBWR SEP  
Page B-134 of 258

REF.

NODE 7-C



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION


BY RR DATE 5-1-79 PROJ. 5101 TASK 026  
CHKD. ABY DATE 6-8-81 PAGE 1 OF 1  
LACBWR SEP  
Page B-135 of 258

INNER SHIELD BLDG

NODE 7-C

REF.

MODEL





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-24-79 PROJ. 5101 TASK D26  
CHKD. af DATE 6-22-81 PAGE        OF         
LACBWR SEP  
Page B-136 of 258

NODE 7-C	REF.
<p>DEAD LOAD</p> <p>USE AREA OF CORE FROM 6-C <math>487.50^{\frac{in}{2}}</math> ✓</p> <p>Load = <math>\left[\frac{4.37}{2} + (5.49)\right] (.150)(487.50^{\frac{in}{2}}) = 557.58^{\frac{lb}{in}}</math> TOTAL DEAD LOAD</p> <p>USE PROPERTIES FROM 6-C</p> <p><math>A = 487.50^{\frac{in}{2}} = 7.0200 \times 10^9 \text{ in}^2</math> ✓</p> <p><math>I_{x_2} = 81164.99 \text{ ft}^4 - 16.8304 \times 10^8 \text{ in}^4</math> ✓</p> <p><math>I_{x_3} = 95324.68 \text{ ft}^4</math> ✓</p>	



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-879 PROJ. 5101 TASK 026  
CHKD. (R.F.) DATE 6-22-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-157 of 258

INNER SHIELD BLDG

NODE 7-C

REF.

CENTER OF MASS CALCULATION

DEAD LOAD	WEIGHT	X <sub>3</sub>	W X <sub>3</sub>
CORE	557.58 <sup>k</sup>	7.7	

$$\bar{X}_3 = 7.7 \text{ FT} \checkmark$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-10-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-22-81 PAGE — OF —  
LACBWR SEP

Page B-138 of 258

INNER SHIELD BLDG

NODE 7-C 52

REF.

SUMMARY For Node 7C 52

$$\text{DEAD LOAD} = 557.58^{\text{in}}$$

$$\text{LIVE LOAD} = —$$

$$\checkmark \text{AREA} = 7.0205 \times 10^4 \text{ in}^2$$

$$\checkmark X_2 = 92 \text{ in}$$

$$\checkmark I_{x2} = 16.8304 \times 10^8 \text{ in}^4$$

$$\checkmark I_{x3} = 19.7665 \times 10^8 \text{ in}^4$$

$$\checkmark K = 3.0733 \times 10^8 \text{ in}^4$$

$$\checkmark SF_2 = 0.786$$

$$\checkmark SF_3 = 0.703$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-27-79 PROJ. 5701 TASK 026  
CHKD. AB DATE 6-23-81 PAGE        OF         
LACBWR SEP  
Page 8-139 of 258

REF.


NODE 8-C

INNER SHIELD BLDG

(NODE B-C)

REF.

MODEL





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 5-1-79 PROJ. 5101 TASK 026  
CHKD. NY DATE 6-22-81 PAGE        OF         
LACBWR SEP  
Page 8-141 of 258

NODE 8-C

REF.

USE PROPERTIES OF NODE 6-C EXCEPT REMOVE A<sub>12</sub>

$$\begin{aligned} \text{AREA} &= 487.50 & I_{yz} + Ad_{yz}^2 &= 81164.99 & I_{xz} + Ad_{xz}^2 &= 130538.39 \\ A_{12} &= 105.75 & - &= 20934.17 & 60357.69 \\ 381.75 \text{ FT}^2 & & 60230.82 \text{ FT}^4 & & 70780.70 \text{ FT}^4 \\ \underbrace{54972 \times 10^4}_{\text{in}^2} & & \underbrace{12.4295 \times 10^8}_{\text{in}^4} & & \end{aligned}$$

$$\text{WEIGHT } \left( 5.44 + \frac{7.55}{2} \right) (\text{AREA FROM B.C.} = 381.75) (.15) = \underline{\underline{527.67}} \checkmark$$



Page B-142 of 258

INNER SHIELD BLDG.		NODE 8-C		REF.		
USING PROPERTIES FROM NODE-C AND SUBTRACTING OUT AREA A <sub>12</sub>						
$\Sigma A = 381.75 \text{ FT}^2$ , $\Sigma A_{12} = 10803.04 \checkmark$						
		$d_{x_3} = \frac{10803.04}{381.75} - 25.03 \checkmark = 3.27 \checkmark$	<sup>39 IN</sup> TO RIGHT OF CENTER			
AREA	$d_{x_3}$	A	$Ad_{x_3}^2$	$I_{x_3}$		
z A <sub>1</sub>	6.61 ✓	46.5 ✓	2031.68 ✓	69.98 ✓		
z A <sub>2</sub>	6.61 ✓	30.34 ✓	1325.62 ✓	45.68 ✓		
z A <sub>3</sub>	11.13 ✓	6.52 ✓	807.68 ✓	12.46 ✓		
A <sub>4</sub>	4.07 ✓	0.82 ✓	13.75 ✓	NEC ✓		
z A <sub>5</sub>	12.78 ✓	29.72 ✓	4859.12 ✓	19.84 ✓		
z A <sub>6</sub>	19.05 ✓	23.50 ✓	8528.21 ✓	189.62 ✓		
z A <sub>7</sub>	10.33 ✓	22.94 ✓	2447.90 ✓	29.29 ✓		
A <sub>8</sub>	4.20 ✓	0.34 ✓	5.00 ✓	NEC ✓		
z A <sub>9</sub>	6.34 ✓	3.2 ✓	128.63 ✓	NEC ✓		
z A <sub>10</sub>	7.34 ✓	3.2 ✓	172.40 ✓	NEC ✓		
z A <sub>11</sub>	12.73 ✓	48.12 ✓	7797.99 ✓	160.89 ✓		
z A <sub>12</sub>	6.36 ✓	12.3 ✓	497.53 ✓	NEC ✓		
z A <sub>13</sub>	10.20 ✓	11.36 ✓	1181.89 ✓	66.20 ✓		
z A <sub>14</sub>	9.44 ✓	69.88 ✓	6293.40 ✓	271.36 ✓		
A <sub>15</sub>	13.96 ✓	7.33 ✓	1428.48	200.52 ✓		
A <sub>16</sub>	18.15 ✓	25.00 ✓	8235.56 ✓	166.88 ✓		
A <sub>17</sub>	17.61 ✓	13.50 ✓	4180.51 ✓	27.87 ✓		
A <sub>18</sub>	23.95 ✓	5.50 ✓	3029.96 ✓	2.65 ✓		
A <sub>19</sub>	28.30 ✓	7.50 ✓	6006.68 ✓	5.64 ✓		
A <sub>20</sub>	29.16 ✓	12.71 ✓	7418.90 ✓	59.12 ✓		
A <sub>21</sub>	5.52 ✓	1.00 ✓	30.97 ✓	NEC ✓		
A <sub>22</sub>	5.69 ✓	0.50 ✓	16.19 ✓	NEC ✓		
			$\bar{I}_{x_3}$	$67756.95 \text{ FT}^4$		
				$14.0501 \times 10^8 \text{ in}^4$		




NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 5-9-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-22-81 PAGE 1 OF 1  
LACBWR SEP  
Page B-143 of 258

INNER SHIELD PLDG.

NODE 8-C

REF.



K FOR TRIANGLES FROM  
NODE 8-C

$$K = 960.4 \text{ FT}^4$$

$$2 A_1 = \frac{b h^2}{3} = \frac{(12.0)(2.83)^2}{3} = 90.66$$

$$1 A_2 = \frac{b h^2}{3} = \frac{(2)(2.42)^2}{3} = 56.69$$

$$1 A_3 = \frac{b h^2}{3} = \frac{11(2.83)^2}{3} = 83.11$$

$$A_4 = \frac{(7.33)(1)^2}{3} = \text{NEG}$$

$$A_5 = \frac{12.5(2)^2}{3} = \frac{33.33}{359.45 \text{ FT}^4}$$

$$K_{TOT} = 1319.85 \text{ FT}^4 = 0.2726 \times 10^6 \text{ IN}^4 \checkmark$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 5-10-79 PROJ. 5101 TASK 026  
CHKD. WY DATE 6-23-81 PAGE        OF         
LACBWR SEP


Page B-194 of 258

INNER SHIELD BLDG

NODE Z-C

REF.

SHEAR AREA CONSTANT



FOR EARTHQUAKE ALONG X<sub>3</sub> AXIS SF.3

TOTAL AREA = 381.75

$\frac{1}{2} \cdot A \text{ TRIANGLES} = 98.75$

SUBTRACT  $2A_5 = \frac{29.72}{68.28}$

REMAINING AREA =  $381.75 - 68.28 = 313.47$

USE .707 (313.47) = 221.62

$SF\ 3 = \frac{221.62 + 68.28}{381.75} = 0.759$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-10-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-22-81 PAGE — OF —  
LACBWR SEP


Page B-145 of 258

INNER SHIELD BLDG

NODE 8-C

REF.

SHEAR AREA CONSTANT



FOR EARTHQUAKE ALONG X<sub>3</sub> AXIS SF. Z

$$\text{TOTAL AREA} = 381.75$$

$$1/2 \cdot 4 \cdot \text{TRIANGLES} = 98.75$$

$$\text{SUBTRACT } 2 \cdot A_6 = \frac{23.5}{74.5}$$

$$\text{REMAINING AREA} = 381.75 - 74.5 = 307.25$$

$$\text{USE } .707 (307.25) = 217.23$$

$$\text{SF. Z} = \frac{217.23 + 74.5}{381.75} = .764 \checkmark$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-8-79 PROJ. 5101 TASK 026  
CHKD. ABY DATE 6-23-81 PAGE        OF         
LACBNR SEP  
Page B-146 of 258

INNER SHIELD BLDG	(NODE 8-C)	REF.
<p><u>CENTER OF MASS CALCULATION</u></p> <p>CORE 527.67' ✓ <math>\bar{x}_3 = 3.27</math> FT</p> <p>PUMP - <math>\frac{80''}{607.67''}</math> ✓</p>		

BY R.R DATE 5-10-79 PROJ. 5101 TASK 026  
 CHKD. AB DATE 6-23-81 PAGE — OF —  
LACBWR SEP  
Page B-147 of 258

INNER SHIELD BLDG	NODE B-C <u>53</u>	REF.
<p style="text-align: center;"><u>SUMMARY For Node B-C <u>53</u></u></p> <p> <math>\checkmark</math> DEAD LOAD = 527.67<sup>k</sup>  <math>\checkmark</math> LIVE LOAD = —  <math>\checkmark</math> AREA = <math>5.4972 \times 10^4</math> IN<sup>4</sup>  <math>\checkmark</math> <math>\bar{x}_z</math> = 39 IN  <math>\checkmark</math> <math>I_{xz}</math> = <math>12.4895 \times 10^8</math> IN<sup>4</sup>  <math>\checkmark</math> <math>I_{x3}</math> = <math>19.0501 \times 10^8</math> IN<sup>4</sup>  <math>\checkmark</math> K = <math>0.2726 \times 10^8</math> IN<sup>4</sup>  <math>\checkmark</math> SF2 = 0.764  <math>\checkmark</math> SF3 = 0.759         </p>		



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 5-1-79 PROJ. 5101 TASK 026  
CHKD. AR DATE 6-25-81 PAGE        OF         
LACBWR SEP  
Page 148 of 258


REF.

NODE 9-C

INNER SHIELD BLDG

REF.


MODEL





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 5-1-79 PROJ. 5101 TASK 026  
CHKD. AW DATE 6-8-81 PAGE — OF —  
LACBWR SEP  
Page 150. of 258






**NUCLEAR ENERGY SERVICES INC.  
NES DIVISION**

BY R.R DATE 4-9-79 PROJ. 5101 TASK 026  
CHKD. (By) DATE 6-23-81 PAGE        OF         
LACBWR SEP

Page 151 of 258

INNER SHIELD BLDG. (BASEMENT LEVEL

REF.



## PLAN C BASEMENT




NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-26-79 PROJ. 5101 TASK 026  
CHKD. RR DATE 6-23-81 PAGE        OF         
LACBWR SEF\*  
Page 152 of 258

FOUNDATION WEIGHT

REF.



PLAN C BASEMENT FLOOR




NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-26-79 PROJ. 5101 TASK 026  
CHKD. AB DATE 6/23/81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP

Page 153 of 258

FOUNDATION WEIGHT

REF.



ELEVATION



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-20-79 PROJ. 5101 TASK 026  
CHKD. ABY DATE 6-23-81 PAGE        OF         
LACBWR SEP  
Page 154 of 258

FOUNDATION WEIGHT CALCULATION (BELOW 621.0)

REF.

VOLUME V<sub>1</sub>

$$\text{BOTTOM AREA} = \pi R^2 = \pi 7.5^2 = 176.71 \text{ FT}^2 \checkmark$$

$$\text{TOP AREA} = \pi R^2 = \pi 18.79^2 = 1109.18 \text{ FT}^2 \checkmark$$

$$\text{VOLUME} = \frac{2.81}{3} (176.71 + 1109.18 + \sqrt{176.71 \times 1109.18}) = 1619.13 \text{ FT}^3 \checkmark$$

VOLUME V<sub>2</sub>

$$\text{BOTTOM AREA} = 1109.18 \text{ FT}^2$$

$$\text{TOP AREA} = \pi R^2 = \pi (26.08)^2 = 2136.81 \text{ FT}^2 \checkmark$$

$$\text{VOLUME} = \frac{3.65}{3} (1109.18 + 2136.81 + \sqrt{1109.18 \times 2136.81}) = 5822.36 \text{ FT}^3 \checkmark$$

VOLUME V<sub>3</sub>

$$\text{AREA} = \pi R^2 = \pi 33.25^2 = 3473.23 \text{ FT}^2$$

$$\text{VOLUME} = 3473.23 \times 4.94 = 17157.76 \text{ FT}^3 \checkmark$$

NEGATIVE VOLUME

FROM SEC AA & B-B

DEPTH = 3.5'

$$\text{AREA} = 9-0\frac{1}{2}$$

5-3

5-3

9-0 $\frac{1}{2}$

$$28'-7'' \times 10-6''$$

9-0 $\frac{1}{2}$

$$37-7\frac{1}{2}'' \times 10-6'' \times 3-6''$$

$$\text{AREA } 9-0\frac{1}{2} \times 10-6''$$

$$\text{VOLUME} = 1382.72 \text{ FT}^3$$

$$15775.04$$

$$5822.36$$

$$1619.13$$

$$\text{NET VOLUME} = 17157.76$$

$$\frac{1382.72}{15775.04} \text{ FT}^3 \checkmark$$

$$23216.53 \text{ FT}^3 \checkmark$$

$$\text{WEIGHT} = .15 \times 23216.53 = 3482.5 \text{ k} \checkmark$$

$$\text{CORE WT} = (48750 \text{ ft})(5.44)(.150) + \frac{487.5 \text{ k}}{3970.0 \text{ k}}$$

FOUNDATION WEIGHT

REF.

BASE AREA A<sub>1</sub>

$$A = .785398(d^2 - d_1^2)$$

$$A = .785398(32.5^2 - 27.5^2) = 515.42 \text{ ft}^2$$


TOP AREA A<sub>2</sub>

$$A = .785398(32.5^2 - 27.5^2) = 235.62 \text{ ft}^2$$

$$\text{VOLUME} = \frac{1}{2}(515.42 + 235.62)(4.5)$$

$$= 1689.84 \text{ ft}^3$$

$$\text{WEIGHT} = 253.48 \text{ k}$$



AREA A<sub>2</sub>

TOP

$$A = .785398(31^2 - 29.25^2) = 82.81 \text{ ft}^2$$

$$\text{VOLUME} = \frac{1}{2}(82.81 + 235.62)(1.5) = 238.82 \text{ ft}^3$$

$$\text{WEIGHT} = 35.82 \text{ k}$$

9 LONG. OUTSIDE CYLINDER

$$A = .785398(30.91^2 - 30.16^2) = 35.97 \text{ ft}^2$$

$$\text{WEIGHT} = 12 \times 35.97 \times .15 = 64.75 \text{ k}$$

3482.50

487.50

253.48

35.82

$$\begin{array}{r} 64.75 \\ \hline 4329.05 \end{array} \text{ TOTAL FOUNDATION WEIGHT}$$

Use  $\frac{1}{2}$  weight at 9-C and  $\frac{1}{2}$  at 10C



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 9-24-75 PROJ. 5101 TASK 026  
CHKD. ABY DATE 6-25-81 PAGE — OF —  
LACBWR SEP  
Page 156 of 258

(NODE 9-C)

REF.

PROPERTIES OF FOUNDATION

$$A = \pi 33.25^2 = 3473.23 \text{ ft}^2 \quad I_{144} = 50.015 \times 10^4 \text{ in.}^4$$

$$I_{x_2} = I_{x_3} = .785398 R^4 = 959.967.1893 \text{ ft}^4 = 199.06 \times 10^8 \text{ in.}^4$$

TOTAL FNONWEIGHT 3970.0 k

$$J = 398.12 \times 10^8 \text{ in.}^4$$

LIVE LOAD = 767.54 k

WEIGHT OF 9-C = 1985.0. USING  $\frac{1}{2}$  FNONWT

2 TANKS 6000GAL = 130.00 ✓

$$\begin{aligned} \text{LIVE LOAD} &= \frac{767.54}{2882.54} \\ \text{STEEL CONTAINMENT} &= \frac{62.12}{2944.66} \rightarrow 9-C \text{ weight} \end{aligned}$$

WEIGHT OF 10-C = 1985.0 ( $\frac{1}{2}$  Foundation weight).




NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 4-18-79 PROJ. 5101 TASK 026  
CHKD. CBY DATE 6-23-81 PAGE 157 OF 258  
LACBWR SEP

Page 157 of 258

REF.



CONTAINMENT VESSEL  
BASEMENT FLOOR  
EL 621'-0"



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 4-29-79 PROJ. 5101 TASK D26  
CHKD. BS DATE 6-23-81 PAGE        OF         
LACBWR SEP

Page 158 of 258

BASEMENT FLOOR

REF.

LIVE LOAD

$$\text{TOTAL AREA} = \pi R^2 - \pi 29.21^2 = 2680.48 \text{ ft}^2 \checkmark$$

$$\text{CORE AREA} = 487.50 \text{ ft}^2$$

$$350 \text{ PSF LOAD } (2680.48 - 487.50)(.350) = 767.54 \text{ K } \checkmark$$

LIVE LOAD

**NIPS**

NUCLEAR ENERGY SERVICES

BY \_\_\_\_\_ DATE \_\_\_\_\_ PROJ. 5101 TASK 247  
CHKD. A2 DATE 7/26/82 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-159 of 258

REF.

REACTOR

VESSEL




NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 4-26-79 PROJ. 5101 TASK 026  
CHKD. 23 DATE 6-24-81 PAGE — OF —  
LACBWR SEP  
Page B-160 of 258

REACTOR VESSEL

REF.

WALL THICKNESS = 4"



6129:

## REACTOR VESSEL

REF.

## PROPERTIES OF VESSEL

\* FOR CALCULATIONS FOR  
 NODES 1-R AND 10-R  
 SEE PAGE 2b. (next page)

NODES 2-R → 9-R

$$A = \frac{\pi}{4} (d^2 - d_1^2) = \frac{\pi}{4} (8.91^2 - 8.25^2) = 8.895 \text{ FT}^2 \checkmark$$

$$I = \frac{\pi}{64} (d^4 - d_1^4) = \frac{\pi}{64} (8.91^4 - 8.25^4) = 81.9742 \text{ FT}^4 \checkmark$$

## WEIGHT LOADS (TONS)

22

6

143


9

TOTAL OPERATING  
WEIGHT

$$\underline{215} = 430 \text{ k}$$

9.9k REACTOR SUPPORT SKIRT ✓

$$\frac{439.4}{37 \text{ FT}} = 11.88 \frac{\text{KIPS}}{\text{LIN.FT.}} \checkmark$$




REF:  
 LACBWR  
 SAR  
 4.8-1  
 TABLE  
 1-1

NODE	A(FT <sup>2</sup> )	A(IN <sup>2</sup> )	I(FT <sup>4</sup> )	I(IN <sup>4</sup> )	j(IN <sup>3</sup> )	L(FT)	TRIB. WT.
55 1-R	8.94	1287.36	38.69	0.8023x10 <sup>6</sup>	1.6046x10 <sup>6</sup>	2.49	34.93 *
56 2-R	8.895	1280.88	81.9742	1.6998x10 <sup>6</sup>	3.3996x10 <sup>6</sup>	3.30	39.20 *
57 3-R						3.93	46.69 *
58 4-R						4.24	50.37 *
59 5-R						4.23	50.25 *
60 6-R						4.23	50.25 *
61 7-R						3.96	47.04 *
62 8-R						3.67	43.60 *
63 9-R	8.895	1280.88	81.9742	1.6998x10 <sup>6</sup>	3.3996x10 <sup>6</sup>	3.50	41.58 *
64 10-R	8.81	1268.69	57.01	1.1922x10 <sup>6</sup>	2.3693x10 <sup>6</sup>	3.46	41.10 *
							439.4 *
						TOTAL	

## REACTOR VESSEL

REF.



EQUATION OF A CIRCLE

$$x^2 + y^2 = r^2$$

NODE 1-R

$$y = 4.125 - 1.0 = 3.125$$

$$r_1 = 4.125$$

$$x_1 = \sqrt{4.125^2 - 3.125^2} = 2.69'$$

$$\Rightarrow d_1 = 5.38'$$

$$r_0 = 4.125 + .33 = 4.455$$

$$x_0 = \sqrt{4.455^2 - 3.125^2} = 3.175'$$

$$\Rightarrow d_0 = 6.350'$$

AREA @ NODE 1-R

$$\frac{\pi}{4} (6.35^2 - 5.38^2) = 8.99 \text{ FT}^2$$

$$I_{K_2} = I_{K_3} = \frac{\pi}{64} (6.35^4 - 5.38^4)$$

$$= 38.69 \text{ FT}^4$$

NODE 10-R

$$y = 2.34$$

$$r_1 = 4.125$$

$$x_1 = \sqrt{4.125^2 - 2.34^2} = 3.40$$

$$\Rightarrow d_1 = 6.80'$$

$$r_0 = 4.455$$

$$x_0 = \sqrt{4.455^2 - 2.34^2} = 3.79$$

$$\Rightarrow d_0 = 7.58$$

AREA @ NODE 10-R

$$\frac{\pi}{4} (7.58^2 - 6.80^2) = 8.81 \text{ FT}^2$$

$$I_{K_2} = I_{K_3} = \frac{\pi}{64} (7.58^4 - 6.80^4)$$

$$= 57.01 \text{ FT}^4$$




NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-15-79 PROJ. 5101 TASK 026  
CHKD. AR DATE 6-25-81 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-163 of 258

REACTOR SUPPORT SKIRT PROPERTIES

REF.



$$\text{AREA OF A CYLINDER} = \frac{\pi}{4}(d_o^2 - d_i^2) = \frac{\pi}{4}(103^2 - 101^2) = 320.99 \text{ in}^2$$


$$\text{MOMENT OF INERTIA OF A CYLINDER} = \frac{\pi}{64}(d_o^4 - d_i^4) =$$

$$= \frac{\pi}{64}(103^4 - 101^4) = 416,775 \text{ in}^4$$

STIFFENER @ 6°

$$A = 6 \text{ in}^2$$

$$I_x = \frac{bd(b^2 \sin^2 \alpha + d^2 \cos^2 \alpha)}{12} = \frac{1 \times 6(1 \times 104528^2 + 6^2 \times 0.99452^2)}{12} = 17,808.8 \text{ in}^4$$



$$C = \sqrt{b^2 \sin^2 \alpha + d^2 \cos^2 \alpha} = \sqrt{1 \times 104528 + 6 \times 0.99452} = 3.0358$$

$$d = R \cos \alpha + 2.9313 + .05226 = 54.2014 \text{ in}$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY RR DATE 5-15-71 PROJ. 5101 TASK 026  
CHKD. AB DATE 6-25-81 PAGE 1 OF 1  
LACBWR SEP

Page B-164 of 258


REACTOR SUPPORT SKIRT PROPERTIES

REF.

$$I_3 + A d_{x_3}^2 = 17.8088 + 6(54.2014)^2 = \underline{17644.5594} \text{ IN}^4$$

$$I_{x_3} = \frac{1 \times 6 (6^2 \cdot 10452.9^2 + 17 \times .99452^2)}{12} = 0.6412 \text{ IN}^4 \checkmark$$

$$c = \frac{6 \sin 6^\circ + 1 \cos 6^\circ}{2} = 0.8108 \text{ IN} \checkmark$$



$$d = 5.383 + .3134 = 5.6966 \text{ IN} \checkmark$$

$$I_3 + A d_{x_3}^2 = 0.6412 + 6(5.6966)^2 = \underline{195.3987} \text{ IN}^4 \checkmark$$


STIFFENER @  $39^\circ$

$$A = 6 \text{ IN} \checkmark$$

$$I_{x_2} = \frac{bd(b^2 \sin a + d^2 \cos a)}{12} = \frac{1 \times 6 (1^2 \sin^2 39 + 6^2 \cos^2 39)}{12} \checkmark$$

$$= 11.0692 \text{ IN}^4$$

$$c = \frac{1 \sin 39^\circ + 6 \cos 39^\circ}{2} = 2.6961 \text{ IN} \checkmark$$



$$d = 40.0230 + 2.0168 + .3147 = 42.3595 \text{ IN} \checkmark$$

$$I_{x_2} + A d_{x_2}^2 = 10774.4912 \text{ IN}^4$$


— 4 —

$$I_{x_3} = \frac{1 \times 6 (6^2 \sin^2 39 + 1^2 \cos^2 39)}{12} = 7.43 \text{ IN}^4$$

$$c = \frac{6 \sin 39^\circ + 1 \cos 39^\circ}{2} = 2.2765 \checkmark$$

$$d = 1.9944 + .3885 + 32.91 = 34.2979 \text{ IN} \checkmark$$

$$I_{x_3} + A d_{x_3}^2 = 7065.51 \checkmark$$





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 5-15-79 PROJ. 5101 TASK 026  
CHKD. OY DATE 6-25-81 PAGE 1 OF 1  
LACBWR SEP  
Page B-165 of 258

REF.

STIFFENERS @ 84°

$I_{x2}$  IS EQUAL TO  $I_{x3}$  OF STIFFENER @ 6°

$$I_{x2} + Ad_{x2}^2 = 195.3987 \text{ in}^4$$

$I_{x3}$  IS EQUAL TO  $I_{x2}$  OF STIFFENER @ 6°

$$I_{x3} = 17644.5594 \text{ in}^4 \checkmark$$

STIFFENER @ 51°

$I_{x2}$  IS EQUAL TO  $I_{x3}$  OF STIFFENER @ 39°

$$I_{x2} + Ad_{x2}^2 = 7065.51 \text{ in}^4$$

$I_{x3}$  IS EQUAL TO  $I_{x2}$  OF STIFFENER @ 39°

$$I_{x3} + Ad_{x3}^2 = 10774.4912 \checkmark$$

TOTAL	416,775	416,775
2 IC 6°	35289.0	340
2 I @ 39°	21549.0	14131
2 IC 84	390.0	35289
2 IC 51	<u>14131.02</u>	<u>21549</u>
	<u><math>488139.02 \text{ in}^4</math></u>	<u><math>488139.02 \text{ in}^4</math></u>

$$A = \theta(6) = 98 + 320.99 = 368.49 \text{ in}^2$$

$$\text{WEIGHT} = \frac{368.49}{144} = 2.5586 \text{ FT}^2 \checkmark$$

$$\text{SUPPORT SKIRT WEIGHT} = 2.5586 \times 490 \times 7.5 = 9.4 \text{ K}$$

## REACTOR SUPPORT SKIRT PROPERTIES

REF.

Polar moment of Inertia.

$$\bar{J} = \sum Ad_{x_2}^2 + \sum Ad_{x_3}^2 + \bar{J}(\text{cylinder})$$

$$\bar{J}_{\text{cylinder}} = \frac{\pi}{32} (d_o^4 - d_i^4) = 833,551 \text{ in}^4. \checkmark$$

$\sum Ad^2$  of stiffener:

$$\begin{aligned} \sum Ad_{x_2}^2 &= 2(6 \times 54.2014^2 + 6 \times 42.3545^2 + 6 \times 5.6966^2 + 6 \times 34.2979^2) \\ &= 71286 \text{ in}^4. \checkmark \end{aligned}$$


$$\begin{aligned} \sum Ad_{x_3}^2 &= 2 \times 6 (5.6966^2 + 34.2979^2 + 54.2014^2 + 42.3545^2) \\ &= 71286 \text{ in}^4 \checkmark \end{aligned}$$

$$\bar{J} = 71286 \text{ in}^4 + 71286 \text{ in}^4 + 833,551 \text{ in}^4 = 976,123 \text{ in}^4. \checkmark$$



REF.

STIFFNESS OF BELLows SEAL.



Ref. Dwg. Sargent & Lundy Dwg. 41-503383

Material 304 stainless steel ✓

Thickness  $t_1 = 14$  Gage.  $t_1 = 0.0747''$

Bellow seal:

$$\text{Cross-sectional Area } A = \pi \times 131.5 \times 0.0747 = 30.86 \text{ in}^2$$

$$\text{Moment of Inertia } I = \pi \left(\frac{131.5}{2}\right)^3 \times 0.0747 = 66704.9 \text{ in}^4$$

Deflection due to lateral Load  $P = \delta = \frac{PH}{AG} + \frac{PH^3}{3EI}$

Shear Area  $\bar{A} = 0.53K_A$  ✓ (Page B1-112 STARDYME Manual)

$$G = 0.4 \times 28600 \text{ KSI}; E = 28,600 \text{ KSI}$$

$$\therefore \delta = P \left\{ \frac{25.0}{0.53 \times 30.86 \times 0.4 \times 28600} + \frac{(25.0)^3}{3 \times 28600 \times 66704.9} \right\}$$

$$= 1.363 \times 10^{-4} P$$

$$\text{Bellows Stiffness } K_b = \frac{P}{\delta} = 7334.5 \text{ K/in.}$$

REF.

Stiffness of  $\frac{1}{2}$ " thick, 146.0" diameter cylindrical tube:

$$\text{Cross-sectional Area } A_2 = \pi \times 146 \times 0.5 = 229.3 \text{ in.}^2$$

$$\text{Moment of Inertia } I_2 = \pi (73)^3 \times 0.5 = 611066.5 \text{ in.}^4$$

$$\text{Shear Area } \bar{A} = 0.53 \times A_2 = 0.53 \times 229.3 = 121.55 \text{ in.}^2$$

$$G = 0.4 \times 28600 \text{ ksi; } E = 28,600 \text{ ksi.}$$

$$\therefore \delta = \left\{ \frac{25.0}{121.55 \times 0.4 \times 28600} + \frac{(25.0)^3}{3 \times 28600 \times 611066.5} \right\} -$$

$$\delta = 1.8277 \times 10^{-5} P$$

$$\therefore \text{Tube Stiffness } K_T = \frac{P}{\delta} = 54,714.3 \text{ K/in.}$$

The Bellow Seal and the Tube acts in series

∴ The combined stiffness

$$K = \left\{ \frac{1}{K_b} + \frac{1}{K_T} \right\}^{-1}$$

$$= 6467.5 \text{ K/in.}$$

For Beam in X2 Direction

Effective Spring Length = 0.01"

$$\therefore \text{Area of Beam} = \frac{KL}{E} = \frac{0.01 \times 6467.5}{25.7 \times 10^3}$$

$$= 0.002517 \text{ in.}^2$$

For Equivalent Beam in X1 Direction

$$\text{Effective Length} = 86 - 30 = 56"$$


$$\therefore \text{Area of Beam} = \frac{KL}{E} = \frac{6467.5 \times 56}{25.7 \times 10^3} = 14.093 \text{ in.}^2$$



BELLOW SEAL

REF.

Equivalent  $I_{eq}$  for the Beam (86" long).




$$M = \frac{6EI_{eq}\delta}{L^2}$$

$$P = \frac{2M}{L} = \frac{12EI_{eq}\delta}{L^3}$$

$$\therefore \text{Lateral Stiffness } K = \frac{P}{\delta} = \frac{12EI_{eq}}{L^3} \checkmark$$

$$\therefore I_{eq} = \frac{KL^3}{12E} = \frac{6467.5(86)^3}{12 \times 25.7 \times 10^3}$$

$$= 1.33 \times 10^4 = \underline{13300.0}$$



$$I_{X2} = I_{eq}$$

Equivalent  $I_3$ .

from Zilla Brothers Dwg. C 227953

$$P = 10K; \delta = 1.5"$$

$$\therefore K = \frac{P}{\delta} = \frac{10}{1.5} = 6.67 \text{ kN/m}$$

$$\therefore I_{eq} = \frac{6.67 \times (86)^3}{12 \times 25.7 \times 10^3} = \underline{13.756 \text{ in.}^4}$$



REF.

Foundation Spring Stiffness

The stiffness of the lateral and rocking springs representing the shear and vertical deformation of the soil beneath the foundation mat are obtained using the following equations. These equations are taken from Reference 9.

$$\text{Horizontal spring stiffness, } K_x = \frac{32(1-\mu)G\gamma}{7-8\mu}$$

$$\text{Rocking spring stiffness, } K_\theta = \frac{8G\gamma^3}{3(1-\mu)}$$

where  $\gamma$  = Effective Radius of Foundation Mat

$\mu$  = Poisson's Ratio of Soil

$G$  = Shear Modulus of Soil

The soil properties are taken from Reference 1. For the standard foundation spring, the soil properties correspond to averaged values for boring number 3

$$G = \text{Shear Modulus of Soil} = 2.40 \times 10^6 \text{ lbs/ft.}^2$$

(Tables 3.1 and 2.2 of Reference 1)

$$\mu = \text{Poisson's Ratio} = 0.24 \text{ (Calculated from data given in Table 3.1)}$$

$$\gamma = \text{Effective Radius of Foundation Mat} = 33.5 \text{ feet}$$

$$K_x = \frac{32(1-0.24)2.40 \times 10^6 \times 33.5}{7-8 \times 0.24}$$

$$K_x = 384.9 \times 10^6 \text{ lbs/ft.} = 32.08 \times 10^3 \text{ K/in.}$$

$$K_\theta = \frac{8 \times 2.40 \times 10^6 (33.5)^3}{3(1-0.24)}$$

$$K_\theta = 316.59 \times 10^9 \text{ lbs.ft./radian}$$

$$K_\theta = 3799.11 \times 10^6 \text{ K.in./radian}$$



$$\text{Vertical Spring Constant } K_z = \frac{4G\gamma}{1-\mu}$$

$$= \frac{4 \times 2.4 \times 10^6 \times 33.5}{1 - 0.24}$$

$$= 4.2316 \times 10^8 \text{ lbs/in.} \checkmark$$

$$= 35.26 \times 10^3 \text{ K/in.} \checkmark$$

$$\text{TORSIONAL Spring Constant } K_\theta = \frac{16}{3} G\gamma^3$$


$$= \frac{16}{3} \times 2.4 \times 10^6 \times (33.5)^3$$

$$= 481,220.8 \times 10^6 \text{ lbs-ft/radians.}$$

$$= 5774.65 \times 10^6 \text{ KNm/radians}$$

## LACROSSE

page B-172 of 258 Displaced



LACROZ'S CONTAINMENT BLDG EVALUATION			REF.
5%	SP. STRE		
FREQ/ <sub>PERIOD</sub>	a. m/sec <sup>2</sup>	a	
1 / 1	0.1524 ✓	<u>2.54 x 386.4</u>	
2.5 / 4	0.199 ✓		
3.33 / 3	0.206 ✓		
5 / 2	0.218 ✓		
10 / 1	0.183 ✓		
12.5 / 0.8	0.155 ✓		
20 / 0.5	0.133 ✓		
25 / 0.4	0.125 ✓		
30 / 0.33	0.104 ✓		
31 / 0.32	0.104 ✓		

NUCLEAR SAFETY PROGRAM  
SITE SPECIFIC SPECTRA  
PSEUDO SPECTRAL ACCELERATIONS (cm/sec<sup>2</sup>)

Page B-174 of 258

Yankee Rowe	Oyster Creek	Dinna	Weddam Neck	Hillstone	Sig Rock Pt.	LaCrosse	Palisades	Dresd
08.00	172.61	170.85	215.91	196.23	122.29	122.29	122.29	124.1
212.69	178.17	182.52	220.92	210.91	130.19	130.19	130.19	142.1
247.74	206.77	230.16	279.47	253.44	152.05	152.05	152.05	164.1
275.53	229.93	260.38	216.00	287.00	179.69	179.69	179.69	181.1
434.80	353.77	353.92	475.17	433.55	212.50	213.50	214.77	270.1
455.49	375.59	375.52	455.79	415.45	201.96	201.96	224.41	267.4
403.76	339.90	328.79	395.71	360.53	171.68	195.71	218.32	249.2
224.32	180.93	185.10	183.25	165.68	122.90	151.98	174.57	185.1
195.20	161.23	168.65	202.48	184.15	102.50	102.50	102.50	126.1
22.43	18.41	16.92	19.56	17.82	11.39	13.60	15.18	16.0

CONVERSION TO OTHER DAMPING VALUES (RANGE 2% - 20%)

$$PSA_{xx} = PSA_{5x} \times 10^{\frac{4-C}{10} * (\text{new damping}(x) - .05)}$$

↓ result.

CT	Frequencies
**	25
**	20
-0.290	15.365
-0.600	12.5
-0.904	10.0
-1.270	7.62
-1.700	5
-1.990	3.925
-1.980	3.7
-1.810	3.225
-1.960	2

\* VELOCITY = cm/sec

\*cm/sec

Highly Insignificant Coefficient, Use 5% PSA Value

CONTAINMENT BUILDING - RESPONSE SPECTRA - X1 DIRECTION - NORMAL SENSING							REF.
<u>Mode N°</u>	<u>Frequency/Period</u>	<u>Composite Damping</u>	<u>% Damping</u> <u>Site Spe. Spectra</u> <u>(g/s)</u>	<u>C<sub>T</sub></u>	<u>Factor</u>	<u>Result</u> <u>(g/s)</u>	<u>Group</u>
2 ✓	1.876/.5332 ✓	.06356 ✓	.17 ✓	-1.915 ✓	.942 ✓	.160 ✓	1
3 ✓	4.972/.2011 ✓	.06651 ✓	.218 ✓	-1.703 ✓	.937 ✓	.204 ✓	2
5 ✓	6.485/.1542 ✓	.04510 ✓	.19 ✓	-1.419 ✓	1.016 ✓	.193 ✓	3
7 ✓	9.987/.1001 ✓	.06373 ✓	.183 ✓	-.904 ✓	.972 ✓	.178 ✓	4
8 ✓	16.491/.0606 ✓	.04046 ✓	.133 ✓	-.29 ✓	1.106 ✓	.134 ✓	5
10 ✓	23.829/.0420 ✓	.04354 ✓	.125 ✓		1. ✓	.125 ✓	6
12 ✓	24.549/.0407 ✓	.04176 ✓	.125 ✓		1. ✓	.125 ✓	6
14 ✓	28.399/.0352 ✓	.06791 ✓	.120 ✓		1. ✓	.12 ✓	7
15 ✓	32.417/.0308 ✓	.04085 ✓	.104 ✓		1. ✓	.104 ✓	8



NUCLEAR ENERGY SERVICES

BY ML DATE 3/2/82 PROJ. 2101 TASK 247CHKD. JL DATE 3/15/82 PAGE \_\_\_\_\_ OF \_\_\_\_\_NUCLEAR SEZ - SITE SPECIFIC SPECTRA  
Page B-176 OF 258

## CONTAINMENT BUILDING - RESPONSE SPECTRA - X2 DIRECTION-NORMAL SERVING

REF.

From Computer Output SG200W

Mode No	Freq./Period	Composite Damping	Site Spe. Spectra	5% Damping (g's)	C <sub>T</sub>	Factor	Result (g's)	Group
1 ✓	1.871/.5345 ✓	.06442 ✓	✓	.17 ✓	-1.915 ✓	.938 ✓	.159 ✓	1
4 ✓	6.442/.1552 ✓	.04575 ✓	✓	.19 ✓	-1.425 ✓	1.014 ✓	.193 ✓	2
6 ✓	9.840/.1016 ✓	.06613 ✓	✓	.185 ✓	-.924 ✓	.966 ✓	.179 ✓	3
9 ✓	21.506/.0465 ✓	.04309 ✓	✓	.125 ✓	✓	1.	.125 ✓	4
11 ✓	24.117/.0415 ✓	.04899 ✓	✓	.125 ✓	✓	1.	.125 ✓	5
13 ✗	25.267/.0396 ✓	.05637 ✓	✓	.125 ✓	✓	2.	.125 ✓	5



NUCLEAR ENERGY SERVICES

BY NC DATE 3/2/82 PROJ. 5101 TASK 247  
CHKD. JC DATE 3/15/82 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
NUCLEAR SITE SPECIFIC SPECTRA  
Page B-177 OF 258

CONTAINMENT BUILDING - RESPONSE SPECTRA - X3 DIRECTION - NORMAL SPRING

REF.

From Computer Output 36200W

Mode No	Freq./Period	Composite Damping	% Damping	Site Spe. Spectra	C <sub>T</sub>	Factor	Result	Group
				(g/s)			(Vertical = 2/s, Horizontal)	
2	1.876/.5332	.06356 ✓	.17 ✓		-1.915	.942	.107	1
3	4.972/.2011	.06651 ✓	.218 ✓		-1.703	.937	.136 ✓	2
5	6.485/.1542	.04510 ✓	.19 ✓		-1.419	1.016	.129 ✓	3
7	9.987/.1001	.06373 ✓	.183 ✓		- .904	.972	.118 ✓	4
10	23.829/.0420	.04354 ✓	.125 ✓			1.	.083 ✓	5
14	28.399/.0352	.06791 ✓	.120 ✓			1.	.080 ✓	6



NUCLEAR ENERGY SERVICES

BY NC DATE 3/11 PROJ. 5101 TASK 247  
 CHKD. JC DATE 3/15/82 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LAPLWA SFP - SITE SPECIFIC SPECTRA  
Page B178 of 258

CONTAINMENT BUILDING — RESPONSE SPECTRA — X<sub>Z</sub> DIRECTION (STIFFENED SPRINGS)

REF.

From Computer Output 56200 QB

Mode No.	Freq./Period	Composite Damping	5% Damping Site Sp. Spectra	(4/s)	CT Factor	Result	(g/s)	Group
2 ✓	2.253/.4438 ✓	.0635186 ✓	.196 ✓	-1.959 ✓	.941 ✓	.184 ✓	✓	1
3 ✓	6.032/.1658 ✓	.0666024 ✓	.206 ✓	-1.490 ✓	.945 ✓	.195 ✓	✓	2
5 ✓	6.552/.1526 ✓	.0453613 ✓	.190 ✓	-1.493 ✓	1.015 ✓	.193 ✓	✓	2
7 ✓	11.607/.0647 ✓	.0652246 ✓	.162 ✓	-6.71 ✓	.977 ✓	.158 ✓	✓	3
8 ✓	16.540/.0605 ✓	.0403261 ✓	.133 ✓	-2.29 ✓	1.006 ✓	.134 ✓	✓	4
10 ✓	23.849/.0419 ✓	.0434536 ✓	.125 ✓	1		.125 ✓	✓	5
12 ✓	24.577/.0457 ✓	.0420097 ✓	.125 ✓	1		.125 ✓	✓	5
14 ✓	28.849/.0347 ✓	.0678376 ✓	.120 ✓	1		.12 ✓	✓	6
15 ✓	32.431/.1308 ✓	.0407828 ✓	.104 ✓	1		.104 ✓	✓	7

CONTAINMENT BUILDING - RESPONSE SPECTRA - X2 DIRECTION (STIFFENED SPRING).	REF.
--	------

From Computer Output S6200 Q8

(g's)

Mode No	Freq / Period	Composite Damping	5% Damping	Site Sp. spectra	CT	Factor	Result	Group
1 ✓	2.244/.4457 ✓	.0644427 ✓	.196 ✓		-1.958 ✓	.937 ✓	.184 ✓	2
4 ✓	6.507/.1537 ✓	.0460114 ✓	.190 ✓		-1.416 ✓	1.013 ✓	.192 ✓	2
6 ✓	11.591/.0863 ✓	.0674163 ✓	.164 ✓		-6.96 ✓	.972 ✓	.159 ✓	3
9 ✓	21.601/.0463 ✓	.0422083 ✓	.130 ✓		1 ✓		.130 ✓	4
11 ✓	24.295/.0412 ✓	.0457678 ✓	.125 ✓		1		.125 ✓	5
13 ✓	25.591/.0385 ✓	.0610623 ✓	.125 ✓		1		.125 ✓	5

**NES**  
NUCLEAR ENERGY SERVICES

BY NR DATE 3/11 PROJ. 5101 TASK 247  
 CHKD. JC DATE 3/15/82 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP - SITE SPECIFIC SPECTRA  
Page B-180 OF 258

CONTAINMENT BUILDING - RESPONSE SPECTRA - X3 DIRECTION (STIFFENED SPRINGS)


REF.

From Computer output 56250 QB


Mode No	F <sub>n</sub> /Period	Composite Damping	Site Sp. Spectra	(g/s)		CT Factor	m/s (2/3 Vertical)	Group
				Damping	(g/s)			
2 ✓	2.253/.4433 ✓	.0625186 ✓	.196 ✓	-1.959 ✓	.941 ✓	.123 ✓	✓	1
3 ✓	6.033/.1658 ✓	.0666024 ✓	.206 ✓	-1.490 ✓	.945 ✓	.130 ✓	✓	2
5 ✓	6.552/.1526 ✓	.0453619 ✓	.190 ✓	-1.409 ✓	1.015 ✓	.129 ✓	✓	2
7 ✓	11.887/.0947 ✓	.0652246 ✓	.162 ✓	-1.671 ✓	.977 ✓	.106 ✓	✓	3
10 ✓	23.843/.0419 ✓	.0434536 ✓	.125 ✓	1 ✓	.083 ✓	✓	✓	4
14 ✓	28.843/.0347 ✓	.0678376 ✓	.120 ✓	1 ✓	.180 ✓	✓	✓	5

ANALYSIS  
AND  
RESULTS


## CONTAINMENT BUILDING



## CONTAINMENT BUILDING




## CONTAINMENT BUILDING




## CONTAINMENT BUILDING

461510


K-E 10 X 10 TO THE CENTIMETER 10 X 25 CM  
KEUFFEL & ESSER CO. NEW YORK



## CONTAINMENT BUILDING



## CONTAINMENT BUILDING




461510

K.E. TO THE CENTIMETER IN X 25 CM


REDFERF &amp; ESSER CO MADE IN U.S.A.

## CONTAINMENT BUILDING


461510

K-E IN X 10 TO THE CENTIMETER 10 X 25 CM  
KEUFFEL & ESSER CO. NEW YORK

## CONTAINMENT BUILDING



## CONTAINMENT BUILDING






NUCLEAR ENERGY SERVICES, INC.

DOCUMENT NO. (2)

PAGE B-191 OF 258






## NUCLEAR ENERGY SERVICES, INC.

DOCUMENT NO.

(3)

PAGE B-192 OF 258






## NUCLEAR ENERGY SERVICES, INC.

**DOCUMENT NO.**

PAGE B-193 OF 258

(d)



GP - BROWN FINE TO MEDIUM SAND AND FINE TO MEDIUM GRAVEL

SP GRAY FINE SAND WITH TRACE SILT

APPROXIMATE TOP OF  
BEDROCK EL 507.0



REF.


CONTAINMENT SHELL AND REACTOR VESSEL  
 ACCEPTANCE CRITERIA BASED ON ASME SECTION III,  
 DIV 2, ALTERNATE RULES, 1977 ED.

FROM 4-130 BASIC STRESS INTENSITY LIMITS

<u>STRESS INTENSITY</u>	<u>LIMIT</u>
$P_m$	$k S_m$
$P_m + P_b$	$1.5 k S_m$

WHERE  $P_m$  = GENERAL PRIMARY MEMBRANE STRESS  
 $P_b$  = PRIMARY BENDING STRESS  
 $S_m$  = DESIGN STRESS INTENSITY  
 $k$  = FACTOR GIVEN IN TABLE AD-150.1

Containment shell material : A 201 (change to A 515, A 516)



CONTAINMENT SHELL

REF.

## ASME SECTION VIII Analysis

From Article 4-221, page 364

REF: ASME SECTION VIII  
DIV 2, ALT RULES, 1977

Principal stress due to pressure:

$$\sigma_1 = \sigma_t = p(1+z^2)/(Y^2-z) \quad \checkmark$$

$$\sigma_2 = \sigma_\ell = p/(Y^2-z) \quad \checkmark$$

$$\sigma_3 = \sigma_r = -p(1-z^2)/(Y^2-z) \quad \checkmark$$

in which  $p$  = internal pressure,  $Y = \frac{\text{outside radius}}{\text{inside radius}}$ ,  $Z = \frac{\text{outside radius}}{\text{interested point radius}}$

Maximum stress occur at  $r$  = internal radius, thus:

$$\sigma_1 = \sigma_t = p \frac{R_o^2 + R_i^2}{R_o^2 - R_i^2}$$

$$Z = R_o/R_i$$

$$\sigma_2 = \sigma_\ell = \frac{p R_i^2}{R_o^2 - R_i^2}$$

$$\sigma_3 = \sigma_r = -p$$

CONTAINMENT SHELL# Principal stress due to pressure:  $R_i = 30'$ ,  $R_o = 30.0967'$ ,  $p = 52\text{psi}$ 

$$\sigma_1 = \sigma_t = .052 \times \frac{30.0967^2 + 30^2}{30.0967^2 - 30^2} = 16.158 \text{ ksi}$$

$$\sigma_2 = \sigma_\ell = \frac{.052 \times 30^2}{30.0967^2 - 30^2} = 8.053 \text{ ksi}$$

$$\sigma_3 = \sigma_r = -p = -.052 \text{ ksi}$$

$$\sigma_1 - \sigma_2 = 16.158 - 8.053 = 8.105 \text{ ksi}$$

$$\sigma_2 - \sigma_3 = 8.053 - (-.052) = 8.105 \text{ ksi}$$

$$\sigma_3 - \sigma_1 = -.052 - 16.158 = -16.21 \text{ ksi}$$

ASME  
SECT VIII  
DIV 2, ALT.  
1977  
16.21 ksi. SECT 4-120

CONTAINMENT SHELL

REF.

\* Principal stress due to Dead load:

From output S6200Y2, stress due to D.L = -.618 ksi

Since this is the only term cause by D.L, principal stress due to dead load = -.618 ksi  $\Rightarrow$  stress intensity = .618 ksi

\* Principal stress due to Seismic (bending)

$$\sigma_y = \pm 1.127 \text{ ksi}, \quad \sigma = 1.173 \text{ ksi} \quad (\text{S6200Y2}).$$

$$\text{Principal stress: } \sigma_1, \sigma_2 = \frac{1.127}{2} \pm \sqrt{\left(\frac{1.127}{2}\right)^2 + 1.173^2}$$

$$\begin{aligned} \sigma_1 &= 1.865 \text{ ksi} \\ \sigma_2 &= -0.737 \text{ ksi} \end{aligned} \quad \left. \begin{array}{l} \text{stress intensity} = 1.865 - (-0.737) \\ \qquad\qquad\qquad = 2.602 \text{ ksi} \end{array} \right\}$$

LOAD COMBINATION	$P_m$ (ksi)	LIMIT (ksi)	$P_b$ (ksi)	$P_m + P_b$ (ksi)	LIMIT (ksi)	
D+L + Pa	$16.21 + .618$ $= 16.828$	$(1.0)(18.9)$ $= 18.9$	0	$16.828$	$(1.5)(18.9)$ $= 28.35$	OK
D+L + Pa + E'	16.828	18.9	2.602	19.43	28.35	OK

ASSUME K=1.0 FOR BOTH COMBINATIONS

PLATE MATERIAL A201 REPLACED BY AS15, AS16  
 $S_u < 18.9 \text{ ksi}$  @ 300° FOR AS15, AS16 GRADE 6D -  
 TABLE ACS-1  
 ASME SECTION VIII  
 DIV 2, ALT RULES, 1977

CONTAINMENT BUILDING - SHELL ANALYSIS - NORMAL SPRING

REF.

Node 1 to node 35.

- Material : Steel A201 changed to A515 &amp; A516

$$\sigma_y \text{ for A-516 class I} = 30 \text{ ksi } \checkmark$$

(from APPENDIX I - Table I7.1, page 100  
ASME APPENDICES 1980)

at  $100^{\circ}\text{F}$  =  $13.7 \text{ ksi } \checkmark$ - From Output  $S6200 \text{ FT}$ 

$$\text{Maximum bending stress at beam 34, node 35 : } \sigma_{M_1} = .7213 \text{ ksi } \checkmark$$

$$\sigma_{M_2} = .7415 \text{ ksi } \checkmark$$

$$\text{Axial stress : } \sigma_A = -.4726 \text{ ksi (compression) } \checkmark$$

Resulting stress :

$$-.4726 - \sqrt{.7415^2 + .7213^2} = -1.507 \text{ ksi (Compression) } \checkmark$$

$$-.4726 + \sqrt{.7415^2 + .7213^2} = .582 \text{ ksi (Tension) } \checkmark$$

MAXIMUM SHEAR : At node 3 (beam 3 & beam 6)

SHEAR X1 direction:

$$\text{- Beam 3 : } .2184 \checkmark$$

$$\text{- Beam 6 : } \frac{.554}{.7724} \checkmark$$

SHEAR X2 direction

$$.2122 \checkmark$$

$$\frac{.5384}{.7506} \checkmark$$

$$\text{Resulting shear} = \sqrt{.7724^2 + .7506^2} = 1.077 \text{ ksi. } \checkmark$$

Allowable steel stress :

$$1.6 \times .6 \sigma_y = .96 \times 30 = 28.8 \checkmark$$

$$3 S_n = (13.7 \text{ ksi at } 100^{\circ}\text{F}) (3) = 41.1 \text{ ksi } \checkmark$$



NUCLEAR ENERGY SERVICES

BY NK DATE 3/12/82 PROJ. 5101 TASK 2  
CHKD. JC DATE 3/18/82 PAGE 1 OF 1  
LACWR SET - SITE SPECIFIC SECTION  
Page B-700 of 258

CONTAINMENT BUILDING - SHELL ANALYSIS - STIFFENED SECTION

REF.

Node 1 to node 35

From output 56200 YZ .

Max. bending stress at beam 34 node 35 : ✓

$$\sigma_{M_1} = .786694 \text{ ksi} \quad /$$
$$\sigma_{M_2} = .806398 \text{ ksi} \quad /$$

Axial stress: ✓

$$\sigma_A = -.618411 \text{ (compression)} \quad /$$
$$= -.475787 \text{ (compression)} \quad /$$

Resulting stress:

$$-.618411 - \sqrt{.786694^2 + .806398^2} = -1.745 \text{ ksi (compression)} \quad /$$
$$-.475787 + \sqrt{.786694^2 + .806398^2} = .651 \text{ ksi (Tension)} \quad /$$

MAX. SHEAR : at node 3 (beam 3 & beam 6) ✓X<sub>2</sub> SHEAR

- Beam 3 : .237517 ✓  
- Beam 6 : .602791 ✓  
.840308 ✓


X<sub>2</sub> SHEAR

.231432 ✓  
.58735 ✓  
.818782 ✓

Resulting shear  $\sqrt{.840308^2 + .818782^2} = 1.173 \text{ ksi}$  ✓

Allowable side shear:  $1.6 \times .4 \times 30 = 19.2 \text{ ksi}$ .

- \*A 178-73 Electric-Resistance-Welded Carbon Steel Boiler Tubes, Spec. for, 1, 1100-3000 psi, A 178-62 A
- \*A 179-68(1973) Seamless Cold-Drawn Low-Carbon Steel Heat-Exchanger and Condenser Tubes, Spec. for, 1
- A 180 Discontinued—Replaced by A 27 A 180-67
- \*A 181-68 Forged or Rolled Steel Pipe Flanges, Forged Fittings, and Valves and Parts for General Service, Spec. for, 3, 1000-1500 psi, A 181-68
- \*A 182-74 Forged or Rolled Alloy-Steel Pipe Flanges, Forged Fittings, and Valves and Parts for High-Temperature Service, Spec. for, 1
- \*A 183-68 Heat-Treated Carbon Steel Track Bolts and Carbon Steel Nuts, Spec. for, 4
- \*A 184-65(1972) Fabricated Steel Bar or Rod Mats for Concrete Reinforcement, Spec. for, 4
- \*A 185-73 Welded Steel Wire Fabric for Concrete Reinforcement, Spec. for, 4
- A 186 Discontinued—Replaced by A 504
- A 187 Discontinued—Replaced by A 239
- A 188 Discontinued—Replaced by A 239
- A 189 Discontinued—Replaced by A 239
- A 190 Discontinued—Replaced by A 239
- A 191 Discontinued—Replaced by A 239
- \*A 192-73 Seamless Carbon Steel Boiler Tubes for High-Pressure Service, Spec. for, 1
- \*A 193-74 Alloy-Steel and Stainless Steel Boiling Materials for High-Temperature Service, Spec. for, 1
- \*A 194-73 Carbon and Alloy Steel Nuts for Bolts for acid, High-Pressure and High-Temperature Service, Spec. for, 1
- A 195 Discontinued—Replaced by A 502
- A 196 Discontinued—Replaced by A 502
- \*A 197-47(1971) Cupola Malleable Iron, Spec. for, 2
- A 198 Discontinued—Replaced by A 296, A 287
- \*A 199-73 Seamless Cold-Drawn Intermediate Alloy-Steel Heat-Exchanger and Condenser Tubes, Spec. for, 1
- \*A 200-72 Seamless Intermediate Alloy-Steel Still Tubes for Refinery Service, Spec. for, 1
- ~~Applicable by A 239, A 251, A 252, A 253, A 254, A 255, A 256, A 257, A 258, A 259, A 260, A 261, A 262, A 263, A 264, A 265, A 266, A 267, A 268, A 269, A 270, A 271, A 272, A 273, A 274, A 275, A 276, A 277, A 278~~
- \*A 202-74a Pressure Vessel Plates, Alloy Steel, Chromium-Manganese-Silicon, Spec. for, 4
- \*A 203-74a Pressure Vessel Plates, Alloy Steel, Nickel, Spec. for, 4
- \*A 204-74a Pressure Vessel Plates, Alloy Steel, Molybdenum, Spec. for, 4
- A 205 Discontinued—Replaced by A 233, A 251
- A 206 Discontinued—Replaced by A 335
- A 207 Discontinued—Replaced by A 239
- A 208 Discontinued—Replaced by A 239
- \*A 209-73 Seamless Carbon-Molybdenum Alloy-Steel Boiler and Superheater Tubes, Spec. for, 1
- \*A 210-73 Seamless Medium-Carbon Steel Boiler and Superheater Tubes, Spec. for, 1
- \*A 211-73 Spiral-Welded Steel or Iron Pipe, Spec. for, 1
- A 212 Discontinued—Replaced by A 515, A 516
- \*A 213-74 Seamless Ferritic and Austenitic Alloy Steel Boiler, Superheater, and Heat Exchanger Tubes, Spec. for, 1
- A 214-71 Electric-Resistance-Welded Carbon Steel Heat-Exchanger and Condenser Tubes, Spec. for, 1
- A 215 Discontinued—Replaced by A 27
- \*A 216-74b Carbon-Steel Castings Suitable for Fusion Welding for High-Temperature Service, Spec. for, 1
- \*A 217-74a Martensitic Stainless Steel and Alloy Steel Castings for Pressure-Containing Parts Suitable for High-Temperature Service, Spec. for, 1, 2
- A 218 Discontinued—Replaced by A 475
- A 219 Discontinued—Replaced by B 487, B 489, B 504, B 529, B 530
- \*A 220-71 Pearlite Malleable Iron Castings, Spec. for, 2
- A 221 Discontinued—Replaced by A 296, A 297
- A 222 Discontinued—Replaced by A 296, A 297
- A 223 Discontinued—Replaced by A 296, A 297
- A 224 Discontinued—Replaced by G 4
- \*A 225-74a Pressure Vessel Plates, Alloy Steel, Manganese-Vanadium, Spec. for, 4
- \*A 226-73 Electric-Resistance-Welded Carbon Steel Boiler and Superheater Tubes for High-Pressure Service, Spec. for, 1
- \*A 227-71 Steel Wire, Hard-Drawn for Mechanical Springs, Spec. for, 6
- \*A 228-71 Steel Wire, Music Spring Quality, Spec. for, 6
- \*A 229-71 Steel Wire, Oil-Tempered, for Mechanical Springs, Spec. for, 6
- \*A 230-71 Steel Wire, Oil-Tempered Carbon Valve Spring Quality, Spec. for, 6
- \*A 231-68 Chromium-Vanadium Alloy Steel Spring Wire, Spec. for, 6
- \*A 232-68 Chromium-Vanadium Alloy Steel Valve Spring Quality Wire, Spec. for, 6
- A 233 Discontinued—Available from American Welding Society
- \*A 234-74 Piping Fittings of Wrought Carbon Steel and Alloy Steel for Moderate and Elevated Temperatures, Spec. for, 3, 1000-1500 psi, A 234-67
- \*A 235-67 Carbon Steel Forgings for General Industrial Use, Spec. for, 1
- A 236-69a Carbon Steel Forgings for Railway Use, Spec. for, 4, 5
- \*A 237-67 Alloy Steel Forgings for General Industrial Use, Spec. for, 4, 5
- A 238-69 Forgings, Alloy Steel, for Railway Use, Spec. for, 5
- A 239-73 Locating the Thinnest Spot in a Zinc-Coated (Galvanized) Coating on Iron or Steel Articles by the Prece Test (Copper Sulfate Dip), Test for
- \*A 240-74 Heat-Resisting Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Fusion-Welded Unfired Pressure Vessels, Spec. for, 3, 4
- A 241-68 Hot-Worked High-Carbon Steel Tie Plates, Spec. for, 4
- \*A 242-74 High-Strength Low-Alloy Structural Steel, Spec. for, 4
- \*A 243-64(1970) Carbon and Alloy Steel Ring, Hollow Cylinder, and Disk Forgings for General Industrial Use, Spec. for, 5
- A 244 Discontinued—Replaced by A 504
- A 245 Discontinued—Replaced by A 570, A 617
- A 246 Discontinued—Replaced by A 245
- A 247-67(1972) Evaluating the Microstructure of Graphite in Iron Castings, 2
- A 248 Discontinued—Replaced by A 273, A 274
- \*A 249-74 Welded Austenitic Stainless Steel Boiler, Superheater, Heat-Exchanger, and Condenser Tubes, Spec. for, 1
- \*A 250-73 Electric-Resistance-Welded Carbon-Molybdenum Alloy-Steel Boiler and Superheater Tubes, Spec. for, 1
- A 251 Discontinued—Available from American Welding Society
- A 252-73 Welded and Seamless Steel Pipe Piles, Spec. for, 1
- A 253 Discontinued
- \*A 254-70 Copper Braze Steel Tubing, Spec. for, 1
- \*A 255-67(1974) End-Quench Test for Hardenability of Steel, 6
- A 256-46(1971) Compression Testing of Cast Iron, 2
- A 257 Discontinued—Replaced by A 34
- A 258 Discontinued—Replaced by A 34
- A 259 Discontinued—Replaced by A 34
- A 260 Discontinued
- A 261 Discontinued
- A 262-70 Detecting Susceptibility to Intergranular Attack in Stainless Steels, Rec. Practices for, 3
- \*A 263-74 Corrosion-Resisting Chromium Steel Clad Plate, Sheet, and Strip, Spec. for, 3, 4
- \*A 264-74 Stainless Chromium-Nickel Steel Clad Plate, Sheet, and Strip, Spec. for, 3, 4
- \*A 265-74 Nickel and Nickel-Base Alloy Clad Steel Plate, Spec. for, 3, 4
- \*A 266-69 Carbon Steel Forgings for Seamless Drums, Heads, and Other Pressure Vessel Components, Spec. for, 1, 5
- A 267 Discontinued
- \*A 268-73 Seamless and Welded Ferritic Stainless Steel Tubing for General Service, Spec. for, 1
- \*A 269-73 Seamless and Welded Austenitic Stainless Steel Tubing for General Service, Spec. for, 1
- \*A 270-73 Seamless and Welded Austenitic Stainless Steel Sanitary Tubing, Spec. for, 1
- \*A 271-73 Seamless Austenitic Chromium-Nickel Steel Still Tubes for Refinery Service, Spec. for, 1
- A 272 Discontinued—Replaced by E 109
- \*A 273-64(1969) Carbon-Steel Blooms, Billets, and Slabs for Forgings, Spec. for, 6
- \*A 274-64(1969) Alloy Steel Blooms, Billets, and Slabs for Forgings, Spec. for, 6
- \*A 275-71 Magnetic Particle Examination of Steel Forgings, 6
- \*A 276-73 Stainless and Heat-Resisting Steel Bars and Shapes, Spec. for, 6
- A 277 Discontinued—Replaced by A 338
- \*A 278-64(1971) Gray Iron Castings for



## CONTAINMENT BUILDING - OUTER SHIELD BUILDING ANALYSIS - NORMAL STRESS

REF.

NODE 36 to node 35 (Outer Shield Building)

From output 56200 FT

Maximum bending stress at node 35 (beam 44)

$$\sigma_{b_1} = .12344 \text{ ksi } \checkmark \quad \sigma_{b_2} = .11572 \text{ ksi. } \checkmark$$

$$\text{SRSS} = \sqrt{.12344^2 + .11572^2} = .169 \text{ ksi } \checkmark$$

Axial stress at node 35

$$\sigma_a = -.17478 \text{ ksi (compression) (output case 3)} \checkmark$$

$$\sigma_a = -.1261 \text{ ksi (compression) (output case 2)} \checkmark$$

Resulting:

$$\sigma_a + \text{SRSS} = -.17478 + .169 = -.00578 \text{ (compression)} \checkmark$$

$$\sigma_a - \text{SRSS} = -.17478 - .169 = -.344 \text{ ksi (compression) Calculable OK}$$

$$\text{Tension: } \sigma_a + \text{SRSS} = -.1261 + .169 = .0429 \text{ ksi } \checkmark$$

SHEAR STRESS

Maximum at node 35:

$$\tau_1 = .02644 \checkmark \quad \tau_2 = .02518 \checkmark$$

$$\text{Resulting: } \tau = \sqrt{.02644^2 + .02518^2} = .0365 \text{ ksi. Calculable OK } \checkmark$$

ALLOWABLE STRESSMaximum allowable compression stress:  $.95 f_c = .95(3500) = 2975 \text{ psi } \checkmark$ Maximum shear stress =  $2\sqrt{f_c} = 2\sqrt{3500} = 118.32 \text{ psi. } \checkmark$

**NES**

NUCLEAR ENERGY SERVICES

BY NC DATE 2/25/82 PROJ S101 TASK 247CHKD. JL DATE 3/18/82 PAGE OF

LACBWR SEP - SITE SPECIFIC STEEL

Page B-204 of 258

CONTAINMENT BUILDING - OUTER SHIELD BUILDING ANALYSIS - NORMAL SPRING

REF.

REINFORCING CHECKING : 2 # 5 BARS @ 12" % C both faces E.W.

Reinforcing take tension load of concrete

Max tension from previous case :

$$\sigma_t = .0429 \text{ ksi } \checkmark$$

Tension force in steel:  $(.0429)(9)(12) = 4.633 \text{ k.} < \text{allowable}$  ✓

OK

Maximum force in steel:  $40 \times 2 \times .71 = 24.8 \text{ k.} \checkmark$

Max tension stress:  $\frac{24.8}{9 \times 12} = .23 \text{ ksi.} \checkmark$

CONTAINMENT BUILDER - OUTER SHIELD BUILDING ANALYSIS - STIFFENED SCANNING	REF.
---	------

Node 36 to node 35 (Outer shield building)

From output SG200YZ

Max. bending stress at node 35 (beam 44) ✓

$$\sigma_{b1} = .141677 \text{ ksi} \quad \checkmark \quad \sigma_{b2} = .131911 \text{ ksi} \quad \checkmark$$

$$\sigma_{RSS} = \sqrt{.141677^2 + .131911^2} = .193 \text{ ksi} \quad \checkmark$$

Axial stress at node 35: ✓

$$\sigma_a = -.124499 \text{ ksi (Comp.)} \quad \checkmark \quad \sigma_a = -.176389 \text{ ksi (Comp.)} \quad \checkmark$$

$$\text{Max resulting compression: } -.176389 - .193 = -.369 \text{ ksi} < 2.975 \text{ ksi} \quad \underline{\text{OK}} \quad \checkmark$$


$$\text{Max resulting tension: } -.124499 + .193 = .069 \text{ ksi} < .23 \text{ ksi} \quad \underline{\text{OK}} \quad \checkmark$$

### SHEAR STRESS

Max. at node 35 ✓

$$\tau_1 = .0301577 \text{ ksi} \quad \checkmark \quad \tau_2 = .0286576 \text{ ksi} \quad \checkmark$$

$$\text{Resulting Shear: } \sqrt{.0301577^2 + .0286576^2} = .0418 \text{ ksi} < 116.32 \text{ psi} \quad \underline{\text{OK}} \quad \checkmark$$





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION


BY RR DATE 6-7-79 PROJ. 5101 TASK 026  
CHKD. JNC DATE 7/17/82 PAGE 1 OF 1  
LAC/BVR SEP  
Page B-207 of 258

INNER SHIELD BLDG

REF.

MAIN SUPPORT COLUMNS

$$f'_c = 3500 \text{ PSL}$$
$$f_y = 40 \text{ KSL}$$



$$\text{GROSS AREA CONCRETE} = 8.125(100.375) + 8.125(108.50) + \frac{1}{2}(101.375)(101.375)$$
$$= 6835.6 \text{ IN}^2$$

$$\text{AREA STEEL} = 27(1.27) = 34.29 \text{ IN}^2 \quad A_{s_{\text{min}}} = 1.27 \text{ IN}^2$$

$$\rho = \frac{A_s}{A_g} = \frac{34.29}{6835.6} = 0.005$$

SECTION 10.5 - MINIMUM REINFORCEMENT OF FLEXURAL MEMBER

$$\rho_{\text{MIN}} * \frac{200}{F_y} = \frac{200}{40000} = 0.005$$

LIMITS FOR REINFORCEMENT OF COMPRESSION MEMBERS

$$A_{\text{max}} = .01 A_g = .01(6835.6) = 68.36 \text{ IN}^2 \text{ N.G.}$$

TIES DON'T CONFORM W ACIR-318-77



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 6-7-79 PROJ. 5101 TASK 026  
CHKD. NC DATE 3/10/79 PAGE 1 OF 1  
LACBWR SEP  
Page B-208 of 258

INNER SHIELD BLDG

REF.

NODE 46 & 53 & 66

APPROXIMATE MOMENT CAPACITY

$$F_y = 40 \text{ ksc} \quad w/27-t/10 \quad A_s = 34.29$$

$$F = (40)(34.29) = 1371.6^k$$

USING TWICE THIS /FOR 2 COLUMNS

$$d_{app} = 8.25'$$

$$M_u = 2(1371.6)(8.25)(12) = 2.71577 \times 10^5 (\text{k-in})$$

$$\text{ALLOWABLE STRESS} = \frac{(40)(34.29)}{6835.6} = 0.201 \text{ ksc}$$

$$\text{MODULUS OF RUPTURE OF CONCRETE} = f_r = 7.5 f_c = 493.7 \text{ psf} = 0.444 \text{ ksc}$$

CHECK SHEAR

$$\text{FOR CONCRETE ALONE} \quad N_c = \phi \cdot 2\sqrt{f_c} = (85)2\sqrt{3500} = 100.57 \text{ psf}$$

Moment from C.E. 620 ft-lb at beam 52 node 66.

$$M = 6.1816 \times 10^5 \text{ kip-in (case 2)} \quad (\text{normal spring})$$

$$M = 6.585849 \times 10^5 \text{ kip-in (case 2)}$$

$$\text{From C.E. } M = 7.0991 \times 10^5 \text{ kip-in (case 2)} \quad (\text{stiffened spring})$$

$$N = 7.39543 \times 10^5 \text{ kip-in (case 3)}$$

Reinforced not good but O.K. with modulus of rupture  
of concrete (at node 66).

CONTAINMENT BUILDING - INNER SHIELD BUILDING ANALYSIS - FORMAL LETTER

REF.

NCDE 46 → 53 & 66 (Inner shield building)

From output 56200.FH

Maximum bending stress at node 66 (Beam 52) ✓

$$\sigma_b = .13957 \text{ ksi} \quad \sigma_{b2} = .14852 \text{ ksi} \quad \checkmark$$

$$\text{SRSS} = \sqrt{.13957^2 + .14852^2} = .2038 \text{ ksi} \quad \checkmark$$

Axial stress at node 66

$$\sigma_a = -.1562 \text{ ksi} \quad (\text{Output case 2}) \quad \checkmark \quad (\text{Compression})$$

$$\sigma_{a2} = -.19705 \text{ ksi} \quad (\text{Output case 3}) \quad \checkmark$$

Resulting

$$\sigma_a + \text{SRSS} = -.1562 + .2038 = .0476 \text{ ksi} \quad (\text{Tension}) \quad \checkmark$$

$$\sigma_a - \text{SRSS} = -.19705 - .2038 = -.40085 \text{ ksi} \quad (\text{Compression}) < 2975 \text{ psi}$$

OK ✓

SHEAR STRESS

MAX. at node 66

$$\tau_1 = .2699 \times 10^7 \text{ ksi} \quad \tau_2 = .2704 \times 10^7 \text{ ksi} \quad \checkmark$$

$$\text{Resulting : } \tau = \sqrt{\tau_1^2 + \tau_2^2} = \sqrt{.2699^2 + .2704^2} \times 10^7 = 38.2 \text{ ksi} \quad \checkmark$$

For concrete alone :

$$\tau_c = \phi 2 \sqrt{f_c} = .85 \times 2 \sqrt{3500} = 100.57 \text{ psi}$$

$$\tau_u = \tau = 38.2 \text{ psi} < 100.57 \text{ psi} \quad \underline{\text{OK}}$$

CONTAINMENT BUILDING - INNER SHIELD BUILDING ANALYSIS - STIFFENED SPRINGS

REF.

Node 46 → 53 & 66 (Inner shield Building)

From output S6200 YZ.

Max bending stress at node 66 (Beam 52)

$$\sigma_{b_1} = .160289 \text{ ksi } \checkmark \quad \sigma_{b_2} = .168834 \text{ ksi } \checkmark$$

$$SRSS = \sqrt{.160289^2 + .168834^2} = .233 \text{ ksi } \checkmark$$

Axial stress at node 66

$$\sigma_a = -.156274 \text{ ksi (Comp)} \quad \sigma_a = -.196984 \text{ ksi (Comp)} \checkmark$$

$$\text{Resulting max compression: } -.196984 - .233 = .43 \text{ ksi} < 2,975 \text{ ksi } \underline{\text{OK}}$$

$$-- \text{ max tension: } -.156274 + .233 = .0767 \text{ ksi. } \checkmark$$

### SHEAR STRESS

Max at node 66

$$\tau_1 = .030825 \text{ ksi } \checkmark \quad \tau_2 = .0310668 \text{ ksi } \checkmark$$

$$\text{Resulting shear } \tau = \sqrt{.030825^2 + .0310668^2} = .0438 \text{ ksi} < 150.57 \text{ ksi } \underline{\text{OK.}}$$

### CHECK OUTER REINFORCING

TYPICAL REINFORCING: #6 @ 18% C FOR 2' WALL, AS = .44 in<sup>2</sup>.

$$\sigma_f = .0767 \text{ ksi}$$

$$\text{Tension in steel} = .0767 \times 24 \times 12 = 22.49 \text{ k. } < 35.2 \text{ k. } \underline{\text{OK}}$$

$$\text{Max. Force in steel: } 40 \times 2 \times .44 = 35.2 \text{ k.}$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 7-19-79 PROJ. 5101 TASK 026  
CHKD. JL DATE 3/23/82 PAGE / OF         
LACBWR SEP.


Page B-211 of 258

INNER SHIELD BLDG.

REF.

LOCATIONS FOR STRESS INVESTIGATIONS

(FOR BEAM 45 NODE 47)



$$\frac{H_2}{2} = 23.0'$$

$$\frac{H_2}{3} = 12.57'$$

## CONTAINMENT BUILDING - INNER SHIELD REBUILDING

REF.

BEAM 45 NODE 47

Find stresses at different locations of cross sections using linear interpolation and combine RSS.

LOCATION	<u>D.L. (um-MIN)</u>	<u>Stress (ksi)</u>	<u>E.Q.</u>			<u>Allowable Tension</u>
			<u><math>\sigma_{x_2}</math></u>	<u><math>\sigma_{x_3}</math></u>	<u><math>\sqrt{\sigma_{x_2}^2 + \sigma_{x_3}^2}</math> (ksi)</u>	
2	14.0	0 / -.02458	0 ✓	.00265 ✓	.00265 ✓	No ✓
2	0	9.5 / -.02458	.00122 ✓	0 ✓	.00122 ✓	No ✓
3	12.0	7.0 / -.02458	.00090 ✓	.00227 ✓	.00244 ✓	No ✓
4	18.0	3.0 / -.02458	.00038	.00341 ✓	.00343 ✓	No ✓

minimum axial

EQ + Dead load V compression at node 47 beam 45 : -.02458 ksi (Output S6200 FH)

Bending stress due to  
earthquake

$$\sigma_{x_2} = .00161 \text{ ksi (Output S6200 FH)} \checkmark$$

$$\sigma_{x_3} = .00436 \text{ ksi (Output S6200 FH)} \checkmark$$

No tension occur.

⇒ Minimum steel required.

CONTAINMENT BUILDING - INNER SHIELD BUILDING - STIFFENED SPRING CONSTANT	REF.
NOVE 47 BEAM 45	
From Output 56200 YZ:	
Bending stress: $\sigma_{x_2} = 1.6213 \times 10^3 \text{ ksi}$ ✓	
$\sigma_{x_3} = 5.74912 \times 10^3 \text{ ksi}$ ✓	
$\sigma_{RSS} = \sqrt{1.6213^2 + 5.74912^2} \times 10^3 = 6.031 \times 10^3 \text{ ksi}$ ✓	
Axial stress: $\sigma_A = -2.46 \times 10^2 \text{ ksi}$ ✓ (Compression)	
$\sigma_A = -3.211 \times 10^2 \text{ ksi}$ ✓	
MAX COMPRESSION: $-3.211 \times 10^2 - .6031 \times 10^3 = -3.8141 \times 10^2 \text{ ksi}$ ✓	
NO TENSION! ✓	
Since no tension, minimum steel required for reinforced concrete.	



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION


BY R.R. DATE 7-17-79 PROJ. 5101 TASK 026  
CHKD. J.C. DATE 3/23/82 PAGE 1 OF 1  
LACBWR SEP.

Page B-214 of 258

INNER SHIELD BLOC.

REF.

LOCATIONS FOR STRESS INVESTIGATIONS  
(FOR BEAM 47 NODE 49)



$$\frac{H_2}{2} = 22.47'$$

$$\frac{H_3}{2} = 12.57'$$


CONTAINMENT BUILDING - INNER SHIELD BUILDING - NORMAL SPRING								REF.																																													
<u>BEAM 47 NODE 49</u>																																																					
Find stresses at different locations of cross section using linear interpolation and combine R.S.L.																																																					
From output S6200 FH : VCompression by dead load $V = -.04955$ ksi																																																					
From output S6200 FH = Bending (CASE 1) $\sigma_{x_2} = 4.90525 \times 10^2$ ksi ✓ $\sigma_{x_3} = 4.92718 \times 10^2$ ksi ✓																																																					
<table border="1"> <thead> <tr> <th>LOCATION</th> <th><math>d_2</math></th> <th><math>d_3</math></th> <th>stren (ksi)</th> <th><math>\sigma_2</math></th> <th><math>\sigma_3</math></th> <th><math>\sqrt{\sigma_2^2 + \sigma_3^2}</math></th> <th><math>\sigma_{Tens}</math> (ksi)</th> <th>Allowable tension (ksi)</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>9.5</td> <td>0</td> <td>-.04955</td> <td>0</td> <td>.02083</td> <td>.02083</td> <td>No</td> <td>✓</td> </tr> <tr> <td>2</td> <td>3.5</td> <td>0</td> <td>-.04955</td> <td>0</td> <td>.00767</td> <td>.00767</td> <td>No</td> <td>✓</td> </tr> <tr> <td>3</td> <td>19.</td> <td>8.0</td> <td>-.04955</td> <td>.03122</td> <td>.04166</td> <td>.05206</td> <td>.00251</td> <td>&lt;.0515 OK</td> </tr> <tr> <td>4</td> <td>0</td> <td>10</td> <td>-.04955</td> <td>.03902</td> <td>0</td> <td>.03902</td> <td>No</td> <td>✓</td> </tr> </tbody> </table>									LOCATION	$d_2$	$d_3$	stren (ksi)	$\sigma_2$	$\sigma_3$	$\sqrt{\sigma_2^2 + \sigma_3^2}$	$\sigma_{Tens}$ (ksi)	Allowable tension (ksi)	1	9.5	0	-.04955	0	.02083	.02083	No	✓	2	3.5	0	-.04955	0	.00767	.00767	No	✓	3	19.	8.0	-.04955	.03122	.04166	.05206	.00251	<.0515 OK	4	0	10	-.04955	.03902	0	.03902	No	✓
LOCATION	$d_2$	$d_3$	stren (ksi)	$\sigma_2$	$\sigma_3$	$\sqrt{\sigma_2^2 + \sigma_3^2}$	$\sigma_{Tens}$ (ksi)	Allowable tension (ksi)																																													
1	9.5	0	-.04955	0	.02083	.02083	No	✓																																													
2	3.5	0	-.04955	0	.00767	.00767	No	✓																																													
3	19.	8.0	-.04955	.03122	.04166	.05206	.00251	<.0515 OK																																													
4	0	10	-.04955	.03902	0	.03902	No	✓																																													
<u>LOCATION 3</u>																																																					
Reinforced 2#6 C 12 , $A_s = 2 \times .44$ ✓																																																					
Width = 4.75' ✓																																																					
Allowable tension stress: $\frac{40 \times 2 \times .44}{12 \times 4.75 \times 12} = .0515$ ksi ✓																																																					



INNER SHIELD BLOCK (NODE 5C)

REF.

LOCATIONS OF STRESS INVESTIGATION  
(For Beam 49 Node 51)



$$\frac{H_2}{2} = 19.6'$$

$$\frac{H_1}{2} = 23.5'$$

CONTAINMENT BUILDING - INNER SHIELD BUILDING - NORMAL SPRING

REF.

BEAM 49 NODE 51

Find stresses at different locations of cross sections using linear interpolation and combine by RSS.

Minimum axial + E.Q.  
 From output S6200FH : Compression by dead load :  $-.07283 \text{ ksi}$ . ✓

From output S6200FH : Bending by earthquake :  $\sigma_{x_2} = 8.94899 \times 10^{-2}$  ✓  
 (Case 1)  $\sigma_{x_3} = 6.58971 \times 10^{-2}$  ✓

LOCATION	$d_2$	$d_3$	D.L. (long) Stress, ksi	E.Q. Bending (ksi)		$\sigma_{tension}$ (ksi)	Allowable tension (ksi)
				$\sigma_{x_2}$	$\sigma_{x_3}$		
1	19.6	0	-.07283	0	.0659	.0659	No tension
2	19.6	0	-.07283	0	.0659	.0659	-
3	3.5	21.0	-.07283	.07997	.01177	.08083	.008 < .118
4	8.5	0	-.07283	0	.02858	.02858	No tension

Allowable tension stress:

LOCATION 3

2#7 @ 12 EF,  $A_s = 2 \times 6 = 1.2 \text{ in}^2$  ✓

Width 2'-10" ✓

Allowable tension stress on steel :  $\frac{(40) \times 2 \times 6}{12 \times 2.83 \times 12} = .118 \text{ ksi}$ . ✓

CONTAINMENT BUILDING - INNER SHIELD BUILDING - STIFFENED STRINGER

REF.

NODE 51 BEAM 42

From Output S6200YZ.

Max Bending stress:  $\sigma_{x_2} = -102637 \text{ ksi}$  ✓

$\sigma_{x_3} = .0754699 \text{ ksi}$  ✓

SRSS =  $\sqrt{.102637^2 + .0754699^2} = .1274 \text{ ksi}$  ✓

Axial stress:  $\sigma_A = -7.29961 \times 10^{-2} \text{ ksi}$  (compression) ✓

$\sigma_A = -9.55239 \times 10^{-2} \text{ ksi}$  (compression) ✓

Max Compression:  $-.0955239 - .1274 = -.223 \text{ ksi}$  ✓

Max Tension:  $-.0729961 + .1274 = .0544 \text{ ksi}$  ✓

Find stresses at different locations of cross section using linear interpolation & combine by SRSS

LOCATION	d <sub>2</sub>	d <sub>3</sub>	D.L. (Comp.) Stress, ksi	Bending (ksi) $\sigma_{x_2}$	Bending (ksi) $\sigma_{x_3}$	$\sqrt{\sigma_{x_2}^2 + \sigma_{x_3}^2}$	$\sigma_{Tension}$	Allowable tension (ksi)
1	19.6'	0'	-.07299	0	.07547	✓	.07547	<.155
2	19.6'	0'	-.07299	0	.07547	✓	.07547	<.12
3	3.5'	21.'	vv v	.09172	.01348	✓	.09271	<.118 ✓
4	8.5'	0'	vv v	0	.03273	✓	.03273	No tension ✓

LOCATION #1 #10 @ 12" EF A<sub>s</sub> = (1.27 x 2) = 2.54 in<sup>2</sup> ✓

width = 4.54 ft ✓

Allowable tension:  $\frac{40 \times 2.54}{12 \times 4.54 \times 12} = .155 \text{ ksi}$  ✓

LOCATION #2 #6 @ 12" EF A<sub>s</sub> = .44 ✓

Width = 2.54' ✓

Allowable tension:  $\frac{2 \times 40 \times .44}{2.04 \times 12 \times 12} = .12 \text{ ksi}$  ✓




NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 6-20-79 PROJ. 5101 TASK 026  
CHKD. NC DATE 1/4/82 PAGE 1 OF 1  
LACBWR SEP  
Page B-220 of 258

INNER SHIELD BLDG.

REF.

LOCATIONS OF STRESS INVESTIGATION  
(FOR BEAM SZ NOC 66)



$$\frac{H_2}{2} = 26.7' \checkmark$$

$$\frac{H_3}{2} = 23.5' \checkmark$$

PLAN C BASEMENT

CONTAINMENT BUILDING - INNER SHIELD BUILDING - NORMAL SPRINTER

REF.

NODE 66 BEAM 52

Find stresses at different locations of cross-sections using linear interpolation and combine by RSS.

From Output S6200FH : Minimum axial compression by dead load + E.Q. : - .15621 ksi ✓

From Output S6200FH : Bending by earthquake  $\sigma_{x_2} = .13957$  ksi ✓  
 $\sigma_{x_3} = .14852$  ksi ✓

LOCATION	Axial Compression		Bending stress (ksi)		$\sqrt{\sigma_{x_2}^2 + \sigma_{x_3}^2}$	$\sigma_{Tension}$	Allowable Tension (ksi)
	$d_2$	$d_3$	Stress (ksi)	$\sigma_{x_2}$	$\sigma_{x_3}$		
1	21.0	0	- .15621 ✓	0 ✓	.11681 ✓	.11681 ✓	No tension ✓
1'	26.7	0	- .15621 ✓	0 ✓	.14852 ✓	.14852 ✓	w w ✓
2	11.5	20.0	- .15621 ✓	.11878 ✓	.06397 ✓	.13491 ✓	w w ✓
2'	18.0	23.5	- .15621 ✓	.13957 ✓	.1001 ✓	.17176 ✓	.01555 < .118 ✓
3	18.0	15.0	- .15621 ✓	.08909 ✓	.1001 ✓	.134 ✓	No tension ✓
4	8.0	9.0	- .15621 ✓	.05345 ✓	.0445 ✓	.06955 ✓	No tension ✓

Location 2' : Allowable Tension.

$$2 \# 7 C 12 EF \quad A_s = (2 \times 6) = 1.2 \text{ in}^2$$

Widths 2'-10"

$$\text{Allowable stress on steel} = \frac{40 \times 1.2}{12 \times 2.83 \times 12} = .118 \text{ ksi} \quad ✓$$

CONTAINMENT BUILDING - INNER SHIELD BUILDING - STIFFENED SPUNG.

REF.

NODE 66 BEAM 52

From output S6200YZ:

$$\text{Bending stress: } \sigma_{x_2} = .160289 \text{ ksi } \checkmark \quad \sigma_{x_3} = .168834 \text{ ksi } \checkmark$$

$$\text{SRSS: } \sqrt{\sigma_{x_2}^2 + \sigma_{x_3}^2} = .2328 \text{ ksi } \checkmark$$

$$\text{Axial stress: } \sigma_A = -.156274 \text{ ksi } \checkmark \quad \sigma_A = -.19698 \text{ ksi } \checkmark$$

$$\text{Max compression stress: } -.19698 - .2328 = -.42978 \text{ ksi } \checkmark$$

$$\text{Max Tension: } -.156274 + .2328 = .07653 \text{ ksi } \checkmark$$

Find stresses at different locations of cross sections using linear interpolation  
and combine by RSS

LOCATION	d <sub>2</sub>	d <sub>3</sub>	Stress (ksi)	Axial Compressive Stress		Tension (ksi)	Allowable Tension (ksi)
				$\sigma_{x_2}$	$\sigma_{x_3}$		
1	21. ✓	0 ✓	-.15627 ✓	0 ✓	.13273 ✓	.13273 ✓	No ✓
1'	26.7 ✓	0 ✓	..	0 ✓	.16883 ✓	.16883 ✓	.01256 ✓ <.138 ✓
2	11.5 ✓	20. ✓	..	.13641 ✓	.07272 ✓	.15458 ✓	No ✓
2'	18. ✓	23.5 ✓	..	.16029 ✓	.11379 ✓	.19657 ✓	.0403 ✓ <.118 ✓
3	18. ✓	15. ✓	..	.10232 ✓	.11379 ✓	.15303 ✓	No ✓
4	8. ✓	9. ✓	..	.06138 ✓	.05059 ✓	.07954 ✓	1.5 ✓

LOCATION 1': Allowable Tension

$$\pm 7 C 12'' EP \quad A_s = 2 \times 6 = 1.2 \text{ in}^2 \checkmark$$

Width 2'5" ✓

$$\text{Allowable stress: } \frac{60 \times 1.2}{12 \times 24.17 \times 12} = .138 \text{ ksi } \checkmark$$

**NES**  
NUCLEAR ENERGY SERVICES

BY NC DATE 2/25/82 PROJ. 5101 TASK 747  
 CHKD. JC DATE 3/16/82 PAGE \_\_\_\_ OF \_\_\_\_  
LACBWR SED - SITE SPECIFIC SPECTRA  
 Page 8-223 of 258

CONTAINMENT BUILDING - REACTOR VESSEL ANALYSIS - NORMAL SRING

REF.

NODE 55 → NODE 65 (REACTOR VESSEL) : Material ASTM A302 Gr B

From output 56200 FH

$S_y = 45 \text{ ksi}$

Maximum moment at node 65 (beam 62)

$S_M = 25 \text{ ksi} @ 1000^\circ\text{F}$ ,

$$\sigma_{b_1} = .725226 \text{ ksi } \checkmark \quad \sigma_{b_2} = .749476 \text{ ksi } \checkmark$$

$$SRSS = \sqrt{.725226^2 + .749476^2} = 1.0429 \text{ ksi. } \checkmark$$

Axial stress at node 65

$$\sigma_a = -1.6357 \text{ ksi (compression) } \checkmark$$

Resulting

$$\sigma_a + SRSS = -1.6357 + 1.0429 = -.5928 \text{ ksi. (Compression) } \checkmark$$

$$\sigma_a - SRSS = -1.6357 - 1.0429 = -2.6786 \text{ ksi. (Compression) } \checkmark$$

Allowable bending stress:  $1.6 \times .6 \times 45 = 43.2 \text{ ksi}$

### SHEAR STRESS

Max at node 65

$$\tau_1 = .209989 \text{ ksi } \checkmark \quad \tau_2 = .204543 \text{ ksi } \checkmark$$

$$\text{Resulting: } \tau = \sqrt{\tau_1^2 + \tau_2^2} = \sqrt{.209989^2 + .204543^2} = .293 \text{ ksi. } \checkmark$$

Allowable shear stress:

$$1.6 \times .4 \times S_y = 1.6 \times .4 \times 45 = 28.8 \text{ ksi}$$

CONTAINMENT BUILDING - REACTOR VESSEL ANALYSIS - STIFFENED SPRINGS.

REF.

NODE 55 → NODE 65

From Output S6200 YZ.

Maximum moment is at node 65 (beam G2)

$$\sigma_b_1 = .83595 \text{ ksi} \quad \sigma_b_2 = .866896 \text{ ksi. } \checkmark$$

$$S_{RCS} = \sqrt{.83595^2 + .866896^2} = 1.204 \text{ ksi. } \checkmark$$

$$\text{Axial stress at node 65: } \sigma_A = -1.24954 \text{ (Comp) ksi } \sigma_A = -1.6277 \text{ ksi (Comp)}$$

$$\text{Max compression stress: } -1.6277 - 1.204 = -2.8317 \text{ ksi. } \checkmark$$

No tension  $\checkmark$

### SHEAR STRESS

Max at node 65

$$\tau_1 = .243304 \quad \tau_2 = .233921 \quad \checkmark$$

$$\text{Resulting } \tau = \sqrt{.243304^2 + .233921^2} = .338 \text{ ksi. } \checkmark$$

Pressure Stress

Pressure = 1265 psi

$$\begin{aligned} \sigma_1 \text{ - meridional or longitudinal } &= \frac{Pr}{2t} \\ &= \frac{(1265)(51.98''')}{(2)(4)} \\ &= 8140 \text{ psi} = 8.14 \text{ ksi} \end{aligned}$$

$$\begin{aligned} \sigma_2 \text{ - circumferential stress } &= \frac{Pr}{t} : \frac{(1265)(51.98)}{4} \\ &= 16,281 \text{ psi } 16.281 \text{ ksi} \end{aligned}$$

## REACTOR VESSEL

REF.

REACTOR VESSEL

\* Principal stress due to Pressure:  $R_i = 4.125$ ,  $R_o = 4.458$ ,  $p = 1256 \text{ psi}$ .

$$\sigma_1 = \sigma_2 = 1.256 \times \frac{4.458^2 + 4.125^2}{4.458^2 - 4.125^2} = 16.21 \text{ ksi}$$

$$\sigma_2 = \sigma_3 = 1.256 \times \frac{4.458^2}{4.458^2 - 4.125^2} = 8.733 \text{ ksi}$$

$$\sigma_3 = -p = -1.256 \text{ ksi.}$$

$$\sigma_1 - \sigma_2 = 16.21 - 8.733 = 7.477 \text{ ksi.}$$

$$\begin{aligned} \sigma_2 - \sigma_3 &= 8.733 - (-1.256) = 9.989 \text{ ksi.} \\ \sigma_3 - \sigma_1 &= -1.256 - 16.21 = -17.466 \text{ ksi.} \end{aligned} \quad \left. \begin{array}{l} \\ \Rightarrow \text{Stress intensity} = 17.466 \text{ ksi.} \end{array} \right\}$$

\* Principal stress due to Dead load:

stress due to d.l.:  $-1.628 \text{ ksi } (S6200 YZ)$

$\Rightarrow$  stress intensity =  $1.628 \text{ ksi}$  (Since only 1 stress term)

\* Principal stress due to Seismic (Bending)

$$\sigma_y = \pm 1.204 \text{ ksi}, T = .338 \text{ ksi } (S6200 YZ).$$

$$\sigma_1, \sigma_2 = \frac{1.204 \pm \sqrt{(1.204)^2 + .338^2}}{2} -$$

$$\sigma_1 = 1.292 \text{ ksi}, \sigma_2 = -.088 \text{ ksi}$$

$$\text{Stress intensity: } \sigma_1 - \sigma_2 = 1.292 + .088 = 1.380 \text{ ksi.}$$

REACTOR VESSEL						REF.
<u>LOAD COMBINATION</u> $P_m$ (ksi)      Limit (ksi) $P_b$ (ksi) $P_m + P_b$ (ksi)      Limit (ksi)						
D + L + $P_a$	$17,466 + 1,628 / (1.0) \times 25 /$ $= 19,094$	$= 25$	0	19,094	$(1.5)(25) /$ 37.5	O/C
D + L + $P_a$ + E'	19.094	25	1.36	20.474	37.5	O/C

K=1.0 FOR BOTH COMBINATIONS

VESSEL MATERIAL A302 GRADE 1B

$S_u = 25.0$  ksi @  $650^{\circ}$  ✓

CONTAINMENT BUILDING - BELLOW SEAL ANALYSIS - NORMAL SPRING

REF.

Bellow description

#14 Gauge SS #304 Bellows, 8 Corrugations

From Computer Output S6200 FH

1st mode 56, BEAM 63

$$F_{x_1} = 31.913 \text{ K } \checkmark$$

$$F_{x_2} = 31.173 \text{ K } \checkmark$$


$$S_{RSS} = \sqrt{31.913^2 + 31.173^2} = 44.61 \text{ K } \checkmark$$

SHEAR SHAPE FACTOR

$$\bar{A} = .53 A = .53 \times 30.86 = 16.36 \text{ in}^2. \checkmark$$

(page B1-112 STAROVNE MANUAL)

$$f_v = \frac{44.61}{16.36} = 2.73 \text{ ksi } \checkmark$$



BY Mr. DATE 2/16/82 PROJ. 5101 TASK 7-27  
 CHKD. AZ DATE 7/7/82 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACEDUR SEP - SITE SPECIFIC CFFCTRA  
Page B-228 of 258

CONTAINMENT BUILDING - BELLOW SEAL ANALYSIS - STIFFENED SIRANGE.

REF.

From Computer out put 56200 YZ

At node 56 : BEAM 63

$$F_{X_1} = 38.507 \text{ k} \checkmark \quad F_{X_2} = 36.204 \text{ k} \checkmark$$

$$S_{RSS} = \sqrt{38.507^2 + 36.204^2} = 52.85 \text{ k} \checkmark$$

$$f_v = \frac{52.85}{16.36} = 3.23 \text{ ksi} \checkmark$$

REACTOR BASE CONNECTION

REF.

Material:


304 SS

From COMPUTER OUTPUT 56200 FT<sup>2</sup>, at node 65


$F_{x_1} = 38.68 \text{ K}$	$38.61 \text{ K}$
$F_{x_2} = 37.68 \text{ K}$	$37.68 \text{ K}$
$F_{x_3} = 602.68 \text{ K}$	$457.42 \text{ K}$
$M_{z_1} = 6158.2 \text{ K-in}$	$6158.2 \text{ K-in}$
$M_{z_2} = 6362.1 \text{ K-in}$	$6331.09 \text{ K-in}$
$M_{z_3} = 777.8 \text{ K-in}$	$777.8 \text{ K-in}$

Ans at node 64.

$F_{x_1} = 38.61 \text{ K}$	$38.68 \text{ K}$
$F_{x_2} = 37.68 \text{ K}$	$37.68 \text{ K}$
$F_{x_3} = 457.42$	$602.68 \text{ K}$
$M_{z_1} = 3371.4 \text{ K-in}$	$3371.7 \text{ K-in}$
$M_{z_2} = 3393.3 \text{ K-in}$	$3393.3 \text{ K-in}$
$M_{z_3} = 777.8 \text{ K-in}$	$777.8 \text{ K-in}$



REACTOR SUPPORT PLAN



TYPICAL SECTION

## PREDICTIVE BASE CONNECTION

REF.

$$\begin{aligned}d_4 &= 10.54 \\d_3 &= 20.33 \\d_2 &= 48.65 \\d_1 &= 52.48\end{aligned}$$

$$4F_1d_1 + 4F_2d_2 + 4F_3d_3 + 4F_4d_4 = M \quad (1)$$

$$F_2 = \frac{48.65}{52.48} F_1$$

$$F_3 = \frac{20.33}{52.48} F_1$$

$$F_4 = \frac{10.54}{52.48} F_1$$

Substituting into (1) solving for  $F_1$ , we get

$$430.29 F_1 = M$$

\* For  $M_x = 3371.7$  K-in at node 64

$$F_1 = 7.84 \text{ K}, F_2 = 7.26 \text{ K}, F_3 = 3.04 \text{ K}$$

$$F_4 = 1.57 \text{ K.}$$

\* For  $M_{x2} = 3343.3$  k-in

$$F_1 = 7.84 \text{ K}, F_2 = 7.31 \text{ K}, F_3 = 3.05 \text{ K}$$

$$F_4 = 1.58 \text{ K.}$$

$$\text{Max tension by SRSS: } \sqrt{7.84^2 + 1.57^2} = 8.04 \text{ K.}$$

Minimum Concentration due to earthquake + dead load:

$$-\frac{457.42}{16} = -28.57 \text{ K}$$

NO TENSION IN BOLTS

CHECK SHEAR


$$\text{SRSS shear force: } \sqrt{38.68^2 + 37.68^2} = 54 \text{ K.}$$

$$\text{Shear/bolt} = \frac{54}{16} = 3.375 \text{ K/bolt (Neglecting any friction).}$$

$$\text{Bolt area} = \frac{\pi d^2}{4} = \frac{\pi 2^2}{4} = 3.142 \text{ in}^2$$


$$\text{Shear stress on bolt: } \frac{3.375}{3.142} = 1.074 \text{ ksi} < 19.2 \text{ ksi} \quad \underline{OK}$$

$$\text{Allowable shear: } 1.6 \times 4 \times (36) = 19.2 \text{ ksi}$$



REACTOR BASE CONNECTION

REF.



DETAIL 1

$$V_u = \frac{V_u}{\phi b_s d}$$

with  $d = 30''$   
 $b = 8'7'' + 9'' + 15'' = 127''$   
 $b_s = \pi D = \pi \times 127 = 398.98''$   
 $\phi = .85$

At  $\alpha = 65^\circ$ ,  $F_{s3}$  of  $(DL + SRSS EA) = 602.68 \text{ K.} = V_u$ .

$$\Rightarrow V_u = \frac{602.68}{.85 \times 398.98 \times 30} = .0592 \text{ Ksi.}$$

Allowable ultimate punching stress =  $4\sqrt{f'_c} = 4\sqrt{3570} = 236.6 \text{ psi}$

$$V_u = 59.2 \text{ psi} < 236.6 \text{ psi} \quad \underline{OK}$$

CONTINUENT BUILDING - REACTOR DOME (CONNECTION) - STIFFENED SPANNING		REF.
<i>At node 65</i>		
$F_{x_1} = 44.32 \text{ k}$ ✓	$F_{x_1} = 44.75 \text{ k}$ ✓	
$F_{x_2} = 47.03 \text{ k}$ ✓	$F_{x_2} = 47.29 \text{ k}$ ✓	
$F_{x_3} = 599.71 \text{ k}$ ✓	$F_{x_3} = 460.39 \text{ k}$ ✓	
$M_{x_1} = 7096.4 \text{ k-in}$ ✓	$M_{x_1} = 7096.4 \text{ k-in}$ ✓	
$M_{x_2} = 7358.69 \text{ k-in}$ ✓	$M_{x_2} = 7327.89 \text{ k-in}$ ✓	
$M_{x_3} = 903.43 \text{ k-in}$ ✓	$M_{x_3} = 903.43 \text{ k-in}$ ✓	
<i>At node 64</i>		
$F_{x_1} = 44.32 \text{ k}$ ✓	$F_{x_1} = 44.75 \text{ k}$ ✓	
$F_{x_2} = 47.03 \text{ k}$ ✓	$F_{x_2} = 47.29 \text{ k}$ ✓	
$F_{x_3} = 460.39 \text{ k}$ ✓	$F_{x_3} = 599.71 \text{ k}$ ✓	
$M_{x_1} = 3853.7 \text{ k-in}$ ✓	$M_{x_1} = 3853.7 \text{ k-in}$ ✓	
$M_{x_2} = 3863.11 \text{ k-in}$ ✓	$M_{x_2} = 3908.12 \text{ k-in}$ ✓	
$M_{x_3} = 903.43 \text{ k-in}$ ✓	$M_{x_3} = 903.43 \text{ k-in}$ ✓	

CONTAINMENT BUILDING - REACTOR BASE CONNECTION - STIFFENED SIKING

REF.

using same reactor base of normal spring case

$$4F_1d_1 + 4F_2d_2 + 4F_3d_3 + 4F_4d_4 \approx M$$

$$F_{1,2} = \frac{4E(1)}{52,48} F_1$$

$$F_3 = \frac{10.52}{52,48} F_1$$

$$F_4 = \frac{10.52}{52,48} F_1$$

$$\Rightarrow 430.28 F_1 \approx M$$

For  $M_{x_1} = 3653.3$  K-in (node 64)

$$F_1 = 8.96 \text{ K}, F_2 = 8.31 \text{ K}, F_3 = 3.47 \text{ K}, F_4 = 1.60 \text{ K}$$

for  $M_{x_2} = 3908.12$  K-in (node 64)

$$F_1 = 9.08 \text{ K}, F_2 = 8.42 \text{ K}, F_3 = 3.52 \text{ K}, F_4 = 1.62 \text{ K}$$

$$\text{Max tension by SRSS} = \sqrt{8.96^2 + 1.60^2} = 9.14 \text{ K}$$

minimum compression due to earth qudrce + dead load

$$-\frac{465.32}{16} = -29.77 \text{ k}$$

FOR TENSION

CHEMICAL SHEAR

$$\text{SRSS shear force} \cdot \sqrt{44.32^2 + 43.03^2} = 62.17 \text{ ksi}$$

$$\text{Shear bolt} \cdot 62.17/16 = 3.98 \text{ k/bolt}$$

$$\text{bolt area} = \frac{\pi d^2}{4} = \frac{\pi 2^2}{4} = 3.142 \text{ in}^2$$

$$\text{Shear stress on bolt} = \frac{3.98}{3.142} = 1.23 \text{ ksi} < 13.2 \text{ ksi} \quad \underline{OK}$$

CONTAINMENT BUILDING - REACTOR BASE CONNECTION - STIFFENED SPRING


REF.

$$v_u = \frac{V_u}{\phi b d}$$

At node 05,  $\sigma_{xy} = 599.71 \text{ IC.} \approx v_u$

$$v_u = \frac{599.71}{.55 \times 745.12 \times 30} = .0582 \text{ ksi} < .23 \text{ ksi}$$

112






NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 6-6-79 PROJ. 5101 TASK 026  
CHKD. NC DATE 11-7-02 PAGE 1 OF  
LACBWR SEP  
Page B-236 of 258

REF.

PILE ANALYSIS





NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 6-6-79 PROJ. 5101 TASK C26  
CHKD. TJC DATE 4/27/79 PAGE 2 OF 1  
LAC BWR SEP.  
Page B-237 of 258

PROPERTIES ABOUT X<sub>1</sub> AXIS FOR X<sub>2</sub> EARTHQUAKE

REF.

<u>ENd</u>	<u>Nd</u>	<u>d<sup>2</sup></u>	<u>N d<sup>2</sup></u>
<u>EN</u>			
1 (2.17)	= 2.17	965.97	965.97
6 (3.50)	= 21.00	885.06	5310.38
1 (3.75)	= 3.75	870.25	870.25
1 (5.33)	= 5.33	779.53	779.53
6 (7.00)	= 42.00	689.06	4134.38
2 (7.58)	* 15.16	658.95	1317.94
6 (10.50)	= 63.00	517.56	3105.38
4 (10.34)	= 41.36	524.87	2099.47
11 (14.00)	= 154.00	370.56	4076.19
13 (17.50)	* 227.50	248.06	3224.81
13 (21.00)	= 273.00	150.06	1950.81
2 (22.33)	= 44.66	119.25	238.49
11 (24.50)	* 269.50	76.56	842.19
4 (25.08)	= 100.32	66.75	267.00
14 (28.00)	= 392.00	27.56	385.88
18 (31.50)	* 567.00	3.06	55.13
13 (35.00)	= 630.00	3.06	55.13
14 (38.50)	= 539.00	27.56	385.88
11 (42.00)	= 462.00	76.56	842.19
4 (41.42)	= 165.68	66.75	267.00
1 (40.25)	= 40.25	49.00	49.00
13 (45.50)	= 591.50	150.06	1950.81
2 (44.17)	= 88.34	119.25	238.49
13 (49.00)	= 637.00	248.06	3224.81
11 (52.50)	= 577.5	370.56	4076.19
6 (56.00)	= 336.0	517.56	3105.38
4 (56.16)	= 224.64	524.87	2099.47
6 (59.50)	= 357.00	689.06	4134.38
2 (58.92)	= 117.84	658.95	1317.90
6 (63.00)	= 378.00	885.06	5310.38
1 (62.75)	= 62.75	870.25	870.25
1 (61.17)	= 61.17	779.53	779.53
1 (64.33)	= 64.33	965.97	965.97
1 (26.25)	= 26.25	49.00	49.00
228	7581.0		59345.52 ft <sup>2</sup>

$$C_g = \frac{ENd}{EN} = \frac{7581.0}{228} = 33.25$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION


BY R.R. DATE 6-6-79 PROJ. 5101 TASK 026  
CHKD. INC. DATE 1/27/82 PAGE 3 OF 1  
LACBWR S.E.P

Page B-238 of 258

PROPERTIES OF PILE GROUP ABOUT X <sub>2</sub> AXIS					REF.
FOR X. EARTHQUAKE					
N <sub>b</sub>	d <sub>1</sub>	N <sub>b</sub> d <sub>1</sub>	d <sup>2</sup>	Nd <sup>2</sup>	
2	0.83	1.66	1166.22	2332.45	✓
2	3.58	7.16	985.96	1971.92	
4	3.83	15.32	970.32	3881.29	
2	5.16	10.32	889.23	1778.46	
2	6.75	13.50	796.93	1593.87	
6	7.33	43.98	764.52	4581.14	
2	7.83	15.66	737.12	1474.25	
10	10.83	108.30	583.22	5832.23	
10	14.33	143.30	426.42	4264.23	
2	15.91	31.82	367.66	727.33	
2	17.49	34.98	365.90	611.80	✓
6	17.83	106.98	294.12	1764.74	
12	21.33	255.96	186.32	2235.87	
12	24.83	297.96	103.02	1236.27	
12	28.33	339.96	44.22	530.67	
8	31.83	254.64	9.92	79.38	
2	31.41	62.82	12.74	25.49	
4	34.16	136.64	0.67	2.69	
14	35.33	494.62	0.12	1.72	
18	38.83	698.94	14.82	266.81	
18	42.33	761.94	54.02	972.41	
18	45.83	824.94	117.72	2119.00	
12	49.33	591.96	205.92	2471.07	
2	49.00	98.00	196.56	393.12	
2	50.58	101.16	243.36	486.72	
2	52.16	104.32	295.15	590.30	
12	52.83	633.96	318.62	3823.47	
12	56.33	675.96	455.82	5469.87	
6	57.83	358.98	617.52	3705.14	
2	59.75	119.50	613.55	1227.11	
2	61.33	122.66	694.32	1388.65	
2	62.91	125.82	780.08	1560.17	
4	63.33	253.32	803.72	3214.89	
2	64.08	128.16	846.81	1693.62	
<u>228 PILES</u>		<u>7975.20</u>		<u>64314.15 FT<sup>2</sup></u>	
Cg	<u><math>\frac{\sum N_d}{\sum N}</math></u>	<u><math>\frac{7975.20}{228} = 34.98 \text{ FT}</math></u>			

## PILE ANALYSIS - NORMAL STRING

REF.



## PILE PLAN

\* C Files under compression only

REF. DWG. 41-503433 REV D  
& REPORT SL-2003 - SACRAMENTO LNULV  
FEB 25, 1963


CONTAINMENT BUILDING - FOUNDATION ANALYSIS - NORMAL SPRING

REF.

CHECK SHEAR STRESS IN CONCRETE


FROM OUTPUT \$6200FH, at node 54.

$$F_{X_1} = 1655.7 \text{ kN} \quad F_{X_2} = 1651 \text{ kN} \\ \text{SRSS} = \sqrt{1655.7^2 + 1651^2} = 2338.2 \text{ kN}$$

\* AT El. 615.5'

$$\text{Assumed Area} = \frac{\pi}{4} \times 2 (50.5^\circ - 36^\circ) = 492.5 \text{ ft}^2$$

$$f_v = \frac{2338.2}{492.5 \times 144} = .03297 \text{ ksi} = 33 \text{ psi} \\ \text{Allowable shear} = .85(2\sqrt{f_c}) = .85 \times 2 \times \sqrt{3500} \\ = 100.6 \text{ psi} > 33 \text{ psi}$$

\* At El. 621.5'

$$\text{Assume shear area} = \frac{\pi}{4} \times 2 (65^\circ - 55.5^\circ) \\ = 449.5 \text{ ft}^2$$

$$f_v = \frac{2338.2}{449.5 \times 144} = .03612 \text{ ksi} = 36 \text{ psi} < \text{allowable}$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 6-19-79 PROJ. 5101 TASK 036  
CHKD. AZ DATE 7/6/82 PAGE        OF         
LACBWR SEP  
Page B-241 of 258

REF.

TENSILE STRENGTH OF CONCRETE

AVERAGE SPLITTING  
TENSILE STRENGTH  
OF CONCRETE

$$f_{ct} = (0.85)(7.5)\sqrt{f_c}$$

✓

$$f_{ct} = 377.2 \text{ PSI}$$

$$f'_c = 3500 \text{ PSI}$$




#### **NUCLEAR ENERGY SERVICES**

BY NC DATE 3/24/82 PROJ. 5101 TASK 247  
CHKD. JC DATE 3/29/82 PAGE \_\_\_\_ OF \_\_\_\_  
LACBWR SEE - SITE SPECIFIC SPECTRA  
Page B-242 of 258

CONTAINMENT BUILDING - PILE ANALYSIS - NORMAL SPRING.								REF.	
LOADS AT NODE 54									
From Output S6200 RW:									
Vertical load due to dead load : $F_{V_0} = -1.70762 \times 10^4 \text{ K}$ (Compression)									
From Output S6200 FH:									
Vertical load due to S6200 earthquake : $F_{V_E} = 1.572832 \times 10^3 \text{ K}$ .									
From Output S6200 FT:									
Moment in $X_1$ direction : $M_{X_1} = 1.5012 \times 10^6 \text{ K-in}$									
Moment in $X_2$ direction : $M_{X_2} = 2.381256 \times 10^6 \text{ K-in}$									
Pile load due to Dead load : $P_{V_0} = -\frac{1.70762 \times 10^4}{228} = -74.9 \text{ K. (Compression)}$									
Pile load due to earthquake vertical load : $P_{V_E} = \frac{1.572832 \times 10^3}{228} = 6.9 \text{ K.}$									
Max pile load due to moment $M_{X_1}$ : $P_{m_1} = \frac{1.5012 \times 10^6 \times 31.08}{(5.93455 \times 10^4) \times 12} = 65.52 \text{ K.}$									
Max pile load due to moment $M_{X_2}$ : $P_{m_2} = \frac{2.381256 \times 10^6 \times 34.15}{(6.43153 \times 10^4) \times 12} = 105.37 \text{ K.}$									
Pile load investigation at different locations using linear interpolation									
	Results.								
Location	$d_1(\text{ft})$	$d_2(\text{ft})$	$P_{V_0}(\text{K})$	$P_{V_E}(\text{K})$	$P_{m_1}(\text{K})$	$P_{m_2}(\text{K})$	$\sqrt{P_{V_E} + P_{m_1} + P_{m_2}}(\text{K})$	Comp. (K)	Tension
1	13.65	29.75	-74.9	6.9	62.72	42.12	75.86	-158.76	.96
2	34.15	7	-74.9	6.9	14.76	105.37	106.62	-181.52	31.72
3	.82	31.08	-74.9	6.9	65.52	2.53	65.93	-140.83	No ten
4	30.17	10.92	-74.9	6.9	23.02	93.09	96.14	-171.04	21.24
5	24.15	19.25	-74.9	6.9	40.58	74.51	85.12	-160.02	10.22
6	19.07	25.67	-74.9	6.9	54.12	58.84	80.24	-155.14	5.34
Compression : -181.52 K.								At location 2.	
Tension : 31.72 K.									

## PILE ANALYSIS - STIFFENED SPRINGS

REF.



## PILE PLAN

+ ☐ Piles under compression only

REF. DWG. 41-503433 REV D  
4 REPORT SL-2003-SACILENT & LUNLV  
FEB 25, 1963

CONTAINMENT BUILDING - PILE ANALYSIS - STIFFENED SPRING.

REF.

LOADS AT NODE 54

From Output S6200 RW:

Vertical load due to dead load :  $F_{V0} = 1.70762 \times 10^4 \text{ K.}$  ✓

From Output S6200 YZ :

Vertical load due to SRSS earthquake :  $F_{VE} = 1.511173 \times 10^3 \text{ K.}$  ✓

Moment in  $X_1$  direction :  $M_{X_1} = 1.7322 \times 10^6 \text{ kip-in}$  ✓

Moment in  $X_2$  direction :  $M_{X_2} = 2.6037965 \times 10^6 \text{ kip-in}$  ✓

Pile load due to dead load :  $P_{V0} = \frac{1.70762 \times 10^4}{228} = 74.9 \text{ K.}$  ✓

Pile load due to EQ vertical load :  $P_{VE} = \frac{1.511173 \times 10^3}{228} F = 6.63 \text{ K.}$  ✓

Max pile load due to moment  $M_{X_1}$  :  $P_{m_1} = \frac{1.7322 \times 10^6 \times 31.08}{(5.93455 \times 10^4) 12} = 75.6 \text{ K.}$  ✓

Max pile load due to moment  $M_{X_2}$  :  $P_{m_2} = \frac{2.6037965 \times 10^6 \times 34.15}{(6.43153 \times 10^4) 12} = 115.21 \text{ K.}$  ✓

Pile loads investigation at different locations using linear interpolation

Location	$d_1(\text{ft})$	$d_2(\text{ft})$	$P_{V0}(\text{K})$	$P_{VE}(\text{K})$	$P_m(\text{K})$	$P_{m_1}(\text{K})$	$\sqrt{P_{V0}^2 + P_m^2 + P_{m_1}^2} (\text{K})$	$C_{mp}(\text{K})$	Results Tensile (K)
1	13.65	29.75	-74.9	6.63	72.36	46.05	86.03	✓	-160.93
2	34.15	7	-74.9	6.63	17.03	115.21	116.65	✓	-191.55
3	.82	31.08	-74.9	6.63	75.6	2.77	75.94	✓	-150.84
4	30.17	10.92	-74.9	6.63	26.58	101.78	105.4	✓	-180.3
5	24.15	19.25	-74.9	6.63	46.82	81.47	94.2	✓	-169.1
6	19.07	25.67	-74.9	6.63	62.44	64.34	89.9	✓	-164.8
<u>Max pile load?</u>		Compressions : -191.55 K		At location 2.					

Tension : 41.75 K ✓

CHECK SHEAR :

SRSS lateral load :  $\sqrt{1803.192^2 + 1899.079^2} = 2681.49 \text{ K.}$  ✓

Shear load on pile :  $\frac{2681.49}{228} = 11.76 \text{ K/pile}$  ✓

CHECK BEARING : Bearing area  $(12)(6) = 72 \text{ in}^2$

Bearing stress :  $\frac{11.76}{72} = .163 \text{ K/in}^2 < 2.083 \text{ K/in}^2$  (allowable) ✓



NUCLEAR ENERGY SERVICES

BY NC DATE 2/16/82 PROJ. 5101 TASK 247  
CHKD. A2 DATE 7/8/82 PAGE \_\_\_\_ OF \_\_\_\_  
VACUUM SEP - SITE SPECIFIC SPECTRA  
Page B-245 of 258

CONTAINMENT BUILDING - FOUNDATION ANALYSIS - STIFFENED SRING.

REF.

SHEAR STRESS

FROM OUTEUT 66200 YZ, at node 54

$$F_x_1 = 1643.192 \text{ k} \quad F_x_2 = 1649.009 \text{ k}$$

$$\text{SRSS} = \sqrt{1643.192^2 + 1649.009^2} = 2681.49 \text{ k. } \checkmark$$

\* AT El. 615.5": Shear area = 492.5 ft<sup>2</sup>  $\checkmark$ 

$$f_v = \frac{2681.49}{492.5 \times 144} = .03781 \text{ ksi} = 37.81 \text{ psi} < 100.6 \text{ psi}$$

B/C\* At El. 681.5": Shear area = 449.5 ft<sup>2</sup>  $\checkmark$ 

$$f_v = \frac{2681.49}{449.5 \times 144} = .04143 = 41.43 \text{ psi} < 100.6 \text{ psi}$$

C/D



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 6-20-79 PROJ. 5101 TASK 247  
CHKD. AZ DATE 7/8/82 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWTR SEP  
Page B-246 of 258

FOUNDATION ANALYSIS

REF.

CHECK BOND BETWEEN BOTTOM OF VESSEL & CONCRETE

APPROXIMATE BASE SURFACE AREA

ASSUME SPHERICAL SEGMENT

$$\text{RADIUS } R = \frac{4b^2 + c^2}{8b} = \sqrt{}$$


$$c = 2(27.75) \checkmark$$

$$b = 9.1' \checkmark$$

$$R = 46.86 \text{ FT} \checkmark$$

$$\text{SURFACE AREA} = \frac{1}{4}\pi R(4b+c)$$

$$\text{SURFACE AREA} = 3382 \text{ FT}^2 \checkmark$$



BOND STRESS ASSUMING FORMULA FROM 318-63

$$\left(\frac{1}{2}\right)6\sqrt{f'_c} \text{ OR } 250 \text{ PSI}$$

$$\frac{1}{2}(6)\sqrt{3600}$$

$$177.5 \text{ PSI} \checkmark$$

$$\text{TOTAL BOND RESISTANCE} = 0.1775(3382)(144) = 86,443.9 \text{ K}$$

$$\text{TOTAL LATERAL FORCE} = 2681.49 \text{ K} < 86,443.9 \text{ K} \quad \text{OK}$$



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R DATE 6-12-79 PROJ. 5101 TASK 297  
CHKD. A2 DATE 7/9/82 PAGE — OF —  
LACBWR SEP.  
Page B-247 of 258

## PILE ANALYSIS

REF.

### PILES

ASSUME BUTT DIA = 12 INCHES ✓  
CONCRETE = 3500 PSI ✓

$$A_s = \pi \frac{d^2 - d_1^2}{4} = \frac{\pi}{4} 12^2 - 11.6414^2$$

$$A_s = 6.66 \text{ in}^2 \checkmark$$

$$A_c = \frac{\pi}{4} 11.6414^2 = 106.4 \text{ in}^2 \checkmark$$

$$f'_c = .85(3500) \checkmark$$

$$\text{MAX LOAD} = (106.4)(.85)(3.5) = 316.6 \text{ k} \quad \begin{matrix} \text{IF CONCRETE ALONE} \\ \text{IS USED} \end{matrix}$$

COMPRESSIVE CAPACITY

CONSIDERING STEEL ALSO

$$N = \frac{E_s}{E_c} = \frac{29,000}{3372} = 8.6 \checkmark$$

$$\text{TRANSFORMED AREA} = A_c + m A_s = 106.4 + 8.6(6.66) = 163.68 \text{ in}^2 \checkmark$$

$$\text{MAX LOAD} = 158.92(.85)(3.5) = 486.93 \text{ k} \quad \text{COMPRESSIVE CAPACITY}$$

CHECK BOND STRESS OF CONCRETE TO STEEL  
(ASSUME SMOOTH STEEL BAR A-305)

H = DEPTH EMBED. = 6" ✓  
D = 12" Ø ✓

TENSILE CAPACITY OF STEEL =  $6.66 \times 46 = 306.9 \text{ k}$

$$\text{BOND AREA } A = \pi D \frac{6}{\text{EMBEDMENT}} = 226.19 \text{ in}^2 \quad \begin{matrix} \text{CONSERVATIVE} \\ \text{LOAD FACTOR} \end{matrix}$$


$$F_u = \frac{(226.19)(*)}{100} (1.9) = 50.67 \text{ k} \quad \begin{matrix} * \text{ASSUME BOND STRESS} \\ \text{LESS THAN 160 PSI} \end{matrix} \quad \text{ACI-318-63}$$

$$\begin{matrix} \text{TENSION} \\ \text{IN CONCRETE} \end{matrix} \quad \begin{matrix} \text{MODULUS OF RUPTURE} = 7.5 \sqrt{F_u} = 593.7 \text{ PSI} \checkmark \\ \text{AREA} = \frac{\pi D^2}{4} 113.10 \text{ in}^2 \checkmark \quad F = \frac{113.1(593.7)}{1000} = 50.41 \text{ k} \checkmark \end{matrix}$$

ASSUME  
ULTIMATE STEEL  
STRESS = 46 ksi

ACI-318-77  
Eq(9-9)

UNION METAL COMPANY  
MONOTUBE



T = 8 in

TAPEL .14 in/ft ✓

BUTT = 12 in ✓

BY NC DATE 3/1/82 PROJ. S101 TASK 207  
 CHKD. AZ DATE 7/8/82 PAGE \_\_\_\_ OF \_\_\_\_  
 LACBWR SEP - SITE SPECIFIC SPECTRA  
 Page B-248 of 258

CONTAINMENT BUILDING - PILE ANALYSIS - NORMAL SPRING CONSTANT.

REF.

PILE CAPACITY USING SREC. W-1735 Page 4 ✓

HAMMER - MC GIERNAN - TERRY C-5 DOUBLE ACTING

REPORT  
SL-2003  
(2/23/63)

$$E = 16,000 \text{ Ft-lbs/Blow}$$

$$s = \frac{1}{6}'' = .1667 \text{ in/Blow}$$

ENGINEERING NEWS FORMULA

"FOUNDATION  
ENGINEERING  
HANDBOOK",  
Eqn 19.53  
P591  
© 1975

ALLOWABLE PILE LOAD:

$$R = \frac{2E}{s+1} = \frac{2(16000)}{(.1667+.1)} = 119,485 \text{ k} \approx 120 \text{ k}, \checkmark$$

### CHECK SHEAR

SRESS Lateral load : 2681.49

COMPUTER  
OUTPUT:


$$\frac{2338.2}{228} = 11.76 \text{ k/pile.}$$

SG200YZ

GINDER  
S67

### CHECK BEARING

$$\text{BEARING AREA} = (12)(6) = 72 \text{ in}^2 \checkmark$$



$$\text{BEARING STRESS} = \frac{10.2k}{72} = .163 \text{ ksi}$$


$$\text{Allowable} = \phi (.85 f'_c) \checkmark$$

$$= .7 (.85)(3.5) = 2.083 \text{ ksi} \checkmark$$

$$.163 \text{ ksi} < 2.083 \text{ ksi} \quad \underline{\underline{\text{OK}}} \quad \checkmark$$

# CONTAINMENT BLDG PILE ANALYSIS

page B-249 of 258



## REFERENCE:

DAVYLAND POWER CO-OP  
DRAWING LR-22, OCT. 2, 1945.

RAYMOND FROU CB-1154-C

## PLOT PLAN

MISSISSIPPI RIVER



FROM: DAMES & MOORE, "LIQUIFICATION POTENTIAL  
AT LACBWR, ... " SEPT 28, 1979, p.13

DAMES & MOORE

## KEY:

TEST BORING FOR D&M INVESTIGATION IN 1973

TEST BORING BY RAYMOND INT'L IN JULY 1962


TEST BORING FOR D&M INVESTIGATION IN 1979

CONTAINMENT BUILDING - PILE ANALYSIS, Uplift Single

REF.

Uplift Capacity of a single pile, (approximation). Assume upward frictional resistance approximately =  $f_s = \frac{\bar{N}}{50}$ . Where  $\bar{N}$  = the average standard penetration resistance, in blows/ft. within the embeded length of pile.

*DM-7	*DM-8	*DM-9	*DM-10
13	10	P	10
13	13	↓	14
30	14	P	17
	16		17
	25		22
<u>56</u>	<u>104</u>	/ P	<u>121</u>



$$\bar{N} = \frac{\sum \text{blows/ft}}{\sum i} = \frac{281}{15} = 18.73$$

$$\text{average dia. of pile} = \frac{12+8}{2} = 10"$$

$$\text{surface area of one pile} = \pi(\text{dia.})(\text{depth}) = \pi(10)(32) = 83.78 \text{ ft}^2$$

$$** f_s = \frac{\bar{N}}{50} = 18.73/50 = .3746 \text{ T.S.F.} \checkmark$$

Total uplift resistance is;

$$P_u = 83.78(.3746) 2 \frac{P_s^2}{f_s} \left( \frac{K}{T} \right) \left( \frac{K}{T} \right)$$

$$\underline{P_u = 62.78^k} \checkmark$$

$$P_u > 41.75^k = (\text{the largest tension on a single pile}) \checkmark$$

\*\* "ASCE Journal of Geotechnical Engineering" Vol. 102, No. GT3  
 March 1979, pg 205

\* Report prepared by Dames + Moore, "Liquefaction Potential  
 At LA Cross Boiling Water Reactor (LACBWR) Site Near  
 Genoa, Vernon County, Wisconsin", Sept. 28, 1979 pg A-3 → A-6



NUCLEAR ENERGY SERVICES INC.  
NES DIVISION

BY R.R. DATE 6-8-79 PROJ. 5101 TASK 02C  
SEE CALL OF 7/8/82 (PREVIOUS PAGE)  
CHKD. DATE PAGE OF  
LACBWR SEP  
Page B-251 of 258

PILE ANALYSIS

REF.

UPLIFT CAPACITY OF A SINGLE PILE APPROXIMATION

ASSUME FRICTIONAL RESISTANCE UPWARD APPROXIMATELY  
EQUAL TO

$$f_s = \frac{\bar{N}}{50} *$$

WHERE  $\bar{N}$  = AVERAGE STANDARD  
PENETRATION RESISTANCE, IN BLOWS  
PER FOOT, WITHIN EMBEDDED LENGTH  
OF PILE.

B-1	B-2	B-3
12	20	13
18	24	27
13	46	25
16	23	65
19		
34		
112	113	

ULTIMATE  
FRICTION  
RESISTANCE

$$f_s = \frac{22.3}{50} = 0.446 \text{ T.S.F.}$$

$$E = \frac{290}{13} = 22.3 = \bar{N}$$

$$\text{AREA} = \frac{1}{12} \pi \left( \frac{12+8}{2} \right) (32') = 83.8'$$

TOTAL UPLIFT RESISTANCE

$$P_u = 0.446 (83.8) = 37.4 \text{ TONS}$$

74.8 KIPS

\* REFER TO ASCE  
"JOURNAL OF THE GEOTECHNICAL  
ENGINEERING"  
VOL. 102 NO. GT3 MARCH 1976  
Pg 206

\* SEE CALCULATIONS USING  
BORINGS: DM-7, DM-8, DM-9, DM-10.  
(PREVIOUS PAGE)


**NES**

NUCLEAR ENERGY SERVICES

BY D.L. Summers DATE 5/27/82 PROJ. 5101 TASK 247  
CHKD. A2 DATE 7/9/82 PAGE \_\_\_\_\_ OF \_\_\_\_\_  
LACBWR SEP  
Page B-252 of 258


## CONTAINMENT BUILDING - PILE ANALYSIS, UPLIFT

REF.

"1/4 of foundation"

## CONTAINMENT BUILDING - PILE ANALYSIS, Uplift

REF.



Find the area which contains the most piles per area

$$A_I = 3.5^2 + 3.5(7) = 22.75 \text{ ft}^2 \rightarrow 5 \text{ piles} = 4.55 \text{ ft}^2/\text{pile}$$

$$A_{II} = 1.58(3.5 - .58) = 4.6126 \text{ ft}^2 \rightarrow 3 \text{ piles} = 1.54 \text{ ft}^2/\text{pile}$$

By inspection  $A_{II}$  is the lowest  $\frac{\text{ft}^2}{\text{pile}}$  (SAME AS  $\Delta 7-8-10$ )

$$\text{The Linear Perimeter of } A_{II} = (\sqrt{1.58^2 + (3.5 - .58)^2}) + 2(1.58) = 9.800'$$

## CONTAINMENT BUILDING - PILE ANALYSIS, uplift

REF.


The generalized soil strata and properties are from ref. ①.---- Notice that this soil data is generalized for the whole area, the specific Containment Building site data not available.

FIG. 1

OR

DWG

41-503433




Elevations and lengths of piles are from previous calculations, specifically for the Containment Building.

CONTAINMENT BUILDING - PILE ANALYSIS, Uplift

REF.

The concrete filled piler reach an average depth of about 32' below the concrete footing/slab. The soil they penetrate is SP gray fine to medium sand.

Effective Overburden Stress vs. Depth



CONTAINMENT BUILDING - PILE ANALYSIS, Uplift

REF.

$$P_s = \text{friction resistance} = \int_0^L P \bar{g} K \tan \delta \, dz ; \int_0^L dz = 32' -$$

Where

$$P = \text{perimeter} = 9.8' \checkmark$$

$$\bar{g} = \text{effective over burden pressure at } dz = 1000.8 \text{ psf} (\text{@ center of pile})$$

$$K = \text{coefficient of lateral earth pressure} = .5 \checkmark$$

$$*\delta = \text{friction angle of soil (interval 4)} = 31' \checkmark$$

$$P_s = 9.8' (1000.8) .5 (\tan 31) 32' \checkmark$$

$$\underline{P_s = 99.290 \text{ kips}} \checkmark$$

$P_s >$  the actual pull out force of the system of piles.

$$\underline{P_s > 91.55^k = 91.75^k + 30.5^k + 19.3^k} (\text{by Nhan Huu Cao}) = P_a = 91.55^k \checkmark$$

\* Arriving at 8

$N \left( \frac{\text{blow}}{\text{ft}} \right)$  Δ of internal friction

8                   $30^\circ \checkmark$

16                 $32^\circ \checkmark$

(ref 1)              (ref 3)

} us =  $31^\circ \checkmark$

$$\text{Weight of pile} = \pi (5^2) 32' \frac{1}{144} \left( 145 \frac{16}{ft^3} \right) = 2530 \text{ lb} = P_w \checkmark$$

$$\text{avg. dia.} = (12'' + 8'') \div 2 = 10''$$

$$\text{Length} = 32' \checkmark$$

$$Y_{conc} = 145 \frac{lbf}{ft^3} \checkmark$$

(the difference between  $Y_{conc}$  and  $Y_{steel}$  neglected)

$$P_T = P_s + P_w = 99.29^k + 2.53^k = 96.82^k \checkmark$$

$$P_T > P_a$$

$$\underline{96.82^k > 91.55^k} \checkmark$$

from  
④  
PS30

CONTAINMENT BUILDING - PILE ANALYSIS, Uplift

REF.

The tributary volume of soil that resists the pull out force of the pile is conical in shape, the bottom of the pile being the point of the cone. As the elevation increases the cone broadens. The tributary cones are not describable mathematically at present. A simplified conservative procedure was used. Within the perimeter bounded by the piles was considered the volume effective in resisting pullout. The soil that would be in this cone was ignored if outside the straight line perimeter pile to pile.

The friction value is larger for round piles (of diameter = D) as compared to a square pile whose side = D by about 4:3 respectively. Tapper is an asset if the tapper  $\geq 1\%$ , the friction capacity is likely to increase by 1.5 to 2.5. Although the piles used here are tapered  $> 1\%$  ( $4''/32' = 1.0\%$ ) this was not considered because the accuracy of how much of an increase can not be pin-pointed.

The cohesion (effective in upper portions of piles) was ignored due to simplifying and so variable with piles at different lengths. The 32' length of pile was used as a representative average of all the piles. This is conservative because on the outside edge of the building where pullout forces exist, the floor/foundation curves closer to the surface more contact with soil. This in turn allows more friction area on the pile and deeper soil increasing the effective overburden stress, ( $P$  and  $\gamma$  respectively).

The coefficient of lateral earth pressure was chosen from the lower end of the spectrum of pullout tests. The actual pull out force was assumed to be the three piles experiencing the highest pull out force. Assuming they act together is conservative. In

## CONTAINMENT BUILDING - PILE ANALYSIS, Uplift

REF.

reality they do not.

References.

1. "Liquefaction Analysis for Lacross Nuclear Power Station", by W. F. Marcuson II and W. A. Biernousky from Geotechnical Laboratory U.S. Army Engineer Waterways Experiment Station Vicksburg, Mississippi
2. "Foundation Engineering" edt. by G. A. Leonards, pub. by McGraw Hill Book Company 1962.
3. "Foundation Engineering Handbook" edt. by H. F. Winterkorn and H. Y. Fang, pub. by McGraw Hill Book Company.
4. "Foundation Analysis and Design", by J. E. Bowels, 2<sup>nd</sup> edt, pub. by McGraw Hill Book Company.