

OPERATING DATA REPORT

DOCKET NO 50-409
DATE 6-4-82
COMPLETED BY L.S. GOODMAN
TELEPHONE 608-680-2331

OPERATING STATUS

1. Unit Name: La Crosse Boiling Water Reactor
2. Reporting Period: 0001, 05-01-82 TO 2400, 05-31-82
3. Licensed Thermal Power (MWt): 165
4. Nameplate Rating (Gross MWe): 65.3
5. Design Electrical Rating (Net MWe): 50
6. Maximum Dependable Capacity (Gross MWe): 50
7. Maximum Dependable Capacity (Net MWe): 48
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons

Notes

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>3623</u>	<u>110,282</u>
12. Number Of Hours Reactor Was Critical	<u>0</u>	<u>1796.6</u>	<u>73,070.2</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>478</u>
14. Hours Generator On-Line	<u>0</u>	<u>1706.2</u>	<u>67,398.4</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>79</u>
16. Gross Thermal Energy Generated (MWH)	<u>0</u>	<u>212,692.4</u>	<u>9,208,481.1</u>
17. Gross Electrical Energy Generated (MWH)	<u>0</u>	<u>59,143</u>	<u>2,749,001</u>
18. Net Electrical Energy Generated (MWH)	<u>-466</u>	<u>53,931</u>	<u>2,541,923</u>
19. Unit Service Factor	<u>0</u>	<u>47.1</u>	<u>61.1</u>
20. Unit Availability Factor	<u>0</u>	<u>47.1</u>	<u>61.2</u>
21. Unit Capacity Factor (Using MDC Net)	<u>0</u>	<u>31.0</u>	<u>48.0</u>
22. Unit Capacity Factor (Using DER Net)	<u>0</u>	<u>29.8</u>	<u>46.1</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>27.6</u>	<u>8.1</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
None

25. If Shut Down At End Of Report Period, Estimated Date of Startup: July 19, 1982

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____