

MISSISSIPPI POWER AND LIGHT COMPANY

MIDDLE SOUTH ENERGY, INC.

SOUTH MISSISSIPPI ELECTRIC POWER ASSOCIATION

DOCKET NO. 50-416

GRAND GULF NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

License No. NPF-13
Amendment No. 1

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for amendment filed by the Mississippi Power and Light Company dated June 23, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-13 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 1, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

OFFICE
SURNAME	8208120389	820630
DA1	P	PDR
	PDR	ADOCK 05000416

MISSISSIPPI POWER AND LIGHT COMPANY
MIDDLE SOUTH ENERGY, INC.
SOUTH MISSISSIPPI ELECTRIC POWER ASSOCIATION
DOCKET NO. 50-416
GRAND GULF NUCLEAR STATION, UNIT 1
AMENDMENT TO FACILITY OPERATING LICENSE

License No. NPF-13
Amendment No. 1

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for amendment filed by the Mississippi Power and Light Company dated June 23, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-13 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 1, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

OFFICE ▶						
SURNAME ▶						
DATE ▶						

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

LSI

A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: JUN 30 1982

OFFICE ▶	DL:LB#2/LA	DL:LB#2/PM	DL:LB#2/BC	W. W. WELD			
SURNAME ▶	EHouston:kw	DHouston	ASchwencer	M. WAGNER			
DATE ▶	6/30/82	6/30/82	6/1/82	6/30/82			

ATTACHMENT TO LICENSE AMENDMENT NO. 1

FACILITY OPERATING LICENSE NO. NPF-13

DOCKET NO. 50-416

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. This revised page is identified by Amendment number and contains a vertical line indicating the area of change. The corresponding page is also provided to maintain document completeness.

REMOVE

3/4 6-49

3/4 6-50

INSERT

3/4 6-49

3/4 6-50

OFFICE ▶
SURNAME ▶
DATE ▶

TABLE 3.6.6.2-1 (Continued)

SECONDARY CONTAINMENT VENTILATION SYSTEM AUTOMATIC ISOLATION DAMPERS/VALVES

<u>VALVE FUNCTION (Number)</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>
b. Valves	
Plant Chilled Water System Aux. Bldg. Isol. Valve (P71-F306)	30
Plant Chilled Water System Aux. Bldg. Isol. Valve (P71-F304)	30
Plant Chilled Water System Aux. Bldg. Isol. Valve (P71-F302)	4
Plant Chilled Water System Aux. Bldg. Isol. Valve (P71-F300)	4
Plant Chilled Water System Aux. Bldg. Isol. Valve (P71-F307)	30
Plant Chilled Water System Aux. Bldg. Isol. Valve (P71-F305)	30
Plant Chilled Water System Aux. Bldg. Isol. Valve (P71-F303)	4
Plant Chilled Water System Aux. Bldg. Isol. Valve (P71-F301)	4
Service Air System Aux. Bldg. Isol. Valve (P52-F221A)	4
Service Air System Aux. Bldg. Isol. Valve (P52-F160A)	4
Service Air System Aux. Bldg. Isol. Valve (P52-F221B)	4
Service Air System Aux. Bldg. Isol. Valve (P52-F160B)	4
Instrument Air System Aux. Bldg. Isol. Valve (P53-F026A)	4
Instrument Air System Aux. Bldg. Isol. Valve (P53-F026B)	4
FPCC Filtr-Demin System Backwash Aux. Bldg. Isol. Valve (G46-F253)	30

TABLE 3.6.6.2-1 (Continued)

SECONDARY CONTAINMENT VENTILATION SYSTEM AUTOMATIC ISOLATION DAMPERS/VALVES

<u>VALVE FUNCTION (Number)</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>
Valves (Continued)	
RWCU Backwash RCVG Tk. Aux. Bldg. Isol. Valve (G36-F108)	30
RWCU Backwash RCVG Tk. Aux. Bldg. Isol. Valve (G36-F109)	30
Nuclear Boiler System Aux. Bldg. Isol. Valve (B21-F113)	30
Nuclear Boiler System Aux. Bldg. Isol. Valve (B21-F114)	30
RWCU Aux. Bldg. Isol. Valve (G33-F235)	30
RWCU Aux. Bldg. Isol. Valve (G33-F234)	30
SPCU Aux. Bldg. Isol. Valve (P60-F003)	30
SPCU Aux. Bldg. Isol. Valve (P60-F004)	30
SPCU Aux. Bldg. Isol. Valve (P60-F007)	30
SPCU Aux. Bldg. Isol. Valve (P60-F008)	30
Fire Protection System Aux. Bldg. Isol. Valve (P64-F282A)	4
Fire Protection System Aux. Bldg. Isol. Valve (P64-F283A)	4
Fire Protection System Aux. Bldg. Isol. Valve (P64-F332A)	4
Fire Protection System Aux. Bldg. Isol. Valve (P64-F282B)	4
Fire Protection System Aux. Bldg. Isol. Valve (P64-F283B)	4
Fire Protection System Aux. Bldg. Isol. Valve (P64-F332B)	4
Cond. & Refuel Water Transfer Aux. Bldg. Isol. Valve (P11-F062)	9