



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-295

ZION STATION UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 75
License No. DPR-39

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The request for amendment by Commonwealth Edison Company (the licensee) dated June 25, 1982, as confirmed by letter dated June 28, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the request, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-39 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 75, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment was effective on June 26, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 30, 1982

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 75 TO FACILITY OPERATING LICENSE NO. DPR-39

DOCKET NO. 50-295

Revise Appendix A as follows:

Remove Page

168

Insert Page

168

LIMITING CONDITION FOR OPERATION	SURVEILLANCE REQUIREMENT
<p data-bbox="85 313 989 536"> 3.8 2. Safety Injection pump system A. The two safety injection systems* shall be operable whenever the reactor is going from hot shutdown to hot standby. (See 3.3.2.G for low RCS temperature operation.) </p> <p data-bbox="234 892 968 1164"> *For Unit 1 during the period June 26th through July 3, 1982 reactor operation is allowed with one safety injection pump inoperable provided that both centrifugal charging pump systems and both residual heat removal systems are operable. During this period, power level will not exceed approximately 5% of rated power level. </p>	<p data-bbox="1064 305 1787 371"> 4.8 2. Safety injection pump System (Table 4.8-2) </p> <p data-bbox="1138 396 1808 495"> A. Surveillance and pump testing of the safety injection system shall be performed as follows: </p> <ol data-bbox="1234 520 1979 991" style="list-style-type: none"> 1. The safety injection pumps shall be started manually from the control room each month. Performance will be acceptable if the pump starts upon actuation, operates for at least 10 minutes on recirculation flow, and the discharge pressure and recirculation flow are within +10% of a point on the pump head curve. 2. Valves MOV-SI8813 & MOV-SI8814 closing control switch contacts shall be tested for shorts quarterly.