

REACTOR COOLANT SYSTEM

SAFETY VALVES - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.4.2 A minimum of one pressurizer code safety valve shall be OPERABLE with a lift setting of 2500 PSIA +1, -3%*#.

APPLICABILITY: MODES 4 AND 5.

ACTION:

With no pressurizer code safety valve OPERABLE, immediately suspend all operations involving positive reactivity changes and place an OPERABLE shutdown cooling loop into operation.

SURVEILLANCE REQUIREMENTS

4.4.2 No additional Surveillance Requirements other than those required by Specification 4.0.5.

*The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure. If found outside of a +1% tolerance band, the setting shall be adjusted to within $\pm 1\%$ of the lift setting shown.

#Equivalent relief capacity during MODE 5 satisfies the requirements of this Specification. This allows both pressurizer code safety valves to be removed for testing and/or maintenance.

DISTRIBUTION

~~Docket File~~

NRC/LOCAL PDR
PDIV-1 Reading File
LBerry
SPeterson
TQuay
MVirgilio
WJones
GPA/PA
OGC
ARM/LFMB
DHagan
JCalvo
GHill (4)
ACRS (10)
PDIV-1 Plant File
RMullikin, RIV