BIG ROCK POINT PLANT

NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M I B R P 1 (2) LICENSEE CODE | 0 0 - 0 0 0 0 0 - 0 0 (3) LICENSE NUMBER | 4 1 1 1 1 (4) LICENSE TYPE | (5) CAT

CON'T 0 1 | REPORT SOURCE L (6) | 0 5 0 0 - 0 1 5 5 (7) DOCKET NUMBER | 0 7 0 7 8 2 (8) EVENT DATE | 0 8 0 5 8 2 (9) REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During a quarterly test operation of the back-up core spray valve, MO7071,
0 3 both the open and the closed position indication lights remained on with
0 4 the valve returned to the normal closed position. The valve motor circuit
0 5 was de-energized with the valve in the closed position to complete re-
0 6 pairs on 7/7/82. The primary core spray system was in service and no
0 7 hazard to the public occurred.
0 8

0 9

SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
S F	X	Z	V A L V O P	A	D

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 2	—	0 2 1	/	0 3	L	—	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
E	Z	Z	Z	0 0 0 0	N	N	A	R 3 7 8

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The exact cause of misalignment of the open position switch is not known.
1 1 The switch was readjusted and tested satisfactorily. The vendor has been
1 2 contacted to evaluate the problem with this incident as well as a prior
1 3 valve operator problem in LER 82-017. Reportability based on Tech Spec
1 4 6.9.2.b(2).

1 5 FACILITY STATUS (28) E | % POWER (29) 0 8 8 | OTHER STATUS (30) N/A | METHOD OF DISCOVERY (31) B | DISCOVERY DESCRIPTION (32) Routine test observation

1 6 ACTIVITY RELEASED (33) Z | CONTENT OF RELEASE (34) Z | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES

1 7 NUMBER (37) 0 0 0 | TYPE (38) Z | DESCRIPTION (39) NA

PERSONNEL INJURIES

1 8 NUMBER (40) 0 0 0 | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (43)

1 9 TYPE (42) Z | DESCRIPTION NA

PUBLICITY

2 0 ISSUED (44) N | DESCRIPTION (45) NA | NRC USE ONLY

8208130279 820805
PDR ADOCK 05000155
S PDR

12