

Mailing Address

Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 783-6081

F. L. Clayton, Jr.
Senior Vice President
Flintridge Building



Alabama Power

the southern electric system

August 11, 1982

Docket No. 50-348

Director, Office of Management
Information and Program Control
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555


Dear Sir:

RE: Joseph M. Farley Nuclear Plant
Unit 1
Monthly Operating Data Report

Attached are two (2) copies of the July, 1982 Monthly Operating Report for Joseph M. Farley Nuclear Plant, Unit 1, required by Section 6.9.1.6 of the Appendix A Technical Specifications. As requested by letter from Mr. John F. Stolz to Mr. Alan R. Barton, dated October 21, 1977, a "Narrative Summary of Operating Experience" is included in the attached report.

If you have any questions, please advise.

Yours very truly,


F. L. Clayton, Jr.

FLCJr/KWM:nac

Enclosures

xc: Mr. Ted Cintula (1 copy)
Director, IE (10 copies)
Director, RII (1 copy)

IE24

JOSEPH M. FARLEY NUCLEAR PLANT
UNIT 1
NARRATIVE SUMMARY OF OPERATIONS
JULY, 1982

In the month of July there were no unit shutdowns or major power reductions.

The following safety-related maintenance was performed in the month of July:

1. Performed miscellaneous maintenance on diesel generators.
2. Replaced Waste Evaporator feed filter.
3. Replaced 1B Waste Gas Compressor pump.
4. Repaired leak on Waste Evaporator feed filter "O" ring seal.
5. Repaired 1A Reactor Makeup Water pump.