



LOUISIANA
POWER & LIGHT


142 DELARONDE STREET
P O BOX 6008 • NEW ORLEANS, LOUISIANA 70174 • (504) 366-2345

August 5, 1982

G. D. McLENDON
Senior Vice President

W3K-82-0481
Q-3-A35.07.38

Mr. John T. Collins, Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76012



SUBJECT: Waterford SES Unit No. 3
Docket No. 50-382
Significant Construction Deficiency No. 38
"Start-Up Test Control; Flooding of Emergency Diesel
Generator Control and Relay Panel"
Third Interim Report

Reference: LP&L Letter W3K-82-0414 to NRC dated July 14, 1982

Dear Mr. Collins:

The Final Report on Significant Construction Deficiency No. 38 was to be submitted on August 16, 1982. We are unable to meet this date.

The replacement panels for the Emergency Diesel Generator are presently being installed. Completion of the corrective action and the reivev of the supporting documentation will be accomplished to allow the submittal of the Final Report of Significant Construction Deficiency No. 38 by September 10, 1982.

If you have any questions, please advise.

Very truly yours,

G.D. McLendon

GDMcL/LLB/grf

- cc: 1) Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555
- 2) Director
Office of Management
Information and Program Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

IE 27