

Appendix A

NOTICE OF VIOLATION

University of California at Los Angeles
Los Angeles, California 90024

Docket No. 50-142
License No. R-71

As a result of the inspection conducted on June 28 to June 30, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified:

Technical Specification Section VII.J, "Procedures," states: "All procedures and major changes thereto shall be reviewed and approved by the Director of the Nuclear Energy Laboratory prior to being effective. Changes which do not change the original intent of a procedure may be approved in writing by the reactor supervisor. Such changes shall be recorded and submitted to the Director for routine review. The following types of written procedures shall be maintained:

1. Normal startup, operation, and shutdown procedures for the reactor. These procedures shall include applicable check-off lists and instructions."


Contrary to the above on June 29, 1982, an addendum to "pre-start check-off" dated January 11, 1982, had not been submitted to the Director for routine review.

This is a Severity Level V Violation.

Pursuant to the provisions of 10 CFR 2.201, the University of California, Los Angeles is hereby required to submit to this office within twenty-five days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further items of noncompliance; and (3) the date when full compliance will be achieved.

Original signed by
G. B. Zwetzig for

JUL 22 1982
dated 20 July 1982


T. Young, Jr., Chief, Reactor Projects
Section 2, Reactor Operations Projects
Branch