



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

BALTIMORE GAS & ELECTRIC COMPANY

DOCKET NO. 50-317

CALVERT CLIFFS UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 47
License No. DPR-53

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The applications for amendment by Baltimore Gas & Electric Company (the licensee) dated July 3, 1979, August 31, 1979, and January 15, 1980, as supplemented by filings dated April 14 and 18, 1980, May 20 and 30, 1980, July 7, and September 12, 1980, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter 1.
 - B. The facility will operate in conformity with the applications, the provisions of the Act, and the rules and regulations of the Commission.
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations.
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C(2) of Facility License No. DPR-53 is hereby amended to read as follows:


(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 47, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

8010080 246

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in black ink, appearing to read "Robert A. Clark". The signature is written in a cursive style with a long horizontal stroke at the end.

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 19, 1980

ATTACHMENT TO LICENSE AMENDMENT NO. 47

FACILITY OPERATING LICENSE NO. DPR-53

DOCKET NO. 50-317

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the area of change. The corresponding overleaf page 5-6 is also provided to maintain document completeness. No changes were made on 5-6.

Page

5-5

DESIGN FEATURES

VOLUME

5.4.2 The total water and steam volume of the reactor coolant system is 10,614 ± 460 cubic feet at a nominal T_{avg} of 532°F.

5.5 METEOROLOGICAL TOWER LOCATION

5.5.1 The meteorological tower shall be located as shown on Figure 5.1-1.

5.6 FUEL STORAGE

CRITICALITY - SPENT FUEL

5.6.1 The spent fuel storage racks are designed and shall be maintained with a minimum 10 3/32" x 10 3/32" center-to-center distance between fuel assemblies placed in the storage racks to ensure a k_{eff} equivalent to < 0.95 with the storage pool filled with unborated water. The k_{eff} of < 0.95 includes the conservative allowances for uncertainties described in Section 9.7.2 of the FSAR. The maximum fuel enrichment to be stored in the fuel pool will be 4.1 weight percent.

CRITICALITY - NEW FUEL

5.6.2 The new fuel storage racks are designed and shall be maintained with a nominal 18 inch center-to-center distance between new fuel assemblies such that k_{eff} will not exceed 0.98 when fuel having a maximum enrichment of 4.0 weight percent U-235 is in place and aqueous foam moderation is assumed. The k_{eff} of < 0.98 includes the conservative allowance for uncertainties described in Section 9.7.2 of the FSAR.

DRAINAGE

5.6.3 The spent fuel storage pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 63 feet.

CAPACITY

5.6.4 The fuel storage pool is designed and shall be maintained with a combined storage capacity, for both Units 1 and 2, limited to no more than 1760 fuel assemblies.

5.7 COMPONENT CYCLIC OR TRANSIENT LIMITS

5.7.1 The components identified in Table 5.7-1 are designed and shall be maintained within the cyclic or transient limits of Table 5.7-1.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

BALTIMORE GAS & ELECTRIC COMPANY

DOCKET NO. 50-318

CALVERT CLIFFS UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 30
License No. DPR-69


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The applications for amendment by Baltimore Gas & Electric Company (the licensee) dated July 3, 1979, August 31, 1979, and January 15, 1980, as supplemented by filings dated April 14 and 18, 1980, May 20 and 30, 1980, July 7, and September 12, 1980, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter 1.
 - B. The facility will operate in conformity with the applications, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations.
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - F. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C(2) of Facility License No. DPR-69 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 30, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in cursive script, appearing to read "Robert A. Clark".

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 19, 1980

ATTACHMENT TO LICENSE AMENDMENT NO. 30

FACILITY OPERATING LICENSE NO. DPR-69

DOCKET NO. 50-318

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the area of change. The corresponding overleaf page 5-6 is also provided to maintain document completeness. No changes were made on 5-6.

Page

5-5

DESIGN FEATURES

VOLUME

5.4.2 The total water and steam volume of the reactor coolant system is 10,614 ± 460 cubic feet at a nominal T_{avg} of 532°F.

5.5 METEOROLOGICAL TOWER LOCATION

5.5.1 The meteorological tower shall be located as shown on Figure 5.1-1.

5.6 FUEL STORAGE

CRITICALITY - SPENT FUEL

5.6.1 The spent fuel storage racks are designed and shall be maintained with a minimum 10 3/32" x 10 3/32" center-to-center distance between fuel assemblies placed in the storage racks to ensure a k_{eff} equivalent to < 0.95 with the storage pool filled with unborated water. The k_{eff} of < 0.95 includes the conservative allowances for uncertainties described in Section 9.7.2 of the FSAR. The maximum fuel enrichment to be stored in the fuel pool will be 4.1 weight percent.

CRITICALITY - NEW FUEL

5.6.2 The new fuel storage racks are designed and shall be maintained with a nominal 18 inch center-to-center distance between new fuel assemblies such that k_{eff} will not exceed 0.98 when fuel having a maximum enrichment of 4.0 weight percent U-235 is in place and aqueous foam moderation is assumed. The k_{eff} of < 0.98 includes the conservative allowance for uncertainties described in Section 9.7.2 of the FSAR.

DRAINAGE

5.6.3 The spent fuel storage pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 63 feet.

CAPACITY

5.6.4 The fuel storage pool is designed and shall be maintained with a combined storage capacity, for both Units 1 and 2, limited to no more than 1760 fuel assemblies.

5.7 COMPONENT CYCLIC OR TRANSIENT LIMITS

5.7.1 The components identified in Table 5.7-1 are designed and shall be maintained within the cyclic or transient limits of Table 5.7-1.