



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUQUESNE LIGHT COMPANY

OHIO EDISON COMPANY

PENNSYLVANIA POWER COMPANY

DOCKET NO. 50-334

BEAVER VALLEY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 31
License No. DPR-66

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duquesne Light Company, Ohio Edison Company, and Pennsylvania Power Company (the licensees) dated March 22, 1980, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


8010140022

2. Accordingly, Facility Operating License No. DPR-66 is hereby amended so that Paragraph 2.D. reads as follows:

The licensee shall fully implement and maintain in effect all provisions of the NRC approved physical security plan, including amendments and changes made pursuant to 10 CFR 50.54(p). The approved security plan, withheld from public disclosure pursuant to 10 CFR 2.790(d), identified as "Beaver Valley Power Station Unit No. 1 Physical Security Plan", Revision 1, dated October 31, 1977 as supplemented by Revision 2 dated May 15, 1978, Revision 3 dated February 21, 1979 includes as Chapter 8 the NRC approved Safeguards Contingency Plan as transmitted by letter of March 22, 1980.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 12, 1980

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 31 TO FACILITY OPERATING LICENSE NO. DPR-56

DOCKET NO. 50-334

Revise Appendix A as follows:

Remove Page

6

Insert Page

6

- (9) The licensee shall implement a secondary water chemistry monitoring program to inhibit steam generator tube degradation. This program shall be described in the station chemistry manual and shall include:
1. Identification of sampling schedule for the critical parameters and control points for these parameters;
 2. Identification of the procedures used to measure the values of the critical parameters;
 3. Identification for process sampling points;
 4. Procedure for the recording and management of data;
 5. Procedures defining corrective actions for off control point chemistry conditions; and
 6. A procedure identifying (a) the authority responsible for the interpretation of the data, and (b) the sequence and timing of administrative events required to initiate corrective action.
- D. The licensee shall fully implement and maintain in effect all provisions of the NRC approved physical security plan, including amendments and changes made pursuant to 10 CFR 50.54(p). The approved security plan, withheld from public disclosure pursuant to 10 CFR 2770(c), identified as "Beaver Valley Power Station Unit No. 1 Physical Security Plan", Revision 1, dated October 31, 1977 as supplemented by Revision 2 dated May 15, 1978, Revision 3 dated February 21, 1979 includes as Chapter 6 the NRC approved Safeguards Contingency Plan as transmitted by letter of March 22, 1980.
- E. All work and activities in connection with this project shall be performed pursuant to the provisions of the Commonwealth of Pennsylvania Clean Streams Acts of June 24, 1913, as amended, and of June 22, 1937, as amended, and in accordance with all permits issued by the Department of Environmental Resources of the Commonwealth of Pennsylvania.
- F. This amended license is effective as of the date of issuance and shall expire at midnight on June 25, 2010.

FOR THE NUCLEAR REGULATORY COMMISSION

CHIEFING SIGNED BY

R. E. S. BOYD

Roger S. Boyd, Director
Division of Project Management
Office of Nuclear Reactor Regulation