



SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3271

RJR 80-561

November 3, 1980 3 00

US NRC
DISTRIBUTION SERVICES
BRANCH

Mr. R. H. Engelken, Director
Region V Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
1990 North California Boulevard
Walnut Creek Plaza, Suite 202
Walnut Creek, California 94936

Re: Operating License BPR-54
Docket No. 50-312
Reportable Occurrence 80-44

Dear Mr. Engelken:

In accordance with Technical Specifications Section 6.9.4.1(1), the Sacramento Municipal Utility District is hereby submitting the following written confirmation of a 24-hour Licensee Event Report initially reported to Mr. S. Zwetzig of your office on October 31, 1980.

As a result of I&E Bulletin 79-018 review, it was determined that at present no qualification documentation is available for the pressure switches utilized in the main steam system. These pressure switches are manufactured by Meletron Corporation and are utilized to initiate isolation of the steam generator from the main feedwater following a low pressure indication.

Due to the requirements of NUREG 0660, the District is presently designing a new system in the area of Main Steam Line Failure Logic. The new system will be designed with components meeting all the required qualifications. Installation of the new system will alleviate the necessity of requiring qualification documentation of the Meletron pressure switches. Either the new system will be installed and operational or the existing Meletron switches will be replaced within the time frame specified in the bulletin.

A followup report will be submitted within 14 days.

Sincerely,

R. J. Rodriguez
Manager, Nuclear Operations

RJR:HH:jr

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

*Moore
S. 10*

8011120 386